

5.6 Procedures, Programs and Manuals

---

5.6.2.6 Post Accident Sampling (continued)

- c. Provisions for maintenance of sampling and analysis equipment.

5.6.2.7 Containment Tendon Surveillance Program

This program provides controls for monitoring any tendon degradation in concrete containments, including effectiveness of its corrosion protection medium, to ensure containment structural integrity. The program shall include baseline measurements prior to initial operations. The Containment Tendon Surveillance Program, inspection frequencies, and acceptance criteria shall be in accordance with Regulatory Guide 1.35, Revision 3, 1990.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Containment Tendon Surveillance Program inspection frequencies.

5.6.2.8 Inservice Inspection Program

This program provides controls for inservice inspection of ASME Code Class 1, 2, and 3 components, including applicable supports. The program shall include the following:

- a. Provisions that inservice inspection of ASME Code Class 1, 2, and 3 components shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50.55a;
- b. The provisions of SR 3.0.2 are applicable to the frequencies for performing inservice inspection activities;
- c. Inspection of each reactor coolant pump flywheel per the recommendation of Regulation Position c.4.b of Regulatory Guide 1.14, Revision 1, August 1975, except, the volumetric examinations and complete surface examination of the flywheels for the Second ISI Interval may be delayed one cycle to coincide with the Spring 1998 refueling outage; and
- d. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any TS.

---

(continued)