

(1) Maximum Power Level

Public Service Electric and Gas Company is authorized to operate the facility at a steady state reactor core power level not in excess of 3411 megawatts (one hundred percent of rated core power). Prior to attaining the one hundred percent power level, Public Service Electric and Gas Company shall complete the preoperational tests, startup tests and other items identified in Attachment 1 to this amended license in the sequence specified. Attachment 1 is an integral part of this amended license.

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Deleted Per Amendment 22, 11-20-79

(4) Less than Four Loop Operation

Public Service Electric and Gas Company shall not operate the reactor at power levels above P-7 (as defined in Table 3.3-1 of Specification 3.3.1.1 of Appendix A to this license) with less than four (4) reactor coolant loops in operation until safety analyses for less than four loop operation have been submitted by the licensees and approval for less than four loop operation at power levels above P-7 has been granted by the Commission by Amendment of this license.

(5) PSE&G shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report, and as approved in the NRC Safety Evaluation Report dated November 20, 1979, and in its supplements, subject to the following provision:

PSE&G may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

9511080406 951103
PDR ADOCK 05000272
P PDR