

August 1, 1984

Docket No.: 50-354

APPLICANT: Public Service Electric & Gas Company (PSE&G)

FACILITY: Hope Creek Generating Station

SUBJECT: SUMMARY OF REACTOR SYSTEMS BRANCH DRAFT SER OPEN ITEMS MEETING

On July 11, 1984, a meeting was held in the Bethesda, Maryland offices of the NRC to discuss open items identified in the Draft SER by the Reactor Systems Branch. Representatives of the NRC, PSE&G General Electric (GE) and the Bechtel Power Corporation were in attendance (See Enclosure 1).

The open items discussed and their status are identified in Enclosure 2 to the meeting summary.

After discussion of the open items, the staff indicated to the applicant that it may be requested to address the effects of loss of offsite power for all FSAR Chapter 15 transients.

Dave Wagner, Project Manager  
Licensing Branch No. 2  
Division of Licensing

Enclosure: As Stated

cc: See next page

DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#2 Reading  
LDewey, OELD  
ASchwencer  
DWagner  
PShuttleworth

NRC Participants

Dave Wagner  
George Thomas  
Wayne Hodges  
Martin Virgilio  
Summer Sun  
Jerry Mauck

LB#2/DL  
DWagner:dh  
07/31/84

LB#2/DL  
ASchwencer  
08/1/84

8408130050 840801  
PDR ADOCK 05000354  
E PDR

Hope Creek

Mr. R. L. Mittl, General Manager  
Nuclear Assurance & Regulation  
Public Service Electric & Gas Company  
80 Park Plaza T22A  
Newark, New Jersey 07101

cc:

Troy B. Conner, Jr. Esquire  
Conner & Wetterhahn  
1747 Pennsylvania Avenue N.W.  
Washington, D.C. 20006

Richard Fryling, Jr., Esquire  
Associate General Solicitor  
Public Service Electric & Gas Co.  
80 Park Plaza T5E  
Newark, New Jersey 07101

Mr. P. R. H. Landrieu  
Project Manager - Hope Creek  
Public Service Electric & Gas Co.  
80 Park Plaza T17A  
Newark, New Jersey 07101

Richard F. Engel  
Deputy Attorney General  
Division of Law  
Environmental Protection Section  
Richard J. Hughes Justice Complex CN-112  
Trenton, New Jersey 08625

Mr. David A. Caccia  
Box 70, A.R.D. #2  
Swell, New Jersey 08080

Mr. R. P. Douglas  
Manager-Licensing & Analysis  
Public Service Electric & Gas Co.  
80 Park Plaza T22A  
Newark, New Jersey 07101

Mr. B. G. Markowitz, Project Manager  
Bechtel Power Corporation  
50 Beale Street  
P. O. Box 3965  
San Francisco, California 94119

Susan C. Remis  
Division of Public Interest Advocacy  
New Jersey State Department of  
the Public Advocate  
Richard J. Hughes Justice Complex  
CN-850  
Trenton, New Jersey 08625

F. Michael Parkowski, Esquire  
Deputy Attorney General  
Tatnall Building  
Dover, Delaware 19901

Mr. K. W. Burrows, Project Engineer  
Bechtel Power Corporation  
50 Beale Street  
P. O. Box 3965  
San Francisco, California 94119

Mr. W. H. Bateman  
Resident Inspector  
U.S.N.R.C.  
P. O. Box 241  
Hancocks Bridge, New Jersey 08038

Mr. J. M. Ashley  
Senior Licensing Engineer  
c/o PSE&G Company  
Bethesda Office Center, Suite 550  
4520 East-West Highway  
Bethesda, Maryland 20814

Mr. N.C. Vasuki, Director  
Division of Environmental Control  
Tatnall Building  
Dover, Delaware 19901

Mr. R. S. Salvesen  
General Manager-Hope Creek Operation  
Public Service Electric & Gas Co.  
P.O. Box A  
Hancocks Bridge, New Jersey 08038

Mr. B. A. Preston  
Principal Engineer  
Public Service Electric & Gas Co.  
80 Park Plaza T22A  
Newark, New Jersey 07101

Mr. A.E. Giardino  
Manager - Quality Assurance E&C  
Public Service Electric & Gas Co.  
P.O. Box A  
Hancocks Bridge, New Jersey 08038

MEETING TITLE: REACTOR SYSTEMS BRANCH DRAFT SER OPEN ITEMS MEETING  
APPLICANT: PUBLIC SERVICE ELECTRIC & GAS COMPANY  
FACILITY: HOPE CREEK GENERATING STATION  
DATE: WEDNESDAY, JULY 11, 1984

<u>NAME</u>	<u>AFFILIATION</u>
Dave Wagner	NRC
George Thomas	NRC
Wayne Hodges	NRC
Gus Kapandritis	Bechtel
Paul Schragger	Bechtel
Chuck Bradford	Bechtel
Jim Ashley	PSE&G
R. L. Huang	GE
D. B. James	GE
J. C. Larrew	GE
Ron. Drewnowski	PSE&G
T. R. McGuire	PSE&G
R. A. Lint	Bechtel
William Gailey	PSE&G
Bruce Preston	PSE&G
Robert L. Mittl	PSE&G
Martin Virgilio (part-time participant)	NRC
Summer Sun (part-time participant)	NRC
Jerry Mauck (part-time participant)	NRC

DSER Section 6.3.3

We require the applicant to verify that the LPCS and LPCI injection valves are interlocked to prevent them from opening unless reactor pressure is below the low pressure system design pressure or to conform to one of the acceptable designs given in Section 6.3 of the SRP. (OPEN)

STATUS

At the meeting the applicant provided a proposed response to this open item (attached). The staff finds this response acceptable. Pending formal submittal of this response by July 31, 1984, the staff considers this item CLOSED.

DSER Sections 6.3.5 and 15.9.3

We require a plant-specific LOCA analysis for Hope Creek. We require the LOCA analysis to be submitted at least 6 months prior to fuel loading. (OPEN)

STATUS

At the meeting the applicant provided a proposed response to this open item (attached). The staff finds this response acceptable. The applicant will formally submit this response to the NRC by July 31, 1984. This item will be considered a CONFIRMATORY item in the SER.

#### PLANT SPECIFIC LOCA ANALYSIS

The LOCA analyses reported in the FSAR were for a lead plant representative of Hope Creek. The applicant has committed to supply plant-specific LOCA analyses in a later amendment to the FSAR before fuel loading. The NRC staff will report the results of its review of the plant-specific analyses in a supplement to this report.

The applicant has included small-break LOCA calculations in FSAR Section 6.3.3 that were performed for a lead plant representative of Hope Creek. The applicant has committed to supply plant-specific LOCA analyses in a later amendment before fuel load. The staff will report on its review of the plant-specific analyses in a supplement to this report.

#### Response

The plant-specific LOCA analysis will be provided in July 1985 and will utilize the evaluation model described in Reference 1 and accepted by the NRC staff in Reference 2.

#### References

1. "General Electric Company Analytical Model for Loss-of-Coolant Analysis in Accordance with 10CFR50, Appendix K," NEDE-20566P, November 1975.
2. Letter to G.G. Sherwood (General Electric) from R.L. Tedesco (NRC), "Acceptance for Referencing of Topical Reports-20566P, NEDO-20566-1 Revision 1, and NEDE-20566-4 Amendment 4," February 4, 1981.

DSER Section 15.1.1

We require the applicant to submit an analysis to justify that operation with partial feedwater heating to extend the cycle beyond the normal end of cycle would not result in a more limiting change in MCPR than that obtained using the assumption of normal feedwater heating. Otherwise, operation with partial feedwater heating will be prohibited. (OPEN)

STATUS

At the meeting the applicant provided a proposed response to this open item (attached). The staff finds this response acceptable. Pending formal submittal of this response by July 31, 1984, the staff considers this item CLOSED.

DSEI OPEN ITEM 177 (Section 15.1.1)

The applicant was asked to justify that operation with partial feedwater heating to extend the cycle beyond the normal end-of-cycle condition would not result in a more limiting change in minimum critical power ratio than that obtained using the assumption of normal feedwater heating. The staff requires that analyses be provided before operation in this mode if a decision is made to operate in this mode. Until such analyses are provided, the staff will condition the license from operation in this mode.

Response

PSE&G will accept a license condition as described above until such time as a HCGS analysis is submitted.



DSER Section 15.9.5

TMI-Item II.K.3.3.

Response given in Section 1.10 of the FSAR is not acceptable. We require a detailed response explaining how PSE&G is planning to comply with the requirements of II.K.3.3.

STATUS

By letter dated June 29, 1984 (R. L. Mittl to A. Schwencer), the applicant provided a response to this open item. The staff has reviewed this response and finds it acceptable. This item is considered CLOSED.

DSER Section 15.9.10

TMI Item II.K.3.18

The applicant should specify which option they are planning to implement. Either option 2 or option 4 is acceptable to the staff.

STATUS

By letter dated June 1, 1984 (R. L. Mittl to A. Schwencer), the applicant provided a response to this open item. The staff has reviewed this response and finds it acceptable. This item is considered CLOSED.

125  
7.11.84

## Description of the Proposed Hope Creek LPCI Injection Valve Pressure Interlock


Illustrated in the attached figure are the present design and a proposed new design for the Hope Creek LPCI injection valve pressure interlocks.

The present design permits the injection valves to open when the differential pressure across the valves is equal to or less than 730 psi. Therefore, the injection valves can open when the reactor pressure is equal to 1080 psig (ie: 730 psi plus the LPCI pump discharge pressure of approximately 350 psi = 1080 psig). The NRC has established the position that this arrangement is unacceptable because a single failure of the inboard testable check valve could result in overpressurization of the LPCI low-pressure piping upstream of the injection valve.

The proposed design would eliminate this single failure concern by preventing the injection valve from opening when the pressure downstream of the injection valve is greater than the design pressure of the LPCI piping upstream of the injection valve. The pressure indicating switch would have a nominal trip setpoint (NTSP) of 460 psi. Pressure downstream of the injection valve would have to be equal to or less than this NTSP before the automatic or manual open signal would be transmitted to the injection valve. Therefore, the LPCI low-pressure piping that has a design pressure of 500 psi could not be overpressurized by injection valve opening.

PROPOSED HOPE CREEK LPCI  
PRESSURE INTERLOCK

PRESENT DESIGN



PROPOSED DESIGN

