

JUL 30 1984

Docket Nos.: 50-443  
and 50-444

Mr. Robert J. Harrison  
President & Chief Executive Officer  
Public Service Company of New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Dear Mr. Harrison:

SUBJECT: USE OF ASME CODE CASE FOR THE SEABROOK STATION  
UNITS 1 AND 2, DOCKET NOS. 50-443 and 50-444

DISTRIBUTION  
~~Document Control~~  
NRC PDR  
LPDR  
NSIC  
PRC System  
LB#3 Reading  
JLee  
VNerses  
TMNovak  
GWKnighton  
Attorney, OELD  
EJordan:IE  
NGrace:IE  
RKirkwood  
RBosnak  
ACRS (16)

We completed our review of the Public Service Company of New Hampshire (PSNH) request for authorization to use ASME Code Case N-368 for application in the pressure testing of piping associated with the discharge side of Code Classes 2 and 3 centrifugal pumps for Seabrook Station Units 1 and 2, Docket Nos. 50-443 and 50-444, as identified in PSNH letter SBN-674 dated June 22, 1984.

Code Case N-368, "Pressure Testing of Pump Discharge, Section III, Division 1, Classes 2 and 3", is conditionally acceptable provided applicants using this code case provide information to demonstrate that the length of discharge piping to which the code case is applied is reasonably short. We find the use of Code Case N-368 as indicated above to be acceptable. This code case will be identified as conditionally acceptable in Revision 22 of Regulatory Guide 1.84 which is in the course of preparation.

Use of the Code Case should be documented in the FSAR.

Questions or additional information regarding this matter, and specifically this letter, should be directed to the Seabrook Project Manager, Mr. V. Nerses, (301-492-7238).

181  
George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing

cc: See next page

DL:LB#3 DL:LB#3  
VNerses/ch GWKnighton  
7/27/84 7/27/84

8408130217 840730  
PDR ADOCK 05000443  
A PDR

JUL 30 1984

Docket Nos.: 50-443  
and 50-444

Mr. Robert J. Harrison  
President & Chief Executive Officer  
Public Service Company of New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Dear Mr. Harrison:

SUBJECT: USE OF ASME CODE CASE FOR THE SEABROOK STATION  
UNITS 1 AND 2, DOCKET NOS. 50-443 and 50-444

DISTRIBUTION  
Document Control  
NRC PDR  
LPDR  
NSIC  
PRC System  
LB#3 Reading  
JLee  
VNerses  
TMNovak  
GWKnighton  
Attorney, OELD  
EJordan:IE  
NGrace:IE  
PKirkwood  
RBosnak  
ACRS (16)

We completed our review of the Public Service Company of New Hampshire (PSNH) request for authorization to use ASME Code Case N-368 for application in the pressure testing of piping associated with the discharge side of Code Classes 2 and 3 centrifugal pumps for Seabrook Station Units 1 and 2, Docket Nos. 50-443 and 50-444, as identified in PSNH letter SBN-674 dated June 22, 1984.

Code Case N-368, "Pressure Testing of Pump Discharge, Section III, Division 1, Classes 2 and 3", is conditionally acceptable provided applicants using this code case provide information to demonstrate that the length of discharge piping to which the code case is applied is reasonably short. We find the use of Code Case N-368 as indicated above to be acceptable. This code case will be identified as conditionally acceptable in Revision 22 of Regulatory Guide 1.84 which is in the course of preparation.

Use of the Code Case should be documented in the FSAR.

Questions or additional information regarding this matter, and specifically this letter, should be directed to the Seabrook Project Manager, Mr. V. Nerses, (301-492-7238).

151

George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing

cc: See next page

DL/LB#3      DL/LB#3  
VNerses/ch    GWKnighton  
7/27/84      7/27/84



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUL 8 6 1984

Docket Nos.: 50-443  
and 50-444

Mr. Robert J. Harrison  
President & Chief Executive Officer  
Public Service Company of New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Dear Mr. Harrison:


SUBJECT: USE OF ASME CODE CASE FOR THE SEABROOK STATION UNITS  
1 AND 2, DOCKET NOS. 50-443 and 50-444

We completed our review of the Public Service Company of New Hampshire (PSNH) request for authorization to use ASME Code Case N-368 for application in the pressure testing of piping associated with the discharge side of Code Classes 2 and 3 centrifugal pumps for Seabrook Station Units 1 and 2, Docket Nos. 50-443 and 50-444, as identified in PSNH letter SBN-674 dated June 22, 1984.

Code Case N-368, "Pressure Testing of Pump Discharge, Section III, Division 1, Classes 2 and 3", is conditionally acceptable provided applicants using this code case provide information to demonstrate that the length of discharge piping to which the code case is applied is reasonably short. We find the use of Code Case N-368 as indicated above to be acceptable. This code case will be identified as conditionally acceptable in Revision 22 of Regulatory Guide 1.84 which is in the course of preparation.

Use of the Code Case should be documented in the FSAR.

Questions or additional information regarding this matter, and specifically this letter, should be directed to the Seabrook Project Manager, Mr. V. Nerses, (301-492-7238).

  
George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing

cc: See next page

Seabrook

Mr. Robert J. Harrison  
President and Chief Executive Officer  
Public Service Company of New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Thomas Dignan, Esq.  
John A. Ritscher, Esq.  
Ropes and Gray  
225 Franklin Street  
Boston, Massachusetts 02110

Mr. Bruce B. Beckley, Project Manager  
Public Service Company of New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Dr. Mauray Tye, President  
Sun Valley Association  
209 Summer Street  
Haverhill, Massachusetts 01839

Robert A. Backus, Esq.  
O'Neil, Backus and Spielman  
116 Lowell Street  
Manchester, New Hampshire 03105

Ms. Beverly A. Hollingworth  
7 A Street  
Hampton Beach, New Hampshire 03842

William S. Jordan, III  
Diane Curran  
Harmon, Weiss & Jordan  
20001 S Street, NW  
Suite 430  
Washington, DC 20009

Jo Ann Shotwell, Esq.  
Office of the Assistant Attorney General  
Environmental Protection Division  
One Ashburton Place  
Boston, Massachusetts 02108

D. Pierre G. Cameron, Jr., Esq.  
General Counsel  
Public Service Company of New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Regional Administrator - Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

E. Tupper Kinder, Esq.  
G. Dana Bisbee, Esq.  
Assistant Attorney General  
Office of Attorney General  
208 State House Annex  
Concord, New Hampshire 03301

Resident Inspector  
Seabrook Nuclear Power Station  
c/o US Nuclear Regulatory Commission  
Post Office Box 700  
Seabrook, New Hampshire 03874

Mr. John DeVincentis, Project Manager  
Yankee Atomic Electric Company  
1671 Worchester Road  
Framingham, Massachusetts 01701

Mr. A. M. Ebner, Project Manager  
United Engineers & Constructors  
30 South 17th Street  
Post Office Box 8223  
Philadelphia, Pennsylvania 19101

Mr. Philip Ahrens, Esq.  
Assistant Attorney General  
State House, Station #6  
Augusta, Maine 04333

Mr. Stephen D. Floyd  
Public Service Company of  
New Hampshire  
Post Office Box 330  
Manchester, New Hampshire 03105

Seacoast Anti-Pollution League  
Ms. Jane Doughty  
5 Market Street  
Portsmouth, New Hampshire 03801

Mr. Diana P. Randall  
70 Collins Street  
Seabrook, New Hampshire 03874

Mr. Calvin A. Canney, City Manager  
City Hall  
126 Daniel Street  
Portsmouth, New Hampshire 03801

Ms. Letty Hett  
Town of Brentwood  
RFD Dalton Road  
Brentwood, New Hampshire 03833

Ms. Roberta C. Pevear  
Town of Hampton Falls, New Hampshire  
Drinkwater Road  
Hampton Falls, New Hampshire 03844

Ms. Sandra Gavutis  
Town of Kensington, New Hampshire  
RDF 1  
East Kingston, New Hampshire 03827

Ms. Anne Verge, Chairman  
Board of Selectmen  
Town Hall  
South Hampton, New Hampshire 03842

Mr. Angie Machiros, Chairman  
Board of Selectmen for the Town of Newbury  
Newbury, Massachusetts 01950

Ms. Rosemary Cashman, Chairman  
Board of Selectmen  
Town of Amesbury  
Town Hall  
Amesbury, Massachusetts 01913

Honorable Richard E. Sullivan  
Mayor, City of Newburyport  
Office of the Mayor  
City Hall  
Newburyport, Massachusetts 01950

Mr. Donald E. Chick, Town Manager  
Town of Exeter  
10 Front Street  
Exeter, New Hampshire 03823

Mr. Alfred V. Sargent,  
Chairman  
Board of Selectmen  
Town of Salisbury, MA 01950

Senator Gordon J. Humphrey  
U. S. Senate  
Washington, DC 20510  
(Attn: Tom Burack)

Senator Gordon J. Humphrey  
1 Pillsbury Street  
Concord, New Hampshire 03301  
(Attn: Herb Boynton)

Mr. Owen B. Durgin, Chairman  
Durham Board of Selectmen  
Town of Durham  
Durham, New Hampshire 03824

Charles Cross, Esq.  
Shaines, Mardrigan and  
McEaschern  
25 Maplewood Avenue  
Post Office Box 366  
Portsmouth, NH 03801

Mr. Guy Chichester, Chairman  
Rye Nuclear Intervention  
Committee  
c/o Rye Town Hall  
10 Central Road  
Rye, New Hampshire 03870