

CP&L

Carolina Power & Light Company

AUG 7 9:17
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 23461-0429

August 3, 1984

FILE: B09-13510C
SERIAL: BSEP/84-1730

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, GA 30323


BRUNSWICK STEAM ELECTRIC PLANT UNIT 2
DOCKET NO. 50-324
LICENSE NO. DPR-62

SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (2-SR-84-10)

Dear Mr. O'Reilly:

During an ongoing Unit 2 refueling/maintenance outage, a Unit 2 fire barrier LCO was initiated on June 29, 1984, for a fire door in the Unit 2 Reactor Building. Door No. 303, located on the 50-foot elevation of the building, provides personnel access to the Reactor Building from the roof area of the Unit 2 Turbine Building. The subject LCO was initiated to permit repair of the door, which would not open properly due to problems with the door hinges and interlock device. Required repairs to the door were completed, and the door was returned to service on July 11, 1984. During the time period the subject door was inoperable, appropriate fire watches were maintained.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/sdl/LETSB2

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8408130338 840803
PDR ADOCK 05000324
S PDR

OFFICIAL COPY

IE31/10