

**Mailing Address**  
Alabama Power Company  
600 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291  
Telephone 205 783-6090

**R. P. McDonald**  
Senior Vice President  
Flintridge Building

Docket No. 50-364



July 27, 1984

Director, Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. S. A. Varga

**Joseph M. Farley Nuclear Plant - Unit 2**  
**Inservice Inspection Program for ASME**  
**Code Class 1, 2 and 3 Components**

Gentlemen:

Alabama Power Company's Inservice Inspection (ISI) Program has been previously submitted to the NRC along with requests for relief where certain ASME Code requirements were found to be impractical. The NRC reviewed the ISI Program and granted relief as discussed in letters dated August 24 and September 22, 1983.

Alabama Power Company has performed a detailed review of the ISI Program and the Safety Evaluations transmitted with the NRC letters referenced above. As a result, it has been determined that two additional relief requests are needed. One relief request was previously granted, however, Alabama Power Company has subsequently determined that a portion of the alternative examination is impractical. The remaining relief request was not identified at the time of the previous submittals for Unit 2.

The NRC Safety Evaluation dated September 22, 1983, item II.B.5 granted relief to perform the volumetric examination of the charging pump casing weld whenever the pumps are disassembled for maintenance reasons. Upon additional review, Alabama Power Company has determined that the geometrical configuration of the casing weld is such that a meaningful volumetric examination cannot be performed. It is requested that the alternative examination originally granted be revised to permit surface and visual examinations to be performed in lieu of the volumetric examination. The revised relief request incorporating this proposed change is included as Attachment 1.

8408130345 840727  
PDR ADOCK 05000364  
Q PDR

Rec'd w/ check  
#469211 FOR \$150.00

A047  
1/1

Docket No. 50-364  
Director, Nuclear Regulatory Commission  
July 27, 1984  
Page 2

The ASME Code, Section XI, 1974 Edition through the Summer 1975 Addenda, requires Class 2 components to be hydrostatically tested for four hours at  $1.25 P_D$ . Item II.B.12 of the NRC Safety Evaluation referenced above granted relief from the hydrostatic test requirements for Class 2 components based on the 1980 Edition through the Winter 1980 Addenda of the ASME Code, Section XI. This relief permits the reduction of hydrostatic test pressure from  $1.25 P_D$  to  $1.25 P_{sv}$  where  $P_D$  is the design pressure and  $P_{sv}$  is the lowest safety valve setting for the system. In addition it is noted that for the secondary side of the steam generator, Westinghouse recommends holding the hydrostatic test pressure at  $1.25 P_D$  (1356 psi) for a maximum of 30 minutes, and then reducing the pressure to  $1.0 P_D$  (1085 psi) for the remainder of the required four hour hold time. The safety valve setting (1075 psi) for the secondary side of the steam generator is only 10 psi lower than the design pressure (1085 psi). The hydrostatic test pressure at  $1.25 P_{sv}$  (1343 psi) is only slightly less than  $1.25 P_D$  (1356 psi). Therefore, additional relief is requested to perform the hydrostatic test at  $1.25 P_{sv}$  for up to 30 minutes and reduce the pressure to  $1.0 P_D$  for the remainder of the four hour hold time based on the previously granted relief for Class 2 components and on the current Westinghouse recommendations. Westinghouse has developed this recommended hydrostatic testing procedure to prevent overstressing the steam generator. A summary of the relief request is included in Attachment 2.


Pursuant to the requirements of 10CFR50.55 a(g)(6)(i), Alabama Power Company hereby requests that relief be granted from certain requirements of the ASME Code, Section XI, 1974 Edition through the Summer 1975 Addenda. It is respectfully requested that these relief requests be granted by November 30, 1984. The ISI activities required to be performed during the Unit 2 third refueling outage, tentatively scheduled to begin January 4, 1985, may include some of these impractical inspections.

This relief request is designated as a required approval in accordance with 10CFR170.21 requirements. Enclosed is the application fee of \$150.

Docket No. 50-364  
Director, Nuclear Regulatory Commission  
July 27, 1984  
Page 3

If you have any questions or need additional information, please advise.

Yours very truly,

A handwritten signature in cursive script, appearing to read 'R. P. McDonald', written in dark ink.

R. P. McDonald

RPM/STB:drs/D-338

Attachments

cc: Mr. L. B. Long  
Mr. J. P. O'Reilly  
Mr. E. A. Reeves  
Mr. W. H. Bradford

ATTACHMENT 1

RELIEF REQUEST - RELIEF IS REQUESTED FROM THE VOLUMETRIC EXAMINATION OF THE CHARGING PUMP CASING WELDS. (ITEM C3.1, CATEGORY C-F OR C-G)

EXAMINATION REQUIREMENT:

Table IWC-2600 Item C3.1 requires volumetric examination of pump casing pressure retaining welds.

BASIS FOR RELIEF:

The pressure retaining welds in the charging pump casings are not normally accessible for examination as required by IWC-2600. Examination of the charging pump casing weld, Item C3.1, by ultrasonic, radiographic or surface examination requires complete disassembly of the pump casing and removal of the inboard seal housing and rotor assembly. It has been recently determined that, due to geometrical limitations of the casing weld (i.e., weld crown), volumetric examinations cannot be performed.

ALTERNATIVE EXAMINATION:

Surface and visual examinations of each pump casing weld will be conducted, once per inspection interval, when a pump is disassembled for maintenance reasons. If no such occasion arises, the examinations will be performed at or near the end of the ten year interval.

## ATTACHMENT 2

### RELIEF REQUEST - RELIEF IS REQUESTED FROM THE HYDROSTATIC TEST OF THE CLASS 2 PORTIONS OF THE STEAM GENERATORS AND RELATED PIPING AT 1.25 P<sub>D</sub>

#### EXAMINATION REQUIREMENTS:

IWC-5220 of the ASME Code, Section XI, 1974 Edition through Summer 1975 Addenda requires that the hydrostatic test pressure be at least 1.25 P<sub>D</sub> for Class 2 components.

#### BASIS FOR RELIEF:

In order to prevent undue stress on the steam generators, Westinghouse recommends that the hydrostatic test of the secondary side of the steam generators be conducted at 1.25 P<sub>D</sub> for a minimum of 10 minutes and maximum of 30 minutes, and then reduced to operating pressure, 1.0 P<sub>D</sub> for the balance of the four-hour holding period. The related Class 2 piping is hydrostatically tested along with the steam generator.

#### ALTERNATIVE EXAMINATION:

The hydrostatic test of the Class 2 portions of the steam generator and related piping will be hydrostatically tested at 1.25 P<sub>sv</sub> (based on previously granted relief for 1.25 P<sub>sv</sub> vice 1.25 P<sub>D</sub>) for a minimum of 10 minutes and a maximum of 30 minutes. The test pressure will then be reduced to 1.0 P<sub>D</sub> for the remainder of the required four-hour holding time.