



Tennessee Valley Authority, Post Office Box 2000, Nashville, Tennessee 37278

J. L. Wilson
Vice President, Sequoyah Nuclear Plant

February 28, 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:


In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - UNITS 1 AND 2 - DIESEL GENERATOR (DG)
RELIABILITY DATA REPORT

The enclosed report provides details concerning the 6.9-kilovolt DGs installed at SQN. This report is being submitted in accordance with Technical Specification 6.9.2.2.

Please direct questions concerning this issue to K. C. Miller at (615) 843-7527.

Sincerely,


J. L. Wilson

Enclosure
cc: See page 2

020184

9203030232 920228
PDR ADDCK 05000327
R PDR

ADD 1/1

U.S. Nuclear Regulatory Commission

Page 2

February 28, 1992

cc (Enclosure):

Mr. D. E. LaSarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

SEQUOYAH NUCLEAR PLANT (SQN)
UNITS 1 AND 2
DIESEL GENERATOR (DG) RELIABILITY DATA REPORT FOR 1991

This report is submitted to comply with Technical Specification (TS) 6.9.2.2 for an annual data report on DG reliability. The 6.9-kilovolt DGs at SQN serve as the onsite Class 1E power source. Surveillance requirements of the TSs that demonstrate DG operability are accomplished by the routine performance of Surveillance Instructions (SIs) 1-SI-OPS-082-007.A and B and 2-SI-OPS-082-007.A and B, "Electrical Power System - Diesel Generator"; 0-SI-OPS-082-007.0, "Diesel Generator Operability Verification"; the SI-26 series for loss of offsite power coincident with a safety injection; the SI-102 series for periodic, vendor-recommended inspections; and the Standard Operating Instruction (SOI) 82 series for normal operation of DGs.

The information listed below is a tabulation of DG testing data taken from the aforementioned SIs and/or SOIs. The data was taken from testing performed during the period January 1, 1991, through December 31, 1991. "Valid test" and "invalid test" are defined in accordance with the criteria established in Regulatory Guide 1.108, Revision 1, August 1977.

<u>Diesel Generator</u>	<u>Valid Test</u>	<u>Invalid Test</u>	<u>Failures</u>
1A-A	15	14	0
1B-B	16	23	1*
2A-A	12	23	0
2B-B	17	24	0

* Power CT failure during the performance of SI-26.1B

The above data indicates an average of 36 starts per DG with one failure. One failure out of 144 valid and invalid tests supports the high confidence level that the DGs will perform when required.

SQN continues to recognize the importance of reducing the number of DG starts as indicated by the trend below:

1988: approx. 170 starts per DG per year
1989: approx. 55 starts per DG per year
1990: approx. 36 starts per DG per year
1991: 36 starts per DG per year

Continued effort will keep DG starts as low as possible and thereby enhance engine life and DG reliability.