

U. S. NUCLEAR REGULATORY COMMISSION
REGION I

Report No. 50-289/83-20

Docket No. 50-289

License No. DPR-50 Priority -- Category C

Licensee: GPU Nuclear Corporation

100 Interpace Parkway

Parsippany, New Jersey 07054

Facility Name: Three Mile Island Nuclear Station, Unit 1

Inspection At: Middletown, Pennsylvania

Inspection Conducted: July 11 - September 9, 1983

Inspectors:

J. W. Chung
J. W. Chung, Lead Reactor Engineer

9-21-83
date

J. W. Wen
J. W. Wen, Reactor Engineer

9-21-83
date

E. C. Vanterpool
E. C. Vanterpool, Summer Technical Intern

9/21/83
date

J. H. Tusar
J. Tusar, Summer Technical Intern

9/21/83
date

Approved by:

L. H. Bettenhausen
L. H. Bettenhausen, Chief, Test Programs Section

9/21/83
date

Inspection Summary:

Inspection on July 11, 1983 - September 9, 1983 (Report Number 50-289/83-20)

Areas Inspected: Special unannounced inspection of Reactor Coolant System Leak Rate test procedures, equipment and records for the period of April 1, 1978, through March 31, 1979. The inspection included approximately 800 hours at site and local NRC offices and 200 hours at the NRC Regional office by two region-based inspectors and two technical interns.

Results: Instances of failure to follow station procedures and regulatory requirements were found.

TABLE OF CONTENTS

	<u>Page</u>
<u>EXECUTIVE SUMMARY</u>	5
<u>DETAILS</u>	8
1.0 <u>Persons Contacted</u>	8
2.0 <u>Scope of Inspection</u>	9
2.1 Objectives	9
2.2 Documents and Records Reviewed	9
2.3 Summary of Record Review	11
3.0 <u>Reactor Coolant System (RCS) Leak Rate</u>	16
3.1 Background	16
3.2 RCS Leak Rate Calculations	17
3.3 Procedural Inadequacies	22
3.4 Measurement Sensor Limitations	24
3.5 Uncertainty of Make-Up Tank (MUT) Chart Time	26
3.6 System and Human Error Potential	26
4.0 <u>Effects of Hydrogen Addition on Leak Rate Test Results</u>	28
4.1 Discussion	28
4.2 Makeup Tank Level Shifts with Hydrogen Addition	28
4.3 Findings Regarding Hydrogen Addition	30
4.3.1 Existence of Loop Seal	30
4.3.2 Test to Develop Recorder Trace for Hydrogen Addition	31
4.3.3 Hydrogen Additions During Leak Rate Tests	32
5.0 <u>Effects of Water Addition on Leak Rate Test Results</u>	37
5.1 Discussion	37
5.2 Findings Regarding Water Addition	38
6.0 <u>Effects of Reactor Coolant Drain Tank (RCDT) Level Inputs on Leak Rate Test Results</u>	40
6.1 Discussion	40
6.2 Findings Regarding RCDT Level Inputs	40

7.0 Management Meetings

ATTACHMENTS

- A. Copies of RCS Leak Rate Test Raw Data Supporting Table 2, Feed and Bleed Operations
- B. Copies of RCS Leak Rate Test Raw Data Supporting Table 6, Hydrogen Additions
- C. Copies of RCS Leak Rate Test Raw Data Supporting Table 7, Water Additions
- D. Computer Program Listing of RCS Leak Rate Calculation
- E. Applicable Technical Specifications
- F. Surveillance Procedure SP 1303-1.1
"Reactor Coolant System Leak Rate", Revision 7, May 25, 1976

EXECUTIVE SUMMARY

OBJECTIVES

The basic objective of this inspection was to verify that records of Reactor Coolant System (RCS) leak rate testing at Three Mile Island (TMI) Unit 1, from the period April 1, 1978, to March 31, 1979, showed no indications of practices similar to alleged irregularities at Unit 2. The allegations related to Unit 2 RCS leak rate testing involved the following:

- That tests were often repeated until the results met the acceptance criteria and that unfavorable results were discarded;
- That RCS water inventory was adjusted contrary to procedural requirements; in that water additions were made and not recorded in the test package nor included in the RCS leak rate test calculations;
- That computer data entries for the leak rate calculations were "fudged" to make the leak rate test calculations appear acceptable; and,
- That hydrogen gas was added to the Make-Up Tank (MUT) to influence leak rate test calculations.

Supplemental objectives of the inspection were to:

- Examine compliance with the Technical Specifications on RCS Leak Rate;
- Inspect the leakage test procedure for technical and functional adequacy; and,
- Examine the effects of instrument calibration and variations on leak rate determinations.

CONDUCT OF INSPECTION

From July 11, 1983 to September 9, 1983, members of the engineering staff of Region I conducted an inspection of TMI-1 records, procedures, equipment and specifications related to reactor coolant system leak rate testing performed by station personnel in the year immediately preceding the accident at TMI-2. The inspectors reviewed and correlated diverse records related to leak rate tests, performed an "as-built" walkdown of related plant systems and instrumentation, and, in conjunction with licensee personnel, demonstrated by system operation a technique by which RCS leak rate results could be modified.

Surveillance records for RCS leak rate tests were reviewed for the period from April 1, 1978 through March 31, 1979. Six hundred and forty-five test records were the principal object of this review. These surveillance records were compared with control room logs, power traces and makeup tank level recorder charts developed during the tests to determine abnormal test operations, adequacy of records and compliance with test procedures. The station surveill-

ance test procedure in effect at that time was evaluated for completeness and adequacy. Independent leak rate calculations were performed by the NRC staff with an NRC microcomputer and compared with TMI-1 data to verify the validity of licensee calculations.

The inspector performed a walkdown inspection of the makeup system and verified that the instrumentation system for measuring makeup tank (MUT) level contained a loop seal. The significance of this loop seal is that hydrogen additions made to the MUT during a test could result in errors in RCS leak rate test calculations. Further, a review of plant maintenance records for 1978 identified narrative which described the effects of gas additions on indicated Make-Up Tank (MUT) level.

The MUT strip chart recorder traces were independently analyzed and evaluated by the inspectors to identify instances of improper performance of RCS leak rate tests, such as the addition of hydrogen or water during the performance of the leak rate test. Strip chart data were compared with control room logs and surveillance test calculations to determine if test conditions as indicated by the strip chart were incorporated, or considered, in the calculation of leak rate. Further, the inspectors directed and monitored an actual demonstration of the effects of gas additions to the MUT at Unit 1 on indicated MUT level to support their conclusions. Licensee personnel assisted in this demonstration and acknowledged the resulting conclusions.

MAJOR FINDINGS

The RCS leak rate tests performed at TMI-1 during the year prior to the accident at TMI-2 contained several inadequacies and deviations from procedural and regulatory requirements. These would, in most instances, have lead to a less conservative calculation of RCS leakage rates.

- a. The RCS leak rate procedure, SP 1303-1.1, Rev. 7, in use during the time period reviewed, was inadequate because:
 - o it contained incorrect procedural steps (§3.3);
 - o it did not prohibit acceptance of test results showing negative leakage (§2.3);
 - o it failed to incorporate temperature compensation for several leak rate factors (§3.3);
 - o it omitted several important factors; such as, no provisions to include steam generator tube leakage as identified leakage or the effects of pressure variation in the RCS (§3.3); and,
 - o it utilized incorrect values for volume and water mass change per unit level change (§3.3).

- b. The as-built configuration of the MUT level instrument system provided a loop seal on the low pressure reference leg, which introduced the potential for non-conservative effects on RCS leak rate test results from MUT gas additions. During discussions with station operating personnel, the inspectors were informed there was no loop seal in the makeup tank level instrument system. An NRC walkdown revealed the loop, which provides a means to affect leakage calculations (§4.3.1).
- c. An analysis of MUT level strip charts for the period inspected indicated at least seven hydrogen additions were made during RCS leak rate tests. There were no entries in the control room logs which recorded the fact that these gas additions were made nor were they compensated for in the leak rate calculations. The calculated leak rates, therefore, were in error. Actual leakages were, in fact, higher than the recorded values (§4.3.3).
- d. Seven instances of apparent water addition to the RCS during leak rate tests were identified. In only one test was the water addition accounted for in the calculations; and, in that case, the volume accounted for was considerably less than the apparent actual addition. These unaccounted additions resulted in recorded leakage values lower than actual leakages (§5.2).
- e. Eleven instances of apparent feed and bleed operations during testing were identified, for which the leak rate calculation was not properly corrected for the operator-caused water inventory change (§2.3).
- f. A number of instances of substantial apparent level changes in the Reactor Coolant Drain Tank during leak rate tests were identified. No logbook entries which would explain these level changes were found. (86.2)
- g. The licensee established a conservative administrative test frequency for RCS leak rate testing of once per shift, whereas, technical specification required only daily testing. Seventeen missing test records were identified (§2.3).

CONCLUSION

Based on this review of licensee records and limited discussions with licensee personnel, it is concluded that there were indications of practices at TMI Unit 1 related to RCS leak rate testing similar to those alleged at Unit 2; i.e., seven (7) examples of water additions, seven (7) examples of hydrogen gas additions, and eleven (11) examples of feed and bleed operations were identified, from a population of 645 test records, which were not properly incorporated in RCS leak rate test calculations.

DETAILS1.0 Persons ContactedGPU Corporation

J. D. Abramovici, Mechanical System Engineer, Parsippany
R. Barley, Lead Mechanical Engineer
N. Hollerbush, Supervisor, Document Control
H. Hukill, Director, TMI-1
V. Orlandi, Lead I&C Engineer
F. Paulewicz, Mechanical Engineer
M. Sanford, Supervisor, Plant Engineering, Parsippany
H. Shipman, Operations Engineer
C. Smyth, Supervisor, Licensing
P. Snyder, Manager, Preventive Maintenance
H. Wilson, Supervisor, Preventive Maintenance

USNRC

R. Conte, Senior Resident Inspector
F. Young, Resident Inspector

The inspector also held discussions with other licensee employees during the inspection, including operations, technical support, and administrative personnel.

2.0 SCOPE OF INSPECTION

2.1 Objectives

The basic objective of this inspection was to verify that records of Reactor Coolant System (RCS) leak rate testing at Unit 1, from the period April 1, 1978, to March 31, 1979, showed no indications of practices similar to alleged irregularities at Unit 2. The allegations related to Unit 2 RCS leak rate testing involved the following:

- That tests were often repeated until the results met the acceptance criteria and that unfavorable results were discarded;
- That RCS water inventory was adjusted contrary to procedural requirements; in that, water additions were made and not recorded in the test package nor included in the RCS leak rate test calculations;
- That computer data entries for the leak rate calculations were "fudged" to make the leak rate test calculations appear acceptable; and,
- That hydrogen gas was added to the Make-Up Tank (MUT) to influence leak rate test calculations.

Supplemental objectives of the inspection were to:

- Examine compliance with the Technical Specifications on RCS Leak Rate;
- Inspect the leakage test procedure for technical and functional adequacy; and,
- Examine the effects of instrument calibration and variations on leak rate determinations.

2.2 Documents and Records Reviewed

The RCS leakage test records for the period of April 1, 1978, through March 31, 1979 were reviewed. The requirements and commitments discussed herewith are those applicable specifications and requirements for that review period.

2.2.1 Specifications/System Descriptions

- FSAR, Unit 1, Sections 4.2.3.8 and 4.2.3.9.
- Technical Specifications Amendments through March 1979: Amendment Nos. 11, 15, 17, 29, 32 and 35.

- Make-up and Purification System, Preliminary System description by Babcock and Wilcox (B&W), Med. Ed. Co., TMI Unit 1, Initial Issue, August 14, 1969.
- Pressurizer Instruction Manual, Babcock & Wilcox Instruction Book No. 620-0006, 01-0110 01.
- Drawings: RCS, TMI Unit 1, DWG #4192 C-302-650, Revision 21; Make-up and Purification, TMI Unit 1, DWG #4192-C-302-661, Revision 23; Liquid Waste Disposal, TMI Unit 1, DWG #4192-C-302-690; Make-up Tank, B&W 35-44-002-05; Reactor Coolant Drain Tank, B&W DWG #37-44-001-01.

2.2.2 Procedures

- SP 1303-1.1, Reactor Coolant System Leak Rate, Revision 7, May 25, 1976; Revision 8, August 21, 1981; Revision 10, May 18, 1983; Revision 11, July 13, 1983.
- TP 600/10, RCS Hot Leakage Test, Revision 0, December 16, 1973, performed February 19, 1974
- Operating Procedure (OP) 1101-1, Plant Limits and Precautions, Revision 15, May 18, 1983.
- OP-1102-4, Power Operations, Revision 34.
- OP-1103-4, Soluble Poison Level Control, Revision 20
- OP-1104-2, Make-up and Purification System, Revision 41.
- OP-1101-21, Nuclear Plant Setpoints.
- Station Administrative Procedure (AP) 1012, Shift Relief and Log Entries, Revision 8, November 4, 1977

2.2.3 Control Room Records

- Control Room Operator (CRO) Logs, dated April 1, 1978 to March 31, 1979.
- Senior Reactor Operator (SRO) Logs, dated April 1, 1978 to March 31, 1979.
- Technical Specification Surveillance Procedure (SP) 1303-1.1 Records, dated April 1, 1978 to March 31, 1979.

- Selected Computer Outputs, Daily Summaries
- Selected Auxiliary Operator Logs
- Makeup Tank (MUT) Strip Chart Traces, dated April 1, 1978 to March 31, 1979, excluding those dated July 8, 1978 to August 4, 1978
- Power Range (NI-5) Recorder (SA-125) Traces, April, 1978 to March, 1979

2.2.4 Other Records

- Selected Instrument Calibration Records; Reactor Coolant Drain Tank (RCDT) Foxboro Temperature Sensor, July 26, 1972; RCS Wide Range Pressure Sensor, March, 1972; Pressurizer Level Detector, June 5, 1971; RCS RTD, December 15, 1973, August 22, 1974; pressure vessel specification data sheet for MUT and RCDT.
- Selected Chemistry and Sampling records, 1978
- Plant Operations Review Committee (PORC) minutes of meetings, dated December 31, 1975 to December 30, 1976; January 1, 1978 to December 3, 1978; January 8, 1979 to January 22, 1979.
- Selected Work Requests (WR).

2.3 Summary of Record Review

Surveillance records of RCS leak rate tests were reviewed for a period from April 1, 1978 through March 31, 1979. During that period, there were 290 days which required daily RCS leak rate testing in accordance with Technical Specification Table 4.1-2, item 7. The reactor was not in operation during June 22-29, 1978 and February 16 - March 27, 1979.

The surveillance test procedure (SP 1303-1.1) records were compared with SRO Shift Foreman and CRO log entries in order to obtain the number of times of test performance. The following entries were identified:

<u>Record</u>	<u>No. Tests</u>	<u>Period</u>
CRO Log	713	4-1-78/3-31-79
SRO Log	707	4-1-78/3-31-79
SP 1303-1.1	714	4-1-78/3-31-79

The surveillance records from the period of July 8, 1978 to August 4, 1978 were not reviewed due to missing MUT recorder traces. Thus, 69 surveillance test records could not be reviewed. Therefore, 645 surveillance test records were reviewed against MUT recorder traces and other data, such as daily logs and computer listings.

The licensee had established a conservative administrative test frequency of once per shift. Tests were often performed once per shift, whereas Technical Specification required a daily test.

The total number of days covered by surveillance record was 290 days, during which the following tests were completed:

<u>No. Tests Performed Per Day</u>	<u>No. Days</u>
1 (Daily)	27
2 (Twice Daily)	114
3 (Each Shift) or more	149

Major findings from the record review are:

- Some of the tests noted in the CRO and SRO shift logs were missing in the surveillance files. These surveillance records were either never created, lost, discarded or misfiled. Two test records were found filed out of normal sequence and six were found misfiled. Seventeen missing test records were identified. They are listed in Table 1.
- The surveillance test records frequently showed negative leak rate results. Two months of leak rate test data were reviewed to identify examples of test records demonstrating negative leakage. The following summarizes the results of that review:

	<u>May, 1978</u>	<u>June, 1978</u>	<u>May + June 1978</u>
Total Test Records Reviewed	60	61	121
<u>Number Test Records Demonstrating Negative Leakage Rate Results</u>			
Leakage Plus Losses	10	4	14
Gross Leak Rate	20	16	36
Unidentified Leak Rate	28	20	48

Table 1

Lost, Misfiled, Discarded or Never Created RCS Leak Rate Test Records

<u>No.</u>	<u>Date</u>	<u>Time</u>
1	4-29-78	1400
2	5-07-78	1436
3	5-21-78	1025
4	6-06-78	0530
5	7-04-78	2205
6	7-10-78	0338
7	8-19-78	1450
8	9-03-78	1247
9	11-05-78	1955
10	11-10-78	1125
11	12-11-78	0432
12	01-07-79	0600
13	01-18-79	0530
14	01-18-79	1310
15.	01-26-79	0032
16	01-29-79	0310
17	02-11-79	2230

Almost 40% (48 out of 121) of the calculated and recorded unidentified leak rates during the two month period had negative values.

- The RCS leak test procedure, SP 1303-1.1, recommended water additions such as Feed-and-Bleed (F&B) operations be avoided during the test. The inspector identified at least 11 tests, during which F&B operations appeared to have taken place; and in each case, the change in water inventory was not properly compensated for by the operator in the computer calculations of RCS leakage rates. They are identified in Table 2.

These record review findings are indicative of the failure of the licensee to comply with regulatory and procedural requirements for record-keeping and test performance.

Table 2

Apparent Uncompensated Feed & Bleed Operations
During RCS Leak Rate Testing

<u>No.</u>	<u>Date</u>	<u>Test Start Time</u>	<u>F&B Recorded In CRO/SRO Log</u>	<u>Power*</u>
1	5-12-78	0047	No	89.5 Steady
2	5-30-78	0134	No	99.0 Steady
3	7-02-78	0256	Yes	89.0 - 87.0 Decreasing
4	8-05-78	1456	No	100.5 Steady
5	9-15-78	0921	No	101 Steady
6	11-13-78	0304	No	100 Steady
7	11-16-78	0426	Yes	72.0 - 81.0 Increasing
8	11-20-78	2110	Yes	100.0 Steady
9	11-24-78	0423	No	102.0 Steady
10	11-24-78	1111	No	102.0 Steady
11	11-24-78	1724	No	102.0 Steady

*Strip chart traces of power range recorder, SA-125. "Steady State" was assumed if there was less than $\pm 0.2\%$ Variation on the recorder traces.

Attachment A contains copies of records for these tests.

3.0 Reactor Coolant System (RCS) Leak Rate

3.1 Background

The TMI Unit 1 Technical Specifications, paragraph 3.1.6 and Table 4.1-2, required that RCS leakages be determined at least once per day during steady state operations, and that the leakage-plus-losses, total gross leakage and unidentified leakages be maintained within their respective limits of 30 Gallons-Per-Minute (GPM), 10 GPM and 1 GPM. The TMI-1 Final Safety Analysis Report (FSAR), Section 4.2.3.8.a, specified that the leakages were measured by counting water inventory changes within the RCS pressure boundary for a fixed time interval.

The test procedure included a precaution to avoid addition or removal of water and chemicals from the RCS. The procedure also recommended that, for the most accurate leak rate determination, the initial and final values of power, RCS temperature, RCS pressure and pressurizer level should be maintained identical.

The procedure specified a test duration of one to eight hours, and specified the plant computer as the favored tool for performing test calculations. Hand calculations were allowed as a backup when the computer was not available. There was only one record of a hand calculation during the one year period from April, 1978 thru March, 1979.

When the computer program was initiated, data was taken automatically from hard-wired, pre-designated computer points, except for RCDT water levels, which did not have the direct input points to the computer. Therefore, RCDT levels were always required to be taken from a local patch panel using a digital voltmeter (DVM), and were entered manually into the computer calculations. Other manual actions required by the computer method were input specifications, such as test time interval (normally one hour), any identified leakages and the operator actions of make-up water additions and RCDT pumping. RCS leak rate calculations were automatically done by the computer when the above steps were completed. For hand calculations, the preferred data source was defined to be DVM readings from a patch panel rather than data obtained from control room indicators, due to the inherent inaccuracies in the latter readings.

The procedure also specified a set of corrective steps to be taken when the RCS leakages were in excess of the requirements. The first step was to perform another leak rate determination, followed by careful examination of the operator actions affecting the water inventory. The final step was to initiate action to determine the source of the leakage, and then to proceed with the ACTION statements specified in Technical Specification 3.1.6, which required placing the reactor in hot shutdown within 24 hours of detection of excessive leakage.

3.2 RCS Leak Rate Calculations

The leakage determination was based on a mass balance of the RCS water inventory changes over a prescribed time interval, normally one hour, even though the procedure allowed a test duration of up to eight hours.

The station surveillance procedure for RCS leak rate testing, SP 1303-1.1, Revision 7, May 25, 1976 (effective through August 21, 1981), determined "total RCS leakages plus losses" (30 gpm limit) from the difference between initial and final water inventory of the RCS, compensated for thermal expansion (or contraction) and level changes in the pressurizer and the make-up tank. "Gross RCS leakage rate" (10 gpm limit) was determined from the difference between "total RCS leakages plus losses" and changes to Reactor Coolant Drain Tank inventory. The "unidentified leakage" was determined from the difference between the gross and operator identified leakages, excluding the combined effects of normal evaporative losses and Reactor Coolant Pump (RCP) seal purge. An evaporative loss of 0.51 gpm was applied, based on the results of preoperational test TP 600/10, performed February 19, 1974.

Details of the computer algorithm and calculational steps are illustrated in Figure 1.

Where the symbols used are:

T_{c_a}, T_{h_a} = A loop T_{cold}, T_{hot} ($^{\circ}F$)

T_{c_b}, T_{h_b} = B loop T_{cold}, T_{hot} ($^{\circ}F$)

Z = Water level (in)

ρ = density (lb_m/ft^3)

Δm = mass change (lb_m)


ΔV = volume change (gal)

$\Delta V'$ = operator induced change to the RCS or RCDT (gal)

CF = conversion factor from lb_m to gallon, a function of T_{ave} based on a linear interpolation about 2155 psig


FIGURE 1. TMI-1 RCS LEAK RATE CALCULATION (pre-April 1979)

1303-1.1 Rev. 7, 5/25/76




TMI-1 RCS LEAK RATE CALC. (pre-April 1979)

1303-1.1 Rev. 7, 5-25-76



TMI-1 RCS LEAK RATE CALC. (pre-April 1979)

1303-1.1 Rev. 7, 5-25-76



TMI-1 RCS LEAK RATE CALC. (pre-April 1979)

1303-1.1 Rev. 7, 5-25-76

CONTINUE

GROSS LEAK RATE =
 $(\Delta V_{rcs} + \Delta V'_{rcs} + \Delta V_{rcdt} - \Delta V'_{rcdt}) / \Delta t$

PROCEDURE STATED
ACCEPTANCE CRITERIA: 10 gpm

INPUT: IDENTIFIED LEAK RATE
(MEASURED BY OPERATOR)

CORRECTION TERMS = EVAPORATIVE LOSSES +
RCP SEAL #3 PURGE = -0.23 gpm

21

UNIDENTIFIED RCS LEAK RATE = GROSS LEAK RATE -
IDENTIFIED LEAK RATE + CORRECTION
TERMS

PROCEDURE STATED
ACCEPTANCE CRITERIA: 1 gpm

END

Table 3

Selected RCS Leak Rate Results Comparison

	<u>GPU</u>	<u>USNRC</u>	<u>(NRC - GPU)</u> <u>Δ</u>	<u>Δ</u> <u>NRC</u> <u>% Δ</u>
<u>Leakage-Plus-Losses</u>				
6-21-78:	4.1299	4.14771	0.01781	0.42939
7-6-78:	0.2205	0.22516	0.00466	2.0696
9-11-78:	-0.3875	-0.389682	-0.002182	0.5600
11-28-78:	0.1972	0.2029735	0.0057785	2.847
1-6-79:	-0.1774	-0.179124	-0.001724	0.9624
<u>Gross</u>				
6-21-78:	1.1721	1.189077	+0.016977	1.42775
7-6-78:	-0.1476	-0.13949	+0.00811	5.814
9-11-78:	-0.3562	-0.36010	-0.0039	1.0830
11-28-78:	-0.1162	-0.10750	+0.0087	8.093
1-6-79:	-0.3648	-0.366395	-0.001595	0.435
<u>Unidentified</u>				
6-21-78:	0.9421	0.959077	+0.016977	1.7701
7-6-78:	-0.3776	-0.36949	+0.00811	2.140
9-11-78:	-0.5812	-0.59010	-0.0039	0.6610
11-28-78:	-0.3462	-0.33750	-0.0039	1.156
1-6-79:	-0.5948	-0.596395	-0.001595	0.2674

CF_1 = pressurizer water mass change per level height change (lb_m/in).

CF_2 = make-up tank mass change per level height change (lb_m/in).

CF_3 = reactor coolant drain tank mass change per level sensor voltage output change ($lb_m/volt$)

Subscripts:

pzr = pressurizer

mu = make-up tank

rcdt = reactor coolant drain tank

R&I = reactor vessel & loops

rsc = reactor coolant system

To verify the licensee surveillance calculations, a program was written for an Osborne portable computer, based on SP 1303-1.1, Revision 7. Sample calculations were performed for five test cases. The results indicated an average of 0.31% difference between the licensee's and NRC calculations with a 2.98% standard deviation. The results are tabulated in Table 3. Most of the differences in licensee and NRC calculations are attributed to the use of different density correction factors. The NRC computer program then was used to independently check licensee results for many of the tests examined and to calculate the effects and changes due to the irregularities found and described in the sections which follow.

3.3 Procedural Inadequacies

3.3.1 Total RCS Leakage Plus Losses

Technical Specification Section 3.1.6.8 stated in part, "Loss of reactor coolant through reactor coolant pump seals and system valves to connecting systems which vent to the gas vent header and from which coolant can be returned to the reactor coolant system... when added to leakage shall not exceed 30 gpm."

Surveillance Procedure SP 1303-1.1 computed "Total RCS Leakage Plus Losses" as shown in Figure 1. The calculational procedure did not account for temperature and pressure differences between the MUT and RCS. Table 4 shows that the MUT water is normally at 125°F in comparison to RCS Tave of 579°F. Failure to convert MUT level changes to equivalent RCS conditions volume changes resulted in errors in the leak rate calculations and was a procedural inadequacy.

To illustrate this, assume that during a one hour test period an operator adds 60 gallons of water (at 125°) into the MUT. If temperature correction was not required, the 60 gallons would remain 60 gallons and the calculation would not be in error. In reality the 60 gallons would expand in the RCS to 82.56 gallons, but SP 1303-1.1 assumes no expansion and therefore would introduce a nonconservative reduction in RCS leakage rates of 0.376 gpm.

3.3.2 Total RCS Leakage

Technical Specification 3.1.6.1 stated, "if the total reactor coolant leakage rate exceeds 10 gpm, the reactor shall be placed in hot shutdown within 24 hours of detection". The total reactor coolant system leakage was called the "Gross RCS Leak Rate" in SP 1303-1.1 and was computed as shown in Figure 1.

Surveillance Procedure SP 1303-1.1, Rev. 7 incorrectly accounted for RCS leakage collected in the Reactor Coolant Drain Tank (RCDT) which was removed by operator action, since the calculation failed to correct for the lower temperature of RCDT water as compared to the RCS; thus, each gallon removed from the RCDT caused a nonconservative estimate of "Gross RCS Leak Rate."

3.3.3 Unidentified RCS Leak Rate

Technical Specification Section 3.1.6.2 states: "If unidentified reactor coolant leakage (excluding normal evaporative losses) exceeds one gpm or if any reactor coolant leakage is evaluated as unsafe, the reactor shall be placed in hot shutdown within 24 hours of detection."

Surveillance Procedure SP 1303-1.1 computes "Unidentified RCS Leak Rate" as shown in Figure 1. The calculational procedure incorrectly accounts for Reactor Coolant Pump #3 Seal Purge in that the value of this purge was added to the calculation of "Unidentified RCS Leak Rate" as a correction factor. Since the purge is taken from the MUT and ultimately flows to the RCDT, it is appropriately compensated in the calculation of "Total RCS Leakage."

3.3.4 Other Procedural Deficiencies

- The evaporative loss factor (-0.51 gpm) utilized in computing "Unidentified RCS Leak Rate", was obtained from the pre-operational test results TP600/10, "RCS Hot Leakage Test", Revision 0, performed March 14, 1974. In that procedure, the evaporative loss (-0.51 gpm) was calculated assuming 125°F MUT water, which was not corrected to equivalent RCS conditions.

Table 4

System Data for RCS Leak Rate Calculations

<u>System</u>	<u>Operating Conditions</u>
<u>Reactor Coolant System</u>	
T _{ave} , °F	579
volume (without pressurizer, at 579°F), ft ³	10678
Pressure, psig	2155
<u>Make-up Tank</u>	Vertical, Cylindrical
pressure psig	15 - 35
Temperature, °F	125
Level, inch	73
Volume, gallon	2955
<u>Reactor Coolant Drain Tank</u>	Vertical, Cylindrical
Pressure, psig	0
Temperature, °F	105 - 110
Level, inch	94.5
Volume/Level, gal/inch	35.4
Volume, ft ³	771
<u>Pressurizer</u>	
pressure, psig	2166
Temperature, °F	648
Level, inch	220
Volume (liquid), ft ³	800
Volume (Steam), ft ³	702
Volume/Level, gal/inch	240

- In addition to the failure to correctly convert MUT level changes to equivalent RCS water inventory changes, due to failure to correct for the higher RCS temperature, the procedure assumed the MUT and RCDT were maintained at a constant temperatures, and therefore did not account for the effects of temperature variation on water density.
- The Reactor Coolant Pump #3 Seal Purge was incorrectly converted to equivalent gallons at 534°F versus the proper conversion to 579°F.
- The procedure failed to account for the effects of changes in pressurizer pressure on pressurizer level.
- The procedure utilized an RCS Volume figure (excluding the pressurizer) of 10,673 ft³ in calculations; whereas, the correct Volume figure at an RCS Tave of 579°F was 10,678 ft³.
- The procedure utilized a MUT water mass change per unit level change of 250 lbm/in in calculations; whereas, the correct value for 125°F was 255 lbm/in.

3.4 Measurement Sensor Limitations

The sensors and instrumentation used in leak rate calculations were examined for accuracy and repeatability. Since these instruments have direct input (except for the RCDT level) to the plant process computer for use in the leak rate calculations, an understanding of their accuracy and repeatability is useful when reviewing leakage rate determinations.

Table 5 summarizes the estimations of accuracy and repeatability. These estimations were checked against a period of stable reactor operation and found to be realistic. Instrument and sensor limitations and performance were not found to be limitations in leak rate calculations. A conservative estimate of measurement error due to instrument repeatability is 11.6 gallons regardless of test duration.

The following reference documents were reviewed to determine repeatability to construct Table 5.

- Calibration notes, TMI-1
- Bailey BYXXX0 type differential pressure transmitter specifications E 21-17, page 31; Type BY8230-A Make-up Tank level differential pressure transmitter, order number, A-29062Z, calibration specifications sheet No. 150L339.
- Foxboro model E13DM Differential pressure Transmitter, MI 20-110, January 1969.

- RCS RTD Calibration Acceptance Test Data Sheet, February 8, 1974.
- Model 694A Converter, Foxboro; Model 620 Series indicating transmitter
- Model 1152GP Rosemont pressure transmitter
- Foxboro 99B series totalizer specification sheet, February 1967.

A significant variation in reactor coolant system parameters can be expected due to inherent periodic oscillations of some of these parameters. The oscillations can be significant if a beginning or final data set is gathered over a time span which is comparable to the period of oscillations. It was understood that due to relatively improved system tune-up for Unit 1, during the one year period of interest, the system oscillation or inherent periodic perturbation in Unit 1 was negligible compared with the expected errors from such perturbation in Unit 2. This was understandable since Unit 1 had been in commercial operation since 1974 and Unit 2 started its operation in December 1978.

A stable period of plant operation was selected to check for such oscillations. The inspector noted that the reactor was maintained at 100% power for seven hours during a period of 1600-2300 hour on September 30, 1978.

The inspector reviewed computer summary sheets for the same date, and verified that the cold and hot leg temperatures (total six readings; 4 cold legs and 2 hot leg readings) were indeed maintained constant during the entire seven hour period. Also, the T_{ave} variation was far less than one tenth of the RTD uncertainty and less than the estimated repeatability of the instrumentation.

Accuracy of the RCS leakage calculation is not dependent on the absolute accuracy of the RCS inventory measurements but rather is dependent on accurate measurement of the inventory changes. Therefore, test accuracy does not depend on the absolute instrument accuracy of the individual detection systems, but rather on each instrument's repeatability, or closeness of agreement among a number of consecutive measurements. Based on several discussions with licensee representatives and review of listed documents, it was learned that repeatability of pressure, temperature and level detection elements was considerably better than their respective accuracies.

Table 5 shows a summary of the instrument accuracy and estimated repeatability and consequently expected measurement errors. Note that the measurement errors due to the instrument repeatability are independent of the test duration. For example, total measurement

Table 5
Instrument Repeatability

<u>Instrument</u>	<u>Accuracy</u>		<u>Repeatability</u> parameter	<u>Expected</u> <u>Inventory</u> <u>Change</u> <u>Variance</u> gal
	<u>Individual</u>	<u>Over-all (RMS)</u>		
<u>RCS Temperature (100°F span)</u>		0.52%	0.052%	<6 gal.
RTD	0.25%			
Drift after 2 yrs.	0.25%			
Bridge	0.35%			
Signal Conversion	0.15%			
<u>RCS Pressure (800 psi span)</u>		1.128%	0.113%	~0
Transmitter	0.5%			
Buffer Amplifier	0.15%			
Isolation Amplifier	1.0%			
<u>Pressurizer Level (400 inch span)</u>				
Level	0.5%	.4 inch	0.4"	9.6 gal
RTD (same as RCS RTD)	2.8°F/700°F			
<u>MUT level, (100 inch span)</u>		0.5%	0.05"	1.5 gal
<u>RCDT level, (120 inch span)</u>		0.5%	0.06"	2.1 gal
<u>Flow Totalizer</u>		0.25%	0.1%	
<u>Total RMS Variance in Inventory Change Calculation</u>				<u><11.6 gal</u>

errors estimated from the instrument repeatability would be 11.6 gallons regardless of test duration, and subsequent contribution to the leak rate error would be 0.19 gpm and 0.05 gpm for one and four hour test durations, respectively.

3.5 Uncertainty of Make-Up Tank (MUT) Chart Time

During the one year period, 264 water additions were logged in CRO logbooks and these entries were identified on the MUT strip chart tracings, as tabulated in Table 10. The purpose of this comparison was to determine the accuracy and validity of the chart time. It was understood that the time entered in the shift log by an SRO and CRO was the control room clock time, and the control room MUT recorder time was adjusted periodically to the control room clock time at midnight.

The traces of water addition on MUT charts were compared statistically with the CRO log entry times. Statistical analysis showed that the chart traces of water additions were ahead of the log times by an average of 3.2 minutes with a standard deviation of 10.73 minutes. This was an expected result since the operator or SRO would enter the water additions into the shift log after completion of the operation. On this basis, it was determined that the MUT recorder chart time was accurate statistically to ± 10 minutes.

This information was later utilized to isolate the interval of the MUT level strip chart trace which bracketed the period of test performance. The resulting interval of strip chart was typically 80 minutes wide, (a 60 minute test + 13 minutes before + 7 minutes after) starting 13 minutes prior to the recorded test start time in terms of chart time. All available records were then correlated to identify the actual period of test performance within this interval.

3.6 System and Human Error Potential

Beside the procedural inadequacies and the "As Built" system limitations, there are three additional expected or potential errors in the RCS leakage rate calculations.

(1) RCDT level patch panel DVM readings

The procedure specified that all other level readings besides the RCDT's were automatically fed from the process computer input data points. RCDT levels were manually entered after taking patch panel DVM readings. Since a small error in DVM readings could cause a large error in the RCS leak rate result, the RCDT level readings could be a major source of the errors in leak rate calculations. This is discussed further in Section 6.0.

(2) MUT Water Addition

Procedure SP 1303-1.1 recommended that no addition of make-up water be made during a test, and further specified that water addition, if any, be entered manually into computer.

If make-up water was added during a test, after initial data taking but before final data reading, and the addition was not included in the computer calculations, the RCS leak rate calculated results would be inaccurate and understated. This is discussed further in Section 5.0.

(3) Hydrogen Addition

Because of the configuration and environment of the MUT level detection instrumentation system, water condenses and collects in the low pressure reference leg. Under this condition, hydrogen additions to the MUT during a test cause an increase in the indicated MUT level without actually adding water into the system. This would definitely change the RCS leak rate test results, yielding inaccurate and understated RCS leak rate test results. So long as the condensed water is blocking the low pressure U-leg as described above, hydrogen addition would cause an indicated MUT level shift upward.

Details are discussed in the Sections 4.0.

4.0 Effects of Hydrogen Addition on Leak Rate Test Results

4.1 Discussion


Hydrogen addition to the make-up tank is often required in order to limit the oxygen content in the Reactor Coolant System. The RCS leak rate test procedure, SP 1303-1.1, prohibits the addition of chemicals during a test, although the procedure did not specifically identify hydrogen as a chemical.

As discussed later, the addition of hydrogen to the make-up tank (MUT) can cause an indicated increase in the MUT level without water addition. Therefore, addition of hydrogen at an appropriate time (after initial data collection, and preferably just prior to final data readings) will affect the leak rate results in a non-conservative fashion. The conditions under which such hydrogen additions were made resulted in a characteristic trace on the MUT level chart record. In order to isolate hydrogen additions, level recorder charts were searched for the characteristic trace of the hydrogen addition. These traces, once found, were then compared with the CRO logbook entries and surveillance records.

4.2 Makeup Tank Level Shift with Hydrogen Addition

The water level in the make-up tank is determined by measuring the differential pressure between the top and bottom of the tank, as shown in figure 2. With the level instrumentation operating properly, any change in cover gas pressure (P_1) will be applied equally to the top and bottom of the tank, and the level transmitter will give the pressure P_2 , representing the liquid head in the tank. The piping leading from the bottom of the tank to the higher pressure side of the level detector is intended to be filled with water, and the piping from the top of the tank to the low pressure side of the detector is intended to be dry. The water in the MUT is normally at 125°F, a higher temperature than the ambient room temperature, and the saturated water vapor over the MUT water is at a higher pressure than that which can exist in the colder pipe. Thus, the Low Pressure Piping will act as a slow vapor condenser, and the condensed water will gradually fill the "dry" low pressure leg (see figure 2). If enough water exists in the loop it will form a water loop seal and, for small pressure changes, serve to isolate the low pressure side of the level detector from the make-up tank.

FIGURE 2
LOOP SEAL



NOTE: The "e" term accounts for the slight compression of the trapped gas due to the movement of the water column and is approximately equal to zero.

Referring to the bottom diagram in Figure 2, if a small amount of pressure, say P_H , is added to the MUT, the condensed loop seal water will behave like a manometer, and the high pressure side will sense the additional pressure (P_H) added to the tank, but the low pressure side will only sense a small percentage of the addition. The net effect will be an apparent increase of the MUT water level, equal to the pressure increase (P_H) expressed in inches of water. For each inch of apparent level change, it takes only 0.036 psi pressure addition (P_H), or 1 psi pressure addition can give 2.3 ft (27.69 inches) water level increase. To influence the leak rate, it takes only a few inches level change, since the water volume change for each inch of level in the MUT is 30.8 gallons. For example, by adding 0.072 psi hydrogen pressure (P_H), the apparent MUT level will increase by 2 inches, an apparent inventory increase of 61.7 gallons, resulting in a decrease of the calculated gross and unidentified leak rates by 1.028 gpm in a one hour test.

The characteristic trace of a hydrogen addition on the MUT level recorder when a water loop seal is present will be a strip chart trace like a step increase with over-and under-shoot. This pattern (H) of over/under-shoot is due to the manometer-like oscillation of loop seal water in the incompletely filled low pressure reference leg due to the sudden pressure increase.

Obviously, the effect of a pressure addition on the level is limited by the height of the water column in the loop seal. Any excess pressure will either push the water column toward the top of the U-loop and into the detector or cause gas bubbles through the water seal, negating the pressure effect. For practical purposes, 2 - 4 inch level changes by hydrogen addition will not cause any measurable gas compression on the detector side of the loop seal in the low pressure leg.

4.3 Findings Regarding Hydrogen Addition

4.3.1 Existence of Loop Seal

The inspector questioned several licensee staff members relative to the possible existence of a loop seal in the MUT level instrument system legs. These licensee representatives informed the inspector that no loop seal existed.

During an as-built inspection on July 11, 1983, the inspector found the existence of a loop seal in the "dry" leg of the MUT level instrumentation. Subsequently, the inspector, accompanied by a licensee representative, verified that the U-loop in the dry leg is more than 4 ft. in height. The following entries in the plant maintenance logs indicate that some members of the plant staff were aware of the effect of water condensation in the low pressure leg of the level instrument:

- Work Request (WR) No. 23660, April 28, 1978 at 2200 hour, "make-up tank level recorder is not responding correctly. Put in 100 gallon - recorder went up 8" or 240 gallons. If you change make-up tank pressure 4 lbs. - level changes \geq 18".
- WR No. 23904, May 16, 1978 at 2145 hour, "while adding H² to MUT-1, received MUT-1 high level alarm..."
- WR No. 23852, May 23, 1978, Make-up tank level increase 10" for addition of 100 gal. - should only move by about 3".
- WR No. 24843, August 8, 1978, "Transmitter/recorder erratic. Suspect that reference leg has moisture in it"; blow down low side. Got a lot of water."
- WR No. 21284, September 12, 1979 at 1900 hour, "... suspect MUT-1 level transmitter"

4.3.2 Test To Develop Recorder Trace For Hydrogen Addition

On July 28, 1983, the licensee challenged the proposition that hydrogen addition would cause an increase of the MUT's indicated level and produced MUT strip chart traces from a test. The inspector recognized that during this test, the licensee introduced over 20 psi pressure. This pressure was much greater than that required to affect MUT level. It would require a loop seal 46 feet in elevation versus the existing loop seal with a maximum four foot elevation. To demonstrate the effect of a realistic hydrogen addition on MUT level, the inspector proposed a test.

On July 29, 1983, two inspectors were accompanied by licensee representatives inside and outside of the MUT room, and another inspector with a licensee representative directed the test from the control room. The test was performed with nitrogen gas. The effect of the pressure addition was observed as summarized in the following:

- When the loop seal was drained immediately preceding the test, no effect of pressure addition was observed on indicated level.
- With water in the loop seal, small amounts of nitrogen gas were introduced for 1 second, 2 seconds and 10 seconds by opening and closing MU-V-27, and the resulting level increases were 1.0 inch, 2 inches and 7 inches. The pressure increases during these tests were too small to register on the pressure indicator in the control room.

- The trace of the level shift due to the pressure increase (—) was the same as those suspected hydrogen additions on the MUT chart for the period April 1978 thru March 1979. (See Table 6)

The test traces are shown in Figure 3. For clarity, Figure 3A provides a magnified hand drawn version of the appropriate section of Figure 3. A computer graphic trace is shown in Figures 4 for this test. After the test, licensee representative acknowledged the inspector's findings of the effect of hydrogen additions and their characteristic traces on the MUT level charts.

4.3.3 Hydrogen Additions During Leak Rate Tests

The Control Room Operator's and Shift Foreman's logs were searched for entries showing hydrogen addition during the periods of leak rate testing records. This was done for records from April, 1978, through March, 1979. No entries showing the hydrogen additions were observed in the logs. The makeup tank level strip chart was then examined for the additions; 13 additions were identified. Considering the accuracy of MUT chart times, seven hydrogen additions during RCS leak rate testing were confirmed as shown in Table 6. The hydrogen additions were not recorded in the logs nor compensated for in the leak rate calculations. When the hydrogen additions and consequent level shifts were included in the leak rate calculations, the unidentified leak rates were all increased, and all but one exceeded the limiting conditions of operation in Technical Specification 3.1.6.2, which specified the limit as 1 gpm. Further, Technical Specification 3.1.6.2 stated that if the unidentified reactor coolant leakage exceeded 1 gpm, the reactor should be placed in hot shutdown within 24 hours of detection.

These findings constitute examples of apparent failure to comply with procedural and regulatory requirements.

Figure 3. Hydrogen Addition Test, July 29, 1983




Figure 3A. Detail Sketch of Make-Up Tank Level Response
Hydrogen Addition Test, July 29, 1983
Time and Level Expansion of Figure 3.





FIGURE 4. Process Computer Display
 Hydrogen Addition Test
 MUT Level Shift on Gas Addition :
 10 Seconds Opening/Closing



PLOT RATE = 2 SECOND(S)

Table 6

Hydrogen Additions To Makeup Tank During Leak Rate Test

<u>Date</u>	<u>Time</u>	<u>Effect on Level inch</u>	<u>Effect on Leak Rate, Gallon</u>		<u>Unidentified Leak Rate, gpm</u>		<u>Hydrogen Entry in CRO Log</u>	<u>Power* %</u>
			<u>Temperature not corrected</u>	<u>Temperature corrected</u>	<u>Original</u>	<u>Corrected</u>		
8/8/78	0735	2	61.77	84.996	-0.1099	1.3067	No	99.5, steady
9/8/78	1629	3	92.649	127.439	-0.5823	1.5417	No	99.0, steady
9/18/78	2355	1	30.883	42.512	0.4014	1.1099	No	100.0, steady
9/19/78	2348	2	61.17	84.996	0.0168	2.1536	No	100.0, steady
10/2/78	1645	3	92.649	127.457	0.0293	1.4612	No	99.0, steady
11/12/78	0816	1.5	46.32	63.761	-0.1954	0.8673	No	100.0, steady
2/3/79	1608	3	92.649	127.509	0.4092	2.5344	No	102.0, steady

*Strip chart traces of Power Range Recorder, SA-125

Attachment B contains copies of records for these tests.

5.0 Effects of Water Additions on Leak Rate Test Results

5.1 Discussion

When water is added to the makeup tank during an RCS leak rate test (before the final readings but after the initial data taking), it should always cause an apparent reduction in the leak rate results.

Even though procedure SP 1303-1.1 recommended against any water additions during the leak rate test, the procedure provided for the entry of the water additions into the computer.

As stated earlier, the computer program did not account for the water expansion as the cold water from MUT (125°F) heated up in the RCS (579°F), and consequently, even a correctly entered water addition would result in an error. For example, a 100 gallon water addition and subsequent computer entry would result in a 100 gallon water inventory increase, even though that 100 gallons of water would expand to 137.6 gallons in the RCS. If not manually entered into the calculation by the operator, this would give a 1.67 gpm (100 gal. in 60 min.) reduction in the uncompensated gross and unidentified leak rates for a 60 minute test and would result in an actual 2.29 gpm (137.6 gal into RCS in 60 min.) reduction of the leak rates.

The water additions to the RCS are required to be entered in the Control Room Operator's (CRO) log in order to account for the operator actions. Therefore, one would expect to see any operator-induced water addition to the RCS recorded in the CRO log as well as in the computer calculations.

Water addition could be identified from the makeup tank level recorder chart, whose traces shifted upward in level when the water was added. This characteristic pattern or trace could be easily correlated with the entries in the CRO log. However, the trace of a water addition would be different than the trace or pattern seen when hydrogen was added. The hydrogen addition would result in an almost perfect step increase with a characteristic overshooting due to the loop seal water oscillations. In contrast to this, water additions would not produce sharp, right-angled step-wise indicated level changes with overshoot, but would show some slope of increasing indicated level with time.

The makeup tank recorder chart was reviewed in order to determine if water additions had been made during RCS leak rate tests without recording the addition in the control room CRO and SRO logs, and/or without including such additions in the RCS leak rate calculations.

5.2 Findings Regarding Water Addition

During a previous inspection, four such water additions were identified. During this inspection it was determined that three of them were wrongly identified. In fact, one of the three wrong cases is now identified as a hydrogen addition.

Based on the review of MUT strip chart traces of water addition, surveillance SP 1303-1.1 computer output and pressurizer level response during tests, seven tests were identified during which water additions were made but were not entered into the computer calculations. Table 7 summarizes these water additions.

In some cases, the chart traces indicated that water might have been added gradually to the RCS. One test, performed January 6, 1979, accounted for 300 gallons of water addition in the computer calculations. However, the level shift, a characteristic trace of water addition on the MUT strip chart, indicated that approximately 479 gallons of water was added instead of 300 gallons. This recorded MUT level shift provided additional evidence of the existence of a loop seal in the low pressure reference leg, since raising MUT level compresses the MJT cover gas and causes the same effect as a gas addition discussed in Section 4.

When these water additions were accounted for in the leak rate calculations, all but one showed that the failure to enter the water addition into the computer resulted in the unidentified leak rate in excess of 1 gpm, as tabulated in Table 7. This was contrary to the requirement specified in Technical Specification 3.1.6.1 and are further examples of apparent failure to comply with procedural and regulatory requirements.

Table 7

Water Additions During RCS Leak Rate Test Without Entry Into the Computer

Date	Time	inch	Water Addition		Unidentified Leak Rate, GPM			Power** %
			gallons	Entry in CRO Log	Original	Compensation	Corrected	
5/12/78	1643	8.0	247.1	Yes	-0.7443	3.384	4.930	90, steady
6/11/78	0804	9.0	277.9	Yes	-0.5826	5.215	6.977	97, steady
6/21/78	0341	8.0	247.1	Yes	0.9421	5.060	6.613	99.5, steady
8/31/78	0801	5.5	169.86	No	-0.4141	2.417	3.481	100, steady
11/7/78	1608	2.0	61.77	No	0.0445	1.0735	1.553	100, steady
12/13/78	1842	10.0	308.83	Yes	-0.2170	4.930	6.865	100, steady
1/6/79*	0756	15.5*	478.69*	Yes	-0.5948	0.1497	0.900	101, steady

*300 gallons of 478.69 gallons added were included in the original leak rate calculations.

**Strip chart traces of Power Range Recorder, SA-125

Attachment C contains copies of records for these tests.

6.0 Effects of Reactor Coolant Drain Tank (RCDT) Level Inputs on Leak Rate Test Results

6.1 Discussion

The Reactor Coolant Drain Tank collects the effluent or leakage from the pressurizer PORV and code safety valves. It also collects leakage past the reactor coolant pumps primary mechanical seal. The tank fluid can be circulated through a cooler and returned to the tank by spraying into the tank vapor space. The RCDT also has a connection to the Reactor Building Sump. Surveillance Procedure SP 1303-1.1, Revision 7 (effective revision during 1978-79), treated the water level change in the RCDT as a loss of Reactor coolant covered by Technical Specification 3.1.6.8. Therefore this was not subject to the 10 gpm limit of total RCS leakage. This treatment of RCDT water would allow leakage through relief and safety valves and reactor coolant pump seals to approach a 30 gpm limit.

6.2 Findings Regarding RCDT Level Inputs

Manual reading of RCDT level and manual input of the value into the computer were required. The RCDT level transmitter output was not hard-wired into the computer, and consequently its value had to be manually entered into the computer after taking a patch panel DVM reading. A 0.1 volt error in the reading could lead to a 1.0 gpm error in total and unidentified leak rate measurements during a one hour test. Normal RCDT level readings were 8 to 9 volts. It was not possible to cross-check records to determine if actual errors were made.

When an operator took an action such as pumping out water from the RCDT, this action is required to be logged in the CRO shift log. As listed in Table 8, the RCDT tank levels were decreased substantially according to the surveillance records of leak rate tests; yet, no entries in the SRO or CRO logs were identified reporting the cause for the apparent large volume of water removed from the RCDT. An unaccounted water removal from the RCDT would result in conservative values of calculated gross leakage rate. These are additional apparent failures to follow procedural requirements concerning required log entries.

Based on the computer printouts of surveillance results, Table 9 lists those RCDT level changes greater than 60 gallons of water during the review period. If these changes are overstated, the resulting RCS leak rate calculations will be nonconservative.

Table 8

Reactor Coolant Drain Tank Decreases During
Leak Rate Test (≤ 0.1 Volt)

<u>Date</u>	<u>Time</u>	<u>Level change</u> <u>Volt</u>	<u>Volume change</u> <u>at 579°F, gal</u>	<u>Effect on</u> <u>Leak Rate gpm</u>
4/27/78	0805/0905	-0.112	-66.212	-1.104
5/12/78	1643/1743	-0.279	-164.939	-2.749
5/16/78	1615/1915	-0.117	-69.168	-0.384
6/7/78	1646/1846	-0.184	-108.777	-0.906
9/14/78	2355/0055	-0.218	-128.877	-2.148
10/16/78	1852/1952	-0.890	-526.150	-8.769
12/13/78	1842/1942	-0.592	-349.979	-5.833

Table 9

Reactor Coolant Drain Tank Increases During
Leak Rate Test (≥ 0.1 Volt)

<u>Date</u>	<u>Time</u>	<u>Level change Volt</u>	<u>Volume change at 579°F, gal</u>	<u>Effect on Leak Rate, gpm</u>
5/8/78	2320/0120	0.123	72.715	0.606
5/21/78	0328/0428	0.114	67.395	1.123
6/1/78	0746/0846	0.145	85.721	1.429
6/2/78	0046/0346	0.247	146.021	0.811
6/2/78	1658/1858	0.175	103.457	0.862
6/9/78	2341/0441	0.430	254.207	0.847
6/11/78	0804/0904	0.111	65.621	1.094
6/12/78	1645/1745	0.187	110.551	1.843
6/16/78	0035/0135	0.928	548.615	9.144
6/16/78	1925/2125	0.190	112.324	0.936
6/20/78	0041/0141	0.112	66.212	1.104
6/21/78	0341/0441	0.309	182.675	3.045
6/21/78	0912/1012	0.480	283.766	4.729
7/7/78	1603/1903	0.181	107.004	0.594
7/8/78	1935/2135	0.190	112.324	0.936
7/11/78	1535/2035	0.117	69.163	0.235
7/17/78	0040/0440	0.219	129.468	0.539
8/15/78	0455/0555	0.224	132.424	2.207
8/23/78	2349/0349	0.217	128.286	0.535
11/5/78	1712/1812	0.105	62.074	1.035
12/24/78	0740/1040	0.395	233.516	1.300
12/28/78	1627/1927	0.151	89.268	0.496
1/12/79	2347/0047	0.111	65.621	1.094

7.0 MANAGEMENT MEETINGS

An entrance meeting was conducted with H. Hukill and staff on July 11, 1983. The purpose and scope of the inspection was discussed at this meeting. No other management meetings were held. No written notes or requests were provided to the licensee by the inspectors during the course of this inspection.

Table 10

Log Time Versus MUT Recorder Chart Time for Water Additions

No.	Date	Time		Δ , min.
		CRO	Chart	
1.	4/30/78	1400	1355	5
2.	5/4/78	0130	0145	-10
3.	5/5/78	0005	0005	0
4.	5/5/78	0315	0315	0
5.	5/5/78	1700	1700	0
6.	5/5/78	0520	0515	5
7.	5/8/78	1300	1255	5
8.	5/9/78	2055	2050	5
9.	5/10/78	0830	0820	10
10.	5/12/78	1745	1735	10
11.	5/12/78	1543	1547	-4
12.	5/11/78	1800	1746	14
13.	5/13/78	0815	0800	5
14.	5/13/78	1505	1500	5
15.	5/14/78	2225	2220	5
16.	5/15/78	0050	0045	5
17.	5/15/78	1845	1840	5
18.	5/16/78	2120	2110	10
19.	5/16/78	0500	0450	10
20.	5/17/78	0325	0320	5
21.	5/17/78	1530	1530	0
22.	5/18/78	1340	1340	0
23.	5/19/78	0415	0415	0
24.	5/20/78	0525	0523	2
25.	5/21/78	0315	0315	0
26.	5/21/78	0003	0005	-2
27.	5/21/78	1930	1930	0
28.	5/21/78	2245	2245	0
29.	5/22/78	0419	0419	0
30.	5/22/78	1130	1130	0
31.	5/23/78	0530	0520	10
32.	5/24/78	0630	0625	5
33.	5/26/78	2200	2200	0
34.	5/26/78	0112	0107	5
35.	5/26/78	1826	1810	16
36.	5/28/78	1925	1910	15
37.	5/28/78	0320	0315	5
38.	5/30/78	0240	0235	5
39.	6/3/78	0214	0150	24
40.	6/3/78	1515	1450	25
41.	6/4/78	0847	0850	-3
42.	6/5/78	0140	0140	0

No.	Date	Time		Δ , min.
		CRO	Chart	
43.	6/6/78	1500	1500	0
44.	6/7/78	0330	0330	0
45.	6/8/78	0620	0620	0
46.	6/8/78	1930	1925	5
47.	6/9/78	1440	1440	0
48.	6/9/78	1230	1230	0
49.	5/9/78	0500	0500	0
50.	6/11/78	0755	0750	5
51.	6/11/78	0838	0830	8
52.	6/11/78	1000	0952	8
53.	6/11/78	1055	1050	5
54.	6/11/78	1125	1120	5
55.	6/12/78	1035	1035	1
56.	6/13/78	1110	1055	15
57.	6/13/78	1848	1835	13
58.	6/14/78	1140	1133	7
59.	6/14/78	1325	1315	10
60.	6/14/78	1615	1555	20
61.	6/14/78	1730	1720	10
62.	6/15/78	0845	0840	5
63.	6/15/78	1812	1807	5
64.	6/15/78	2000	1955	5
65.	6/15/78	2131	2113	18
66.	6/16/78	0840	0840	0
67.	6/16/78	1752	1745	7
68.	6/17/78	0200	0155	5
69.	6/17/78	1225	1220	5
70.	6/17/78	2005	2000	5
71.	6/18/78	1500	1455	5
72.	6/19/78	0445	0446	-1
73.	6/19/78	1105	1055	10
74.	6/19/78	1735	1727	8
75.	6/19/78	2040	2030	10
76.	6/20/78	0632	0625	7
77.	6/20/78	2029	2015	14
78.	6/20/78	1530	1520	10
79.	6/21/78	0030	0032	-2
80.	6/21/78	0200	0152	8
81.	6/21/78	0325	0315	10
82.	6/21/78	0450	0440	10
83.	6/21/78	0730	0710	20
84.	6/21/78	0900	0832	28
85.	6/21/78	1100	1040	20
86.	6/21/78	1315	1240	35
87.	6/21/78	1415	1350	25
88.	6/21/78	1620	1620	0
89.	7/1/78	0740	0705	35

No.	Date	Time		Δ , min.
		CRO	Chart	
90.	7/3/78	2225	2215	10
91.	7/5/78	0730	0722	8
92.	7/5/78	1815	1810	5
93.	7/7/78	0445	0440	5
94.	8/6/78	1535	1535	0
95.	8/7/78	0345	0345	0
96.	8/9/78	1600	1608	-8
97.	8/9/78	1859	1905	-6
98.	8/10/78	2335	2335	0
99.	8/11/78	2330	2330	0
100.	8/12/78	0042	0050	-8
101.	8/12/78	2313	2314	-1
102.	8/13/78	2315	2320	-5
103.	8/14/78	0507	0510	-3
104.	8/14/78	2315	2320	-5
105.	8/15/78	0610	0610	0
106.	8/15/78	2310	2310	0
107.	8/16/78	0801	0735	26
108.	8/16/78	1115	1115	0
109.	8/16/78	2320	2320	0
110.	8/17/78	0615	0615	0
111.	8/18/78	1955	1950	5
112.	8/20/78	0015	0032	-17
113.	8/20/78	0910	0917	-7
114.	8/22/78	0700	0700	0
115.	8/24/78	0815	0815	0
116.	8/26/78	0142	0140	2
117.	8/28/78	1600	1550	10
118.	8/30/78	0355	0345	10
119.	9/1/78	0032	0027	5
120.	9/2/78	0725	0710	15
121.	9/2/78	1947	1940	7
122.	9/3/78	2240	2235	5
123.	9/4/78	0830	0828	2
124.	9/4/78	1520	1516	4
125.	9/5/78	1945	1940	5
126.	9/7/78	2015	2005	10
127.	9/9/78	0050	0050	0
128.	9/9/78	0715	0705	10
129.	9/9/78	1830	1825	5
130.	9/10/78	0557	0550	7
131.	9/10/78	2245	2240	5
132.	9/12/78	0530	0528	2
133.	9/12/78	1715	1710	5
134.	9/13/78	0300	0330	-30
135.	9/13/78	2035	2035	0
136.	9/16/78	0240	0238	2

No.	Date	Time		Δ , min.
		CRO	Chart	
137.	9/16/78	2345	2345	0
138.	7/18/83	0030	0032	-2
139.	7/18/78	2147	2143	4
140.	9/19/78	2315	2308	7
141.	9/20/78	1435	1435	0
142.	9/20/78	2345	2343	2
143.	9/21/78	1501	1455	6
144.	9/27/78	0725	0715	10
145.	9/27/78	2142	2125	17
146.	9/29/78	0740	0715	25
147.	9/30/78	1915	1900	15
148.	10/3/78	0125	0115	10
149.	10/4/78	2140	2135	5
150.	10/5/78	0800	0755	5
151.	10/5/78	2215	2215	0
152.	10/7/78	2330	2335	-5
153.	10/8/78	1425	1430	-5
154.	10/8/78	1940	1950	-10
155.	10/9/78	0035	0050	-15
156.	10/10/78	1122	1140	-18
157.	10/12/78	1820	1855	-35
158.	10/13/78	0605	0635	-20
159.	10/15/78	0405	0400	5
160.	10/15/78	2145	2140	5
161.	10/15/78	2226	2221	5
162.	10/17/78	1503	1455	8
163.	10/17/78	1902	1850	12
164.	10/17/78	2237	2233	4
165.	10/18/78	1350	1340	10
166.	10/18/78	2015	2015	0
167.	10/19/78	0859	0850	9
168.	10/19/78	2330	2325	5
169.	10/22/78	2305	2308	-3
170.	10/23/78	0220	0215	5
171.	10/24/78	2340	2339	1
172.	10/25/78	2130	2125	5
173.	10/25/78	1556	1540	16
174.	10/27/78	0100	0100	0
175.	10/27/78	0844	0843	1
176.	10/28/78	1859	1853	6
177.	11/3/78	2205	2200	5
178.	11/5/78	1520	1510	10
179.	11/6/78	0530	0520	10
180.	11/6/78	1935	1925	10
181.	11/7/78	1530	1518	12
182.	11/8/78	1352	1338	14
183.	11/9/78	0409	0358	11

<u>No.</u>	<u>Date</u>	<u>Time</u>		<u>Δ, min.</u>
		<u>CRO</u>	<u>Chart</u>	
184.	11/9/78	1345	1335	10
185.	11/12/78	1415	1402	13
186.	11/13/78	2025	2020	5
187.	11/13/78	0100	0052	8
188.	11/14/78	2145	2140	5
189.	11/15/78	1553	1542	11
190.	11/15/78	1810	1805	5
191.	11/17/78	0645	0638	7
192.	11/18/78	0315	0305	10
193.	11/18/78	1437	1418	19
194.	11/19/78	0408	0357	11
195.	11/19/78	2110	2105	5
196.	11/20/78	0813	0810	3
197.	11/20/78	1015	1013	2
198.	11/21/78	0120	0105	15
199.	11/22/78	0520	0505	15
200.	11/23/78	0610	0600	10
201.	11/23/78	2350	2350	0
202.	11/27/78	2220	2220	0
203.	11/28/78	1400	1400	0
204.	11/30/78	1300	1330	-30
205.	12/1/78	0424	0458	-34
206.	12/2/78	1145	1220	-35
207.	12/5/78	1132	1123	9
208.	12/7/78	0520	0508	12
209.	12/7/78	2332	2330	2
210.	12/9/78	1415	1403	12
211.	12/10/78	2220	2230	-10
212.	12/11/78	1000	1008	-8
213.	12/13/78	1110	1130	-20
214.	12/13/78	1858	1915	-17
215.	12/15/78	0504	0528	-24
216.	12/16/78	0540	0546	-6
217.	12/16/78	1805	1813	-8
218.	12/18/78	0430	0430	0
219.	12/18/78	2130	2135	-5
220.	12/19/78	1330	1335	-5
221.	12/23/78	0350	0350	0
222.	12/23/78	1245	1255	-10
223.	12/23/78	2345	2348	-3
224.	12/25/78	2145	2145	0
225.	12/26/78	0035	0035	0
226.	12/27/78	0900	0850	10
227.	12/28/78	1950	1947	3
228.	12/28/78	2335	2330	5
229.	12/29/78	0730	0723	7
230.	12/29/78	2230	2220	10

<u>No.</u>	<u>Date</u>	<u>Time</u>		<u>Δ, min.</u>
		<u>CRO</u>	<u>Chart</u>	
231.	1/5/79	0807	0740	27
232.	1/6/79	0915	0917	-2
233.	1/8/79	0900	0908	-8
234.	1/8/79	1905	1914	-9
235.	1/9/79	1625	1630	-5
236.	1/10/79	0750	0743	7
237.	1/11/79	0701	0735	-34
238.	1/11/79	1745	1738	7
239.	1/12/79	1437	1425	12
240.	1/13/79	1550	1538	12
241.	1/14/79	0940	0930	10
242.	1/15/79	0417	0408	9
243.	1/16/79	1800	1750	10
244.	1/20/79	1520	1512	8
245.	1/21/79	2330	2323	7
246.	1/21/79	2350	2340	10
247.	1/23/79	2115	2108	7
248.	1/24/79	1641	1532	9
249.	1/27/79	0335	0408	-33
250.	1/28/79	0623	0640	-17
251.	1/29/79	1620	1655	-35
252.	1/30/79	1930	1945	-15
253.	2/2/79	0210	0205	5
254.	2/3/79	0830	0820	10
255.	2/4/79	0508	0517	-9
256.	2/5/79	0350	0342	8
257.	2/5/79	2335	2330	5
258.	2/6/79	2205	2215	-10
259.	2/7/79	0510	0515	-10
260.	2/9/79	0315	0305	10
261.	2/10/79	1930	1943	-13
262.	2/13/79	1040	1043	-3
263.	2/14/79	1325	1315	10
264.	2/15/79	1745	1738	7

ATTACHMENT D

COMPUTER PROGRAM LISTING

OF

RCS LEAK RATE CALCULATION

ATTACHMENT A

COPIES OF RCS LEAK RATE

TEST RAW DATA SUPPORTING

TABLE 2

FEED AND BLEED OPERATIONS

SHIFT RELIEVED W. H. [Signature] TIME 1300 DATE 6-28
Signature

SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: R'S TEMPERATURE 7.0 at RWS CROSS 245 HRS
R & P-2-775 245 gals. HI POWER 90 S
R'S BOLLX CONC. 819 ppm C.H. POS. 1-4 100 S

PLANT CONDITIONS/SPECIAL REMARKS
6 100 S
7 90 S
8 30 S

- 1801 Soden Hydrolytic Hl. on RWS
- 1802 Completed SP 1303-1.1 R.R.S. bal rate -0.25 gpm
- 1900 Started at 05-78-6 2" WCCST
- 1900 Completed SP 1303-1.1 bal rate 0.2

SHIFT RELIEVED W. H. [Signature] TIME 2200 DATE July 8
Signature

SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: R'S TEMPERATURE 5.7 at RWS CROSS 7.5 HRS
R'S FLESH 215 gals. HI POWER 90 S
R'S BOLLX CONC. 817 ppm C.H. POS. 1-4 100 S

PLANT CONDITIONS/SPECIAL REMARKS
6 100 S
7 90 S
8 31 S

- 2305 Rm 8-9 returned to service
- 2315 Rm 8-5 monthly curv 1300-3.1
- 0005 SP 1303-0.25 clear test completed
- 0050 Completed SP 1302-1.1 bal balance cat
- 0100 terminated 05-78-6 2" WCCST
- 0210 completed SP 1303-1.1 bal rate -0.77 gpm
- 0240 Rm 8-6 returned to service

rc

DATE: 5/12/78

TIME: 0:47: 8

+3.11
92.649 gal
5/12/78 gpm

REACTOR COOLANT LEAKAGE TEST

SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1.0

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCSCHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
0:47:26:	560.094	600.053	559.047	599.383	579.641	213.928	79.945	9.042
1:47:26:	560.547	600.516	559.617	599.766	580.109	215.604	80.470	9.052

LEAKAGE PLUS LOSSES (<30 GPM): -0.0436 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.1460 GPM


NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.3760 GPM

OPERATOR: J E Bensch 5/12/78

APPROVED: [Signature]

STOP 0

0C051



POSITION BUFFALO, NEW YORK

No. SA 100 - 1

PRINTED IN U.S.A.

5/12/78

2300 ~~Paul Chalich~~ Rx Power 90% Tavg 579°F Pressure 2155 psi
RCS Boron 819 ppm Rod Index 292 G18 @ 317
Tech Spec Emergency Boron Source is B' RCBT - concentration
is 12366 ppm. Level 9.8'. Min Level for present
concentration is 8.5'.

2305 RM-A8 RETURNED TO SERVICE.

2315 RM-A6 005 FOR MONTHLY SURV. 1302-3.1

2330 STARTED AHE-101

0005 COMPLETED 1303-11.25 Rx Bldg Door TEST SAT +2.9 SCF.

0050 COMPLETED SP 1302-1.1 HEAT BALANCE SAT

0100 TERMINATED Rebase 85-78-L 'A' WELST

→ 0210 COMPLETED SP 1303-1.1 LEAK RATE SAT. -0.37 gpm

0540 RM-A6 RETURNED TO SERVICE.

0630 STOPPED AHE-101

0700 ~~Paul Chalich~~

0700 ~~Battelman~~ Rx Pur. ≈ 90%, Tavg. 579, Press. 2155
Boron 819, Gp. #7 at 94%, Gp. #8 at 33%, #Mwe 748

0720 started MO-P-1A

0745 Verified S.B.L.R.T. headsets operable and in place

0825 Completed SP 1302-1.1 SAT.

0845 Filled RCP Standpipes

1500 ~~Battelman~~

1700 Paul Chalich 90% Rx Pur as before

* } 1723 ADDED 75 GALS. FROM 'A' RCBT TO MUT-1 } *
1745 ADDED 70 GALS. FROM 'A' RCBT TO MUT-1 } *
→ 150 Completed SP 1303-1.1 -7443 GPM

1705 Completed SP 1302-1.1 HEAT BALANCE SAT

1820 STARTED MOP 1F

1945 Filled RCP STANDPIPES

2040 Completed SP 1301-9.9D PIPE SUPPORTS HANGERS

2130 Completed SP 1303-4.14 RBS System Logic Chan

2205 STOPPED MOP 1B + MOP 1E

2210 Verified headsets AT MUT 16A6D

2230 Completed SP 1301-4.1 Weekly Checks

2235 Completed SP 1300-3AD BS Pumps

□ 2240 ADDED 50 GALS FROM 'A' & 'B' RCBT TO MUT-1
2250 Paul Chalich

700
~~Success~~

1630 Checkd long part meter on alarm
 1631 Checkd meter @ RA-A-9, R-9, D all good
 1750 Read AH-E-12 0.2% RH, RH-F-10 575.76, RH-F-11 40.7%
 1820 Completed SP1302-1.1 heat balance 99.278% sat
 1945 Completed OP 1302-1.1 RCS leak rate - 0.2391 gpm sat
 2015 Started liquid release 98-78-2 - B HRCST
 2115 Conducted Fin Drill at Unit 1 yard. OP 1302-5.1 and 2 followd.
 2130 Checked pipe for drill
 2230 Checkd long part meter on alarm

SHIFT RELIEVED [Signature] TIME 2245 DATE 5-29-78
 SHIFT ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS: RCS TEMPERATURE 579° at HRC STAGE 216 MW
 RCS PRESSURE 2155 psig RE POWER 100 %
 RCS BORON CONC. 792 ppm C.R. POS. 1-4 100 %
 _____ 2 100 %
 _____ 6 100 %
 _____ 7 95 %
 _____ 8 29 %

PLANT CONDITIONS/SPECIAL REMARKS: 757 HRCST

FW?

0012 completed valve testing per OP1106-1 on FW PUMPS
 0014 Stopped 62-780 Due To RA-A-9 Pump Trip
 0135 completed SP1302-1.1 Heat Balance sat.
 0242 completed SP1303-1.1 RCS leak rate - 0.2391 gpm
 0425 commenced New TR Dump
 0445 completed SP1303-11.25 RB personnel door lock/unlock sat.

SHIFT RELIEVED [Signature] TIME 0200 DATE 5-30-78
 SIGNATURE
 SHIFT ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS: RCS TEMPERATURE 512° at HRC STAGE 774 MW
 RCS PRESSURE 2155 psig RE POWER 100 %
 RCS BORON CONC. 792 ppm C.R. POS. 1-4 100 %
 _____ 2 100 %
 _____ 6 100 %
 _____ 7 93 %
 _____ 8 28 %

SP Log Revisited nylon

5/29/78
2300

- R. Heilman Rx. Pur. 100%, Temp. 579, Press. 2150,
Gp. #7 at 94%, Gp. #8 at 28%, Boron 742, & MWe 812.
Tech. Spec. emergency S.A. Tank is "B" R.B.A.T.
at a level of 9.8 ft. and a conc. of 12,283 ppm b
Minimum level for this conc. is 8.4 ft.
Met. Ed. Equip. O.D.S. same as 5/28/78 except the
order #726 on R.C. Evap. was cleared
2345 Verified S.B.L.A.T. headsets in place & operable
0130 Terminated Waste Gas Release #61-786 of "B" WGD
0140 Checked noise monitor
0250 Completed SP1303-1.1 RC leakrate is -.07 gpm
0440 Added 100 gal. to M.U. Tank
0450 Completed SP1302-1.1 SAT.
0500 Filled RCP standpipes
0540 Completed liq. release #96-782 of "B" WECST
0700 R. Heilman

0700 J. E. Kirsch REACTOR Power 100%, TAVE 579°F, R.C. PRESSURE
2155 PSIG, GROUP 7 AT 94%, GROUP 8 AT 29%.

0715 VERIFIED HEADSETS AT MU-V-16 A/B/C/D.

0730 CHECKED LOOSE PARTS MONITOR - NO ALARMS.

0900 COMPLETED S.P. 1302-1.1 HEAT BALANCE.

1015 STARTED R.B. PURGE #62-78-G.

1345 CHECKED LOOSE PARTS MONITOR - NO ALARMS.

1500 J.E. Kirsch

1500 D.R. Dutton Rx Pur. 100%, Temp. 579 F, R.C. Press 2155 PSIG
Red Index 293 Gp 8 at 28%.

1630 CHECKED LOOSE PARTS MONITOR. NO ALARMS.

1631 VERIFIED HEADSETS AT MU-V-16 A, B, C, D OPERABLE.

1758 DRAINED RB FAN #1 Oil, B⁴⁰ ~~oil~~, and C⁸⁰ ~~oil~~.

1820 COMPLETED SP1302-1.1 HEAT BALANCE SAT.

1945 Completed SP1303-1.1 Leak rate Sat. .4877

2015 STARTED Liquid release 98-78-L

2115 Dale Pilsetz conducted a fire drill at unit I powder
EP 1202-31 was followed.

2130 Secured from fire drill

2230 checked loose parts monitor - no Alarms.

2300 D.R. Dutton

DATE: 5/30/78
TIME: 1:34:39

+64
185.3 gal
3.09 gpm

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESTROYED INTERVAL (1-8 HOURS)
1.0
ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)
0.0

ENTER COUNTERCHANGE (GAL)
0.0

ENTER CHANGE (GAL)
0.0

TIME	TCA (F)	TIA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	AUTK LVL (IN)	RCDT LVL (VOLT)
1:34:57	557.508	601.609	556.514	600.577	579.117	215.133	71.057	9.041
2:34:57	557.867	601.914	556.516	601.227	579.375	216.578	71.086	9.081

LEAKAGE PLUS LOSSES (<30 GPM): 0.3904 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.0091 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.2391 GPM

OPERATOR: *B. Heilmann* 11-7

APPROVED: *[Signature]*

STOP 0

CRD

'5/30/78

2300

Paul Chalichu Rx Power 100% RC Press 2155 TAIR 579°F
 Rod Index 274 GPH 29.5% Tech Spec Emergency
 Boration Source is 'B' RBAT at 9.7' @ 12, 129 ppm.
 min level for this conc is 8.6"
 Met ED Equipment OOS SAME AS 5/29/78 with the

 2335

ADDED 75 GALS FROM A+B RCBT TO MUT-1

0010 Verified SMALL LOCA Headsets AT MU-V-16 A, B, C, D

0012 Completed VALVE Testing per SP 1106-1 on FW Pumps

0114 STOPPED 62-78-G Due To RMA-9 Pump Tripping

0135 Completed SP 1302-1.1 HEAT BALANCE SAT

 2400

ADDED 100 GALS FROM 'A' RCBT TO MUT-1

0242 Completed SP 1303-1.1 - 7,2391 GPM SAT

0425 Commence Heat TH Dump

0440 Filled RCP Standpipes

0445 Completed SP 1303-1.1.25 R/B Personnel LR Check ST

0450 Check Loose Parts Monitor - No Alarms

 0500

ADDED 100 GALS FROM 'A' RCBT TO MUT-1

0700 Paul Chalichu

0700 ReBarnette 100% Power as before

Ch log reviewed w/ Paul

0725 started MO-P-1A + MO-P-1D

0742 Loose parts monitor checked no alarms

0810 Terminated Rel# 96-78L

0905 Sampling Shutdown

0913 Stopped MO-P-1B + MO-P-1E

0930 RMA 2 OOS for IC-48

1014 RMA 2 Returned to Service

 0440

2.0 100 gal from RCBT 'A'

 1145

2.0 132 gal from 'B' RCBT, 65 gal from 'A' RCBT

1213 RMA 9 Returned to Service

1219 Verified Small LOCA Headsets at MU-V-16 A, B, C, D

1400 Loose parts monitor checked no alarms

1420 Completed SP 1302-1.1 Heat Bal (sat)

1425 ReBarnette

1425

J. J. Mastri Rx Power @ 100%, TAIR

579°F, RC Press 2155 PSIG, GA B @ 289, Rod

INDEX @ 29.5%

 1501

ADDED 65 gal FROM 'A' RCBT + 132 GAL

FROM 'B' RCBT TO MU-TNR


1530

Verified Headsets at MU-V-16 A, B, C, D OPERABLE

5-30-78
0235 hr

0500 hr

feed & bleed



SHIFT BELIEVED C. Miller TIME 9/2/78
 SHIFT ASSIGNED BY Miller SIGNATURE Miller

PLANT CONDITIONS: RCS TEMPERATURE 579 of KEK GROUP 745 KW
 RCS PRESSURE 2153 psig EX POWER 90 S
 RCS BORON CONC. 670 ppm C.R. POS. 1-4 100 S

*Blank & feed
0300 hr*

- 0007 started RR-R-101
- 0120 checked up to R101B for 100% and from R101B
- 0140 completed 971302-1.1 cat
- 0140 completed 971302-1.1 cat
- 0150 started RR-R-101
- 0150 stopped RR-R-101
- 0230 completed 971302-1.1 cat
- 0300 completed 1200-3000 RR Pump & lubricating (cont)
- 0330 stopped RR-R-101

SHIFT BELIEVED Miller TIME 10:50 AM DATE 7/2/78
 SHIFT ASSIGNED BY Miller SIGNATURE Miller

PLANT CONDITIONS: RCS TEMPERATURE 579 of KEK GROUP 745 KW
 RCS PRESSURE 2153 psig EX POWER 90 S
 RCS BORON CONC. 670 ppm C.R. POS. 1-4 100 S
 SPECIAL REMARKS: Remaining logs to 100% 100 S
92 S
29 S

- 0730 checked 1100 gal
- 0810 started RR-R-101 Inverse R100%
- 0830 R100%
- 0900 started 4091C/F
- 0915 verified MU-V16A, B, C, D headlights
- 0955 completed 971302-1.1 cat
- 1057 971302-1.1 completed cat
- 1110 S/D margin calculation - 4.08 $\times 10^4$
- 1145 completed IRT TEST 1710-3C
- 1205 started liquid release 100-78-6
- 1235 completed 971302-1.1 cat

[REDACTED]

[REDACTED]

DATE: 7/...
TIME: 2:56:29

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS):
1

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM):
0

ENTER RCS CHANGE (GAL):
0

TIME	TCA	THA	TCB	THB	TAVF	PRZR LVI	ARTK LVI	RCDT LVI
2:56:47	559.742	598.680	557.115	597.375	578.227	226.920	73.857	7.645
3:1...07	560.516	598.516	558.000	597.242	578.563	226.537	72.791	7.574

[REDACTED]

LEAKAGE PLUS LOSSES (<30 GPM): 0.2597 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.9566 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.7266 GPM

OPERATOR: *[Signature]*


APPROVED: *[Signature]* 7/2/78

CEO LOG

7-2-78

- 2300 ~~R. Parnell~~ 90% Power as before Tave 571
 Press 2155 psig Rod Index 291% Gr. Sat 29%
 Leak Spec Emergency Boration Source Source is "B"
 ROBT at 8.5' core is 13,203 ppm min level is 7
 Met El Equipment 005 same as 7-1-78
- 2335 Checked Loose Parts Monitor No alarms
- 2345 Verified Headsets at MU-V-16A, B, C, +D for Small LOC
- 2037 Started AH-E-101
- 0120 Bled 1000 gal to ROBT "B" Fed 1000 gal from ROBT "A"
- 0250 Completed SP-1302-1.1 Neat Bal (Sat)
- 0330 Checked Loose Parts Monitor no alarms
- * 0345 ~~Leak~~ Bled 1590 gal? to ROBT "B" From ROBT "A"
- 0400 Completed SP-1303-1.1 Leak Rate +.726 gpm
- 0345 Bled Seal Inj filter "B" in Service Tank "A" out
- 0517 Started MU-P-1A stopped MU-RP
- 0524 Stopped MU-P-1A
- 0430 Completed SP-1303-11.25 on RB Pres. doors (Sat)
- 0600 Completed 1300-3HA/B MU Pump + Valve Testing (Sat)
- 0639 Stopped AH-E-101
- 0700 ~~R. Parnell~~
- 0700 ~~D. Woodall~~ R. Parnell 77% Tave 577% RCS Press.
 2155 psig. Rod Index 297 GP 8 @ 312
- 0730 STARTED BLEED & FEED
- 0800 COMPLETED 1100 gal. FEED & BLEED
- 0810 STARTED R. Power INCREASE FROM 90% TO 100% PWR.
- 0850 R. Power 100%
- BACKLOG 0900 BACKLOG STARTED MO-PIC & PIF @ 0805
- 0905 Verified MU-V-16 A/D HEADSETS
- 0930 TERMINATED NEUTRALIZING TANK DUMP
- 0955 COMPLETED SP 1302-1.1 SAT
- 1057 SP1303-1.1 COMPLETE +0.0837 GPM
- 1130 RCS Boron 670 ppm
- 1140 S/D MARGIN CALCULATION -4.08 ΔK/K
- 1145 COMPLETED ISI TEST 1300-3.C.
- 1205 STARTED LIQUID RELEASE 124-78-L
- 1235 COMPLETED SP 1302-1.1 SAT
- 1500 ~~D. Woodall~~
- 1500 Sub Brandy R. power 100% Tave 579°F RCS pressure
 2155 psig, Rod index 292 GP 8 @ 25%
- 1600 STARTED BLEED & FEED

7-2-78 0300



0400 Blod + food 1200gals from 11/11/70
 0570 at 100% for 100
 0600 added 50 gals from BAST

SHIFT RELIEVED *[Signature]* TIME 10:00
 SIGNATURE
 SHIFT ASSIGNED BY *[Signature]*
 SIGNATURE

PLANT CONDITIONS	SP	1200	100
WATER PRESSURE	115	100	100
WATER TEMP	115	100	100
PLANT CONDITIONS/SPECIAL REMARKS	20	100	100
	20	100	100
	20	100	100

0730 checked 500
 1010 3.00 fed 6.00 gal from "2" "B" ACBT
 1135 started 40-P-16 STOPPED 40-P-16
 1245 completed 40/302-1.1 last balance

SHIFT RELIEVED *[Signature]* TIME 11:45 AM 8/15/70
 SIGNATURE
 SHIFT ASSIGNED BY *[Signature]*
 SIGNATURE

PLANT CONDITIONS	SP	1200	100
WATER PRESSURE	115	100	100
WATER TEMP	115	100	100
PLANT CONDITIONS/SPECIAL REMARKS	20	100	100
	20	100	100
	20	100	100

1545 Completed SP 1300-11 Hot Balance 99.5572 Lat
 1546 Checked level sets operable @ 154-170 A, B, C, D?
 1646 Look out complete 1.2072 gal 1st SP 1300-11
 1740 Started changing Rest tanks

STOP 0

rc

DATE: 8/ 5/78
TIME: 15:46:19

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1.

DESIRED INTERVAL (1-8 HOURS)

1

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2. (GPM)

0

ENTER RCDT CHANGE (GAL)

0

ENTER RCS CHANGE (GAL)

0

TIME	TCA (F)	THA (F)	TCB (F)	THD (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
15:46:37:	557.984	601.547	556.094	600.617	579.055	227.861	83.961	9.164
16:46:37:	558.000	601.758	556.030	600.805	579.141	228.137	83.201	9.168

LEAKAGE PLUS LOSSES (<30 GPM): 0.5398 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.4977 GPM


NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.2677 GPM

OPERATOR: *J. M. [Signature]*

APPROVED: *R. S. [Signature]*

STOP 0

8-5-78
1546 ~ 1646



200

8-5-78

0255 tilt less than 3.64
0230 value timer for testing as follows

CV-1	8.8 sec	MS-V-1	27.2 sec
CV-2	9.7 sec	MS-V-2	11.7 sec
CV-3	N/A	MS-V-3	25 sec
CV-4	N/A	MS-V-4	27 sec
CIV-1	28 sec	CIV-4	24.5 sec
CIV-2	24.2 sec	CIV-5	28 sec
CIV-3	26.5 sec	CIV-6	25 sec

0305 added 500 gallon feed & bleed from A RCST to C RCST

0315 started MOPIB & MOPIF

0400 added feed & bleed 1000 gal from A RCST to C RCST

0510 maintaining 100% power.

* 0630? added 56 gal Boric acid from BAMT TORCS.

0700 J. Smith

0700 J. E. Keirch Reactor Power 100%, TAVE 579°F, R.C. PRESSURE 2155 PSIG, GROUP 7 AT 83%, GROUP 8 AT 17%.

1010 BLEED & FEED 600 GAL FROM A RCST TO B RCST.

1135 STARTED C HEATER DRAIN PUMP STOPPED A HEATER DRAIN PUMP

1245 COMPLETED S.P. 1302-1.1 HEAT BALANCE.

BACK LOG 0730 CHECKED S.B.L. HEADSETS.

1500 J. E. Keirch

1500 J. Smith R. Pinger 100%, TAVE 579°F
R.C. PRESS 2155 PSIG, FEED INDEX 94% 628
@ 26% MWE/AWT 807/2506.

1545 HEAT BALANCE COMPLETE SAT. SP-1302-1.1

1546 HEAD SETS VERIFIED. AVAILABLE FOR S.B.L.

1646 LEAK RATE COMPLETE SAT. SP-1303-1.1 1.2697

1745 STARTED DURING THE NEXT TRK.

2300 J. Smith

SHIFT RELIEVED

SHIFT ASSIGNED

- 2320 Stopped RR...
- 2330 Stopped RR...
- 2335 Stopped RR...
- 2350 completed SP 1207-12 RR...
- 0100 completed SP 1207-12 RR...
- 0330 started RR...
- 0510 completed SP 1207-12 RR...
- 0625 started RR...

SHIFT RELIEVED

SHIFT ASSIGNED

Signature

PLANT CONDITIONS: BUS TEMPERATURE 57.0 at BUS BOUND 227
 BUS FREQUENCY 60.0 Hz at BUS BOUND 227
 BUS BOUND CODE 400

PLANT CONDITIONS/SPECIAL MESSAGE

SP log reviewed

- 0795 MU-V-32 in hand & check MU-V-32
- 0815 3rd Handwritten Verdict
- 0846 MU-V-32 in hand
- 0925 completed SP 1207-12
- 1216 completed SP 1207-12
- 1255 started logging
- 1322 completed SP 1207-12

FC

DATE: 9/15/78
TIME: 9:20:52

+ 4"
2.0589 gpm

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1. ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RODT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RODT LVL (VOLT)
9:21: 9:	558.313	602.133	556.500	601.227	579.539	227.242	82.911	9.012
10:21: 9:	558.617	602.352	556.914	601.191	579.813	226.281	83.199	9.041

LEAKAGE PLUS LOSSES (<30 GPM): -0.0422 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.3203 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.5503 GPM

OPERATOR: *W.P. Kealy*

APPROVED: *L. Kealy*

260
1-15-78
2300

R.H. Helman Rx. Pwr. 100%, Temp. 579, Press. 2150, Boron 480, Gr. #7 at 95%, Gr. #8 at 24%, #MWe 830
Tech. spec. emerg. B.A. Tank is "B" ABAT at a level of 10.6 ft. and a conc. of 15,315 ppmb. Minimum level for this conc. is 6 ft.
Met.-Ed. equip. O.O.S. same as 9-14-78 except as follows: order #1115 MD-V1011 #1013, #1116 MU-23-DPT-2, #1117 solid waste were added to equip. O.O.S. and order #1111 solid waste, #1107 EG-V15B, #1095 WBL-P-3A were cleared

2320 Stopped MO-P-1B and MO-P-1E
2330 Verified S.B.L.R.T. headsets operable and in place
2330 started AH-E-101
2335 Stopped AH-E-17B and AH-E-19B and started AH-E-19A and AH-E-17A due to Hi ΔP across "B" filter
2355 Completed SP1302-1.1 sat.

0100 Completed SP1303-1.1 RC lestrate is +.78 gpm
0320 Restarted R.B. Purge #101-78G. Stopped AH-E-101
0510 Completed SP1303-11.25 on R.B. Personnel Door sat.
0625 Started MO-P-1B and MO-P-1E
0700 R.H. Helman

0700 R.E. Boyer Rx Pwr 100%, Temp 579, Press 2155
Rad Index 291, Grp 8 19% mwe/mwe 2516/1620


0815 SBL Headsets verified
0745 MU-V32 to hand & closed MU-V90 opened for Is.
0816 MU-V32 back to normal MU-V90 closed

0923 1302-1.1 SAT 99.22E %
1216 1303-1.1 SAT -.5503 GPM
1255 Next tank dump started

1323 1303-3.1 RB Clog & Isolation Test Complete - SAT
1500 R.E. Boyer
1500 J.E. Reich REACTOR POWER 100%, TEMP 579°F, R.C. PRESSURE 2155 PSIG, GROUP 7 AT 94%, GROUP 8 AT 22%.

1540 SP1302-11 COMPLETE O.K., SBL phones checked
1710 STARTED NRP1A

1715 NRP1A IS OPERABLE NRP1A & C ARE E.S. SELECTED
1800 Secured R.B. Purge 101-78-G.
2300 J.E. Reich



A
 Q
 0921-1021

2" F+B

rc

DATE: 11/13/78
TIME: 3: 4:24

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1.0

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

0.0

ENTER RCDT CHANGE (GAL)

0.0

ENTER RCS CHANGE (GAL)

0.0

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	RZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
3: 4:45:	557.922	601.789	556.180	600.867	579.180	228.477	74.537	9.182
4: 4:45:	557.945	601.875	556.383	600.977	579.289	228.920	74.987	9.188

LEAKAGE PLUS LOSSES (<30 GPM): -0.2594 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.3207 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.5507 GPM

OPERATOR: *Jane Chelich*

APPROVED: *H. Jarvis*


050

STOP 0

GRAPHIC CONTROLS CORPORATION BUFFALO, NEW YORK

PRINTED IN U.S.A.

6:00 PM
419
680 60



11/13/79

2300 ~~Ward~~ R Power 100% Temp 579% RC Press 2155 psig
 Rod Index 297 GPR @ 22% Tub Spec Energy.
 Borated Water source is RBAT 'B' Present Level is
 10.6' Present concentration is 15,185 ppm Boron.
 Min Level for present concentration is 6.3'

2335 Completed SP1302-1.1 Heat Balance SAT.

9015 Verified SBL Headsets

0100 Completed 300 gal Feed & Bleed RC BT 'A' TO RC BT 'B'

* 0335 Completed 600 gal Feed & Bleed RC BT 'A' TO RC BT 'B'

0405 Completed SP1303-1.1 Leak Rate SAT. -0.5507 gpm

0410 Started R Bldy Purge Release # 112-78-6

0415 Completed SP1303-11.25 R Bldy Duct Test SAT. +175 scfh

0445 Completed SP3303-M1 SAT. Fill Pump Surv.

0550 Stopped Neutralizing Tank Dump

0600 Started MO-P-1B & MO-P-1E

0700 ~~Ward~~

0700 ~~J. M. ...~~ R Power 100%, Temp 579%, RC
 Press 2155 psig, Rod Index 293% GPR @ 19%.
 MWT / MWE 2535 / 841

0755 Starting RMS Monthly SP-1303-4.15

0827 Heat Balance Complete SAT - SP-1302-1.1.

0830 Verified S.B.L. Headsets Operable.

1350 Verified Operability of DR-P-1B.

1420 Leak Rate Complete SP-1303-1.1 -0.1202 gpm

1500

1500 ~~Ward~~ R Power 100%, Temp 579, Press. 2150, Boron
 305, Gp. #7 at 96%, Gp. #8 at 21%, & MWE 846

1525 Verified S.B.L.R.T. headsets in place & operable

1530 Completed SP1302-1.1 sat.

1550 SP1303-4.15 complete

1700 started DR-P-1A to prove operability

1740 Completed SP1303-1.1 RC leakrate is -.26 gpm
 2025 Added 300 gal. To M.U. Tank from "A" RC BT

2215 Stopped MO-P-1C and MO-P-1F

2230 Completed Small break LOCA drill

2300 ~~Ward~~

SHIFT 1st TIME 2300 DATE 11-15-74
 SHIFT ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITION: 579 at 100% OPER. 71
 2155 76
 201 100%
 C.P. POS. 1-4 100%
 100%
 PLANT CONDITION/SPECIAL REMARKS: 2155 NAC 100%
 100%
 100%

- 2300 Verified 501 contact operate
- 2325 Start Relining to NACSE follow 176-784
- 2400 Stop vent the dump
- 2400 Start cap 26
- 0115 Start 40-PIB & 40-MK stopped NPP-11
- 0120 Start 5.2nd PW-110
- 0310 changed CCS limit to 660 MW E
- 0200 Backlog stop FW-PIB want operate 5min
- 0440 Warning and FW in hand
- 0445 Warned and FW in Auto
- 0500 See 176-784
- 0530 Complete 21302-61 out

SHIFT RELIEVED [Signature] TIME 0700 DATE 11-16-74
 SHIFT ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITION: 579 at 100% OPER. 76
 2155 76
 201 100%
 C.P. POS. 1-4 100%
 100%
 PLANT CONDITION/SPECIAL REMARKS: 2155 NAC 100%
 100%
 100%

- 0700 100% 100% from 08MT
- 0710 100% 100% from 08MT
- 0712 checked 526 pluses
- 0715 FW 9-10 on line
- 0726 FW 9-10 on Auto
- 0726 verified RPS set to @ 95%
- 0730 increasing Turb 2.2 MW/min
- 0800 holding @ 98% PWR
- 0832 operate nos 2 & 5 Reset hi flow PWR @ 10475

SYLLABUS
 WATER ESTABLISH

rc

DATE: 11/16/78
TIME: 4:26:20



REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1.0

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MTRK LVL (IN)	RCDT LVL (VOLT)
4:26:39:	565.453	594.508	563.758	593.078	579.195	236.361	83.516	8.948
5:26:39:	563.055	597.141	561.109	595.727	579.250	230.223	85.353	8.953

LEAKAGE PLUS LOSSES (<30 GPM): 0.8877 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.8359 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.6059 GPM

OPERATOR:


Woodgett

APPROVED:

D. Jones

STOP 0

3-162



Res

11/16/78

DR. J. L. ...
DUFFAL

10 PM

12 MN

2 AM

4 AM

6 AM

8 AM

10 AM

2300 *Paul Chalich* Rx PWR 207, TAVE 579°F RC Press 255
 Rod Index 295 - GPT 72%, Emer Tech Spec
 Boration Source is 'B' RPT @ 15, 15.4 ppm & 10.7'
 Min. level for this conc. is 6.25
 Verified SBL headset operable

0035 Commence 176-78-L

^{Backlog} 0800 Secure Neut TK Dump

0100 STARTED CO-P213

0115 STARTED HD-P1B, HD-P1C STOPPED 4D-P1A

0117 STARTED MO-P1C, MO-P1D, MO-P1E

0130 STARTED FW-P1B

0300 changed ICS Runback Limit to 660 MW2

^{Backlog} for 1 feed pump

0200 STOPPED FW-P1B

0340 Went to MANUAL ON ~~ALL~~ DIAMOND & FW DEMANDS A&B

0445 Went to AUTO on DIAMOND & FW DEMAND A&B (INC PWR SB 9752)

0500 Secured 176-78-L

0520 Pumped 40 GALS. FROM BMT TO RCS

0530 Completed SP1303-1.1 .6059 GPM

0540 Pumped 40 GALS FROM BMT TO RCS

0600 Pumped 26 GALS FROM BMT TO RCS

0640 Pumped 40 GALS FROM BMT TO RCS

11/16/79

0700 *J. Bank III* PWR ≈ 1986 MWt, INDEX 272, GPT @ 14%,
 579°F, 2155 PSI, ≈ 80% PWR

0700 ROOED 100 GAL FROM BMT

0840 ROOED ≈ 100 GAL FROM BMT

0843 CHECKED SOL PHONES

0925 FW-P1B ON LINE, Burn 338 ppm in RCS

0926 FW-P1A+B IN AUTO

0926 RPSA SET POINTS SET AT 95%

0930 INCREASING PWR ≈ 2 MWt/min

1000 HOLDING @ ≈ 90% PWR

1037 STARTING 1005-2 TO RESET H. Trip SET POINT to 104.75%

1045 B RPS IN MANUAL BYPASS

1100 B RPS OUT OF MANUAL BYPASS SET @ 104.75

1105 A RPS IN MANUAL BYPASS

1110 A RPS OUT OF MANUAL BYPASS

C RPS IN MANUAL BYPASS

C RPS OUT OF MANUAL BYPASS

D RPS IN MANUAL BYPASS

NAME BELIEVED *[Signature]*
 NAME MEMBER *[Signature]*
 NAME ORGANIZATION AND ADDRESS
 NO. POSITION
 NAME ORGANIZATION/INSTITUTION

- 1872 Standard Redwood 20' round
- 1873 Standard 2 1/4" Standard square
- 1874 Standard Redwood Complete set 12' round
- 1875 Standard 20' Red 20' Round
- 1876 Standard 20' Red 20' Round
- 1877 Standard 20' Red 20' Round
- 1878 Standard 20' Red 20' Round
- 1879 Standard 20' Red 20' Round
- 1880 Standard 20' Red 20' Round
- 1881 Standard 20' Red 20' Round
- 1882 Standard 20' Red 20' Round
- 1883 Standard 20' Red 20' Round
- 1884 Standard 20' Red 20' Round
- 1885 Standard 20' Red 20' Round
- 1886 Standard 20' Red 20' Round
- 1887 Standard 20' Red 20' Round
- 1888 Standard 20' Red 20' Round

[Signature] 11-21-78
 Signature

879	931
2157	100
783	100
783	100
783	100
783	100
783	100
783	100

- 0036 completed SP 1300-1.1
- 0130 Standard SP 1300-3MB
- 0215 completed SP 1300-1.1
- 0425 completed SP 1300-1.1
- 0500 completed SP 1300-2MB
- 0600 Standard SP 1300-1.1

DATE: 11/20/78
TIME: 21: 9:55



REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
1:10:11:	557.859	601.742	556.203	600.750	579.133	221.658	77.356	9.866
2:10:11:	558.148	601.961	556.281	600.953	579.336	220.410	76.970	9.862

LEAKAGE PLUS LOSSES (<30 GPM): 1.0663 GPM

GROSS RCS LEAK RATE (<10 GPM): 1.1072 GPM


NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.8772 GPM

OPERATOR: *Brantley*

APPROVED: *DR [Signature]*

STOP 0

089



11/20/78

1500

J. Bonh III

1500 ~~J. Bonh III~~ Rx Power 10090, TAVE 5794, TOL
 PARS 2155 psw, GA 8@ 23% FOD Index 292%
 MWT/MWE 2535/837.

1552 RM-A-8 RETURNED TO NORMAL.

1630 REPAIRED S.B.L. DEVICES OPERABLE.

1820 ARA BALANCE COMPLETE STAT SP-1302-1.1.

1855 TERMINATED NEXT TUR DUND.

1900 ~~BREED'S FEED 1500 GAL FROM "A" RC BT.~~2040 ~~BREED'S FEED 500 GAL FROM "A" RC BT.~~2130 ~~BREED'S FEED 1000 GAL FROM "A" RC BT.~~

2140 AH-E-1B 55 gal SEAKAGE.

~~2215~~ LEAK RATE COMP. STAT SP-1303-1.1. ^{.8772} _{+.8782} JPM

2215 ~~BREED'S FEED 1000 GAL FROM "A" RC BT.~~

2237 TANK LIQUID RELEASE 179-78-L.

2238 STOPPED MO-P-6'S 1B.

2245 ~~BREED'S FEED 1000 GAL FROM "A" RC BT.~~

2300

J. Bonh III

DEPT. CHIEF: *[Signature]*
 DEPT. CHIEF: *[Signature]*
 DEPT. CHIEF: *[Signature]*

PLANT CONDITIONS: AIR TEMPERATURE 877 °C AIR SPEED 837 mph
 AIR PRESSURE 31.85 psia IN POWER 100 %
 AIR FLOW CORR. 2.85 psia C.P. FOR 1-4 100 %
 PLANT CONDITIONS/SPECIAL REMARKS: 777 Heat Map 6.100 %
 7.75 %
 8.17 %

- 0100 Started Liquid Release 780-782 of A WEAST
- 0207 Start Heat TK Drop
- 0210 stopped Heat TK Drop
- 0310 Start Heat TK Drop
- 0318 completed SP1302-1.1 Heat Bal set
- 0525 completed SP1302-1.1 RC Leak rate @ -0.37 gpm
- 0540 completed SP1302-1.1 25 on RB. Personnel Door set.

DEPT. CHIEF: *[Signature]* TIME 0700 DATE 11-20-77
 Signature
 DEPT. CHIEF: *[Signature]*
 Signature

PLANT CONDITIONS: AIR TEMPERATURE 877 °C AIR SPEED 836 mph
 AIR PRESSURE 31.85 psia IN POWER 100 %
 AIR FLOW CORR. 2.85 psia C.P. FOR 1-4 100 %
 PLANT CONDITIONS/SPECIAL REMARKS: AWEAST 777 6.100 %
 7.92 %
 8.15 %

- SF Log Review of flow
- 0710 verified headsets operate at 200 STATIONS
 - 0730 completed of liquid release 170-174
 - 0915 completed sp 1302-1.1 67.
 - 1220 completed sp 1302-1.1 -0.36 gpm



GROUP NUMBER: _____
 GROUP ASSIGNED BY: J. W. [unclear]
 SIGNATURE: _____
 DATE: _____
 NAME IDENTITIES: R-1 [unclear] 100
 R-2 [unclear] 100
 R-3 [unclear] 100
 NAME IDENTITIES/SPECIAL REVISIONS: 100
 100
 96
 20

1725 SP1902-1.1 Not Bad
 1725 115-72-6 STARTED
 1825 SP1903-1.1 Complete - 09 gpc
 2000 191-72-6 STARTED

GROUP RECEIVED: [Signature] DATE: 11/20/54
 SIGNATURE: _____
 GROUP ASSIGNED BY: [Signature]
 SIGNATURE: _____

NAME IDENTITIES: R-1 [unclear] 100
 R-2 [unclear] 100
 R-3 [unclear] 100
 NAME IDENTITIES/SPECIAL REVISIONS: 100
 100
 96
 20

- 2721 Sealed samples - 100-10
- 2722 Completed SP1902-1.1 Mass Balance (100)
- 2005 Terminated 191-72-6
- 2000 STARTED 191-72-6
- 2006 Completed SP1903-1.1 Mass Balance (100)
- 2007 Completed SP1903-1.1.25 20 gpc Test (100)
- 2008 Performed SP1903-1.1.25 20 gpc Test (100)
- 2009 Completed 704 Mass Balance (100)
- 2000 SP1902-1.1.25 20 gpc Test (100)

PC

DATE: 11/24/78
TIME: 4:22:55

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1
ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

0
ENTER RCDT CHANGE (GAL)

0
ENTER RCS CHANGE (GAL)

0

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
4:23:12:	557.836	601.742	556.266	600.852	579.172	224.143	79.928	9.461
5:23:12:	558.164	601.727	556.586	600.805	579.313	225.602	79.337	9.494

LEAKAGE PLUS LOSSES (<30 GPM): 0.1817 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.1359 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.3659 GPM

OPERATOR: *W. Smith* 11-7 11/24/78

APPROVED: *[Signature]*

DATE: 11/24/78
TIME: 11:10:59

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
11:11:26:	558.156	602.148	556.586	601.188	579.516	224.727	78.591	9.594
12:11:26:	557.992	601.859	556.328	600.914	579.266	223.020	78.520	9.604

LEAKAGE PLUS LOSSES (<30 GPM): 0.0056 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.0967 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.3267 GPM

OPERATOR: *M.P. Kennedy*

APPROVED: *L. A. S.*

STOP 0

109

STOP 0

PC

!

DATE: 11/24/78

TIME: 17:24:48

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1.0

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
17:25: 5:	557.633	601.531	555.867	600.633	578.906	221.477	77.657	8.860
18:25: 5:	558.016	601.664	556.336	600.719	579.180	222.615	77.661	8.847

LEAKAGE PLUS LOSSES (<30 GPM): 0.1366 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.2701 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.0401 GPM

OPERATOR:

APPROVED:

STOP 0

!

11-24-78

2300 R. Hillman R. Pwr. 100%, Press. 2150, Temp. 579, Boron 255
Gp. #7 at 95%, Gp. #8 at 20%, MWe 834, & Xe 2.67%
Tech. spec. emergency B.A. Tank is "B" R.B.A.T. at a
level of 10.6' and a conc. of 15,190ppm b. Minimu
level for this conc. is 6.2 ft. MeT. Ed. equip.
O.D.S. same as 11-23-78.

2315 Verified S.B.L.R.T. headsets operable and in place

2350 Added ~~300 gal.~~ to ~~M.H. Tank~~ from "A" RCBT

0100 Start liq. release #180-78L of "A" NECST

0207 Start neut. tank dump

0210 Stop neut. tank dump

0310 Start neut. tank dump

0315 Completed SP1302-1.1 sat.

0515 De-energized Halon sys.

~~0525~~ Completed SP1303-1.1 R.C. leakrate is -.37gpm

0540 Completed SP1303-11.25 on R.B. Personnel door - sat.

0600 Halon sys. returned to service

0700 R. Hillman

0700 T.K. Keydig R. power 100%, Press. 2155, TAVE 579°
Ind. 292, Lx. 8 @ 16, MW 2530 MWe 340

0715 VERIFIED SBL HEADSETS

0730 TERMINATED LIQUID RELEASE 180-78-L

CRU Log Review in my Room

0915 COMPLETED SP-1302-1.1 SAT. 99.343

~~0920~~ COMPLETED SP-1303-1.1 SAT - 0.3267

1000 1302-3.1 STARTED By EAC

1300 1302-3.1 TERMINATED

1415 FREE BLEED 450 GAL FROM "A" RCBT TO "B" RCBT.

1500 T.K. Keydig

1510 J. Bonham III R. 100% Power, INDEF 296, 67#8 @ 20'h, 579°F,
2155 PSI,

1425 Completed S.P. 1302-1.1

1725 115-78-L STARTED

1825 SP 13.3-1.1 COMPLETE +0.04016PM

2000 STARTED 181-78-L

2300 J. Bonham III

11/25/78 SW Brantley Rt. per 100%, RC pressure 2155 psig
 2300 Tank STA F, GP 7 @ 95%, GP 8 @ 20%, #We 843
 Tech spec emergency location tank is 3' REAT. @ a level
 of 10.6' and a concentration of 15,190 ppm. Min. level for
 this concentration is 6.2'. Met-Ed equipment O.O.S. is
 #195 - CO-26

#222 - EHC unit ltr. fan

#400 - Jib crane

#521 - WDL-P-2A

#772 - SS-P-1

#876 - WOL-T-8

#1050 - 4A ltr. sight/glass

#1123 - Solid waste

#1124 - SR-P-2C

#1159 - PI-330

#1213 - A' BAR RACK

#1228 - SP-10A1PTZ

#1265 - SW-P-2A

#1289 - 10-P-38/39

#1308 - security camera

#1336 - Heat tracing

#1337 - Heat tracing

#1351 - SR-P-3A

#1359 - IW-P-2/IW-T-2

#1362 - W-P-31

#1385 - FW-V-1B

#1387C

2324 Secured MO-P-1C & MO-P-1F

2338 COMPLETED HEAT BALANCE SAT SP-1302-1.1

0025 TERMINATED 181-78-4

0040 STARTED NEXT. TX. DUMP (SECONDARY)

0046 COMPLETED SP 1303-1.1 CRACK RATE SAT - 0.7176 GPM

0050 REMOVED RM-A-2 FROM SERVICE TO FIX FILTER TEAR PROBLEM

0140 RB DOWR TEST COMPLETE SAT.

0205 PREPARED SP 1303-4.17 SAT. OBTAIN STD ISOLATION VALUES TEST

0500 PLACED RM-A-2 BACK IN SERVICE

LATE 0540 VERIFIED SBL HEADSETS OPERABLE


0700 SW Brantley

0700 JX Zooly


0701 Verified SBL HEADSETS

0730 COMPLETED SP 1302-1.1 SAT. 99.049


14F
↓



PL-42-11
111-1211
Lan 527



11-24-78



ATTACHMENT B

COPIES OF RCS LEAK RATE

TEST RAW DATA SUPPORTING

TABLE 6

HYDROGEN ADDITIONS

DATE: 6/8/78
TIME: 7:35:26

REACTOR COOLANT LEAKAGE TEST
SH 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

1.0
ENTER IDENTIFIED LEAKAGE FROM DS 1107-1.1 (OPM)

0.0
ENTER RCCT CHANGE (GAL)

0.0
ENTER RCS CHANGE (GAL)

+ 2.11

61.22 gal

1.03 gpm

TIME	ICA (F)	IHA (F)	ICB (F)	IHB (F)	TAVE (F)	MCZR LVL (IN)	MCZR LVL (IN)	MCOT LVL (VOLT)
------	------------	------------	------------	------------	-------------	------------------	------------------	--------------------

7:35:24 550.0 550.0 550.0 550.0 550.0 550.0 550.0 550.0

8:35:24 557.76 601.71 558.88 600.78 559.84 600.78 559.84 600.78

LEAKAGE PLUS LOSSES (<10 GPM)

GROSS RCS LEAK RATE (<10 GPM): 0.1201 GPM

NET UNIDENTIFIED LEAK RATE (<10 GPM)

OPERATOR: *James Chelchek*

APPROVED: *C. Chelchek*

STOP

0700 VERIFIED SP-1302-1.1 REPAIRS COMPLETE
 0700 COMPLETED SP-1302-1.1 REPAIRS COMPLETE - 205 PSI
 1100 COMMENCED CONDENSER RETURN FROM UNIT 2
 1140 AIR INTAKE SERVICE ON REPAIRS TO SERVICE
 1215 AIR INTAKE CONTROL SYS OUT OF SERVICE FOR 1302-1.1

SHIFT RELIEVED *C. Mathews* TIME *11:45* DATE *8/27/78*
 SHIFT ASSIGNED BY *J. Jones*

PLANT CONDITIONS: H2O TEMPERATURE *579* OF H2O CROSS *911* WPH
 H2O FLOW *2055* GPM IN POWER *100* %
 H2O BORE COND. *594* WPH C.E. POS. 1-4 *100* %

PLANT CONDITIONS/SPECIAL REMARKS: *2.12* H2O *100* %
95 %
36 %

1555 *Started RR-E101*
 1620 *unified gain local control*
 1755 *SP-1302-1.1 out*
 1806 *SP-1302-1.1 out*
 1807 *air tunnel cleanup complete*

SHIFT RELIEVED *O. Jones* TIME *2:15* DATE *8-8-78*
 SHIFT ASSIGNED BY *J. Jones*

PLANT CONDITIONS: H2O TEMPERATURE *579* OF H2O CROSS *912* WPH
 H2O FLOW *2055* GPM IN POWER *100* %
 H2O BORE COND. *586* WPH C.E. POS. 1-4 *100* %

PLANT CONDITIONS/SPECIAL REMARKS: *2.12* H2O *100* %
95 %
36 %

2305 *completed SP-1302-1.1 Heat Bal set*
 0450 *completed SP-1302-1.1 RCS Leak Rate @ -0.7 gpm*
 0615 *started RR-p-18 to verify operability set*
 0616 *stopped SP-p-18*
 0630 *stopped RR-E101*
 0640 *started R.D. purge 2P-276*
 0645 *started Mo-p-18*

2 hour check

204.

8-8-77
2300

B. Helman Rx. Pow. 100%, Temp. 577, Press. 2150,
Baron 574, Gp. #7-J 95%, Gp. #8-J 26%, MWE 814
Tech. Spec. Emerg. B.A. Tank is "B" R.B.A.T. at a conc.
of 15,388 ppm and a level of . Minimum level
for this conc. is 8 ft. Met. Ed. equip. O.O.S.
same as 8/7/78 except as follows: #994
DR-P-B, #995 MD-P-1A, #996 Halon, & #997 IA-P-1A
were added to equip. O.O.S. and #988 WDL-P-7B,
#990 Halon, #985 JW-P-38 & 39, ~~#997~~ were
returned to service.

2335 Completed SP1302-1.1 sat.

2335 Verified S.B.L.R.T. headsets in place & operable

2345 Started AH-E-101

0040 Completed SP1303-1.1 RC leakrate is +.11 gpm.

0630 Started MD-P-1D

0630 Stopped AH-E-101

0700 B. Helman

0700 J. [Signature] Rx Power @ 100%, Temp. 574 F Press. 2155 psig
Rod Index 293 Gp 8 @ 25%

0740 Completed SP1302-1.1 Heat Balance Sat.

0800 Verified SBL Headsets

0900 Completed SP1303-1.1 Leakrate Sat - 0.109 gpm

1100 Started Condensate Return From UN. EIT

1500 J. [Signature]

1500 J. [Signature] Rx Power @ 100%, Temp. 574 F
Press. 2155 psig Rod Index 294 Gp 8 @
26% MWE/MWT 798/2521

1525 Added 300 gal to RCS from "A" D.B.T.

1555 Stopped AH-E-101


1620 Verified Headsets for S.B.L. Operation.

1755 Heat Balance Complete Sat SP1302-1.1

1806 Leak Rate Complete Sat SP-1303-1.1 +.223 gpm

1807 Air Tunnel Furnace Sys Returned to Service.

2300 J. [Signature]



0735
0835

2/18/80

Close

*+3"
92.649 gal
1.5442 gpm*

DATE: 9/ 8/78
TIME: 16:28:54

REACTOR COOLANT LEAKAGE TEST
SP I303-I.1

DESIRED INTERVAL (I-8HOURS)

ENTER IDENTIFIED LEAKAGE FROM DS I303-I.1.2 (GPM)

ENTER RCOT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	TNA (F)	TCS (F)	TNB (F)	TAVE (F)	PRZR LVL (IN)	MTRK LVL (IN)	RCOT LVL (VOLT)
16:29:13:	557.363	601.273	555.797	600.266	578.719	230.068	68.349	8.919
17:29:13:	557.703	601.445	556.016	600.453	578.098	229.512	69.604	8.919

LEAKAGE PLUS LOSSES (<30 GPM): -0.3523 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.3523 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.5823 GPM

OPERATOR: *Steve Brantley*

APPROVED: *D. H. Pate*

STOP

NAME: P. J. Kelly NO: 1142 DATE: 8/10/78
 UNIT & OPERATOR: 178 Kelly
 REASON:

NAME CONDITIONS: R'S TEMPERATURE 679 °C INSTEAD 821 °C
 R.P. POINTS 265 172 IN STEAD 100 S
 R'S RISE CODE 997 100 R.S. FOR 24 100 S
 NAME CONDITIONS/SPECIAL REASON: 100 S 100 S
100 S
100 S

1540 Completed SP 1303-41 but before 9:00 AM
 1603 Verified location of fault @ 10:46 AM, C.D.
 1730 Completed SP 1303-41 70% but not 7:50 AM
 1730

UNIT OPERATOR: 178 Kelly NO: 1142 DATE: 9-8-78
 REASON:

NAME CONDITIONS: R'S TEMPERATURE 679 °C INSTEAD 827 °C
 R.P. POINTS 265 172 IN STEAD 100 S
 R'S RISE CODE 997 100 R.S. FOR 24 100 S
 NAME CONDITIONS/SPECIAL REASON: 100 S 100 S
100 S
100 S

2130 Completed SP 1303-1.1 and heat data
 0030 Started AM-10-101
 0100 Completed SP 1303-2.1 Control Rod Movement
 0110 Reducing R.R. Pwr To 65%
 0130 @ 65% R.R. Pwr
 0145 Increasing R.R. Pwr Completed Toolair valve testing
 CV-1 8.5mm MS-V-1 27.5000 CI-V-1 20mm CV-5 15mm
 CV-2 7.5mm MS-V-2 11.5300 CI-V-2 24.5mm CV-6 25mm
 CV-3 7.5mm MS-V-3 28.5000 CI-V-3 26.5mm
 CV-4 7.5mm MS-V-4 27.5000 CI-V-4 27mm
 0055 added 50gals to MSTR from BMT.
 0140 DAPS To Manual bypass per OP 1105-2. To avoid N. Trip
 0145 DAPS To Normal + CRPS To Manual bypass
 0120 1CRPS To Normal + 1CRPS To Manual bypass
 0125 1CRPS To Normal + 1CRPS To Manual bypass ILL from 80%
 0130 CRPS To Normal and all N. Trip set points are now
 95%
 0600 CRPS To Manual bypass per OP 1105-2 To avoid N. Trip set points

4/8/78


- 2300 ~~W. Brantley~~ H. Pomeroy 100% Tave 579°F RC Press 2155 PSI
 Rod Index 296 618 @ 256 Tub Spun Smog. Purated
 WATER SOURCE IS BRBAT Level 10.6' CONCENT RATION IS
 15070 ppub. M. Level for present concentration is 6.4'
- 2310 Stopped MO-P 1A & PID
- 2315 Verified SBL HEADSETS
- 2353 Stopped S. B. L. Pury # 99-74-6
- 0005 Completed SP1303-11.25 R. B. L. Reasoned Duct Test SAT. 0.75 CFH
- 0045 Completed SP1302-1.1 Heat Balance SAT.
- 0200 Completed SP1303-1.1 LEAK RATE SAT. -0.0992 gpm
- 0245 Fed & bleed 300 gal.?
- 0525 Verified operable RR-P 1B, DR-P 1A, NR-P 1B, NR-P 1C
 Verified NR-P 1B on IR BUS & NR-P 1C on IT BUS IS SELECTED
- 0530 Removed From Service RR-P 1A, DR-P 1B, NR-P 1A, FS-P 3
 Switching ORDER # 1082
- 0600 Started MO-P 1A & PID
- 0700 ~~W. Brantley~~
- 0700 J. Brantley III ~ 100% PWR, INDEX 294.5, GP # 224%,
 578°F TAVE, 2155 PSI, BRON 497 PPM
- 0723 Verified S. B. L. HEADSETS
- 0930 SP1302-1.1 COMPLETE
- 1230 ISOLATED CONDENSATE RETURN
- 1337 RETURNING CONDENSATE FROM UNIT #2
- 1345 ISOLATED CONDENSATE RETURN
- 1445 STARTED CONDENSATE RETURN
- 1500 ~~W. Brantley~~
- 1500 J. Brantley P. Pomeroy 100% Tave 579 RC Press 2155 PSI
 No INDEX 296 GP # 262
- 1540 Completed SP-1302-1.1 HEAT BALANCE SAT.
- 1603 Verified SBL HEADSETS OPERABLE
- 1730 Completed SP-1303-1.1 SAT. = .5823 GPM
- EMY KAL6 Verified FS-P-3 OPERABLE
- 1826 Verified DR-P-1B OPERABLE
- 1828 Verified NR-P-1A OPERABLE
- 1830 Verified RR-P-1A OPERABLE
- 1923 Verified SW-P-2A OPERABLE
- 2245 Stopped MO-P 1B & MO-P 1E
- 2300 J. Brantley

0050

GRAPHIC CONTROLS CORPORATION BUFFALO, NEW YORK

chart time

loggi time



↑
 1730 HR
 9/3/78

STOP 0

IFC

DATE: 9/18/78
TIME: 23:55:26

+1"
30.883
0.5749 gpm

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-BIDOURS)

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCS CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	ICA (F)	TIA (F)	ICB (F)	TIB (F)	IAVE (F)	PRZR LVL (IN)	MIX LVL (IN)	RCDT LVL (VOLT)
01:55:42	557.984	601.844	558.250	600.891	579.242	229.336	81.899	8.847
01:55:42	558.117	601.875	556.328	600.953	579.313	228.887	81.349	8.981

LEAKAGE PLUS LOSSES (<300GPM): 0.6761 GPM

GROSS RCS LEAK RATE (<13 GPM): 0.6314 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.4014 GPM

OPERATOR: *J. M. [Signature]*

APPROVED: *DR [Signature]*

STOP 0

DATE DELIVERED Alb. 11/15/78 1500 9-15-78
SHIFT ASSIGNED BY [Signature]

SHIFT CONDITIONS: ICE TEMPERATURE 579 °F ICE CUBE 100 WT
ICE FINISHING 3125 POUNDS IN TONS 100 S
ICE MASH CUBE 100 POUNDS U.S. TON 1-1 100 S

SHIFT CONDITIONS/SPECIAL NUMBER: _____

1523 SBL phone operable ✓
1922 Verified DA-P-12, SE-P-18 & SE-P-2 operable
3126
2558 SP1202-11 completed - 0.4222 gpm
3020 SP1202-11 completed int

SHIFT DELIVERED [Signature] 2300 9-18-78
SHIFT ASSIGNED BY [Signature]

SHIFT CONDITIONS: ICE TEMPERATURE 579 °F ICE CUBE 100 WT
ICE FINISHING 3125 POUNDS IN TONS 100 S
ICE MASH CUBE 100 POUNDS U.S. TON 1-1 100 S

SHIFT CONDITIONS/SPECIAL NUMBER: ONE OUT TEST 0-100 S

2300 Verified 300 products operable, Heat balance SP1202-11
Completed (Set)
0075 Completed SP1202-12 back rate 4028 gpm
0000

SHIFT DELIVERED [Signature] 2300 9-19-78
SHIFT ASSIGNED BY [Signature]

SHIFT CONDITIONS: ICE TEMPERATURE 579 °F ICE CUBE 100 WT
ICE FINISHING 3125 POUNDS IN TONS 100 S
ICE MASH CUBE 100 POUNDS U.S. TON 1-1 100 S

0740 SHIFT CONDITIONS/SPECIAL NUMBER: 267 MARKET 0-100 S
1140 Completed SP1202-11 Heat Bal rate 493 S
1140 Started Monitoring TX dump 0-21 S

SF Log Reference by Ty...

9/19/78

2300 J. M. Weston R. Power 100%, TAVE 579°F, RC
 PRESS 2155 PSI, GR 8 @ 2 1/2% Pd TUDY 296%
 TECH SPEC Boron Tank "B" RBAT LVL
 MIN LEVEL 6.2' Boron Concentration 15,315 ppm @ 6.4
 AWE/AWT 839/2507, MTR 65 END 003 SAME AS
 9/18/78.

2350 VERIFIED SBL HEADSETS OPERABLE.

2350 HEAT BALANCE COMPLETE SAT SP-1302-1.1

0017 STARTED AN-E-101

0055 LEAK RATE COMPLETE SAT SP-1303-1.1 +.4014 gpm

0220 OPERABILITY OF DR-P-1A, NR-P-1A, SRP-P-K SATISFACTORY

0605 STARTED NO-P-1B & 1E.

0618 STOPPED AN-E-101.

0700

J. C. Hermann R. Power 100%, TAVE 579, 2155 PSI,
 Boron 463 Rod Index 294 GR 8 @ 22.

0720 VERIFIED SBL HEADSETS OPERABLE AND IN PLACE

CRO Log Reviews in progress

1140 STARTED DUMPING NEUT. TANK

1240 PRESSURIZED CF TANKS WITH N₂

BACK LOG

0741 COMPLETED SP-1303-1.1 SAT HEAT BALANCE

1500 J. C. Hermann

1500 J. E. Bush REACTOR POWER 100%, TAVE 579°F, RC PRESSURE
 2155 PSI, GROUP 7 AT 96%, GROUP 8 AT 24%.

1523 CHECKED SBL PHONES OPERABLE

1600 SP1302-1.1 COMPLETE O.K.

1715 SP1303-1.1 COMPLETE - .40 GPM

1950 DRP1B TESTED & OPERABLE

1952 FSP-2 TESTED & OPERABLE

1955 SRP1B TESTED & OPERABLE

2300 J. E. Keim

+ 2 1/2

61,966 gal
1,0294 gpm

DATE: 9/19/78
TIME: 23:48:23

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS) 1
ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM) 0
FILTER RCDC CHANGE (GAL) 0
ENTER RCS CHANGE (GAL) 0

TIME	TCA (F)	TIA (F)	TCB (F)	THB (F)	TAVB (F)	PRZR LVL (IN)	WATR LVL (IN)	RCOT LVL (VOLT)
23:48:46	558.242	601.020	556.500	600.859	579.352	230.052	79.804	9.254
0:48:46	558.383	603.859	556.563	600.914	579.422	229.059	80.370	9.253

LEAKAGE PLUSLOGSES (<30GPM): 0.3395 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.2468 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.0168 GPM

OPERATOR: *[Signature]*
APPROVED: *[Signature]*

SHIFT RELIEVED

[Signature]

TIME 1500

DATE 9-20-78

SHIFT ASSIGNED BY

[Signature]

Signature

PLANT CONDITIONS:

HC TEMP 777

at

HC CROSS

100

HC PRESSURE

2185

HC POWER

100

HC BURN CONC

4.3

U.S. P.O.S. 1-4 100

PLANT CONDITIONS/SPECIAL REMARKS:

100

100

95

24

1523 checked 58h shown operable

1500 SP1502-1.1 complete OK.

1715 SP1503-1.1 complete -0.4 gpm

SHIFT RELIEVED

[Signature]

TIME 2300

DATE 9-20-78

SHIFT ASSIGNED BY

[Signature]

Signature

PLANT CONDITIONS:

HC TEMP 777

at

HC CROSS

100

HC PRESSURE

2185

HC POWER

100

HC BURN CONC

4.3

U.S. P.O.S. 1-4 100

PLANT CONDITIONS/SPECIAL REMARKS:

HC TEMP 777

100

95

24

2320 Ver. Prod 58h Headrate operable

2350 Completed SP1500-1.1 set Heat Malacca

2045 Completed SP1505-1.1 set 4.0168 gpm

2040 OR-P-18, HA-P-18 003

2050 Secured Heat. Tank Dump.

268

9/24/78

2300 John Brantly RC Press 70071 Tank 579°F RC pressure -
 2155 p.g. Prod Index 296 GP 88 249. Tech spec
 Temporary (normal) source tank is B KBAT tank
 level of 10.6' and concentration of K, 815 ppm. Min
 level is 6.2' MET ED EQUIPMENT OUT OF SERVICE IS
 SAME AS 9/19/78 WITH FOLLOWING EXCEPTIONS
 PROD- #1139 - W-P-23, #142 - AH-E-99, Rammer #1128
 HD-T-18

- 2315 ADDED 300 GALLONS FROM 'A' RCBT TO MU TANK
- 2320 VERIFIED SBL HEADSETS OPERABLE
- 2330 STOPPED MO-P-1C, 1E
- 2345 PLACED MU-K-1A IN SERVICE
- TOOK MU-K-1B OUT OF SERVICE

2350 COMPLETED SP 1302-1.1 SAT
 LATE ENTRY 2310 PLACED AH-E-101 IN SERVICE

- 0048 LEAK RATE COMPLETE SAT SP-1302-1.1 + .0168 gpm
- 0400 VERIFIED DR-P-1A, NR-P-1A, NR-P-1C OPERABLE
- 0440 - DR-P-1B, NR-P-1B 005. START 72 HR. CLOCK
- 0510 - SEC MET TK PUMP
- LATE ENTRY 0445 - PLACED MU-K-1 B IN SERVICE, PLACED TANK MU-K-1A 005.
- 0610 - SEC AH-E-101
- 0625 - STOPPED MO-P-1C, 1E

0700 John Brantly

0700 Paul Chalochi 100 RC PWR RC Press 2155 Tank 579°F
 Prod Index 293.5 GP VIII 22

0810 Commence SP 1303-4.1 RPS 'D' Test, 'D' RPS
 IN MANUAL

0812 Verified RRP 1B OPERABLE, RR P 1A 005 AND
 ON A 72 hr clock

0831 Verified SBL headsets operable

0950 Completed SP 1303-1.1 .2271 GPM SAT

1035 Went to MANUAL on DIAMOND & FW FOR EXR TRIPS

1130 Completed SP 1303-4.1 - RPS 'D' SAT

1200 STARTED HD P 1B, STOPPED HD P-1C


1230 STARTED AH-E-101

1335 ADDED 200 GALS FROM 'A' RCBT TO MUT-1

1437 Verified RR P 1A OPERABLE

1500 Paul Chalochi

(2115) 2350h
7-19-78 (+ H₂)



(written)
2348 → 0048
9-19 → 9-20-78

01C
rc

F3''

DATE: 10/ 2/78
TIME: 16:45:40

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESTRED INTERVAL (1-8 HOURS)

1.0

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

0.0

ENTER RCS CHANGE (GAL)

0.0

ENTER RCS CHANGE (GAL)

0.0

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
16:45:57:	557.578	601.406	555.813	600.414	578.797	226.156	76.440	9.163
17:45:57:	557.828	601.602	556.117	600.617	579.031	228.689	76.591	9.784

LEAKAGE PLUS LOSSES (<30GPM): -0.5212 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.2593 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.0293 GPM

OPERATOR: *Paul Chalich*

APPROVED: *D. Jones*

STOP 0

2300 MU-K1A in Service MU-K1A-005
 2305 Verified SGL Headsets
 2330 Completed SP-1302-1.1 Heat Bal (Sat)
 0100 MU-K1B in Service MU-K1B-005
 0141 Completed 3303-M1 on FS-A5 sat
 0159 terminated run of 26 drums
 0237 Completed SP-1303-1.1 leak test -0095
 0200 started MO-P-16 + MO-P-10

SHIFT RELIEVED *[Signature]* 0700 DATE 10/2/75

SHIFT ASSUMED BY *[Signature]*
 Signature

PLANT CONDITIONS: RCS TEMPERATURE _____ at HSE CROSS _____ MW
 RCS PRESSURE _____ PSIG RE POWER _____ S
 RCS BORON CONC. _____ PPM C.E. POS. 1-4 _____ S

PLANT CONDITIONS/SPECIAL REMARKS:

0735 Completed SP1302-1!
 1025 Isolated MU-V-17 for Repair
 1445 STOPPED R.2. Pump

SHIFT RELIEVED *[Signature]* 1500 DATE 10/2/75

SHIFT ASSUMED BY *[Signature]*
 Signature

PLANT CONDITIONS: RCS TEMPERATURE 579 at HSE CROSS 890 MW
 RCS PRESSURE 2155 PSIG RE POWER 100 S
 RCS BORON CONC. 470 PPM C.E. POS. 1-4 100 S

PLANT CONDITIONS/SPECIAL REMARKS: 792 MAX - Act

1530 wind off
 1620 Restart RO Pump 102-786
 1645 Complete SP1312-AL sat
 1650 stopped RO Pump 102-786
 1755 Complete SP1303-1.1 sat + 0.076PM

OCT 2 1978

2300 *H. Gallay* RR-PURVIS. TANK 579 REPR 2155 GAGE 23
1302.09 EPD BOON 440

2300 MU-KIA IN Service - MU-KIB OUT
TECH. SPEC. CRAY BORATION SOURCE. B CBAT @ 154000MB 10.7
MIN. REQUIRED LEVEL 613"

2305 Verified SBL HEADS

2330 1302-1.1 SAT 99.412%

0005 TEST FP TURB. ST. VS PR 1105-1

0100 MU-KIB IN Service - MU-KIA OUT

0141 3303-MV Comp. - SAT ON FB-R

0155 TERMINATED NUC. TR. DUMP

0237 1303-1.1 Comp. - SAT - 0095

0515 Verified operability of DR-PIB & RR-PIA

0600 DR-PIA, RR-PIB, AL-PIA, & SC-PIA TAGS OK

0605 STARTED MU-PIB & MC-PIB

0700 *H. Gallay*

0700 *E. Smith* 100% REPAIR, 835 MWG,
579 TANK, 2150 PSI G, GP7 @ 9470, GP8 @ 2120

0730 Verified SBL HEADSETS operable

CAD Log Reviewed OK

0755 completed SP 1302-1.1

1025 ISOLATED MU-V-17 FOR REPAIRS, CONTINUING
PROBLEMS WITH MU-V-5

1445 STOPPED RB Purge 102-78-6 DUE TO RELEASE
IN FH & AUX BLDG.

1500 *E. Smith*

1500 ~~Stopped~~ RR-PURVIS TANK 579 REPR 2155 PSI
RADIATOR 294 GP8 @ 212

1530 Wind speed & direction RECORDER RETURN TO SERVICE

1620 RESTARTED RB Bldg Purge 102-78-6

1645 completed SP 1302-1.1 HEAT BALANCE SAT

1650 STOPPED RB Bldg Purge 102-78-6 DUE TO RELEASE IN FH &
AUX BLDG.

1755 completed SP 1303-1.1 LEAK RATE SAT 0.02939/4

1800 Verified SBL HEADSETS

1845 STARTED Neutralizing TANK DUMP

1900 ALERT ALARMS ON RM-A4 PART, Iodine, GAS

RM-A6 PART & GAS, RM-A8 GAS, ALERT AND HIGH
ALARM ON RM-G10

!! LOCAL Emergency Declared By S.H. FT FREMAN

10/2/78

- 1901 ANNOUNCEMENT OF LOCAL EMERGENCY MADE
EVACUATED UNIT 1 Aux & FUEL HANDLING BLDGS AND
UNIT II FUEL HANDLING BLDG. NOTIFIED Shift
SUPERVISOR OF LOCAL EMERGENCY CONDITIONS
- 1910 HEALTH PHYSICS DEPT. DISPATCHED TO SOUTH END
OF ISLAND TO OBTAIN SAMPLES. UNIT 1 Aux
& FUEL HANDLING BLDGS. RE-ENTERED TO DETERMINE
CAUSE OF RELEASE
- 1942 RECEIVED RM-AB PART. HIGH ALARM
- 2035 ALL ~~RMS~~ RMS ALARMS CLEAR FOR Aux &
FUEL HANDLING BLDGS. SECURED FROM LOCAL
EMERGENCY
- 2105 STARTED & VERIFIED OPERABLE DR-P1B, RR-P1B
AND NR-P1C
- 2108 SELECTED NR-P1C FOR ES ON THE IT BUS &
REMOVED NR-P1B FROM SERVICE
- 2135 RESTARTED A BLDG PUMP 102-78-6
- 2210 STOPPED MO-P1B & MO-P1E
- 2300 ~~DR-P1B~~

No. SA160

PRINTED IN U.S.A.


2 PM

4 PM

6 PM

8 PM

10 PM



10-2-78

878

STOP 0

H₂
1.5"

Lrc

DATE: 11/12/78
TIME: 8:16:35

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (I-8 HOURS)

1
ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

0
ENTER RODT CHANGE (GAL)

0
ENTER RCS CHANGE (GAL)

0

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MOTK LVL (IN)	RODT LVL (VOLT)
8:16:53:	557.945	601.797	556.391	600.891	579.250	229.441	74.674	8.861
9:16:53:	557.945	601.742	556.242	600.820	579.180	229.193	75.486	8.796

LEAKAGE PLUS LOSSES (<30 GPM): -0.6127 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.0346 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.1954 GPM

OPERATOR:

APPROVED:

035

STOP 0

0030 Uam Prod 1302 Headnote
 0030 Completed at 1302-1.1 last entry on 1302-1.1
 SHIFT BELIEVED [Signature] TIME 1300 DATE 11-12-78
 SHIFT ASSIGNED BY [Signature]

PLANT CONDITIONS:	R/S TEMPERATURE	079	at	W/S CROSS	047	W/S
	R/S FLOW	2165	gals	BY POWER	100	g
	R/S DRYING CONC.	307	DEB	G.R. POS. 1-4	100	g
					5	100 g
PLANT CONDITIONS/SPECIAL REMARKS:	798 MWE NWT				6	100 g
					7	95 g
					8	22 g

OHL

- 1945 completed started Liquid Rol # 125-78L 1A WECST
- 1626 completed SP1302-1.1 NWT Bal sat
- 1744 completed Res Log with SP1302-1.1 @ +0.25 gpm
- 2117 completed Liquid Rol # 125-78L 1A WECST
- 2155 started NWT TK dump

[Signature] DATE 11-12-78
J. James

579	845
2155	100
305	100
	5 100
798 MWE NWT	6 100
	7 96
	8 22

- 2335 1702-1.1 sat
- 0015 Verified 50L headnote
- 0100 300 Gall Black & fuel
- 0405 Complete 1303-1.1 sat.
- 0410 slow pump 112-78-6
- 0415 Complete 1303-1.1 sat
- 0445 SP1303-1.1 complete sat.
- 0550 stopped NWT TK dump

11/12/78

2300 Paul Chalochi Rx Pwr 100% Tave 579°F RC Press 2155
 Rod Index 296 Gp @ 24% Tech Spec Emergency
 Boration Source is 'B' RCBAT @ 15,185 + 10.6' min
 level for this conc is 6.3' Verified SBL headsets
 operable. STARTED AHE-101 Met ED Equipment OAS
 SAME AS 11/11/78 with the following Exceptions:
 ADD #1352 MISC EVAP

23:55 Fed 4 Bled 500 FROM A RCAT TO 'B' RCBT

0120 Completed SP1303-11.25 Rx BLDG Door Check SAT

0300 Completed SP1303-1.1 -4548 GPM

0340 Completed SP1303-5.4 EMERGENCY FEEDWATER Pumps

0350 Completed SP1302 7.1 HEAT BALANCE SAT

0600 STARTED MOP1A & MOP1D

0700 Paul Chalochi

0700 O.B. Maguire Rx 100% Tave 579°F RC Press 2155

Rod Index 294 Gp @ 21%

0745 Secured Neut. TK DUMP

0816 HEAT BALANCE COMPLETE SAT. SP 1302-1.1

0830 VERIFIED SBL HEADSETS OPERABLE

0900 LEAK RATE COMPLETE SAT. SP-1303-1.1 -0.1954 gpm

1415 BLEED FEED 250 gpm TO NU-TK. TO 'B' BLEED TK.

1500 O.B. Maguire

1500 J.C. Hermann Rx Power 100% Tave 579 Pressure

2155 Rod index 295 Gp @ 23%

BACK LOG 1445 - started Lig Rel. #175-78-L

1606 - completed SP1302-1.1 SAT.

1744 - completed SP1303-1.1 sat +.25 GPM.

1750 - verified SBL headsets in place and operable.

1755 terminated Lig Rel. #175-78-L


2155 - started Dumping Neut. tank.

2232 - started pumping BAMB to "B" spent fuel pool

2243 - stopped mo-P-1B and mo-P-1E

2300 J.C. Hermann

11-12-78



Serial Number

irc

F-34
92.65 gal
1.5442 gpm

DATE: 22 1978
TIME: 10:10

QUANTIC COMPANY LEAKAGE TEST
SP 1375-1.1

DESIRED INTERVAL (MINUTES)

1. WATER IDENTIFIED LEAKAGE FROM DC 1707-1.1.2 (CR)

2. WATER REST CHANGE (CAL)

3. WATER REST CHANGE (CAL)

4. WATER REST CHANGE (CAL)

TIME	WATER	WATER	WATER	WATER	WATER	REST LVL	REST LVL	REST LVL	
	(GPM)	(GPM)	(GPM)	(GPM)	(GPM)	(IN)	(IN)	(IN)	
10:10	58	52.128	501.161	506.178	502.099	577.172	559.717	75.155	0.001
17:18	58	52.128	501.161	506.178	502.099	577.172	559.717	75.155	0.001

LEAKAGE FROM IDENTIFIED SOURCE (GPM) 1.5442

WATER REST CHANGE RATE (GPM) 0.001

WATER REST CHANGE RATE (GPM) 0.001

Signature: [Handwritten Signature]
Date: 2/22/78

STOP

NAME (Last, First, Middle)

NO.

DATE: 10/17/78
TIME: 10:00 AM

ACTOR COOLANT LEAKAGE TEST
SP-1303-1.1

DESIRED INTERNAL COOLANT LEVEL

- 1 ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (CPM)
- 2 ENTER ROOT COOLANT LEVEL
- 3 ENTER ICE COOLANT LEVEL
- 7

TIME	TEMP	PH	COND	TRC	TRC	TAMP	PROG LVL	INSTR LVL	ROOT LVL
(H:MM)	(C)	(P)	(C)	(CP)	(CP)	(C)	(117)	(111)	(715)
10:10	50	7.5	100	500	500	570	220	75	3.001
10:15	50	7.5	100	500	500	570	220	74	3.045

LEAKAGE PLUS LEAKED COOLANT: 2.000 CPM

GRD. SE. ICE. WARE ROOT COOLANT: 0.715 CPM

NET UNIDENTIFIED LEAK RATE (ICE COOLANT): 2.600 CPM

INITIATOR: *Liberman*

COMPLETION: *10/17/78*

STOP

0607 Stopped AH-E-101

SHIFT ASSIGNED BY P. Parrella SIGNATURE [Signature] TIME 0700 DATE 2/3/79

SHIFT ASSIGNED BY [Signature] SIGNATURE

PLANT CONDITIONS: HRS TEMPERATURE	57.9	OF	HRS GROSS	840	HRS
H.S. DRY TONS	2133	POST	RE POWER	100	%
H.S. DRY TONS	77	POST	C.R. POS. 1-4	100	%
				5.100	%
PLANT CONDITIONS/SPECIAL REASONS:				6.100	%
				7.95	%
				8.20	%

0715. Verified 52L loadouts
 0725 5P 1302-1.1 loadouts - heat bal
 0745 5P 707-1.1 heat rate

SHIFT ASSIGNED BY [Signature] SIGNATURE TIME 1400 DATE 2/3/79

SHIFT ASSIGNED BY [Signature] SIGNATURE

PLANT CONDITIONS: HRS TEMPERATURE	57.9	OF	HRS GROSS	848	HRS
H.S. DRY TONS	2155	POST	RE POWER	100	%
H.S. DRY TONS	77	POST	C.R. POS. 1-4	100	%
				5.100	%
PLANT CONDITIONS/SPECIAL REASONS:				6.100	%
				7.96	%
				8.20	%

1702 Verified 52L loadouts in place and operable.
 1704 Completed 5P 1302-1.1 heat balance 99.130% hot
 1715 Started transferring contents of A WEST to A WEST
 1716 Completed 5P 707-1.1 heat rate 1.4892 gpm hot

2/3/79

0725 Heat balance sat. SP 1302-1.1

0830 Added 300 gal to MU Tank from 'A' bleed tank

0845 Leak rate, sat SP 1303-1.1

1500 T. Ruppert Jr.

1500 S.W. Brantley PA power 100%, TAM 579°F, KC pressure 2155 psig
ROD INCH 296.7%, GP @ 19%

1552 VERIFIED SBL HEADSETS IN PLACE AND OPERABLE

215/552^B COMPLETED HEAT BALANCE SP 1302-1.1 SAT.

1715 COMMENCED TRANSFERRING 'A' WECST TO 'A' RCBT.


1716 COMPLETED LEAK RATE SP 1303-1.1 +. 4892 GPM

2040 DEBATED 1500 GALLONS THRU WOL-K-1A

2240 SECURED MO-P-1B & MO-P-1E

2300 S.W. Brantley

25-1999 16.25 hr



ATTACHMENT C

COPIES OF RCS LEAK RATE

TEST RAW DATA SUPPORTING

TABLE 7

WATER ADDITIONS

T-8-11
 + 247.1 gal
 4.12 gpm

rc

DATE: 5/12/78
 TIME: 1643: 3

REACTOR COOLANT LEAKAGE TEST
 SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)
 ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.1 (GPM)

ENTER RCS CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	TIA (F)	TCB (F)	TIB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
06:43:19:	559.914	600.148	558.977	599.484	579.625	216.025	71.008	8.519
17:43:19:	560.391	600.688	559.406	599.945	580.102	216.297	77.845	8.240

LEAKAGE PLUS LOSSES (<30 GPM): -3.2582 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.5144 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.7143 GPM

OPERATOR: *R. Brinell*

APPROVED: *[Signature]*

0.8682
 3.6144
 3.3843

SHIFT RELIEVED *W. B. [Signature]* TIME 1500 DATE 6-11-58
 Signature
 SHIFT ASSUMED BY *W. B. [Signature]*
 Signature

PLANT CONDITIONS: R/S TEMPERATURE 579 of R/S GROSS 702 MW
 R/S PRESSURE 2155 psig R/S POWER 90 S
 R/S BORE COND. 819 37500 C.R. POS. 1-4 100 S
 _____ 8 100 S
 PLANT CONDITIONS/SPECIAL REPORT: _____ 6 100 S
 _____ 7 92 S
 _____ 8 22 S

- 1801 *Schen Hydroville H. on Basin.*
- 1904 *Completed SP 1303-1.1 R.S. load rate - 232 gpm*
- 1910 *Shutted off 85-78-6 "WECST"*
- 1920 *Completed SP 1302-1.1 Next Release O.R.*

SHIFT RELIEVED *W. B. [Signature]* TIME 2200 DATE 6/11/58
 Signature
 SHIFT ASSUMED BY *[Signature]*
 Signature

PLANT CONDITIONS: R/S TEMPERATURE 579 of R/S GROSS 752 MW
 R/S PRESSURE 2155 psig R/S POWER 90 S
 R/S BORE COND. 817 37500 C.R. POS. 1-4 100 S
 _____ 8 100 S
 PLANT CONDITIONS/SPECIAL REPORT: _____ 6 100 S
 _____ 7 92 S
 _____ 8 31 S

- 2305 *Rm 8-9 returned to service*
- 2315 *Rm 5 monthly sum 1302-3.1*
- 0005 *SP 1303-1.1.25 shuttled completed*
- 0050 *Completed SP 1302-1.1 but balance cut*
- 0100 *terminated 85-78-6 "WECST"*
- 0210 *Completed SP 1303-1.1 shut rate - 0.37 gpm*
- 0240 *Rm 16 returned to service*

SHIFT RELIEVED PC TIME 0700 DATE 5/12/78
Signature
SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: RCS TEMPERATURE 579 at NYS CROSS 748 NYS
RCS PRESSURE 2155 psig EX POWER 90 S
RCS BORON CONC. 819 ppm C.B. POS. 1-4 100 S
PLANT CONDITIONS/SPECIAL REMARKS: 701 NMB A/T 100 S
794 S
37 S

0826 completed SP1302-111 Sat Heat Island

SHIFT RELIEVED [Signature] TIME 1500 DATE 5-12-78
Signature
SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: RCS TEMPERATURE 574 at NYS CROSS 697 NYS
RCS PRESSURE 2155 psig EX POWER 90 S
RCS BORON CONC. 819 ppm C.B. POS. 1-4 100 S
PLANT CONDITIONS/SPECIAL REMARKS: 100 S
794 S
37 S

- 1700 Completed SP1303-41 R.C.C. and Heat 7943
- 1800 Completed SP1302-41 Heat Island Sat.
- 2040 Completed SP1301-990 Southern.
- 2130 Completed SP1303-414 R.B. Sping Logic Check.
- 2230 Completed SP1301-41 Weekly Check.
- 2241 Completed FSE 1300-30 B R.B. Sping Sp. Logic Sat.

SHIFT RELIEVED [Signature] TIME 2300 DATE 5/10/78
Signature
SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: RCS TEMPERATURE 579 at NYS CROSS 748 NYS
RCS PRESSURE 2155 psig EX POWER 100 S
RCS BORON CONC. 819 ppm C.B. POS. 1-4 100 S
PLANT CONDITIONS/SPECIAL REMARKS: NMB A/T 697 100 S
794 S
37 S

5/12/78

2300 ~~Wondell~~ Rx Power 90% TAUG 579° Pressure 2155 psig
 RCS Boron 819 ppm Rod Index 292 G18 @ 317
 Tech Spec Emergency Boron Source is B' RBAT - CONCENTRATION
 is 12366 ppm. Level 9.8'. Min Level for present
 concentration is 8.5'.

2305 RM-A8 RETURNED TO SERVICE.

2315 RM-A6 005 FOR MONTHLY SURV. 1302-3.1

2330 STARTED AHE-101

0005 COMPLETED 1303-11.25 Rx Bldg Door TEST SAT +2.9 SCF.

0050 COMPLETED SP 1302-1.1 HEAT BALANCE SAT

0100 TERMINATED Rebase 85-78-L 'A' WELST

→ 0210 COMPLETED SP 1303-1.1 LEAK RATE SAT. -0.37 gpm

0540 RM-A6 RETURNED TO SERVICE.

0630 STOPPED AHE101

0700

0700 ~~B. Weisman~~ Rx Pwr. ≈ 90%, Taug. 579, Press. 2155
 Boron 819, Gp. #7 at 94%, Gp. #8 at 33%, MWL 748

0720 Started MO-P-1A

0745 Verified S.B.L.K.T. headsets operable and in place

0825 Completed SP 1302-1.1 SAT.

0845 Filled RCP Standpipes

1500 ~~B. Weisman~~

1:00 Paul Chalecki 90% Rx Pwr as before

* 1:43 ADDED 75 GALS. FROM 'A' RCBT TO MUT-1

1:45 ADDED 70 GALS. FROM 'A' RCBT TO MUT-1

→ 1:50 Completed SP 1303-1.1 -7443 GPM

1705 Completed SP 1302-1.1 HEAT BALANCE SAT

1820 STARTED MOP 1F

1:45 Filled RCP STANDPIPES

2040 Completed SP 1301-9.9D PIPE SUPPORTS HANGERS

2130 Completed SP 1303-4.14 RBS System Logic Chan

2205 STOPPED MOP 1B + MOP 1E

2210 Verified headsets AT MUT 16A6D


2230 Completed SP 1301-4.1 Weekly Checks

2235 Completed SP 1300-3A0 BS Pumps

□ 2240 ADDED 50 GALS FROM 'A' & 'B' RCBT TO MUT-1

2:00 Paul Chalecki

5-12-78 1643 ~ 1743



DATE: 6/11/78
TIME: 8:439

+ 94
277.9 gal
4.63245 gpm

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

ENTER IDENTIFIED LEAKAGE FROM DS1303-1.1.1 (GPM)

ENTER CHANGE (GAL)

ENTER CS CHANGE (GAL)

TIME	TGA (F)	THA (F)	TCB (F)	TRB (F)	TAVE (F)	MAZR LVL (IN)	HATR LVL (IN)	ROOF LVL (VOLT)
0:4:56	559.875	602.414	526.859	501.689	580.703	227.865	75.707	9.036
9:4:56	560.016	602.820	539.109	602.078	581.000	220.733	79.478	9.161

p = 2155 Pa

LEAKAGE PLUS LOSSES (<10 GPM): 1.0102 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.8126 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.5826 GPM

OPERATOR: R. B. Walker

APPROVED: C. D. White

SHIFT RELIEVED L. N. M. TIME 2340 DATE 6-10-78

Signature
SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: RCS TEMPERATURE 579 of HWS CROSS 822 HWS
RCS PRESSURE 2155 psig EX POWER 100 %
RCS BORON CONC. _____ ppm G.R. POS. 1-4 100 %

PLANT CONDITIONS/SPECIAL REMARKS: WAT 776 100 %
95 %
29 %

- 2310 Chgd phones @ MU-U16A, B, C, D
- 2330 Checked L.P.M., no alarms
- 0010 finished 109-78-L
- 0035 Completed SP1302-1.1 heat balance
- 0037 STARTED AH-2-101
- 0240 Completed SP1303-1.1 RC bal rate -0.23 gpm
- 0615 110-78-L started
- 0110 checked L.P.M., no alarms

SHIFT RELIEVED [Signature] TIME 0645 DATE 6/11/78

Signature
SHIFT ASSUMED BY [Signature]
Signature

PLANT CONDITIONS: RCS TEMPERATURE 579 of HWS CROSS 770 HWS
RCS PRESSURE 2155 psig EX POWER 90 %
RCS BORON CONC. _____ ppm G.R. POS. 1-4 100 %

PLANT CONDITIONS/SPECIAL REMARKS: PHYSICS TESTING 100 %
IN PROGRESS, HWS NET 723, LIQUID LEVELS 90 %
110-78L IN PROGRESS 29 %

Water level?

- 0739 COMPLETED PHYSICS TESTING, COMMENCED POWER ESCALATION TO 100% (1550-05)
- 0800 STARTED MO-P-1C BIF, STOPPED MO-P-1A & 1D
- 0828 CHECKED LOOSE PARTS MONITOR - NO ALARMS
- 0910 COMPLETED SP1302-1.1 .52 gpm
- 1005 VERIFIED HEADSETS AT MU-U16A, B, C & D OPERABLE
- 1030 FILLED RCP STANOPIPES
- 1130 LOOSE PARTS MONITOR - NO ALARMS
- 1152 "C" RPS IN CHANNEL BYPASS
- 1157 "C" RPS NORMAL; RECTIFIER DISCONNECTED

JUN 11 1978

6/11/78

2300 J. B. Barber III ≈ 100% PWR, BOROW 708 PPM, 579°F, 2155 PSI, INDEX 295, 6P#8 @ 29%

2300 T.S. EMERGENCY BOROW SOURCE IS "B" RCBT @ 12129 PPM MIN LEVEL REQUIRED IS 8.6'. ACTUAL 9.8'

2310 CHECKED PHONES @ MUV 16 A, B, C, D

2330 CHECKED L.P.M. NO ALARMS

0010 FINISHED 109-78-L

0035 COMPLETED S.P. 1302-1.1 HEAT BALANCE.

0037 STARTED AHE-101

0240 COMPLETED S.P. 1303-1.1 P.C. LEAKRATE - .23 GPM

0615 110-78-L STARTED

0534 STARTED 1550-05

0550 CHECKED L.P.M. NO ALARMS

0628 STOPPED AHE-101

0630 REDUCING TO 95% PWR PER 1550-05

0640 @ 95% PWR

0700 J. B. Barber III

0700 Paul Chalichni ^{95%} BOROW PWR TAKE 579°F AC PRESS 2155 INDEX ²⁹⁰ ~~295~~ @ 28.5%

0704 Commence INC Rx PWR TO 100%

0715 Rx PWR AT 97%

0739 Completed Physics Testing per 1550-05

0755 ADDED 100 GALS FROM 'A' RCBT TO MUT-1

0800 STARTED MOP IC & MOP IF. STOPPED MOP IA & ID

0828 Checked Loose Parts Monitor - NO ALARMS

0829 Oled 300 GALS FROM RCS TO 'B' RCBT

* 0838 ADDED 300 GALS FROM 'A' RCBT TO MUT-1

* 0910 Completed SP 1303-1.1 .5826 GPM

1000 ADDED 100 GALS. FROM 'A' RCBT TO MUT-1

1005 Verified SMALL LOCK HANDSETS AT MUV 16 A, B, C, D

1030 Filled ACP STAND PIPES

1055 ADDED 100 GALS FROM 'B' RCBT TO MUT-1

1125 ADDED 100 GALS FROM 'B' RCBT TO MUT-1

1130 Checked Loose Parts Monitor - NO ALARMS

1152 Went To MANUAL BYPASS ON 'C' RPS

1157 Went To NORMAL ON 'C' RPS


1235 ADDED 10 GALS FROM BAMT TO MUT-1

1325 ADDED 10 GALS FROM BAMT TO MUT-1

1350 ADDED 10 GALS FROM BAMT TO MUT-1

1355 Commence Decreasing Rx PWR E 60% Due To Fuel

06-11-78
0180
D



REACTOR COOLANT LEAKAGE TEST

SP 1303-1.1

11-7 shift
06/21/70

+ 8 1/2

DESIRED INTERVAL (1-8 HOURS)

1
ENTER IDENTIFIED LEAKAGE FROM DS1303-1.1.2 (GPM)

247.1 gal

4.1177 gpm

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MJTK LVL (IN)	RCDT LVL (VOLT)
------	------------	------------	------------	------------	-------------	------------------	------------------	--------------------

3:41:47:	557.742	601.961	556.422	601.156	579.320	222.762	80.362	8.187
----------	---------	---------	---------	---------	---------	---------	--------	-------

4:41:47:	558.219	602.383	556.805	601.477	579.711	224.133	74.853	8.487
----------	---------	---------	---------	---------	---------	---------	--------	-------

LEAKAGE PLUS LOSSES (<30 GPM): 4.1299 GPM

GROSS RCS LEAK RATE (<10 GPM): 1.1721 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.9421 GPM

OPERATOR: *JH [Signature]*

APPROVED: *[Signature]*

00098

SHIFT RELIEVED C. Y. Hui TIME 2245 DATE 6/20/78
Signature

SHIFT ASSIGNED BY L. A. Nakh
Signature

PLANT CONDITIONS: RCS TEMPERATURE 579 OF RCS GROUP 817 NTS
RCS PRESSURE 2155 PRESS EX POWER 100 S
RCS BORON CONC. 691 PRESS C.R. POS. 1-4 100 S

PLANT CONDITIONS/SPECIAL REMARKS: MUR NET 771 8:10 S
6:10 S
7:94 S
8:28 S

- 2329 verified headsets operable AT MV-U-166A, 50
- 0008 Received B-1-4 alarm D1 seal leak. RT low. RCP-1C
- 0015 point 0 2-7 decreased TO 0 Gpm on RCP-1C
- 0016 seal #1 outlet dp low alarm 1st seal out.
- 0018 Seal #1 Temp 150°, no vibration.
- 0030 verified readings on #1 seal leak off 10 R.O. as being 0.6 gpm at 11:25
- 0355 completed sp 1303-11:25 SAT - as usual
- 0455 completed sp 1303-11:19 A.D. SAT.
- 0510 completed sp 1303-11:1 SAT.
- 0606 completed sp 1303-11 7:94 Gpm ←

SHIFT RELIEVED L. A. Nakh TIME 0645 DATE 6-21-78
Signature

SHIFT ASSIGNED BY D. S. Tolsty
Signature

PLANT CO. DI. RCS TEMPERATURE 579 OF RCS GROUP 824 NTS
RCS PRESSURE 2155 PRESS EX POWER 100 S
RCS BORON CONC. 694 PRESS C.R. POS. 1-4 100 S

PLANT CONDITIONS/SPECIAL REMARKS: MWE NET 777 8:10 S
6:10 S
7:93 S
8:27 S

- 0750 Completed SP 1302-11 last before 77.606 is sat.
- 0755 Started 1303-41 RPS Monthly
- 0805 Closed D RPS Check in manual bypass
- 0826 Disabled #51. to take vibration readings
- 0845 Closed D RPS in SID bypass
- 0846 Check all lower parts complete. No alarm
- 0905 Verified headsets @ MV-U-166A, B, C, D.
- 0950 Started HH-E-01
- 1020 Started Work Flow tank release 69-78-B.
- 1021 Completed SP 1303-11 RCS last note -0.6308 gpm

2-1-78

SHIFT BELIEVED McDermott DATE 2-1-78
 SIGNATURE _____
 SHIFT ASSIGNED BY McDermott
 SIGNATURE _____

PLANT CONDITIONS: RCS TEMPERATURE 577 at HEM CORE 542 DEG
 RCS PRESSURE 2.55 psig RE POWER 62.85 MW
 RCS BORON CONC. 496 ppm G.E. POS. 1-4 / 100 S
 _____ 8.100 S
 PLANT CONDITIONS/SPECIAL REMARKS: NO REACT 497 8.100 S
 _____ 7.92 S
 _____ 8.32 S

- 2300 secured FW-p-1A
- 2320 stopped 20-p-1B, Co-p-2B, switched 20A heaters
- 2325 stopped 40-p-1A and Co-p-1C
- 2350 Rx power at 0%
- 0012 10 Taps - Boron 760 ppm, Temp 537, 2155 psig, Temp PAT 309, 1-7 100%
- 0017 started RCS circulation
- 0029 stopped RC-p-1C
- 0050 RCS boron 786 ppm
- 0120 RCS boron 844 ppm checked Lpm
- 0145 Rps sat points to 95%
- 0148 "D" Rps in manual bypass
- 0155 "D" Rps out of bypass
- 0156 "C" Rps in manual bypass
- 0205 "C" Rps to normal
- 0206 "B" Rps to manual bypass
- 0207 "B" Rps to normal
- 0209 "A" Rps to manual bypass
- 0210 RCS boron is 923 ppm
- 0215 "A" Rps to normal - Rps sp to 95%
- 0220 RCS boron is 975 ppm
- 0250 RCS boron is 1069 ppm
- 0350 RCS boron is 1234 ppm
- 0420 RCS boron is 1300, commenced cooldown
- 0434 stopped RC-p-1B
- 0450 RCS pressure 175, in safety safeties, stopped Rx
- 0457 RCS boron 1410 ppm
- 0502 Rps sat points - Hi @ sat at 5%
- 0503 Rps A, B, C, D in shut down bypass, cooling safeties
- 0520 RCS boron is 1575 ppm
- 0540 stopped FW-p-1B, bypassed H.P. injection
- 0550 RCS boron is 1557 ppm, safeties locked

2445?

CRO LOG

- 6-21-78 RE Boyer Rx Pwr 100% Rod Index 294 GIP Re 25
 2300 Boron 69! Tave 579 Rcpres 2155 mwe/mwe 809/2500
 EFPD 15.07 Tech Spec Emerg Boration Source "B" RBA
 C 9.8' 12,214 ppmb min level 8.0'
- 2329 SBL Handsets verified
 0015 Point #3 a #7 decrease #1 seal leakoff
 0016 Seal & P low Alarm in rout
 0020 I & C confirmed point #3 a #2 seal
 0030 Larry Knoll & Stupak in R bldg
 0035 local indication no flow indicated Rc stand pipe Normal
 RC drain tank increasing faster normal - No Vibration
- 0018 Seal #1 Temp OK 152° 15 min later 148°
 0030 Added 255 to MUT1 from "A" RCBT, 165 from "C" RCBT
 0200 Added 165 to MUT1 from "C" RCBT, 135 from "A" RCBT
 * 0200 commenced surveillance on "C" RC pump every 30 min
 vibration & Lab & P every 10 min RCBT level,
 MUT1 level, seal out Temp, water to bearing Temp.
- 0325 Added 150 to MUT1 from "C" RCBT, 150 from "A" RCBT
 0355 1303 11.25 Personnel door sat .4 scfm
 0430 MUKIA IN service? MUKIB OOS?
- * 0452 Added 150 to MUT1 from "C" RCBT, 150 from "A" RCBT
 0455 1303 - 11.19 A/O Turb overspeed testing complete SAT
 0510 1303 - 5.5 complete control Bldg Vent
- late 0008 Received E-14 RC #1 seal leakoff low point #7
 0605 started AOP18 & IE
- 0606 SP 1303-1.1 SAT 94
 0630 MUKIB IN service MUKIA OOS
 0659 1302-1.1 SAT 99.37120
 0700 RE Boyer
- 0700 J. M. ... Rx Power @ 100%, TAVE 57
 RC Pwr 2155 PSIG, MWE/MWT 2519.817
 0730 Added 305 GAL TO MU-TNK FROM "A" RCBT
 0750 Added 195 GAL FROM "B" RCBT.
 0850 HEAT BALANCE 10MAGTE SAT SP 1302-1.1
- 0755 STARTING 1303-4.1 RPS MONITOR
 0805 Placed "D" RPS IN MANUAL BYPASS
 0836 TSI IS DISABLED.
 0845 Placed "D" RPS IN SHUTDOWN BYPASS.
 0846 Loose Parts Monitor checked NO ALARMS
- 0900 Added WATER TO MU-TNK 217 gal "A" RCBT 189
 FROM "B" RCBT.


630 (255M)

0200 (157M)

025 (157M)

6-21-80
0440
0710
0110

0110
0110
0110



STOP 0

PG

DATE: 8/31/78

TIME: 8:1:41

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

ENTER IDENTIFIED LEAKAGE FROM DS1303-1.1.2 (GPM)

0

ENTER RC DT CHANGE (GAL)

0

ENTER RCS CHANGE (GAL)

0

TIME	TCA (F)	THA (F)	TCA (F)	THE (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCGT LVL (VOLT)
8:1:58:	557.859	601.656	556.063	600.695	579.063	229.373	75.994	9.290
9:1:58:	557.992	601.656	556.078	600.672	579.094	228.066	77.212	9.183

LEAKAGE PLUS LOSSES (<30 GPM): -0.3501 GPM

GROSS RCS LEAK RATE (<10 GPM): -0.1841 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.4141 GPM

OPERATOR:

APPROVED:

STOP 0

- 0735 Started ES duty SP 1302-4N ES duty
- 0736 Verified head set operable @ 1000 AM
- 0737 Completed SP 1302-4N head set before 99.2119 set
- 0906 Completed SP 1302-1.1 RCS head set - .414 gpm set
- 0935 Started RB pump 97-78-G
- 1102 ES-P-2 Ave start due to flooding of fire system head in Unit 2
- 1115 Completed SP 1302-4N ES duty set

SHIFT RELIEVED [Signature] TIME 1500 DATE 8/31/78
 SHIFT ASSIGNED BY [Signature]
 Signature

PLANT CONDITIONS:	RCS TEMPERATURE	522	at	HEG CROSS	806	W/G	
	R. PRESSURE	2155	psig	HE POWER	100	%	
	RCS LEAK CONC.	529	ppm	C.E. POS. 1-4	100	%	
					5	100 %	
PLANT CONDITIONS/SPECIAL REMARKS:	766 MW PWR					6	100 %
						7	96 %
						8	25 %

- 1605 completed SP 1302-1.1 H-T set
- 1930 Removed Tags from SR-P-1A, MR-P-1B, RR-P-1A, DR-P-1B, & SE-P-3
- 1720 completed SP 1302-1.1 RCS head set @ 0.8 gpm
- 2150 completed SP 1302-1.25 on RB Emergency door set. T 1.820519

SHIFT RELIEVED [Signature] TIME 2300 DATE 8-31-78
 Signature
 SHIFT ASSIGNED BY [Signature]
 Signature

PLANT CONDITIONS:	RCS TEMPERATURE	522	at	HEG CROSS	812	W/G	
	R. PRESSURE	2155	psig	HE POWER	100	%	
	RCS LEAK CONC.	529	ppm	C.E. POS. 1-4	100	%	
					5	100 %	
PLANT CONDITIONS/SPECIAL REMARKS:	PWR 771					6	100 %
						7	96 %
						8	26 %

- 2354 completed sp 1302-1.1 SAT
- 0035 verified head set operable at 884.2707 W/G
- 0123 completed sp 1302-1.1.25 set
- 0633 completed sp 1302-1.1 - .1325 gpm

3/31/78

2300 JH Goodberry Rx. Power 100% G₂₇@15 G₂₅ B₂₅ B₂₇
MWE/MWT 819/2521 106.36 ETPD

2300 YMU-KIA IN Service - YMU-KIB out
Take Sft. Emag. Radiation Same as B Rel. PA
Startup TR @ 10.7' 15481 PPMB MIN. Emag. Lvl 6'5"

2336 1302-1.1 SAT 99.506%

2337 Verified SBL Headsets

2338 Starvo AH-E-101

2342 1303-11a25 Control - SAT Personnel Station .95cfm

0024 Test - FP Stop VU. For 105-1

0100 YMU-K IB IN Service - YMU-KIA OUT

0200 Starvo HD-PIA - STOPPED HD-PIB

0322 1300-3N Control - SAT

0525 Verified operability of DR-PIA & RR-PIB

0530 RR-PIA & DR-PIB OOS 72 Hr. Clock

0552 1303-1.1 Cont. - SAT - .05 GPM

0600 Starvo MO-PI B & E

0601 Starvo AH-E-101

0610 FS-P3 OOS

0625 Starvo AH-E-101

0700 JH Goodberry

0700 JH Goodberry Rx Power 100%, Temp 579°F
RC Press 2155 psig MWE/MWT 806/2516
Reo Index 295% G₂₈@25%

Chg Log Reviews of Unit

0735 Starvo ES Testing SP 1303-4.11 ES Unit

0736 Verified SBL Headsets Operable.

0757 Heat Balance Complete SAT SP 1302-1.1

0906 LEAK RATE COMPLETE SAT SP 1303-1.1 - .414 gpm

0935 Started R.B. Purge 97-78-G

1102 FS-P2 Also started due to flushing
of fire sys. lines in Unit II.

1115 ES Testing Completed SP 1303-4.11 SAT

1500 JH Goodberry


1500 JH Goodberry Rx Power 100% M Power, 805 MWE
2150 psig reactor, 579°F Temp, G₂₇@95% G₂₈@25%

1535 - verified SBLOCA Head set in place & operable.

1630 - completed SP 1302-1.1 rat.

1936 Removed Reo. Log #1061 from SR-PIA,
NR-PIA, RR-PIA, DR-PIA & FS-P-3

8-31-78



No 2

Hr

+2"

rc

DATE: 11/ 7/78
TIME: 16: 8: 7

REACTOR COOLANT LEAKAGE TEST
SP 1505-1.1

DESIRED INTERVAL (1-8 HOURS)

1

ENTER IDENTIFIED LEAKAGE FROM DS 1505-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MJTK LVL (IN)	RCDT LVL (VOLT)
16: 8:27:	557.828	601.641	555.977	600.711	579.031	228.275	76.311	8.935
17: 8:27:	558.031	601.883	556.266	600.906	579.266	230.172	75.928	8.915

LEAKAGE PLUS LOSSES (<30 GPM): 0.0784 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.2745 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): 0.0445 GPM

OPERATOR: *Paul Chalicki*

APPROVED: *D James*

STOP 0

025

1

SHIFT BELIEVED Blower TIME 1500 DATE 11-7-78
 SIGNATURE
 SHIFT ASSIGNED BY B. James
 SIGNATURE

SHIFT CONDITIONS: E'S TEMPERATURE 579 WIND SPEED 633 MPH
 E'S PRESSURE 2155 WIND DIR 180 S
 E'S MOIST CONT. 331 WIND C.S. POS. 1-100 S
 E 100 S
 SHIFT CONDITIONS/SPECIAL RE: 735 E 100 S
 E 95 S
 E 72 S

- 1515 Stop next TC dump.
- 1615 Verified SBL headsets operable
- 1635 Complete SP-1302-1.1 Sat
- 1725 Complete SP-1302-1.1 Sat
- 2200 Stopped MO-P-IC & MO-P-IF

SHIFT BELIEVED B. James TIME 2300 DATE 11-7-78
 SIGNATURE
 SHIFT ASSIGNED BY B. James
 SIGNATURE

SHIFT CONDITIONS: E'S TEMPERATURE 579 WIND SPEED 857 MPH
 E'S PRESSURE 2155 WIND DIR 100 S
 E'S MOIST CONT. 326 WIND C.S. POS. 1-100 S
 E 100 S
 SHIFT CONDITIONS/SPECIAL RE: MWE not 792 E 100 S
 E 95 S
 E 20 S

- 2307 MUXIA in Service MUXIA 005
- 2308 Verified SBL headsets
- 2330 completed SP-1303-1.1 Next Bal (Sat)
- 0107 MUXIA in Service MUXIA 005
- 0412 completed SP-1303-1.1 Leak Rate - 267.7 gpm
- 001X completed SP-1303-11.25 on RB Run down (Sat)
- 0555 Stopped AH-E-101
- 0612 started MO-P-IC & MO-P-IE

11-7-78

2300 R E Boyer Rspwr 100%, Tave 579°, Rc press 2155
 Red index 295, Gp 8 @ 21% mwt/mwe 2529/841
 Tech speech emergency boration "B" RBAT @ 0.8' 15, 117 p/m
 min level required 6.6'
 MET-ED equipment OOS same as 11-6-78 with the
 following exceptions: Add #1328 Halon, 1329, 1332-CAF-12

2301 MUFIA in Service MUKIB OOS

2309 AHE101 started

2315 SBL Headsets verified

0124 1302-1.1 SAT 99.319%

0200 MUKIB in service MUFIA OOS

0230 1303-1.125 complete 1.7 scfm

0404 1303-1.1 SAT .4408 GPM

0420 1300-3W complete

0430 started Ncut Tank dump

0523 RR-PIB, DR-PIA verified operable

DR-PIB, RR-PIA, NR-PIA, SR-PIA Tysed OOS

0600 started MOPIB & MOPIE

0617 AHE101 off

CRO Log Review by *[Signature]*

0700 R E Boyer

0700 John Conrad Banks III, ~100% POWER, INDEX 296,
 Gp # 8 @ 21.5%, Bor. 326 PPM, 579°F Tave, 2155 PSI

0710 SBL PHONES CHECKED

0930 SPI302-1.1 COMPLETE

1200 STARTED CONDENSATE RETURN

1500 John C. Banks III

1500 *[Signature]* Power 100% Tave 579°F Press 2155 PSI
 Red Index 297 Gp 8 @ 22%

1515 Stopped Neutralizing Tank Dump

1530 completed 700 gal Fuel & Bleed

1615 Verified SBL HEADSETS

1625 completed SPI302-1.1 Heat Balance SAT.


1725 completed SPI303-1.1 Leak Rate SAT. 0.0445 gpm

2045 Verified operable RR-PIB, DR-PIB, NR-PIA

2200 Stopped MO-PIB & MO-PIF

2300 *[Signature]*

11-7-78



STOP 0

rc

DATE: 12/13/78
TIME: 18:40:18

+10"
308.83 gal
5.1472 gpm

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRE INTERVAL (1-8 HOURS)

ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)

ENTER RCDT CHANGE (GAL)

ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCDT LVL (VOLT)
18:42:18	557.867	601.602	556.258	600.617	579.078	221.920	72.086	9.428
19:42:18	557.727	601.453	556.063	600.500	578.930	221.324	80.361	8.833

LEAKAGE PLUS LOSSES (<30 GPM): -5.8482 GPM

GROSS RCS LEAK RATE (<10 GPM): 0.0130 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.2170 GPM

OPERATOR: *Robye*

APPROVED: *Thornell*

STOP 0

NO. RM-A-2 005
 1755 RM-A-2 back in service
 1456 SP1303-1.1 - 0.0084 gpm

SHIFT RELIEVED [Signature] TIME 1500 DATE 12-15-78
 SIGNATURE
 SHIFT ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS:	WATER TEMPERATURE	579	of	WATER GROSS	938	WTR
	R.S. PRESSURE	2155	psig	EX. POWER	100	%
	R.S. DRAIN CONC.	218	ppm	C.R. POS. 1-4	100	%
PLANT CONDITIONS/SPECIAL REMARKS:	MWE	not		790		
						1.00 %
						1.00 %
						1.94 %
						1.17 %

1505 Verified SBL Headsets
 1530 started SOP-78-95 Control Bldg Vent. Testing
 1555 delivered 500 gal thru WOL-K-15
 1700 completed SOP-78-95 Control Bldg Vent. Testing
 1845 completed SA-1302-1.1 Next Ball (out)
 1850 fed 200 gal from "A" RCAT
 1950 Vent Tank dump terminated
 2005 completed SP-1302-1.1 Leak Rate - 0.217 gpm
 2202 stopped VVIC-P-1B+1E

SHIFT RELIEVED [Signature] TIME 2330 DATE 12-15-78
 SIGNATURE
 SHIFT ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS:	WATER TEMPERATURE	579	of	WATER GROSS	940	WTR
	R.S. PRESSURE	2155	psig	EX. POWER	100	%
	R.S. DRAIN CONC.	217	ppm	C.R. POS. 1-4	100	%
PLANT CONDITIONS/SPECIAL REMARKS:	MWE	not		712		
						1.00 %
						1.00 %
						1.94 %
						1.21 %

12/13/78

1457 COMPLETED SP 1303-1.1 SAT .0084 GPM

1500 ~~Rob Brantley~~

1500 ~~D. Woodall~~ ~~R. Howard~~ TAKE 579 F RCP Press 2155 PSI
Rod Index 296 GP 8 @ 22%

1505 VERIFIED SBL HEADSATS

1520 STARTED SOP 78-45 CONTROL Bldg VENT. TESTING

1555 COMPLETED 500 gal DEBURATION THRU WDL-K 1.3

1700 COMPLETED SOP 78-45 CONTROL Bldg VENT. TESTING

1845 COMPLETED SP 1302 1.1 HEAT BALANCE SAT.

1850 ~~D. Woodall~~

1850 RE BYE Same as before

1858 Added 200 gals TO MUTI FROM "A" RCBT

1950 NEUT Tank Dump terminated



2005 1303-1.1 SAT -.2170 GPM

2202 MOPIB + MOPIE STOPPED

2300 RE BYE

Chg Log Reviewed ~~by~~

12-17-48
CRC by
(1858 km)
1/9/54



Actual NOT level
and food.

NO Ca

DATE

TIME

DATE: 1/17/70
TIME: 7:58:56

REACTOR COOLANT LEAKAGE TEST
SP 1303-L.1

15.5" + 13"
478.6805
401.48 gal
~~6.6913 gpm~~
1.6728

TESTED INTERVAL (1-6 HOURS)

ENTER IDENTIFIED LEAKAGE FROM DS 1303-L.1.2 (GPM)

ENTER INLET CHANGE (GAL)

ENTER OUT CHANGE (GAL)
000.0

TIME	TCA (F)	TIA (F)	TCA (F)	TIA (F)	TAVE (F)	PRG LVL (IN)	ALTR LVL (IN)	OUT LVL (GAL)
7:58:56	257.650	222.706	256.313	222.022	259.188	222.406	63.312	0.236
8:00:00	256.750	222.236	257.164	222.021	272.150	221.536	77.061	0.372

LEAKAGE PLUS UNID (GPM): -0.1770 GPM

GROSS NET LEAK RATE (<10 GPM): -0.3048 GPM

NET UNIDENTIFIED LEAK RATE (<1 GPM): -0.3048 GPM

OPERATOR: Woodell

APPROVER: J. Garcia

REMARKS

SHEET NO. 100 TITLE 0700 DATE 1-6-73
 SHEET ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS:	229	of	100	TONS	100
	2155				100
	155				100
PLANT CONDITIONS/STANDARD:					100
					97
					21

- 710 SBL Headlatch operable
- 800 1302-61 gate
- 997 decreased power to 95%
- 1700 9/1203-1.1 - 12:00 PM
- 1312 S narrow power to 100% 9/1203-163 complete

SHEET NO. 100 TITLE 1670 DATE 1-6-73
 SHEET ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS:	579				100
	2155				100
	155				100
PLANT CONDITIONS/STANDARD:					100
					7.90
					0.15

- 1510 Verified SBL Headlatch
- 1610 Started power Plant Pump
- 1605 Completed 9/1203-61 gate
- 1720 SBL Headlatch 9/1203-1.1 12:00 PM DATE 1/6/73
- 1916 SBL Headlatch 9/1203-1.1 12:00 PM DATE 1/6/73

SHEET ASSIGNED BY [Signature]
 SIGNATURE

PLANT CONDITIONS:	579				100
	2155				100
	152				100
PLANT CONDITIONS/STANDARD:					100
					9.95
					0.20

SHIFT NO. 1 Crow TIME 0700 DATE 1-6-75
 SHIFT ASSIGNED BY H. Jones

579	100
2155	100
185	100
100	100
100	100
100	100
92	100
21	100

- 710 SBC Headlets operable
- 800 1302-41 sat.
- 947 decreased power to 95%
- 1200 9/1303-1.1 - 1304GPM
- 1312 Increased power to 100% 9/1303-1.13 complete

SHIFT NO. 1 H. Jones TIME 0700 DATE 1-6-75
 SHIFT ASSIGNED BY H. Jones

579	100
2155	100
155	100
100	100
100	100
100	100
90	100
15	100

- 1510 Verified SBC Headlets
- 1610 Started next tank pump
- 1645 Completed 1302-41 sat.
- 1720 1303-1.1 1304GPM 2300 DATE 1/6/75
- 1810 1303-1.1 1304GPM 2300 DATE 1/6/75

519	100
2155	100
152	100
100	100
100	100
100	100
90	100
20	100


- WHY WAREN'T THIS INITIALED
- 1/6/78 79 ~~3006~~ [REDACTED]
- 2300 Job L. Bank II, 100% PWR, 579°F, 2155 PSI, Brass 133 FT
INDEX 297, 6PM @ 21%
- 2300 T.S. EMERG BORON Sample in B RBT @ 15261 PPM
MIN LEVEL REQUIRED IS 6.5', ACTUAL IS 10.6 FT.
- 2308 SBL PHONES CHECKED
- 2323 SP1302-1.1 COMPLETE
- 0100 STARTED AHE 101
- 0100 STOPPED MOD 1A + D
- 0105 SP1303-1.2.5
- 0400 [REDACTED] STARTED 1302-3.1
- 0133 SP1303-1.1 COMPLETE - 0.1 GPM
- 0541 RMA-1 IN DEPART AREA 1302-3.1
- 0550 PERFORMED 1300-6 B EPA-1 TEST A O.K.
- 0605 STARTED MOD 1A + D
- 0635 STARTED AHE 101
- 0700 Job Bank
- 0700 J. Chalich 100% Rx PWR 579°F RC Press 2155 And Index 297
Gp @ 21%
- 0710 Verified SBL Headsets OPERABLE
- 0800 Completed SP1302-1.1 HEAT EXHAUST
- 0915 ADDED 300 GALS. T₀ MUT-1
- 0947 Decreased Rx PWR To 95%
- 0950 Commence SP1303-1.1.3 MAIN Steam Safety Valve Surv.
- 1200 Completed SP1303-1.1 - 5948 GPM
- 1215 Fed & Bled 1500 GALS Thru WDI, KIA
- 1312 INC Rx PWR To 100% Completed SP1303-1.1.3
- 1500 Paul Chalich
- 1500 TX P. Kendig 100% PWR; TAWE 579° RC Press. 2155"
And Index 93 TA @ 18 Thwe 849 Thwe 2503
- 1510 VERIFIED SBL HEADSETS.
- 1610 STARTED NEUT. TK DUMP.
- 1715 SP-1302-1.1 COMP. SAT.
- 1720 SP-1303-1.1 COMP. SAT. - 0.49
- 1915 AUX F.F.H BLDG DOORS EXERCISED
- 2300 TX P. Kendig

1-6-79

6156

Res CRT

1156



ATTACHMENT D

COMPUTER PROGRAM LISTING

OF

RCS LEAK RATE CALCULATION

C*****TATS*IS*THE*REACTOR*COOLANT*LEAKAGE*PROGRAM*****

C**** AUTHOR: ROBERT S. SHENG *****
C**** METROPOLITAN EDISON CO. *****

C**** THREE MILE ISLAND UNIT 1 *****
C*****

REAL INP(6,3), IAVG(6,2), ISUM
DIMENSION RCDL(2)
COMMON//DNI, DNF, RCSV, TRCS, TAVAG, IAVG
COMMON//TAVE(2)
COMMON//ITIME(2), OGAL, OPAL, XIDLK, GAL
COMMON//BOB1/CLOCKI, ITEMP, NTIME, ISAVE, IFLG
COMMON//BOB/CLOCK, ITMP, INP
COMMON//BOB2/INDIC, RCDT(3)

S EXTRN INPUT, OCTBCD
S EXTRN CONV, BCDOUT
S EXTRN SUB1
INDIC=1

S SXJ 3, INPUT
CALL OVERLY(RCDL, CFACT, INDIC, NTIME)

INDIC=0
IFLG=0

K=0
14 INPUTC=1

IRICK=0
ITMP=0

SAV=0
S LDA 043624

S STA CLOCKI
S LDX 2, K

S STA ITIME, 2
SL\$16 SXJ 3, INPUT

S LDX 1, IRICK
S LDA 011742
S SXJ 3, CONV

S FSH21 RCDT, 1
IRICK=IRICK+1
INPUTC=INPUTC+1
IF (INPUTC.GT.3) GO TO 99

S LDA 043624
S CAM CLOCK

S JL \$-2
S J L\$16

99 K=K+1
IF (K.GE.2) GO TO 111

S SXJ 3, SUB1
111 DO 100 I=1,6
100 IAVG(I,K)=(INP(I,1)+INP(I,2)+INP(I,3))/3000.0
RCDL(K)=(RCDT(1)+RCDT(2)+RCDT(3))/30000.0
ISUM=0.0
DO 300 I=1,4
300 ISUM=ISUM+IAVG(I,K)
TAVE(K)=ISUM/4.0
IF (K.GE.2) GO TO 199

```

S LDA IFLG
S CAM = 0
S JE $+7
S LDA 043624
S RSA 16
S SXJ 3 OCTBCD
S CAM TSAVE
S JE $+2
S J $-5
S LDA 043624
S CAM CLOCK
S JL $-2
S J LS14
199 CALL OVERLY(RCDL,CFACT,INDIC,NTIME)
C TOTAL LEAKAGE PLUS LOSSES.
C LEAK RATE
  TGAL=GAL+OGAL
  TIME=NTIME*60
  RLEAK=TGAL/TIME
  TYPE 406,RLEAK
406 FORMAT(////,31H LEAKAGE PLUS LOSSES (<30 GPM):,9X,F10.4,4H GPM)
C GROSS LEAK RATE
  CMRCDT=(RCDL(1)-RCDL(2))*3540.0
  GCRCDT=CFACT*CMRCDT
C GROSS RCS LEAKAGE.
  GRCSL=TGAL+GCRCDT+OPGAL
C GROSS RCS LEAK RATE
  GRCSLR=GRCSL/TIME
  TYPE 409,GRCSLR
409 FORMAT(//,31H GROSS RCS LEAK RATE (<10 GPM):,9X,F10.4,4H GPM)
C CORRECTIONS--IDENTIFIED LEAKAGE.
  XIDLK=-XIDLK
  TIDLK=-XIDLK-.23
  TLKR=GRCSLR+TIDLK
  TYPE 411,TLKR
411 FORMAT(//,37H NET UNIDENTIFIED LEAK RATE (<1 GPM):,3X,
1F10.4,4H GPM,//,9H OPERATOR:,//,9H APPROVED://////////)
STOP
END

```

IEOF

*evaporative leakage
unknown seal pump number?*

CORRECT = 1.37

SUBROUTINE INPLT
REAL INP(6,3)
DIMENSION IDAY(3),ITIN(3)
COMMON/BOB/CLOCK,ITMP,INP
COMMON/BOB2/INDIC,RCDT(3)

S EXTRN CONV
S LDA INDIC
S CAM =1
S JE L\$10
S LDA 043624
S SKL 11
S J \$+16
S SKL 8
S J \$+14
S STA CLOCK
S AND =0177400
S CAM =054400
S LDA CLOCK
S RLU 11
S RLU 8
S JL \$+5
S RLU 12
S RLU 14
S ADDB =0200000
S J \$+4
S ADDB =010000
S J \$+2
S ADDB =0400
S STA CLOCK
S LDX 1,ITMP
S LDA 011235
S SXJ 3,CONV
S F\$H21 INP,1
S ICX 1,19
S LDA 011233
S SXJ 3,CONV
S F\$H21 INP,1
S ICX 1,19
S LDA 011240
S SXJ 3,CONV
S F\$H21 INP,1
S ICX 1,19
S LDA 011234
S SXJ 3,CONV
S F\$H21 INP,1
S ICX 1,19
S LDA 076022
S SXJ 3,CONV
S F\$H21 INP,1
S ICX 1,19
S LDA C.1221
S SXJ 3,CONV
S F\$H21 INP,1
S ICX 1,19

```
S STX 1,ITMP
RETURN
SL$10 CLA
S LDB 043625
S LSC 8
S SXJ 3,CONV
S STA IDAY
S CLA
S LSC 8
S SXJ 3,CONV
S STA IDAY+1
S CLA
S LSC 8
S SXJ 3,CONV
S STA IDAY+2
40 TYPE 50,(IDAY(1),1=1,3)
50 FORMAT(//,6H DATE:,2X,2(12,1H/),12)
S CLA
S LDB 043624
S LSC 8
S SXJ 3,CONV
S STA ITIM
S CLA
S LSC 8
S SXJ 3,CONV
S STA ITIM+1
S CLA
S LSC 8
S SXJ 3,CONV
S STA ITIM+2
60 TYPE 70,(ITIM(1),1=1,3)
70 FORMAT(6H TIME:,2X,2(12,1H:),12)
RETURN
END
!EOF
```

ENTRY SUB1
EXTRN OCTBCD, CONV

SUB1 STX 3, RETURN
LDA CLOCKI

AND =0177777
STA ITEMP

LDA CLOCKI
RSA 16

SXJ 3, CONV
ADDB INTIME

CAM =027
JG \$+2

J \$+6
SUBB =030

STA ISAVE
LDA ONE

STA IFLG
LDA ISAVE

SXJ 3, OCTBCD
STA ISAVE

LSA 16
OR ITEMP

STA CLOCK
J RETURN

ONE DATA 1
RETURN RES 1

BOB\$ COM 5
CLOCKI CEQ 0

ITEMP CEQ 1
NTIME CEQ 2

ISAVE CEQ 3
IFLG CEQ 4

BOB\$ COM 20
CLOCK CEQ 0

ITEMP CEQ 1
INP CEQ 2

END
!EOF

OCTBCD ENTRY OCTBCD
CARRY = 10

IL 0,3
CLB 0,3

RSC 24
DVCB = 10

STB RESS
LSA 4

QR RESS
J 0,3

RESS RES 1
END

!EOF

ENTRY BCDOCT

CONV ENTRY CONV
NOP

BCDOCT STX 1, BDI
STD REX

JAN NEG
STA TEMP
CLAB
STA FLG
J \$+6
NEG AP

STA TEMP
LDA COD
STA FLG
CLA
STA INT
SX 1,0

LOOP CLA
LDB TEMP
LSC 4
STB TEMP
ADDB INT
MUPB =10
STB INT
ICX 1,5
JL LOOP

CLA
LDB TEMP
LSC 4
ADDB INT
STA INT
LDX 1, BDI
LDB REX
LDA FLG
CAM COD
LDA INT
JE \$+2
J \$+2

AN

J 0,3

BDI RES 1

TEMP RES 1

INT RES 1

FLG RES 1

REX RES 1

COD DATA 07777777

END

IEOF

!

```
SUBROUTINE INTER(XIN,OUT,N,A,B)
DIMENSION A(N),B(N)
6  IF (XIN-A(1)) 5,5,6
   IF (XIN-A(N)) 1,2,2
2  OUT=B(N)
   RETURN
5  OUT=B(1)
   RETURN
1  DO 3 I=2,N
   IF (XIN.LT.A(I)) GO TO 4
3  CONTINUE
4  OUT=B(I-1)+(XIN-A(I-1))*(B(I)-B(I-1))/(A(I)-A(I-1))
   RETURN
END
!EOF
!
```

density interpolator


```

SUBROUTINE OVERLY(RCDL,CFAC,INDIC,NTIME)
DIMENSION T1(8),DN(8),T2(6),CF(6)
DIMENSION RCDL(2)
DIMENSION IHR(2),IMIN(2),ISEC(2)
REAL IAVG(6,2)
COMMON//DN!,DNF,RCSV,TRCS,TAVAG,IAVG
COMMON//IAVE(2)
COMMON//ITIME(2),OGAL,OPGAL,XIDLK,GAL
DATA T1(1),T1(2),T1(3),T1(4),T1(5),T1(6),T1(7),T1(8)/516.,
1545.,558.,575.,576.,578.6,580.8,582./
DATA DN(1),DN(2),DN(3),DN(4),DN(5),DN(6),DN(7),DN(8)/
148.85,47.15,46.25,45.1,44.93,44.8,44.66,44.56/
DATA T2(1),T2(2),T2(3),T2(4),T2(5),T2(6)/520.,548.,
1562.5,577.25,580.4,583./
DATA CF(1),CF(2),CF(3),CF(4),CF(5),CF(6)/.154,.1592,
1.1628,.16652,.1674,.16816/

```

T'F steam table density

conversion factor

```

EXTRN CONV
IF (INDIC.NE.1) GO TO 10
T = .00
400 FORMAT(////,22X,28HRE/CTOR COOLANT LEAKAGE TEST)
TYPE 401
401 FORMAT(27X,11HSP 1303-1.1,////)
TYPE 100
100 FORMAT(28HDESIRED INTERVAL (1-8 HOURS))
ACCEPT 11,NTIME
11 FORMAT(11)
RETURN
10 TYPE 404
404 FORMAT(50H ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM))
ACCEPT 405,XIDLK
405 FORMAT(F10.4)
TYPE 406
406 FORMAT(24H ENTER RCDT CHANGE (GAL))
ACCEPT 405,OPGAL
TYPE 407
407 FORMAT(23H ENTER RCS CHANGE (GAL))
ACCEPT 405,OGAL
S LDX 2,ZERO
S CLA
S LDB ITIME,2
S LSC 8
S SXJ 3,CONV
S STA IHR,2
S CLA
S LSC 8
S SXJ 3,CONV
S STA IMIN,2
S CLA
S LSC 8
S SXJ 3,CONV
S STA ISEC,2
S ICX 2,2
S JL $-14
S J $+2

```

✓
✓
✓

SZERO DATA 0

CALL INTER(TAVE(1),BNF,8,T1,BN)

506 TYPE 506
FORMAT(//,2X,4HTIME,6X,3HTCA,6X,3HTHA,6X,3HTCB,6X,3HTHB,

15X,4HTAVE,4X,8HPRZR LVL,2X,8HMUTK LVL,2X,3HRCDT LVL)
TYPE 560

560 FORMAT(12X,5(3H(F),6X),4H(IN),6X,4H(IN),5X,6H(VOLT))
DO 600 J=1,2

TYPE 507, IHR(J), IMIN(J), ISEC(J), (IAVG(I,J), I=1,4), TAVE(J),
1(IAVG(11,J), I=5,6), RCDL(J)

507 FORMAT(/,3(12,1H:),6(2X,F7.3),2(3X,F7.3))
600 CONTINUE

C RCSV=(DNI-DNF)*10673.
C MASS CHANGE IN PZRZ. LEVEL

PRZL=IAVG(5,1)-IAVG(5,2)
CPRZL=PRZL*120.8

C MASS CHANGE IN MU TANK LEVEL
CMUTK=250.0*(IAVG(6,1)-IAVG(6,2))

C TOTAL RCS MASS CHANGE
TRCS=RCSV+CPRZL+CMUTK

C TOTAL RCS CHANGE IN GALLONS
TAVAG=(TAVE(1)+TAVE(2))/2.

CALL INTER(TAVAG,CFAC,6,T2,CF)
GAL=TRCS*CFAC

RETURN
END

! EOF

*initial to final
Tave average*

ATTACHMENT E

APPLICABLE

TECHNICAL SPECIFICATIONS

TABLE 4.1-2

MINIMUM EQUIPMENT TEST FREQUENCY

<u>Item</u>	<u>Test</u>	<u>Frequency</u>
1. Control Rods	Rod drop times of all full length rods	Each refueling shutdown
2. Control Rod Movement	Movement of each rod	Every two weeks, when reactor is critical
3. Pressurizer Safety Valves	Setpoint	50% each refueling period
4. Main Steam Safety Valves	Setpoint	25% each refueling period
5. Refueling System Interlocks	Functional	Start of each refueling period
6. Main Steam Isolation Valves	(See Section 4.8)	
7. Reactor Coolant System Leakage	Evaluate	<u>Daily</u> , when reactor coolant system temperature is greater than 525°F
8. Charcoal and high efficiency filters for Control Room, and RB Purge Filters	DOP test on HEPA filters, freon test on charcoal filter units	Each refueling period and at any time work on filters could alter their integrity
9. Spent Fuel Cooling System	Functional	Each refueling period prior to fuel handling
10. Intake Pump House Floor (Elevation 262 Ft 6 in.)	(a) Silt Accumulation- Visual inspection of Intake Pump House Floor (b) Silt Accumulation Measurement of Pump House Flow	Each refueling period Quarterly
11. Hydraulic Shock Suppressors on Safety Related Systems	Inspection of Hydraulic Shock Suppressors (Snubbers) on Safety Related Systems.	Refueling Interval

3.1.6 LEAKAGE

Applicability

Applies to reactor coolant leakage from the reactor coolant system and the makeup and purification system.

Objective

To assure that any reactor coolant leakage does not compromise the safe operation of the facility.

Specification

- 3.1.6.1 If the total reactor coolant leakage rate exceeds 10 gpm, the reactor shall be placed in hot shutdown within 24 hours of detection.
- 3.1.6.2 If unidentified reactor coolant leakage (excluding normal evaporative losses) exceeds one gpm or if any reactor coolant leakage is evaluated as unsafe, the reactor shall be placed in hot shutdown within 24 hours of detection.
- 3.1.6.3 If any reactor coolant leakage exists through a non-isolable fault in a RCS strength boundary (such as the reactor vessel, piping, valve body, etc., except the steam generator tubes), the reactor shall be shutdown, and cooldown to the cold shutdown condition shall be initiated within 24 hours of detection.
- 3.1.6.4 If reactor shutdown is required by Specification 3.1.6.1, 3.1.6.2, or 3.1.6.3, the rate of shutdown and the conditions of shutdown shall be determined by the safety evaluation for each case and reported as required by specification 6.7.
- 3.1.6.5 Action to evaluate the safety implication of reactor coolant leakage shall be initiated within four hours of detection. The nature, as well as the magnitude, of the leak shall be considered in this evaluation. The safety evaluation shall assure that the exposure of offsite personnel to radiation is within the guidelines of 10 CFR 20.
- 3.1.6.6 If reactor shutdown is required per Specification 3.1.6.1, 3.1.6.2, or 3.1.6.3 the reactor shall not be restarted until the leak is repaired or until the problem is otherwise corrected.
- 3.1.6.7 When the reactor is critical and above 2 percent power, two reactor coolant leak detection systems of different operating principles shall be in operation for the Reactor Building with one of the two systems sensitive to radioactivity. The systems sensitive to radioactivity may be out-of-service for no more than 72 hours provided a sample is taken of the Reactor Building atmosphere every eight hours and analyzed for radioactivity and two other means are available to detect leakage.

3.1.6.8 ~~Loss of reactor coolant through reactor coolant pump seals and system valves to connecting systems which vent to the gas vent header and from which coolant can be returned to the reactor coolant system shall not be considered as reactor coolant leakage and shall not be subject to the consideration of Specifications 3.1.6.1, 3.1.6.2, 3.1.6.3, 3.1.6.4, 3.1.6.5, or 3.1.6.6 except that such losses when added to leakage shall not exceed 30 gpm. If leakage plus losses exceeds 30 gpm the reactor shall be placed in hot shutdown within 24 hours of detection.~~

Bases

Any leak of radioactive fluid, whether from the reactor coolant system primary boundary or not can be a serious problem with respect to in-plant radioactive contamination and required cleanup or, in the case of reactor coolant, it could develop into a still more serious problem and, therefore, the first indications of such leakage will be followed-up as soon as practical. The unit's makeup system has the capability to makeup considerably more than 30 gpm of reactor coolant leakage.

Water inventory balances, monitoring equipment, radioactive tracing, boric acid crystalline deposits, and physical inspections can disclose reactor coolant leaks.

Although some leak rates on the order of gallons per minute may be tolerable from a dose point of view it is recognized that leaks in the order of drops per minute through any of the barriers of the primary system could be indicative of materials failure such as by stress corrosion cracking. If depressurization, isolation, and/or other safety measures are not taken promptly, these small leaks could develop into much larger leaks, possibly into a gross pipe rupture. Therefore, the nature and location of the leak, as well as the magnitude of the leakage must be considered in the safety evaluation.

When reactor coolant leakage occurs to the reactor building, it is ultimately conducted to the reactor building sump. Although the reactor coolant is safely contained, the gaseous components in it escape to the reactor building atmosphere. There, the gaseous components become a potential hazard to plant personnel, during inspection tours within the reactor building, and to the general public whenever the reactor building atmosphere is periodically purged to the environment.

When reactor coolant leakage occurs to the auxiliary building it is collected in the auxiliary building sump. The gases escaping from reactor coolant leakage within the auxiliary building will be collected in the auxiliary and fuel handling building exhaust ventilation system and discharged to the environment via the unit's auxiliary and fuel handling building vent. Since the majority of this leakage occurs within confined, separately ventilated cubicles within the auxiliary building, it incurs very little hazard to plant personnel.

When reactor coolant leakage occurs to the nuclear services closed cooling water system, the leakage, both gaseous and liquid, is contained because the nuclear services closed cooling water system surge tank is a closed tank that is maintained above atmospheric pressure. The leakage would be detected by the nuclear services closed cooling water system monitor and by purge tank liquid level, both of which alarm in the control room. Since the nuclear services closed cooling water system's only potential contact with reactor coolant is in the sample coolers, it is considered not to be a hazard. However, if reactor coolant leakage to this receptor occurred and the surge tank's relief valve discharged, radioactive gases could be discharged to the environment via the unit's auxiliary and fuel handling building vent.

When reactor coolant leakage occurs to the intermediate cooling closed cooling water system, the leakage is indicated by both the intermediate cooling water monitor (RM-L9) and the intermediate cooling closed cooling water surge tank liquid level indicator, both of which alarm in the control room. Reactor coolant leakage to this receptor ultimately could result in radioactive gas leaking to the environment via the unit's auxiliary and fuel handling building vent by way of the atmospheric vent on the surge tank.

When reactor coolant leakage occurs to either of the decay heat closed cooling water systems, the leakage is indicated by the affected system's radiation monitor (RM-L2 or RM-L3 for system A and B, respectively) and surge tank liquid level indicator, all four of which alarm in the control room. Reactor coolant leakage to this receptor ultimately could result in radioactive gas leaking to the environment via the unit's auxiliary and fuel handling building vent by way of the atmospheric vent on the surge tank of the affected system.

Assuming the existence of the maximum allowable activity in the reactor coolant, a reactor coolant leakage rate of less than one gpm unidentified leakage within the reactor or auxiliary building or any of the closed cooling water systems indicated above, is a conservative limit on what is allowable before the guide lines of 10 CFR 20 would be exceeded. This is shown as follows: if the specific activity of the reactor coolant is $130/\bar{E}$ $\mu\text{Ci/ml}$ and the gaseous portion of it (as identified by Table 11-2) is discharged to the environment via the unit's auxiliary and fuel handling building vent, the yearly whole body dose resulting from this activity at the site boundary, using an annual average $\chi/Q = 4.5 \times 10^{-4}$ sec/m^3 , is 0.34 rem. This may be compared with the 10 CFR 20 guideline of 0.5 rem/year whole body dose.

When the reactor coolant leaks to the secondary sides of either steam generator, all the gaseous components and a very small fraction of the ionic components are carried by the steam to the main condenser. The gaseous components exit the main condenser via the unit's vacuum pump which discharges to the condenser vent past the condenser off-gas monitor. The condenser off-gas monitor will detect any radiation, above background, within the condenser vent.

However, buildup of radioactive solids in the secondary side of a steam generator and the presence of radioactive ions in the condensate can be tolerated to only a small degree. Therefore, the appearance of activity in the condenser off-gas, or any other possible indications of primary to secondary leakage such as water inventories, condensate demineralizer activity, etc., shall be considered positive indication of primary to secondary leakage and steps shall be taken to determine the source and quantity of the leakage.

If reactor coolant leakage is to the containment, it may be identified by one or more of the following methods:

- a. The containment air particulate monitor is sensitive to low leak rates. The rate of leakage to which the instrument is sensitive is 0.054 gpm within sixty minutes, assuming the presence of corrosion product activity.
- b. The containment radioactive gas monitor is less sensitive but can be used as a backup to the air particulate monitor. The sensitivity range of the instrument is approximately 2 gpm to greater than 10 gpm.
- c. A leakage detection system which determines leakage losses from water and steam systems within the containment. This system collects and measures moisture condensed from the containment atmosphere by cooling coils of the main recirculation units. This system provides a dependable and accurate means of measuring total leakage, including leaks from the cooling coils themselves which are part of the containment boundary.
- d. Indication of leakage from the above sources shall be cause to require a containment entry and limited inspection at power of the reactor coolant system. Visual inspection means, i.e., looking for steam, floor wetness, or boric acid crystalline formations, will be used. Periodic inspections for indications of leakage within the containment will be conducted to enhance early detection of problems and to assure best on-line reliability.

If reactor coolant leakage is to the auxiliary building, it may be identified by one or more of the following methods:

- a. The auxiliary and fuel handling building vent radioactive gas monitor is sensitive to very low activity levels and would show an increase in activity level shortly after a reactor coolant leak developed within the auxiliary building.
- b. Water inventories around the auxiliary building sump.
- c. Periodic equipment inspections.
- d. In the event of gross leakage, in excess of 13 ± 2 gpm, the individual cubicle leak detectors in the makeup and decay heat pump cubicles, will alarm in the control room to backup "a", "b", and "c" above.

When the source and location of leakage has been identified, the situation can be evaluated to determine if operation can safely continue. This evaluation will be performed by the Three Mile Island Operations Group according to routine established in Section 12.1.1 of the FSAR. Under these conditions, an allowable leakage rate of 30 gpm has been established.

ATTACHMENT F

SURVEILLANCE PROCEDURE

SP 1303-1.1

"REACTOR COOLANT SYSTEM LEAK RATE",

REVISION 7, MAY 25, 1976

A12208 007030001

1303-1.1
Revision 1
05/25/76

CONTROLLED COPY

THREE MILE ISLAND NUCLEAR STATION
UNIT #1 SURVEILLANCE PROCEDURE 1303-1.1
REACTOR COOLANT SYSTEM LEAK RATE

Central file

Table of Effective Pages

<u>Page</u>	<u>Date</u>	<u>Revision</u>	<u>Page</u>	<u>Date</u>	<u>Revision</u>	<u>Page</u>	<u>Date</u>	<u>Revision</u>
1.0	05/02/75	4						
2.0	05/02/75	4						
3.0	05/02/75	4						
4.0	10/14/75	5						
4.1	10/14/75	5						
5.0	05/02/75	4						
6.0	05/02/75	4						
7.0	05/02/75	4						
8.0	05/25/76	7						
9.0	05/02/75	4						
10.0	05/02/75	4						
11.0	10/14/75	5						
12.0	05/02/75	4						
13.0	05/02/75	4						
14.0	05/02/75	4						
15.0	05/02/75	4						
16.0	10/14/75	5						
17.0	05/02/75	4						
18.0	05/02/75	4						
19.0	05/02/75	4						
20.0	05/02/75	4						
21.0	05/02/75	4						
22.0	02/17/76	6						
23.0	02/17/76	6						
24.0	02/17/76	6						

Unit 1 Staff Recommends Approval

Approval *NKE* Date _____
Capizant Dept. Head

Unit 2 Staff Recommends Approval

Approval _____ Date _____
Capizant Dept. Head

Unit 1 PORC Recommends Approval

NKE Date *5-24-76*
Chairman of PORC

Unit 2 PORC Recommends Approval

_____ Date _____
Chairman of PORC

PORC comments of *NKE* included

By _____ Date _____

PORC comments of _____ included

By _____ Date _____

Approval *J. J. [Signature]* Date *5-25-76*
Section Superintendent
Unit Superintendent

999

THREE MILE ISLAND NUCLEAR STATION
UNIT #1 SURVEILLANCE PROCEDURE 1303-1.1
RC SYSTEM LEAK RATE

Required Interval -

Daily, when RCS temperature > 525°F.

1.0 PURPOSE

To evaluate reactor coolant system leakage in accordance with Technical Specification Table 4.1-2 item 7.

2.0 PLANT STATUS

- 2.1 Reactor coolant system temperature is greater than 525°F.
- 2.2 The Make-Up Tank level is between 66" and 96".
- 2.3 The pressurizer level is greater than 200".
- 2.4 Reactor power, temperature and pressure are in a steady state condition. (i.e. initial and final conditions approximately the same.)

3.0 LIMITS AND PRECAUTIONS

- 3.1 Avoid addition and removal of water from the reactor coolant and Make-Up systems during this test. The following operations should not be conducted during this test:
 - a. Make-Up or chemical addition to the make-up system.
 - b. Sampling of the RCS or make-up system.
 - c. Venting or draining of the RCS or make-up system.
 - d. Changing purification demineralizers or make-up filters in service.
 - e. Boration or deboration.

- 3.2 The RCS and makeup system should be maintained in a steady state condition during this test. Changes in valve line-ups, coolers-in-service, pumps-in-service, etc. should be avoided.
- 3.3 For the most accurate determination of the RCS leak rate, the initial and final conditions of reactor power, RCS temperature, pressure and pressurizer level should be identical.
- 3.4 The same sources should be used when recording initial and final RCS temperature, pressurizer level, make-up tank level and RCDT level. Differences in sources could be misinterpreted as RCS leakage when comparing successive readings.
- 3.5 Minimize power level variations during this test.

4.0 LOCATION OF SYSTEM/ASSEMBLY

NOTE: See enclosure two for sources of data.

- 4.1 The computer is the favored source of information.
- 4.2 If two or more inputs are not obtainable on the computer, the patch panel is to be used to obtain the required data.

5.0 EQUIPMENT

- 5.1 Equipment for use on patch panel.
 - 5.1.1 Digital voltmeter capable of reading ± 10 VDC.
 - 5.1.2 Leads for patch panel to voltmeter.

6.0 PROCEDURE

- 6.1 If the computer is available, initiate the "Reactor Coolant Leakage Test" as detailed in Enclosure II. Data sheets for hand calculations are provided for use as follows:

Data Sheet

1303-1.1.1.1

For Use When

Computer is operational

but not available for
RCS program.

1303-1.1.1.2 Computer not operational

- 6.2 If a hand calculation is being performed, obtain the applicable data sheet (see step 6.1) and take the initial set of data. After a minimum of one hour, take the final set of data and determine the net RCS leak rate as per instructions on the data sheet.
- 6.3 If changes to the RCS inventory must be made during the performance of this test, they must be accounted for using Data Sheet 1303-1.1.3. Operations such as adding water to the Make Up Tank or sampling the RCS may be accounted for in this manner.
- 6.4 If the net RCS leakage is excessive as defined by the acceptance criteria in section 7, proceed as follows:
 - 6.4.1 Perform another determination of the RCS leak rate.
 - 6.4.2 Insure that no un-accounted for operator action has occurred that would change the RCS inventory. (See section 3.1 for a listing of possibilities). If such an action has occurred, it invalidates the measurement. Enter this in the "Remarks" section of the data sheet, clearly describing the action that invalidated the measurement.
 - 6.4.3 Initiate action to determine the source of leakage. Check items such as:
 - a. Proper valve line-up.

- b. Valve stem leakage.
- c. Make-up pump packing glands.
- d. Relief valves not seated properly.

6.4.4 If sources of leakage are found, initiate data sheet 1303-1.1.2.

- a. Document completely the source of leakage. (Example: MU-V-159A stem leakage through packing gland).
- b. Determine the leak rate. The most preferred method is to collect the leakage in a calibrated container. (Obtain from Chemistry Dept.) over a known period of time. Use data sheet 1303-1.1.2 to document the method used to determine the leak rate. Include: Model # & Serial # of DVM used, description of other equipment used, length of measurement and quantity of leakage collected (Example: Used 50 cc graduated cylinder to collect 40 cc of water in 10 seconds.)
- c. Determine the leak rate and enter on Data Sheet 1303-1.1.2.

This quantity may be subtracted from the net RCS leakage (Line 8C of Data Sheet 1303-1.1.1 and 1.1.2).
- d. The Shift Supervisor shall make the initial determination of the safety implications of the leak. If he decides that there are possible safety implications, he shall notify the proper personnel in accordance with AP 1014.

7.0 ACCEPTANCE CRITERIA

7.1 If the gross reactor coolant leakage rate (Item 7 of Data Sheet) exceeds 10 gpm, the reactor shall be placed in hot shutdown within 24 hours of detection.

- 7.2 If unidentified reactor coolant leakage (Item 9 of Data Sheet) exceeds 1 gpm of the reactor shall be placed in hot shutdown within 24 hours of detection.
- 7.3 If any reactor coolant leakage is evaluated as unsafe, the reactor shall be placed in hot shutdown within 24 hours of detection.
- 7.4 If any reactor coolant leakage exists through a non-isolable fault in a RCS strength boundary (such as the reactor vessel, piping, valve body, etc., except the steam generator tubes), the reactor shall be shutdown, and cooldown to the cold shutdown condition shall be initiated within 24 hours of detection.
- 7.5 If reactor shutdown is required by criteria 7.1, 7.2, 7.3, or 7.4, the rate of shutdown and the conditions of shutdown shall be determined by the safety evaluation for each case and justified in writing as soon thereafter as practicable.
- 7.6 Action to evaluate the safety implication of reactor coolant leakage shall be initiated within four hours of detection. The nature, as well as the magnitude, of the leak shall be considered in this evaluation. The safety evaluation shall assure that the exposure of offsite personnel to radiation is within the guidelines of 10 CFR 20.
- 7.7 If reactor shutdown is required per Specification 7.1, 7.2, 7.3, the reactor shall not be restarted until the leak is repaired or until the problem is otherwise corrected.
- 7.8 Loss of reactor coolant through reactor coolant pump seals and system valves to connecting systems which vent to the gas vent header and from which coolant can be returned to the reactor

coolant system shall not be considered as reactor coolant leakage and shall not be subject to the consideration of the above criteria except that such losses when added to leakage shall not exceed 30 gpm. If leakage plus losses exceeds 30 gpm the reactor shall be placed in hot shutdown within 24 hours of detection.

DATA SHEET 1303-1.1.1.1

For Use when Computer is Available

Initial Conditions - To be taken at one minute intervals

Line	Time	Computer Point	T ₁	T ₂	T ₃	T ₂ ^o
Line 2a	T _C Loop A	510	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 2b	T _H Loop A	508	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 2c	T _C Loop B	513	_____ + _____	_____ + _____	_____ + _____	_____ +7= _____
Line 2d	T _H Loop B	509	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 2e	Unit Tave	(Sum of Lines 2a, 2b, 2c and 2d + 4)				_____ +4= _____
Line 3	Przr Level	1720	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 4	MJ T _k Level	498	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 5	RCDT Level	Patch Panel DVM	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____

Final Conditions - To be taken at one minute intervals

Line	Time	Computer Point	T ₁	T ₂	T ₃	T ₂ ^o
Line 7a	T _C Loop A	510	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 7b	T _H Loop A	508	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 7c	T _C Loop B	513	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 7d	T _H Loop B	509	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 7e	Unit Tave	(Sum of Lines 7a, 7b, 7c and 7d + 4)				_____ +4= _____
Line 8	Przr Level	1720	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 9	MJ T _k Level	498	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____
Line 10	RCDT Level	Patch Panel DVM	_____ + _____	_____ + _____	_____ + _____	_____ +3= _____

NOTE: Carry Algebraic signs through all steps.

1. Mass change due to RCS Temperature change.

(use line 2a and Figure 1 to determine density)

Line 11 a. Initial Density _____ lbm/ft³

(use line 7a and figure 1 to determine density)

Line 12 b. Final Density _____ lbm/ft³

- c. RCS Volume change (line 11 minus line 2 x 10,673)

Line 11 _____

Minus Line 12 _____

Line 13 10,673 ft³ x _____ lbm/ft³ = _____ lbm

2. Mass change in Pprz. Level

(Line 3 minus Line 8 x 120.8)

Line 3 _____

Minus Line 8 _____

Line 14 120.8 $\frac{\text{lbm}}{\text{in}}$ x _____ in = _____ lbm

3. Mass change in MU Tank Level

(Line 4 minus Line 9 x 250 lbm/inch)

Line 4 _____

Minus Line 9 _____

Line 15 250 $\frac{\text{lbm}}{\text{in}}$ x _____ in = _____ lbm

4. Total RCS Mass Change

(Algebraic sum of lines 13, 14 and 15)

Line 13 _____ Total change of mass

Line 14 _____ Pressurizer mass change

Line 15 _____ MUT mass change

Line 16 _____ lbm

5. Total RCS change in gallons

- a. Mean Tave (Line 2 plus line 7; + 2)

Line 2e ___ of

+Line 7e ___ of

Line 17 ___ + 2 = ___ of

- b. Use figure 2 and Line 17 to find

Line 18 conversion factor from lbm to gallons: ___ gal/lbm

- c. RCS Inventory change (Line 16 times line 18)

Line 16 ___ lbm

Line 19 xLine 18 ___ gal/lbm = ___ gal

- d. Operator caused changes to system

Line 20 (from data sheet 1303-1.1.3): ___ gal

- e. Total RCS leakage plus losses

(Algebraic sum of lines 19 and 20)

Line 19 ___

Line 20 ___

Line 21 ___ gal.6. Total leakage plus losses

- a. Duration of Test (Line 6 minus Line 1)

Line 6 ___ h ___ m

-Line 1 ___ h ___ m

Line 22 ___ h ___ m = ___ min

- b. Leak Rate (Line 21 divided by Line 22)

Line 21 ___

Line 23 +Line 22 ___ = ___ gpm

LIMIT: Line 23 shall not exceed 10 gpm (see acceptance criteria 7.8)

7. Gross Leak Rate

a. Mass change in RCDT

(Line 5 minus line 17 x 3540 lbm/volt)

Line 5 ___

-Line 10 ___

Line 24

___ v x 3540 lbm/volt = ___ lbm

b. RCDT change in gallons

(Line 24 times Line 18)

Line 24 ___

xLine 18 ___ (Conversion factor)

Line 25

= ___ gal

c. Operator caused changes to the RCDT

Line 26

(from data sheet 1303-1.1.3): ___ gal

d. Gross RCS Leakage

(Algebraic sum of Lines 21, 25 and 26)

Line 21 ___ Total RCS Leakage + Losses

Line 25 ___ RCDT increase (considered RCS losses)

Line 26 ___ RCDT change by operator

Line 27

___ gal

e. Gross RCS leak rate (identified and unidentified leakage)

(Line 27 divided by line 22)

Line 27 ___

Line 28

+Line 22 ___ = ___ gpm

LIMIT: Line 28 shall not exceed 10 gpm. (See Acceptance Criteria 7.1)

Unit 1 = RCDT is a vertical T

B. Corrections (Identified leakage)

- a. Evaporative losses -.51 gpm
- b. RCPump Seal #3 Purge +.28 gpm
- c. Identified leakage - _____ gpm (sign is minus)
(from data sheet 1303-1.1.2)

Line 28 Total (Algebraic sum) _____ gpm

B. Net unidentified RCS Leak Rate

Algebraic sum of lines 28 and 29

Line 28 _____

Line 29 _____

Line 30 _____ gpm

LIMIT: Line 30 may not exceed 1 gpm (See Acceptance
Criteria 7.2 and section 6.4 for action)

Remarks:

DVM Model # _____ Serial # _____

Performed by Date

Approved by Date

DATA SHEET 1103-1 1.1.5

For Use When Computer is Not Available

Initial Conditions - To be taken at one minute intervals

Line #	Time	Patch Panel Point	Patch Panel Point			
			T ₁	T ₂	T ₃	T ₃ ⁰
Line 1	Time		_____	_____	_____	_____
Line 2	Vave	40	_____	_____	_____	+30
Line 3	PRP Level	27	_____	_____	_____	+30
Line 4	MJ Tank	18	_____	_____	_____	+30
Line 5	RCDT	DVM	_____	_____	_____	+30

Final Conditions - To be taken at one minute intervals

Line #	Time	Patch Panel Point	Patch Panel Point			
			T ₁	T ₂	T ₃	T ₃ ⁰
Line 6	Time		_____	_____	_____	_____
Line 7	Vave	40	_____	_____	_____	+30
Line 8	PRP Level	27	_____	_____	_____	+30
Line 9	MJ Tank	18	_____	_____	_____	+30
Line 10	RCDT	DVM	_____	_____	_____	+30

Caution: When using patch panel voltage, be sure to record the voltage polarity (+ or -) and treat this as an algebraic sign.

4. Total RCS Mass change
(Algebraic sum of lines 15, 16 and 17)

Line 15 _____ Tave change of mass
Line 16 _____ Pressurizer mass change
Line 17 _____ CRUT mass change

Line 18 _____ lbm

5. Total RCS change in gallons

a. Mean Tave (Line 11 plus Line 12; + 2)

Line 11 _____ of
+Line 12 _____ of

Line 19 _____ + 2 = _____ of

b. Use figure 2 and line 19 to find

Line 20 conversion factor from lbm to gallons: _____ gal/lbm

c. RCS Inventory change (line 18 times line 20)

Line 18 _____ lbm

Line 21 xLine 20 _____ gal/lbm = _____ gal

d. Operator caused changes to system

Line 22 (from data sheet 1303-1.1.3): _____ gal

e. Total RCS leakage plus losses

(Algebraic sum of lines 21 and 22)

Line 21 _____

+line 22 _____

Line 23 _____ gal.

6. Total leakage plus losses

a. Duration of test (line 6 minus line 1)

Line 6 _____ h _____ m

-Line 1 _____ h _____ m

Line 24 _____ h _____ m = _____ min

A02

Revision 4
Page 4 of 5
MAY 2 - 1975

b. Leak rate (line 23 divided by line 24)

Line 23 _____

Line 25 +Line 24 _____ = _____ gpm

LIMIT: Line 25 shall not exceed 30 gpm (see Acceptance
Criteria 7.8)

7. Gross leak rate

a. Mass change in RCDT

(Line 8 minus line 10 x 3540 lbm/volt)

Line 8 _____

-Line 10 _____

Line 26 _____ v x 3540 lbm/volt = _____ lbm

b. RCDT change in gallons

(Line 26 times line 20)

Line 26 _____

xLine 20 _____ (Conversion factor)

Line 27 _____ = _____ gal

c. Operator caused changes to the RCDT

Line 28 (from data sheet 1303-1.1.3): _____ gal

d. Gross RCS leakage

(Algebraic sum of lines 23, 27 and 28)

Line 23 _____ Total RCS leakage + losses

Line 27 _____ RCDT increase (considered RCS losses)

Line 28 _____ RCDT change (by operator)

Line 29 _____ gal

e. Gross RCS leak rate (identified and unidentified leakage)

(line 29 divided by line 24)

Line 29 _____

Line 30 +Line 24 _____ = _____ gpm

A03

Division 5
Page 5 of 5
10/14/75

LIMIT: Line 30 shall not exceed 10 gpm. (see
Acceptance Criteria 7.1)

- 8. Corrections (identified leakage)
 - a. Evaporative losses -.51 gpm
 - b. RCPump Seal #3 Purge +.28 gpm
 - c. Identified Leakage - _____ gpm (sign is negative)
(from data sheet 1303-1.1.2)

Line 31 Total (Algebraic sum) _____ gpm

- 9. Net unidentified RCS Leak Rate
(Algebraic sum of lines 30 and 31)

Line 30 _____

Line 31 _____

Line 32 _____ gpm

LIMIT: Line 32 may not exceed 1 gpm. (See Acceptance
Criteria 7.2 and section 6.4 for action)

Remarks: _____

DVM Model # _____ Serial # _____

Performed by _____ Date _____

Approved by _____ Date _____

A04

SP 1303-1.1

Revision 4
MAY 2 - 1975

Data Sheet 1303-1.1.2

IDENTIFIED LEAKAGE

1. Source of Leakage
(Describe in detail, attach drawings if necessary)

2. Method used to determine leak rate
(Describe briefly)

3. Leak Rate: _____ gpm
(For use in step 8.c of Data Sheet 1303.1.1.1.1 and 1.1.1.2)

_____ Performed By _____ Date _____

4. Possible Safety Implications
(Shift Supervisor Check One)

_____ Yes (Initiate necessary action)

_____ No Explain _____

_____ Shift Supervisor _____ Date _____

SP 1303-1.1

Revision 4
MAY 2 - 1975

Data Sheet 1303-1.1.3

OPERATOR CAUSED CHANGES TO RCS INVENTORY

1. Identify operation that caused change: _____

2. Time Operation Started: _____

Time Operation Completed: _____

3. Calculations

4. Total change to RCS inventory: _____ gal.

- NOTES: 1) If change is to RCDT enter in section 7 of Data Sheet 1303-1.1.1.1 and 1303-1.1.1.2
- 2) If change is to any other part of the system, enter in section 5 of Data Sheet 1303-1.1.1.1 or 1.1.1.2
- 3) SIGNS: Removals from the system have a negative (-) sign. Additions to the system have a positive (+) sign.

Performed By


Date

Approved By

Date

- 3.1.1. The computer shall be used for the following tests:
- 4.1. LOCATION OF DEFECTS ASSUMED
 - 4.1.1. See enclosure for sources of data
 - 4.1.2. The computer is the favored source of information
 - 4.2. If two or more inputs are not acceptable on the computer, the patch panel is to be used to obtain the required data
- 5.0. EQUIPMENT
- 5.1. Equipment for use on patch panel:
 - 5.1.1. Digital voltmeter capable of reading ± 10 VDC
 - 5.1.2. Leads for patch panel to voltmeter
- 6.0. PROCEDURES
- 6.1. If the computer is available, initiate the "Reaction Contact Leakage Test" as detailed in Enclosure II. Data sheets for hand calculations are provided for use as follows:

1289-1.1.1.1 1289-1.1.1.2
 Computer's operations



3. Determine the loss rate. The most preferred method is to collect the leakage in a calibrated container (Obtain from Chemistry Dept.) over a known period of time. Use data sheet 1302-1.1.2 to document the method used to determine the loss rate. Include Model # & Serial # of DPH used, description of other equipment used, length of measurement and quantity of leakage collected (Example: Used 50 cc graduated cylinder to collect 40 cc of water in 10 seconds.)
4. Determine the loss rate and enter on Data Sheet 1302-1.1.2.
- This quantity may be subtracted from the net ACS leakage (Line 02 of Data Sheet 1302-1.1 and 1.1.2).
5. The Shift Supervisor shall note the verbal description of the safety implications of the loss. If no obvious loss there are possible safety implications, he shall notify the proper personnel in accordance with AP 1044.

7.8 REFERENCE MATERIAL

SCHEDULE 1
VALUES OF 1996

FIGURE NO.	ORDINATE POINT	ORDINATE CURVE DESCRIPTION	PRICE PER			METER USE
			DAY	MONTH	YEAR	
None	500 LAMP & 1/2 510 520 LAMP & 1/2 530 540 LAMP & 1/2 550 560 LAMP & 1/2 570	CC 7-100 or CC 8-100	01 10000 Year	570-6000	+07 to +10	1-500 (Example)
Pressureless Leak	1200 1205 1200	Federal Catalytic Foster Pass	27	6-600 to	+00 to +10	4000 (Example)
Weld-up Seal (Leak)	600	General Catalytic Gardner Pass	15	6-100 to	+00 to +10	+1700 (Example)
Detector Contact Shut-Off Leak	600 or Patch Pass	Leak Responder LDR Pass	71	6-120 to	0- to +10	3000 (Example)

Note: Foster Pass Sales may be obtained from the vendors listed for a condition price outside the Federal Pass.

21.8

A09

1303-1.1
Revision 6
02/17/76

ENCLOSURE II

Computer Determination of RC

Leak Rate

E.2.1.0 PURPOSE

This program is designed to perform all the calculations accomplished on Data Sheet 1303-1.1.1.1. The plant computer will automatically gather all input; and average three minute intervals of the initial and final readings. This program is run from the programmer's console of the Bailey 855 computer. It may be run at any time the programmer's console is not being used by another program.

E.2.2.0 PROCEDURE

E.2.2.1 Turn on the programmer's selectric typewriter next to the Bailey 855 computer. Be sure that the "OUTPUT SELECT" switch is on "UTILITY COMPUTER."

E.2.2.2.1 If the computer printout on the selectric shows a question mark (?), type "r", then depress the "Return" Key. The computer will respond with an exclamation mark (!).
Proceed to E.2.2.2.2.

E.2.2.2.2 If the printout on the selectric shows an exclamation mark (!), type "RC" and then press the "Return" key.
(See sample printout: Attachment 1)

E.2.2.3 The computer will then request the time interval over which the test is to be run. Any interval from 1 to 8 hours in one hour intervals may be chosen. Enter a single digit, then press the "Return" Key.

A 10

1303-1.1
Revision 6
02/17/76

E.2.2.4 The computer will now request known leakage. Enter "Identified Leakage" (as determined by Data Sheet 1303-1.1.2) in gallons per minute. Enter operator caused changes to the RCDT or the RCS (as detailed on Data Sheet 1303-1.1.3) in gallons.

CAUTION: For the above entries, be sure to enter a decimal point. If no decimal point is entered, the computer will insert one according to the format it expects to see.

E.2.2.5 The computer will now print out all required data. Be sure to attach data sheets detailing any entries made in step E.2.2.4.

A 1 1

1303-1.1
Revision 6
02/17/76

ATTACHMENT 1

irc
DATE: 01/20/75
TIME: 16: 3:38

REACTOR COOLANT LEAKAGE TEST
SP 1303-1.1

DESIRED INTERVAL (1-8 HOURS)

- 1 ENTER IDENTIFIED LEAKAGE FROM DS 1303-1.1.2 (GPM)
- ENTER RCOT CHANGE (GAL)
- ENTER RCS CHANGE (GAL)

TIME	TCA (F)	THA (F)	TCB (F)	THB (F)	TAVE (F)	PRZR LVL (IN)	MUTK LVL (IN)	RCOT LVL (VOLT)
16: 3:54	556.977	601.055	556.250	600.719	578.750	238.311	79.603	8.925
16: 8:54	557.031	601.070	556.180	600.719	578.742	230.178	79.095	8.945

LEAKAGE PLUS LOSSES (<30 GPM): 0.0473 GPM
 GROSS RCS LEAK RATE (<10 GPM): -0.1463 GPM
 NET UNIDENTIFIED LEAK RATE (<1 GPM) -0.3763 GPM

OPERATOR:

APPROVED:

TABLE A
SUMMARY OF REVISIONS

<u>Page</u>	<u>Changes</u>
5	Revised
6	Changed from page 5 Revision
7	Revised
7A	Added (Summary Table)
7B	Added (Summary Table)
7C	Added (Summary Table)
7D	Added (Summary Table)
7E	Added (Summary Table)
12	Revised
13	Revised (Table 1)
14	Revised
15	Revised (Table 2)
16	Revised
20	Revised
26	Revised
32	Revised
36	Revised (Table 6)
38	Revised
39	Revised (Table 7)
40	Revised

REVISED PAGES TO 289/83-20

EXECUTIVE SUMMARY

OBJECTIVES

The basic objective of this inspection was to verify that records of Reactor Coolant System (RCS) leak rate testing at Three Mile Island (TMI) Unit 1, from the period April 1, 1978, to March 31, 1979, showed no indications of practices similar to alleged irregularities at Unit 2. The allegations related to Unit 2 RCS leak rate testing involved the following:

- That tests were often repeated until the results met the acceptance criteria and that unfavorable results were discarded;
- That RCS water inventory was adjusted contrary to procedural requirements; in that water additions were made and not recorded in the test package nor included in the RCS leak rate test calculations;
- That computer data entries for the leak rate calculations were "fudged" to make the leak rate test calculations appear acceptable; and,
- That hydrogen gas was added to the Make-Up Tank (MUT) to influence leak rate test calculations.

Supplemental objectives of the inspection were to:

- Examine compliance with the Technical Specifications on RCS Leak Rate;
- Inspect the leakage test procedure for technical and functional adequacy; and,
- Examine the effects of instrument calibration and variations on leak rate determinations.

CONDUCT OF INSPECTION

From July 11, 1983 to September 9, 1983, members of the engineering staff of Region I conducted an inspection of TMI-1 records, procedures, equipment and specifications related to reactor coolant system leak rate testing performed by station personnel in the year immediately preceding the accident at TMI-2. The inspectors reviewed and correlated diverse records related to leak rate tests, performed an "as-built" walkdown of related plant systems and instrumentation, and, in conjunction with licensee personnel, demonstrated by system operation a technique by which RCS leak rate results could be modified.

Additional information was obtained subsequent to September 9, 1983. This information and previously obtained information has been extensively reanalyzed by the staff. This led to revision of the inspection report. Revised information is annotated by R1 in the right hand margin.

Surveillance records for RCS leak rate tests were reviewed for the period from April 1, 1978 through March 31, 1979. Six hundred and forty-five test records were the principal object of this review. These surveillance records were compared with control room logs, power traces and makeup tank level recorder charts developed during the tests to determine abnormal test operations, adequacy of records and compliance with test procedures. The station surveillance test procedure in effect at that time was evaluated for completeness and adequacy. Independent leak rate calculations were performed by the NRC staff with an NRC microcomputer and compared with TMI-1 data to verify the validity of licensee calculations.

The inspector performed a walkdown inspection of the makeup system and verified that the instrumentation system for measuring makeup tank (MUT) level contained a loop seal. The significance of this loop seal is that hydrogen additions made to the MUT during a test could result in errors in RCS leak rate test calculations. Further, a review of plant maintenance records for 1978 identified narrative which described the effects of gas additions on indicated Make-Up Tank (MUT) level.

The MUT strip chart recorder traces were independently analyzed and evaluated by the inspectors to identify instances of improper performance of RCS leak rate tests, such as the addition of hydrogen or water during the performance of the leak rate test. Strip chart data were compared with control room logs and surveillance test calculations to determine if test conditions as indicated by the strip chart were incorporated, or considered, in the calculation of leak rate. Further, the inspectors directed and monitored an actual demonstration of the effects of gas additions to the MUT at Unit 1 on indicated MUT level to support their conclusions. Licensee personnel assisted in this demonstration and acknowledged the resulting conclusions.

MAJOR FINDINGS

The RCS leak rate tests performed at TMI-1 during the year prior to the accident at TMI-2 contained several inadequacies and deviations from procedural and regulatory requirements. These would, in most instances, have lead to a less conservative calculation of RCS leakage rates.

- a. The RCS leak rate procedure, SP 1303-1.1, Rev. 7, in use during the time period reviewed, was inadequate because:
 - o it contained incorrect procedural steps (§3.3);
 - o it did not prohibit acceptance of test results showing negative leakage (§2.3);
 - o it failed to incorporate temperature compensation for several leak rate factors (§3.3);
 - o it omitted several important factors; such as, no provisions to include steam generator tube leakage as identified leakage or the effects of pressure variation in the RCS (§3.3); and,
 - o it utilized incorrect values for volume and water mass change per unit level change (§3.3).

- b. The as-built configuration of the MUT level instrument system provided a loop seal on the low pressure reference leg, which introduced the potential for non-conservative effects on RCS leak rate test results from MUT gas additions. During discussions with station operating personnel, the inspectors were informed there was no loop seal in the makeup tank level instrument system. An NRC walkdown revealed the loop, which provides a means to affect leakage calculations (§4.3.1).
- c. An analysis of MUT level strip charts for the period inspected indicated at least eleven hydrogen additions were made during RCS leak rate tests. There were no entries in the control room logs which recorded the fact that these gas additions were made nor were they compensated for in the leak rate calculations. The calculated leak rates, therefore, were in error. Actual leakages were, in fact, higher than the recorded values (§4.3.3). R1
- d. Thirteen instances of apparent water addition to the RCS during leak rate tests were identified. In only one test was the water addition accounted for in the calculations; and, in that case, the volume accounted for was considerably less than the apparent actual addition. These unaccounted additions resulted in recorded leakage values lower than actual leakages (§5.2). R1
- e. Thirteen instances of apparent feed and bleed operations during testing were identified, for which the leak rate calculation was not properly corrected for the operator-caused water inventory change (§2.3). R1
- f. One instance of a combined hydrogen addition, water addition and feed and bleed operation was found (§4.3.3). R1
R1
- g. A number of instances of substantial apparent level changes in the Reactor Coolant Drain Tank during leak rate tests were identified. No logbook entries which would explain these level changes were found. (§6.2)
- h. The licensee established a conservative administrative test frequency for RCS leak rate testing of once per shift, whereas, technical specification required only daily testing. Fifteen missing test records were identified (§2.3). R1

CONCLUSION

Eleven instances of hydrogen addition, 13 instances of water addition, 13 instances of feed and bleed and one instance of combined feed, bleed, hydrogen and water addition were identified in a population of six hundred and forty five test records examined. These inventory changes or additions affected MUT level and were not properly incorporated into the RCS leak rate calculations. The instances were limited to performance by only a few individuals. Recalculation using best available information showed that, except for four instances, Technical Specifications would have been met. R1
R1
R1
R1
R1
R1
R1
R1

SUMMARY TABLE
OF
APPARENT IRREGULARITIES
DURING RCS LEAK RATE TESTING

(added as a result of Revision 1 to
Inspection Report 50-289/83-20)


R1
R1
R1
R1
R1
R1
R1

SUMMARY OF APPARENT IRREGULARITIES DURING RCS LEAK RATE TESTING

DATE	CLOCK TIME	WATER ADDITION			HYDROGEN ADDITION PSI/TIME	UNIDENTIFIED LEAK RATE, GPM		
		CHART GALLON/TIME	INCLUDED IN CALCULATION	CRO/SF LOG ENTRY		UNCORRECTED	CORRECTED	
04/30/78	1532/1632	165/1538 (MUT +1.3"; normal -2")	no	no	--	-1.8580	1.9260	R1
04/30/78	2321/0021 (05/01/78)	60/2335 (MUT +1" ; normal -1.5")	no	no	--	-0.9717	0.4044	R1
05/03/78	1822/1922	F&B (60 gal) (MUT +1.7"; normal -2")	no	no	--	-0.7658	0.6102	R1
# 05/07/78	/1436	no surveillance data				-0.9933		
05/12/78	0047/0147	F&B (60/0125) (MUT +1.4"; normal -3")	no	yes	--	-0.3760	1.0000	R1
* 05/12/78	1643/1743	180/1732 (MUT +5"; normal -1")	no*	yes (70/1745)	--	-0.7443	0.6337	
05/13/78	2340/0040 (05/14/78)	F&B (no effect)	no	no	--	0.5882 (invalid test)		R1
05/21/78	/1025	no surveillance data				0.8460		
05/26/78	1656/1756	90/1753 (jogged) (MUT +0.4"; normal -3")	no	no	--	-0.7518	1.4498	R1
# 06/06/78	/0530	no surveillance data				0.5812		
06/11/78	0804/0904	F&B	no	yes	--	0.5826 (invalid test)		
06/21/78	0341/0441	30/0410, 90/0425 (MUT -6"; normal -11")	no	yes	--	0.9421	1.6301	R1

NOTE # : suspected to be misfiled.

* : RCDT drained ; 165 gal. @ 579°F

DATE	CLOCK TIME	WATER ADDITION			HYDROGEN ADDITION PSI/TIME	UNIDENTIFIED LEAK RATE, GPM		R1
		CHART GALLON/TIME	INCLUDED IN CALCULATION	CRO/SF LOG ENTRY		UNCORRECTED	CORRECTED	
07/02/78	0256/0356	F&B(1590/0310) F&B(100/0340)	no	yes (F&B;1950/0345)	--	0.7266(invalid test)		R1
07/04/78	/2245	no surveillance data				0.9967		R1
07/10/78	/0338	no surveillance data				-0.0771		R1
08/08/78	0735/0835	no	no	no	2"/0750 (1.5" decayed; 0.5" effective)	-0.1099	0.2341	R1
08/19/78	/1450	no surveillance data				-0.2380		R1
? 08/29/78	1547/1647	240/1548 () (MUT+0.3";normal-1" ; 15 gal. effective)	no	no	--	-0.0673	0.2767	R1
08/30/78	1952/2052	no	no	no	1"/1952 (0.6" decayed; 0.4" effective)	0.1023	0.3775	R1
08/31/78	0801/0901	no	no	no	1.5"/0820 (MUT +1.3" ; normal -1")	-0.4141	0.6179	R1
09/03/78	/1138	no surveillance data				0.9667		R1
09/08/78	1629/1729	60/1705 (MUT +1.3";normal -1")	no	no	--	-0.5823	0.7937	R1
09/11/78	1825/1925	60/1840-50(jogged) (MUT +2.6";normal -2")	no	no	--	-0.5862	0.7898	R1
09/15/78	0921, 1021	45/1010-20(jogged) (MUT +0.3";normal -1")	no	no	--	-0.5503	0.4817	R1

? : questionable

DATE	CLOCK TIME	WATER ADDITION			HYDROGEN ADDITION PSI/TIME	UNIDENTIFIED LEAK RATE, GPM		R1
		CHART GALLON/TIME	INCLUDED IN CALCULATION	CRO/SF LOG ENTRY		UNCORRECTED	CORRECTED	
09/17/78	0508/0608	F&B(100/0515-57) (no effect?)	no	no	--	0.7745(invalid test)		R1
7 09/18/78	2035/2136	45/2100(jogged)	no	no	--	-0.4265	0.6055	R1
09/18/78	2355/0055 (09/19/78)	no	no	no	2"/0040 (MUT +1.3"; normal -1")	-0.5823	0.7937	R1
09/22/78	2100/2200	F&B	no	no	--	-0.0373(invalid test)		R1
10/02/78	1645/1745	no	no	no	2"/1720	-0.0293	0.3147	R1
10/17/78	1201/1301	60/1240-1303(jogged)	no	no	(1.5" decayed; 0.5" effective)	-0.4581	0.9179	R1
11/05/78	/1955 /1950	no surveillance data			--	0.3395		R1
11/07/78	1608/1708	no	no	no	2"/1653 {1.6" decayed; 0.4" effective}	0.0445	0.3197	R1
# 11/10/78	/1125	no surveillance data			--	0.5374		R1
11/12/78	0816/0916	no	no	no	2"/0903 (MUT +0.8"; normal -0.5"; 1" effective)	-0.1954	0.4926	R1
11/13/78	0304/0404	F&B(30/0356) (MUT +0.4"; normal -0.7")	no	no	--	-0.5507	0.1373	R1
11/16/78	0426/0526	F&B (MUT +1.8"; normal -0.2")	no	no	--	0.6059(invalid test)		R1
11/20/78	2110/2210	F&B	no	no	--	0.8772(invalid test)		R1
11/21/78	0206/0306	F&B(90 gal)	no	no	--	-0.5078(invalid test)		R1

DATE	CLOCK TIME	WATER ADDITION			HYDROGEN ADDITION PSI/TIME	UNIDENTIFIED LEAK RATE, GPM	
		CHART GALLON/TIME	INCLUDED IN CALCULATION	CRO/SF LOG ENTRY		UNCORRECTED	CORRECTED
11/28/78	1653/1853	F&B(200;1720-50)	no	no	--	-0.3462(invalid test)	
12/11/78	0432	no surveillance data				-0.8118	
** 12/13/78	1842/1942	270/1920 (MUT +8.3"; normal -1")	no**	yes	--	-0.2170	0.1417
12/18/78	0830/0930	no	no	no	/0834(- (no effect?))	0.5220	
01/06/79	0756/1156	400/0923;120F&B/1010	300 gal.	yes	/0937, /0940 (no effect)	-0.5948	0.4485
01/08/79	/0600 /0604	no surveillance data				0.4842	
01/09/79	1936/2036	F&B(30 gal) (MUT +1"; normal -1")	no	no	--	-0.2981	0.3899
01/11/79	1606/1706	no	no	no	2"/1738	-0.6163	0.7597
01/18/79	0401/0501	60/0450(jogged) (MUT +1.1"; normal -1")	no	no	--	-0.6938	0.6824
01/18/79	/1310	no surveillance data				0.0700	
01/26/79	/0032	no surveillance data				-0.4909	
01/29/79	/0310	no surveillance data				-0.3124	
02/02/79	1600/1700	no	no	no	2"/1614,1620 (1.5" decayed; 0.5" effective)	0.3287	0.6727
02/03/79	1615/1715	no	no	no	2"/1623 (0.5" effective)	0.4692	0.8132
02/12/79	/2230	no surveillance data				-0.5000	

** : RCDT drained ; 350 gal. @ 579°F

R1

R1

R1

R1

R1

R1

R1

R1

R1

7E

The surveillance records from the period of July 8, 1978 to August 4, 1978 were not reviewed due to missing MUT recorder traces. Thus, 69 surveillance test records could not be reviewed. Therefore, 645 surveillance test records were reviewed against MUT recorder traces and other data, such as daily logs and computer listings.

The licensee had established a conservative administrative test frequency of once per shift. Tests were often performed once per shift, whereas Technical Specification required a daily test.

The total number of days covered by surveillance record was 290 days, during which the following tests were completed:

<u>No. Tests Performed Per Day</u>	<u>No. Days</u>
1 (Daily)	27
2 (Twice Daily)	114
3 (Each Shift) or more	149

Major findings from the record review are:

- Some of the tests noted in the CRO and SRO shift logs were missing in the surveillance files. These surveillance records were either never created, lost, discarded or misfiled. Two test records were found filed out of normal sequence and six were found misfiled. Fifteen missing test records have been identified. They are listed in Table 1.
- The surveillance test records frequently showed negative leak rate results. Two months of leak rate test data were reviewed to identify examples of test records demonstrating negative leakage. The following summarizes the results of that review:

	<u>May, 1978</u>	<u>June, 1978</u>	<u>May + June 1978</u>
Total Test Records Reviewed	60	61	121
<u>Number Test Records Demonstrating Negative Leakage Rate Results</u>			
Leakage Plus Losses	10	4	14
Gross Leak Rate	20	16	36
Unidentified Leak Rate	28	20	48

TABLE 1

Lost, Misfiled, Discarded or Never Created RCS Leak Rate Test Records

<u>NO.</u>	<u>DATE</u>	<u>TIME</u>	
1	5-07-78	1436	R1
2	5-21-78	1025	
3	6-06-78	0530	
4	7-04-78	2245	
5	7-10-78	0338	R1
6	8-19-78	1450	
7	9-03-78	1247	
8	11-05-78	1955	
9	11-10-78	1125	
10	12-11-78	0432	
11	01-08-79	0600	R1
12	01-18-79	1310	R1
13	01-26-79	0032	
14	01-29-79	0310	
15	02-12-79	2230	R1

Almost 40% (48 out of 121) of the calculated and recorded unidentified leak rates during the two month period had negative values.

- The RCS leak test procedure, SP 1303-1.1, recommended water additions such as Feed-and-Bleed (F&B) operations be avoided during the test. The inspector identified at least 13 tests, during which F&B operations appeared to have taken place; and in each case, the change in water inventory was not properly compensated for by the operator in the computer calculations of RCS leakage rates. They are identified in Table 2.

| R1

These record review findings are indicative of the failure of the licensee to comply with regulatory and procedural requirements for record-keeping and test performance.

Table 2

Apparent Uncompensated Feed & Bleed Operations
During RCS Leak Rate Testing

DATE	CLOCK TIME	WATER ADDITION			HYDROGEN ADDITION PSI/TIME	UNIDENTIFIED LEAK RATE, GPM		
		CHART GALLON/TIME	INCLUDED IN CALCULATION	CNO/SF LOG ENTRY		UNCORRECTED	CORRECTED	
05/03/78	1822/1922	F&B (60 gal) (MUT +1.7"; normal -2")	no	no	--	-0.7658	0.6102	R1
05/12/78	0047/0147	F&B (60/0125) (MUT +1.4"; normal -3")	no	yes	--	-0.3760	1.0000	
05/13/78	2340/0040 (05/14/78)	F&B (no effect)	no	no	--	0.5882 (invalid test)		R1 R1
06/11/78	0804/0904	F&B	no	yes	--	0.5826 (invalid test)		P1
07/02/78	0256/0356	F&B (1590/0310) F&B (100/0340)	no	yes (F&B; 1950/0345)	--	0.7266 (invalid test)		P1
09/17/78	0508/0608	F&B (100/0515-57) (no effect?)	no	no	--	0.7745 (invalid test)		
09/22/78	2100/2200	F&B	no	no	--	-0.0373 (invalid test)		R1
11/13/78	0304/0404	F&B (30/0356) (MUT +0.4"; normal -0.7")	no	no	--	-0.5507	0.1373	
11/16/78	0426/0526	F&B (MUT +1.8"; normal -0.2")	no	no	--	0.6059 (invalid test)		
11/20/78	2110/2210	F&B	no	no	--	0.8772 (invalid test)		
11/21/78	0206/0306	F&B (90 gal)	no	no	--	-0.5078 (invalid test)		R1
11/28/78	1653/1853	F&B (200/1720-50)	no	no	--	-0.3462 (invalid test)		
01/09/79	1936/2036	F&B (30 gal) (MUT +1"; normal -1")	no	no	--	-0.2981	0.3899	R1

3.0 Reactor Coolant System (RCS) Leak Rate

3.1 Background

The TMI Unit 1 Technical Specifications, paragraph 3.1.6 and Table 4.1-2, required that RCS leakages be determined at least once per day during steady state operations, and that the leakage-plus-losses, total gross leakage and unidentified leakages be maintained within their respective limits of 30 Gallons-Per-Minute (GPM), 10 GPM and 1 GPM. The TMI-1 Final Safety Analysis Report (FSAR), Section 4.2.3.8.a, specified that the leakages were measured by counting water inventory changes within the RCS pressure boundary for a fixed time interval.


The test procedure included a precaution to avoid addition or removal of water and chemicals from the RCS. The procedure also recommended that, for the most accurate leak rate determination, the initial and final values of power, RCS temperature, RCS pressure and pressurizer level should be maintained identical.

The procedure specified a test duration of one to eight hours, and specified the plant computer as the favored tool for performing test calculations. Hand calculations were allowed as a backup when the computer was not available. There was only one record of a hand calculation during the one year period from April, 1978 thru March, 1979.

Upon initiation of a computer calculation, data was taken automatically from hard-wired, pre-designated computer points. Manual actions required by the computer method were input specifications such as test time interval (normally one hour), any identified leakages and the operator actions of make-up water additions and RCDT pumping. RCS leak rate calculations were automatically done by the computer when the above steps were completed. For hand calculations, the preferred data source was defined to be DVM readings from a patch panel rather than data obtained from control room indicators, due to the inherent inaccuracies in the latter readings.

R1

The procedure also specified a set of corrective steps to be taken when the RCS leakages were in excess of the requirements. The first step was to perform another leak rate determination, followed by careful examination of the operator actions affecting the water inventory. The final step was to initiate action to determine the source of the leakage, and then to proceed with the ACTION statements specified in Technical Specification 3.1.6, which required placing the reactor in hot shutdown within 24 hours of detection of excessive leakage.



PROCEDURE STATED
ACCEPTANCE CRITERIA:
30 gpm

CF₃ = 3540 lbm/volt

**Z_{rci}
dig
enti

DELETED

rel
readings

RI
RI
RI
RI

errors estimated from the instrument repeatability would be 11.6 gallons regardless of test duration, and subsequent contribution to the leak rate error would be 0.19 gpm and 0.05 gpm for one and four hour test durations, respectively.

3.5 Uncertainty of Make-Up Tank (MUT) Chart Time

During the one year period, 264 water additions were logged in CRO logbooks and these entries were identified on the MUT strip chart tracings, as tabulated in Table 10. The purpose of this comparison was to determine the accuracy and validity of the chart time. It was understood that the time entered in the shift log by an SRO and CRO was the control room clock time, and the control room MUT recorder time was adjusted periodically to the control room clock time at midnight.

The traces of water addition on MUT charts were compared statistically with the CRO log entry times. Statistical analysis showed that the chart traces of water additions were ahead of the log times by an average of 3.2 minutes with a standard deviation of 10.73 minutes. This was an expected result since the operator or SRO would enter the water additions into the shift log after completion of the operation. On this basis, it was determined that the MUT recorder chart time was accurate statistically to ± 10 minutes.

This information was later utilized to isolate the interval of the MUT level strip chart trace which bracketed the period of test performance. The resulting interval of strip chart was typically 80 minutes wide, (a 60 minute test + 13 minutes before + 7 minutes after) starting 13 minutes prior to the recorded test start time in terms of chart time. All available records were then correlated to identify the actual period of test performance within this interval.

3.6 System and Human Error Potential

Beside the procedural inadequacies and the "As Built" system limitations, there are three additional expected or potential errors in the RCS leakage rate calculations.

(1) RCDT pumpout entries

The procedure required computer entry by operators of RCDT pumpouts. This is discussed further in Section 6.0

R1
R1
R1
R1

- The trace of the level shift due to the pressure increase (┆) was the same as those suspected hydrogen additions on the MUT chart for the period April 1978 thru March 1979. (See Table 6)

The test traces are shown in Figure 3. For clarity, Figure 3A provides a magnified hand drawn version of the appropriate section of Figure 3. A computer graphic trace is shown in Figures 4 for this test. After the test, licensee representative acknowledged the inspector's findings of the effect of hydrogen additions and their characteristic traces on the MUT level charts.

4.3.3 Hydrogen Additions During Leak Rate Tests

The Control Room Operator's and Shift Foreman's logs were searched for entries showing hydrogen addition during the periods of leak rate testing records. This was done for records from April, 1978, through March, 1979. No entries showing the hydrogen additions were observed in the logs. The makeup tank level strip chart was then examined for the additions. Twelve (one combined) hydrogen additions during RCS leak rate testing were identified as shown in Table 6. The hydrogen additions were not recorded in the logs nor compensated for in the leak rate calculations. When the hydrogen additions and consequent level shifts were included in the leak rate calculations, the unidentified leak rates were all increased.

R1
R1

R1
R1
R1

5.2 Findings Regarding Water Addition

During a previous inspection, four such water additions were identified. During this inspection it was determined that three of them were wrongly identified. In fact, one of the three wrong cases is now identified as a hydrogen addition.

Based on the review of MUT strip chart, traces of water addition, surveillance SP 1303-1.1 computer output and pressurizer level response during tests, fourteen (one combined) tests were identified during which water additions were made but were not entered into the computer calculations. Table 7 summarizes these water additions.

In some cases, the chart traces indicated that water might have been added gradually to the RCS. One test, performed January 6, 1979, accounted for 300 gallons of water addition in the computer calculations. However, the level shift, a characteristic trace of water addition on the MUT strip chart, indicated approximately 480 gallons added. When gas space compression is accounted for, the addition amounted to approximately 400 gallons, instead of the 300 gallons entered into the computer calculation. This recorded MUT level shift provided additional evidence of the existence of a loop seal in the low pressure reference leg, since raising MUT level compresses the MUT cover gas and causes the same effect as a gas addition discussed in Section 4.

When these water additions were accounted for in the leak rate calculations, three showed the unidentified leak rate in excess of 1 gpm, as tabulated in Table 7. This was contrary to the requirement specified in Technical Specification 3.1.6.1. These are further examples of apparent failure to comply with procedural and regulatory requirements.

R1

R1
R1
R1

R1

R1

R1

Table 6

Hydrogen Additions To Makeup Tank During Leak Rate Test

<u>DATE</u>	<u>CLOCK TIME</u>	<u>WATER ADDITION</u>			<u>HYDROGEN ADDITION PSI/TIME</u>	<u>UNIDENTIFIED LEAK RATE, GPM</u>		
		<u>CHART GALLON/TIME</u>	<u>INCLUDED IN CALCULATION</u>	<u>CRO/SF LOG ENTRY</u>		<u>UNCORRECTED</u>	<u>CORRECTED</u>	
08/08/78	0735/0835	no	no	no	2"/0750 (1.5" decayed; 0.5" effective)	-0.1099	0.2341	R1
08/30/78	1952/2052	no	no	no	1"/1952 (0.6" decayed; 0.4" effective)	0.1023	0.3775	R1
08/31/78	0801/0901	no	no	no	1.5"/0820 (MUT +1.3" ; normal -1")	-0.4141	0.6179	
09/18/78	2355/0055 (09/19/78)	no	no	no	2"/0040 (MUT +1.3"; normal -1")	-0.5823	0.7937	R1
10/02/78	1645/1745	no	no	no	2"/1720 (1.5" decayed; 0.5" effective)	-0.0293	0.3147	
11/07/78	1608/1708	no	no	no	2"/1653 (1.6" decayed; 0.4" effective)	0.0445	0.3197	R1
11/12/78	0816/0916	no	no	no	2"/0903 (MUT +0.8"; normal -0.5"; 1" effective)	-0.1954	0.4926	R1
12/18/78	6830/0930	no	no	no	/0834 (no effect?)	0.5220		R1
01/06/79	0756/1156	400/0923; 120F&B/1010	300 gal.	yes	/0937, /0940 (no effect)	-0.5948	0.4485	R1
01/11/79	1606/1706	no	no	no	2"/1738	-0.6163	0.7597	
02/02/79	1600/1700	no	no	no	2"/1614, 1620 (1.5" decayed; 0.5" effective)	0.3287	0.6727	R1
02/03/79	1615/1715	no	no	no	2"/1623 (0.5" effective)	0.4692	0.8132	R1

Table 7

Water Additions During RCS Leak Rate Test Without Entry Into the Computer

DATE	CLOCK TIME	WATER ADDITION			HYDROGEN ADDITION PSI/TIME	UNIDENTIFIED LEAK RATE, GPM		
		CHART GALLON/TIME	INCLUDED IN CALCULATION	CRO/SF LOG ENTRY		UNCORRECTED	CORRECTED	
04/30/78	1532/1632	165/1538 (MUT +1.3"; normal -2")	no	no	--	-1.8580	1.9260	R1
04/30/78	2321/0021 (05/01/78)	60/2335 (MUT +1" ; normal -1.5")	no	no	--	-0.9717	0.4044	R1
* 05/12/78	1643/1743	180/1732 (MUT +5"; normal -1")	no*	yes (70/1745)	--	-0.7443	0.6337	R1
05/26/78	1655/1756	90/1753(jogged) (MUT +0.4"; normal -3")	no	no	--	-0.7518	1.4498	R1
06/21/78	0341/0441	30/0410,90/0425 (MUT -6"; normal -11")	no	yes	--	0.9421	1.6301	R1
? 08/29/78	1547/1647	240/1548 () (MUT+0.3"; normal-1" : 15 gal. effective)	no	no	--	-0.0673	0.2767	R1
09/08/78	1629/1729	60/1705 (MUT +1.3"; normal -1")	no	no	--	-0.5823	0.7937	R1
09/11/78	1825/1925	60/1840-50(jogged) (MUT +2.6"; normal -2")	no	no	--	-0.5862	0.7898	R1
09/15/78	0921/1021	45/1010-20(jogged) (MUT +0.3"; normal -1")	no	no	--	-0.5503	0.4817	R1
? 09/18/78	2035/2136	45/2100(jogged)	no	no	--	-0.4265	0.6055	R1
10/17/78	1201/1301	60 /1240-1303(jogged)	no	no	--	-0.4581	0.9179	R1
** 12/13/78	1842/1942	270/1920 (MUT +8.3"; normal -1")	no**	yes	--	-0.2170	0.1417	R1
01/06/79	0756/1156	400/0923;120F&B/1010	300 gal.	yes	/0937,/0940 (no effect)	-0.5948	0.4485	R1
01/18/79	0401/0501	60/0450(jogged) (MUT +1.1"; normal -1")	no	no	--	-0.6938	0.6824	R1

? : questionable

* : RCDT drained ; 165 gal. @ 579°F

** : RCDT drained ; 350 gal. @ 579°F

6.0 Effects of Reactor Coolant Drain Tank (RCDT) Level Inputs on Leak Rate Test Results

6.1 Discussion

The Reactor Coolant Drain Tank collects the effluent or leakage from the pressurizer PORV and code safety valves. It also collects leakage past the reactor coolant pumps primary mechanical seal. The tank fluid can be circulated through a cooler and returned to the tank by spraying into the tank vapor space. The RCDT also has a connection to the Reactor Building Sump. Surveillance Procedure SP 1303-1.1, Revision 7 (effective revision during 1978-79), treated the water level change in the RCDT as a loss of Reactor coolant covered by Technical Specification 3.1.6.8. Therefore this was not subject to the 10 gpm limit of total RCS leakage. This treatment of RCDT water would allow leakage through relief and safety valves and reactor coolant pump seals to approach a 30 gpm limit.

6.2 Findings Regarding RCDT Level Inputs

When an operator took an action such as pumping out water from the RCDT, this action is required to be logged in the CRO shift log. As listed in Table 8, the RCDT tank levels were decreased substantially according to the surveillance records of leak rate tests; yet, no entries in the SRO or CRO logs were identified reporting the cause for the apparent large volume of water removed from the RCDT. An unaccounted water removal from the RCDT would result in conservative values of calculated gross leakage rate. These are additional apparent failures to follow procedural requirements concerning required log entries.

Based on the computer printouts of surveillance results, Table 9 lists those RCDT level changes greater than 60 gallons of water during the review period. The last column of Table 9 demonstrates the substantial effect of RCDT level changes on identified leak rates.

R1

R1
R1

NOTE:

ATTACHMENTS A, B, AND C TO ORIGINAL REPORT HAVE BEEN REVISED TO
REFLECT CHANGES NOTED IN THE REVISED REPORT. COPIES OF THE
REVISED ATTACHMENTS ARE VOLUMINOUS AND ARE NOT INCLUDED HERE.

| R1

| R1

| R1