

Docket No. 50-336  
B15422

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

Proposed Revision to Technical Specifications  
One-Time Only A.C. Sources Allowed Outage Time Extension

Marked-up Pages

November 1995

9511130263 951102  
PDR ADOCK 05000336  
P PDR

6/14/94

## 3/4.8 ELECTRICAL POWER SYSTEMS

### 3/4.8.1 A.C. SOURCES

#### OPERATING

#### LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the switchyard, and
- b. Two separate and independent diesel generators each with a separate fuel oil supply tank containing a minimum of 12,000 gallons of fuel.

APPLICABILITY: MODES, 1, 2, 3 and 4.

#### ACTION:

- a. With one offsite circuit inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1 within 1 hour and at least once per 8 hours thereafter. If either diesel generator has not been successfully tested within the past 24 hours, demonstrate its OPERABILITY by performing Surveillance Requirement 4.8.1.1.2.a.2 separately for each such diesel generator within 24 hours. Restore the offsite circuit to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one diesel generator inoperable, demonstrate the OPERABILITY of the A.C. offsite sources by performing Surveillance Requirement 4.8.1.1.1 within 1 hour and at least once per 8 hours thereafter; and if the diesel generator became inoperable due to any cause other than preplanned preventative maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE diesel generator by performing Surveillance Requirement 4.8.1.1.2.a.2 within 24 hours\*; restore the diesel generator to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

\*\* Except that once during the Millstone Unit No.1 Cycle 15 Refueling Outage, this 72 hour Allowed Outage Time can be extended to 7 days.

\*This test is required to be completed regardless of when the inoperable diesel generator is restored to an OPERABLE status.

Docket No. 50-336  
B15422

Attachment 3

Millstone Nuclear Power Station, Unit No. 2

Proposed Revision to Technical Specifications  
One-Time Only A.C. Sources Allowed Outage Time Extension

Retyped Version of Current Technical Specifications

November 1995

## 3/4.8 ELECTRICAL POWER SYSTEMS

### 3/4.8.1 A.C. SOURCES

#### OPERATING

#### LIMITING CONDITION FOR OPERATION

---

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the switchyard, and
- b. Two separate and independent diesel generators each with a separate fuel oil supply tank containing a minimum of 12,000 gallons of fuel.

APPLICABILITY: MODES, 1, 2, 3 and 4.

#### ACTION:

- a. With one offsite circuit inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1 within 1 hour and at least once per 8 hours thereafter. If either diesel generator has not been successfully tested within the past 24 hours, demonstrate its OPERABILITY by performing Surveillance Requirement 4.8.1.1.2.a.2 separately for each such diesel generator within 24 hours. Restore the offsite circuit to OPERABLE status within 72 hours\*\* or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one diesel generator inoperable, demonstrate the OPERABILITY of the A.C. offsite sources by performing Surveillance Requirement 4.8.1.1.1 within 1 hour and at least once per 8 hours thereafter; and if the diesel generator became inoperable due to any cause other than preplanned preventative maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE diesel generator by performing Surveillance Requirement 4.8.1.1.2.a.2 within 24 hours\*; restore the diesel generator to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

---

\*This test is required to be completed regardless of when the inoperable diesel generator is restored to an OPERABLE status.

\*\*Except that once during the Millstone Unit No. 1 Cycle 15 Refueling Outage, this 72 hour Allowed Outage Time can be extended to 7 days.