

ENCLOSURE 1

NRC DOCKET 50-321
OPERATING LICENSE DPR-57
EDWIN I. HATCH NUCLEAR PLANT UNIT 1
REQUEST TO AMEND TECHNICAL SPECIFICATIONS

The proposed change to the Unit 1 Technical Specifications (Appendix A to Operating License DPR-57) would be incorporated as follows:

Insert Page

6-22

ADMINISTRATIVE CONTROL

6.15 POST-ACCIDENT SAMPLING AND ANALYSIS

A program shall be established, implemented, and maintained to ensure the capability to obtain and analyze samples of reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere under accident conditions.

The program shall include the following:

- (1) Training of personnel,
- (2) Procedures for sampling and analysis, and
- (3) Provisions for maintenance of sampling and analysis equipment.

ENCLOSURE 2

NRC DOCKET 50-366
OPERATING LICENSE NPF-5
EDWI: I. HATCH NUCLEAR PLANT UNIT 2
REQUEST TO AMEND TECHNICAL SPECIFICATIONS

The proposed change to the Unit 2 Technical Specifications (Appendix A to Operating License NPF-5) would be incorporated as follows:

Remove Page

6-20

Insert Page

6-20

ADMINISTRATIVE CONTROL

6.14 IODINE MONITORING

The licensee shall implement a program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas* under accident conditions. This program shall include the following:

- (1) Training of personnel,
- (2) Procedures for monitoring, and
- (3) Provisions for maintenance of sampling and analysis equipment.

6.15 POST-ACCIDENT SAMPLING AND ANALYSIS

A program shall be established, implemented and maintained to ensure the capability to obtain and analyze samples of reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere under accident conditions. The program shall include the following:

- (1) Training of personnel,
- (2) Procedures for sampling and analysis, and
- (3) Provisions for maintenance of sampling and analysis equipment.

*Areas requiring personnel access for establishing hot shutdown condition.

ENCLOSURE 3

NRC DOCKETS 50-321, 50-366
OPERATING LICENSES DPR-57, NPF-5
EDWIN I. HATCH NUCLEAR PLANT UNITS 1, 2
REQUEST TO AMEND TECHNICAL SPECIFICATIONS

Pursuant to 10 CFR 50.92, Georgia Power Company has evaluated the attached proposed amendments and has determined that their adoption would not involve a significant hazard. The basis for this determination is as follows:

a. PROPOSED CHANGE

Add the following to the Units 1 and 2 Administrative Technical Specifications:

"A program shall be established, implemented, and maintained to ensure the capability to obtain and analyze samples of reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere under accident conditions. The program shall include the following:

- (1) Training of personnel,
- (2) Procedure for sampling and analysis, and
- (3) Provisions for maintenance of sampling and analysis equipment."

BASIS

This change constitutes an additional control not presently included in the Technical Specifications. This change does not affect the probability or consequences of an accident or malfunction analyzed in the FSAR. This change does not create the possibility of an accident or malfunction of a different type than any analyzed in the FSAR. The margin of safety as defined in the basis for any Technical Specification is not affected. The effect of this change is therefore within the acceptance criteria and the change is consistent with Item (ii) of "Examples of Amendments that are Considered Not Likely to Involve Significant Hazards Considerations" listed on page 14,870 of the April 6, 1983 issue of the Federal Register.