

AUG 24 1988

Docket No. 50-336
File RI-88-A-0067

[REDACTED]

Dear [REDACTED]

This letter addresses the June 10, 1988, concern you reported to the NRC Senior Resident Inspector about a truck trailer parked in downtown New London and posted with "RADIOACTIVE" markings.

On the day of your report, the NRC staff requested and received technical assistance from Northeast Utilities. That afternoon, the utility conducted, in the presence of an NRC inspector, a comprehensive radiation survey of the trailer. The survey, which looked for both airborne and surface contamination, found no radiation. The NRC inspector reported the results of the investigation to the manager of the furniture store and to this office. We concluded that no additional follow-up is needed and have closed out this matter.

Thank you for reporting this potential problem. If you have any additional information or questions for the NRC, please contact me.

Sincerely,
*Original signed by
Ebe C McCabe Jr.*

Ebe C. McCabe, Jr., Chief
Reactor Projects Section 1B
Division of Reactor Projects
Telephone: (215) 337-5231

bcc
W. Raymond
A. Shropshire
S. Barr

RI:DRP
EMcCabe/cph
R
8/27/88

RI:DRP
LBettenhausen
8/22/88

6/28

Enclosure 3

Allegation Package for Section Chiefs

ALLEGATION RECEIPT REPORT

Date/Time Received: October 7 / 2:00 p.m

Allegation No. 101
(leave blank)

Name: [Redacted]

Address: [Redacted]

Phone: _____

City/State/Zip: [Redacted]

Confidentiality Requested: Yes ___ No Implied ___

Allegor's Employer: Northeast Nuclear Energy Company

Position/Title: Instrument and Control Tech.

Facility: Millstone Unit 2

Docket No.: 50-336

Allegation Summary (brief description of concern(s)): ① Change to procedure IC 1104A, currently changed does not accurately reflect wear, sticking or crystallization of bourdon tube ② These gauges calibrated to manufacturer spec (nominal value), not reading on increasing
Number of Concerns: 2 (For Allegation Panel Only) direction

Employee Receiving Allegation: Peter J. Habighorst
(first two initials and last name)

Type of Regulated Activity: (a) Reactor (d) ___ Safeguards
(b) ___ Vendor (e) ___ Other: _____
(c) ___ Materials (Specify)

Materials License No. (if applicable): _____

Functional Area(s): (a) Operations (e) Emergency Preparedness
___ (b) Construction (f) Onsite Health and Safety
___ (c) Safeguards (g) Offsite Health and Safety
___ (d) Transportation (h) Other: _____

* See memo inclosed.

6/29