

MEMORANDUM FOR: Ebe McCabe, Section Chief, DRF 'B  
FROM: Resident Inspector Millstone Unit 2  
SUBJECT: MEETING WITH [REDACTED] ON OCTOBER 12

At 9:00 a.m. on October 12, the resident inspector discussed clarification on the initial allegation received (October 7) from Millstone 2 I&C technician [REDACTED]. The resident questioned the aleger on when the technical concerns were addressed to licensee management.

[REDACTED] Within this meeting, the aleger points out that he informed the unit superintendent of the two basic concerns of: (i) adequacy of I/C1104A procedure revision, ii) the discrepancy between manufacturers recommended tolerances and data from I/C 1104A tolerances for heise gauge pressure instruments. The aleger did not discuss the above concerns with his immediate supervisor and Millstone 2 I/C department head. When questioned why the concerns were not discussed, the aleger was quick to point out that licensee management doesn't want to hear his story, based on past meetings with NRC representatives. The inspector questioned the licensee on why the new licensee allegation procedure was not used. The aleger has never used the system because his belief is that his confidentiality would be compromised and he feels that repercussions from management would occur. The aleger's belief is that because of the nature of the isolate/specific concerns, he would be identified as the source of those concerns.

On the technical justification for the aleger's concern with the new procedure is: the past metrology lab technician who developed the original IC1104A procedure had (20+) years of Navy calibration lab experience and the aleger's reported past Instrument Non-Conformance Reports (ICR) (2 to 3) in his (18+ month) work in the metrology lab on heise pressure gauges. The ICR's reported deviations on downscale pressure readings, not at mid-scale position. (New procedure only verifies mid-scale point.)

The aleger actively accuses the current metrology lab technician of not knowing what he is doing, specifically concerning the metrology preparation/authorship of the revised IC1104A; and general overall activities within the measurement and testing lab.

The inspector challenged the aleger's specific technical justifications of the old and revised IC1104A calibration procedure. The inspector pointed out to the aleger the heise gauge model CM and CMM manufacturer's technical manual description of how to test for hysteresis/crystallization inside bourdon tubes and conclusively the new procedure reflection on manufacturer's recommendation. The aleger still concludes, "Instruments that are out-of-calibration will pass the new IC1104A procedure."

9203110324 910821  
PDR FOIA PDR  
QUILD91-162

The inspector plans to review in detail old/new 1104A procedure, and to review the aleger's second concern on manufacturer's tolerance vs. 1104A procedure tolerance values. The initial review will be completed by October 18, 1988.

PETER HABIGHORST

ALLEGATION RECEIPT REPORTDate/Time Received: October 21 / 1:30 p.m.Allegation No. RI-88-A-0121  
(Leave blank)Name:       Address:       Phone:       City/State/Zip:       Confidentiality Requested: Yes       No X Implied       Allegor's Employer: Northeast Utilities  
(NUSCO)Position/Title:       Facility: Connecticut Yankee I  
Millstone IDocket No.:         
50-245(Allegation Summary (brief description of concern(s)):  
      Monitoring system (2) why licensee  
did not report this "wrong doing" to the  
NRCNature of Concerns:        4       Employee Receiving Allegation: Peter J Habighorst Scott Barber <sup>(4) On the job harassment by the project engineer</sup>  
(first two initials and last name)Type of Regulated Activity (a) X Reactor  
(b)        Vendor  
(c)        Materials(d)        Safeguards  
(e)        Other:  
(Specify) \_\_\_\_\_

Materials License No. (if applicable): \_\_\_\_\_

Functional Area(s): X (a) Operations  
       (b) Construction  
       (c) Safeguards  
       (d) Transportation       (e) Emergency Preparedness  
       (f) Onsite Health and Safety  
       (g) Offsite Health and Safety  
       (h) Other:  
\_\_\_\_\_  
\_\_\_\_\_

[Redacted] is Description of Allegation [Redacted] [Redacted]  
alleged contacted NPPD/MPS President & Projectors  
in their office regarding a problem with the  
fabrication of a Loose Part Monitoring System  
for Connecticut Yankee (CY).

'installing/damaging special cables that were  
ordered for the project' [Redacted]

[Redacted] The  
employee stated that he was indicated  
by the manufacturer's representative who [Redacted] (art [Redacted] BKR  
inspected the cable and determined the flaws  
were due to poor manufacturing. He believes  
new cables were ordered and the LPM system  
was upgraded prior to installation at CY.

Third Description of Allegations:

The inspector informed the allegor.

The allegor did not receive management feedback on the initial allegation directed towards him, or an apparent apology from the licensee.

The inspector provided the allegor a copy of the DOL regulations for filing a complaint.

Currently, the allegor is assigned once again with the affected P.E. on Millstone 1 loose parts monitoring system. He fears for his job and stability of such with the ~~and~~ received harassment in the past.