

C. Williams



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to Post Office Box 787
Chicago, Illinois 60690

August 3, 1984

Mr. James G. Keppler
Regional Administrator
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: LaSalle County Station Unit 2
Supplemental Response to Inspection
Report No. 50-374/84-04
NRC Docket No. 30-374

References (a): W. S. Little letter to Cordell Reed
dated April 24, 1984.

(b): D. L. Farrar letter to J. G. Keppler
dated May 22 and June 14, 1984.

Dear Mr. Keppler:

A meeting was held at Region III between Commonwealth Edison personnel and Messrs. R. Walker, W. Guldmond, C. Williams, et. al. of your staff. During this meeting, Commonwealth Edison proposed an alternative method to satisfy the NRC requirement contained in item 2.C of reference (a). This letter documents our commitment made during that meeting.

1. LaSalle County Station will incorporate into administrative procedures cautions stating the color of control indicating lights have been changed in the field to implement the "green board" concept and may not match the colors shown on drawings.
2. Administrative procedures governing modifications, work requests, and post maintenance testing will be revised to include the cautions necessary to prevent inadvertent compromise of green board concept due possible differences in control light color arrangements shown on drawings.
3. The green board concept and the resulting deviation from control light color arrangements shown on drawings will be included in an annual operator training module and in the station retraining program.
4. The above commitments are applicable to LaSalle County Station and to any other CECO Nuclear Generating Station which elects to implement the green board concept without revision of appropriate drawing control light color arrangements.

J. G. Keppler

- 2 -

AUGUST 3, 1984

We expect to complete the above procedure and training program revisions by October 1, 1984.

If you have any questions regarding this matter, please contact this office.

Very truly yours,



D. L. Farrar
Director of Nuclear Licensing

lm

9015N



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

August 3, 1984

Mr. James G. Keppler
Regional Administrator
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: LaSalle County Station Unit 2
Supplemental Reponse to Inspection
Report No. 50-374/84-04
NRC Docket No. 50-374

References (a): W. S. Little letter to Cordell Reed
dated April 24, 1984.

(b): D. L. Farrar letter to J. G. Keppler
dated May 22 and June 14, 1984.

Dear Mr. Keppler:

A meeting was held at Region III between Commonwealth Edison personnel and Messrs. R. Walker, W. Guldemon, C. Williams, et. al. of your staff. During this meeting, Commonwealth Edison proposed an alternative method to satisfy the NRC requirement contained in item 2.C of reference (a). This letter documents our commitment made during that meeting.

1. LaSalle County Station will incorporate into administrative procedures cautions stating the colors of control indicating lights have been changed in the field to implement the "green board" concept and may not match the colors shown on drawings.
2. Administrative procedures governing modifications, work requests, and post maintenance testing will be revised to include the cautions necessary to prevent inadvertant compromise of green board concept due possible differences in control light color arrangements shown on drawings.
3. The green board concept and the resulting deviation from control light color arrangements shown on drawings will be included in an annual operator training module and in the station retraining program.
4. The above commitments are applicable to LaSalle County Station and to any other CECO Nuclear Generating Station which elects to implement the green board concept without revision of appropriate drawing control light color arrangements.

AUG 8 1984

J. G. Keppler


- 2 -

August 3, 1984

We expect to complete the above procedure and training program revisions by October 1, 1984.

If you have any questions regarding this matter, please contact this office.

Very truly yours,

A handwritten signature in cursive script, appearing to read "D. L. Farrar".

D. L. Farrar
Director of Nuclear Licensing

lm

9015N