

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

March 4, 1992

Docket No. 50-364

Mr. W. G. Hairston, III Senior Vice President Southern Nuclear Operating Company, Inc. Post Office Box 1295 Birmingham, Alabama 35201-1295

Dear Mr. Hairston:

03120308 92030

SUBJECT: REQUEST FOR APPROVAL TO USE ASME CODE CASE N-498 AT JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 2 (TAC NO. M82836)

By letter dated February 24, 1992, you requested approval for the implementation of the alternative rules of Section XI of the ASME Code Case N-498, entitled "Alternative Rules for 10-Year Hydrostatic Pressure Testing for Class 1 and 2 Systems, Section XI, Division 1." Approval was requested to apply the Code Case to Joseph M. Farley Nuclear Plant, Unit 2, during the outage scheduled to begin on March 6, 1992.

ASME Code Case N-498 has been reviewed and found acceptable by the staff and will be included in the next revision of Regulatory Guide 1.147. If these alternate rules cannot be applied to a Class 1 or 2 system or component, the normal rules for the 10year hydrostatic test must be followed. The staff has determined that the granting of this relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Accordingly, pursuant to 10 CFR 50.55(a)(3)(i), the relief is granted based on the finding that the use of Code Case N-498 provides an acceptable level of guality and safety.

Your February 24, 1992, letter also discussed the steam generator 2C upper transition cone-to-shell weld indication found during the Unit 2 seventh refueling outage. As indicated by your letter, the steam generator 2C system leakage test should be performed at a minimum temperature of 100°F.

Sincerely,

Elinor G. Adensam, Director Project Directorate II-1 Division of Reactor Projects - I/II Office of Nuclear Reactor

Regulation

cc: See next page

DISTRIBUTION Docket File NRC & Local PDRs PD21 Reading File SVarga GLainas EAdensam SHoffman PAnderson OGC JWiggins ACRS (10) LReyes RII

*See previous concurrence

OFFICE:	LA: POPIL	PM: PD21	EMCB*	OGC*	D:,PD21
NAME:	PAnderson	SHOPTHAN	JWiggins	JMoore	EAdensam
DATE:	3 14 192	314192	3/2/92	3/4/92	\$ 14 192

FA282836.ltr

Mr. W. G. Hairston, III Southern Nuclear Operating Company, Inc.

CC:

Mr. R. P. McDonald President Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

Mr. J. D. Woodard Vice-President-Farley Project Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

Mr. L. B. Long, Vice President-Technical Services Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

Mr. D. N. Morey General Manager - Farley Nuclear Plant Southern Nuclear Operating Company, Inc. P. O. Box 470 Ashford, Alabama 36312

Mr. B. L. Moore Manager, Licensing Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

Mr. J. W. McGowan Manager, Safety Audit and Engineering Review Southern Nuclear Operating Company, Inc. P. O. Box 1295 Birmingham, Alabama 35201-1295

James H. Miller, III, Esq. Balch and Bingham P. O. Box 306 1710 Sixth Avenue North Birmingham, Alabama 35201 Joseph M. Farley Nuclear Plant

Claude Earl Fox, M.D. State Health Officer State Department of Public Health State Office Building Montgomery, Alabama 36130

Chairman Houston County Commission P. O. Box 6406 Dothan, Alabama 36302

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, Suite 2900 Atlanta, Georgia 30323

Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 24 - Route 2 Columbia, Alabama 36319