

Cooper Industries  
Cooper-Bessemer Reciprocating Products Division  
150 Lincoln Avenue  
Grove City, PA 16127-1699  
412 406-1000



March 2, 1992

Our Ref: QCG-8729

Mr. Walter Haass  
U. S. Nuclear Regulatory Commission  
One White Flint North  
Mailstop 9D4  
Washington, D.C. 20555

Ref: Cooper Nuclear Station 10 CFR 21  
NRC Docket No. 50-298, DPR-46

Dear Mr. Haass:

The purpose of this letter is to define Cooper Energy Services actions concerning the above referenced 10 CFR Part 21 Report.

**History:**

The KSV-16-T diesel generating units supplied to Nebraska Public Power District (NPPD), Cooper Nuclear Station, were furnished by Cooper Energy Services (CES) as commercial units and had not gone through a safety-related classification process. The Amot Valve (Amot Part No. 1475B0212A3) was originally supplied by Cooper as part number 2-05V-153-004 in overspeed shutdown assembly KSV-72-7.

**Discussion:**

The subject valve was supplied to NPPD's Cooper Nuclear Station, and Commonwealth Edison Company's (CECO) Zion Station in the overspeed shutdown assembly as a "commercial" item. This valve has not been supplied to any other nuclear facility by Cooper Bessemer. The valve was obsoleted with no replacement November 1, 1989, as the manufacturer has discontinued production of this valve. Note that an alternate assembly is available.

**Cooper Industries Action:**

No further action is planned. Notification of all affected utilities was accomplished by NPPD's report (attached).


9203130051 920302  
PDR ADOCK 05000298  
S PDR

JE19 1/0

Page 2  
OCG-8729  
March 2, 1992

Please contact Andrew P. Steffan (412-458-3455) or myself, if you have any questions or comments on this matter.

Sincerely,



J. R. Schneider  
Manager, Quality Assurance  
and Nuclear Operations

Attachment

cc: H. A. LaBrun  
A. P. Steffan  
Terry O'Brien - CECD  
G. R. Horn - NPPD  
A. G. Killinger - MPR Assoc.  
K5fb39 - Part 21 Eval.  
K-6e Amot Control Corp.