

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

March 9, 1992

VIA TELECOPIER

Docket Nos. 50-424 and 50-425

> Mr. W. G Hairston, III Senior Vice President -Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING CALCON SENSORS, VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2 (TACS M82914/M82915)

By its Memorandum And Order of February 12, 1992 (CLI-92-03), the Commission dismissed an appeal and denied a petition for intervention by Georgians Against Nuclear Energy (GANE) in the adjudicatory proceeding regarding licensing amendments on the Vogtle facility. The amendments authorized bypassing Calcon sensors used for the high jacket water temperature (HJWT) trip of the diesel generators for unplanned starts. The Commission also noted that certain related issues of interest would be directed to the NRC staff in a separate Staff Requirements Memorandum in the near future.

Subsequently, on February 27, 1992, the Commission requested information on three issues and forwarded a communication from GANE dated February 13, 1992, for appropriate response by the NRC staff. To respond to the Commission's request, we require additional information, requested by the enclosure, regarding the current status and results of your previously identified plans and commitments regarding diesel generator instrumentation.

To meet our scheduled response date, your response is requested by March 12, 1992, by expedited mail.

NRC FILE CENTER COPY

W. G. Hairston, III -2- March 9, 1992

11

If you have questions regarding this matter or are unable to meet this schedule, contact me at (301) 504-3049. This requirement affects fewer than ten respondents, and therefore, is not subject to Office of Management and Budget review under P. L. 96-511.

Sincerely,

DARL HOOD

Darl S. Hood, Project Manager Project Directorate II-3 Division of Reactor Projects-I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure: See next page

Mr. W. G. Hairston, III Georgia Power Company

cc: Mr. J. A. Bailey Manager - Licensing Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. W. B. Shipman General Manager, Vogtle Electric Generating Plant P. O. Box 1600 Waynesboro, Georgia 30830

Regional Administrator, Region 11 U. S. Nuclear Regulatory Commission 101 Marietta Street, NW., Suite 2900 Atlanta, Georgia 30323

Office of Planning and Budget Room 615B 270 Washington Street, SW. Atlanta, Georgia 30334

Mr. C. K. McCoy Vice President - Nuclear Vogtle Project Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. R. P. McDonald Executive Vice President -Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Office of the County Commissioner Burke County Commission Waynesboro, Georgia 30830 Vogtle Electric Generating Plant

Harold Reheis, Director Department of Natural Resources 205 Butler Street, SE. Suite 1252 Atlanta, Georgia 30334

Attorney General Law Department 132 Judicial Building Atlanta, Georgia 30334

Mr. Alan R. Herdt Project Branch #3 U. S. Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Mr. Dan Smith Program Director of Power Production Oglethorpe Power Corporation 2100 East Exchange Place Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire Paul, Hastings, Janofsky & Walker 12th Floor 1050 Connecticut Avenue, NW. Washington, DC 20036

Art Domby, Esquire Troutman, Sanders, Lockerman and Ashmore 127 Peachtree Street Atlanta, Georgia 30303-1810

Enclosure

REQUEST FOR ADDITIONAL INFORMATION REGARDING USE OF CALCON SENSORS AT VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2

1. On February 27, 1992, the Commission requested that:

The staff should inform the Commission whether the licensee has replaced or plans to replace the Calcon pneumatic sensors used in Vogtle's diesel generator (DG) instrumentation. In this regard, the Commission notes that various documents filed before the Licensing Board indicate that the licensee was considering replacement of the sensors. If the Calcon sensors have not been replaced, the staff should explain the rationale for the continued acceptability of the sensors.

We request that you inform us of the considerations that you gave to replacing the Calcon sensors used on Vogtle's DGs, the conclusions reached, and the bases for your conclusions. Include in your discussion any changes made or planned that affect the quantity, the manner of use, or reliability of Calcon sensors at Vogtle.

- 2. In your letter of January 10, 1991, you stated that Georgia Power Company was pursuing a change in the mannner of bypassing the HJWT trip by implementing an automatic bypass on emergency starts of the DGs. Please discuss the results of your study, the subsequent instrumentation design, and its implementation status.
- 3. You also indicated during the course of the earlier prehearing activities that consideration would be given to an alternate starting logic for the DGs. Please describe the results of this study, including the bases for your conclusions.

W. G. Hairston, III

-2- March 9, 1992

If you have questions regarding this matter or are unable to meet this schedule, contact me at (301) 504-3049. This requirement affects fewer than ten respondents, and therefore, is not subject to Office of Management and Budget review under P. L. 96-511.

Sincerely,

ORIGINAL SIGNED BY: Darl S. Hood, Project Manager Project Directorate II-3 Division of Reactor Projects-I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure: See next page

DISTRIBUTION: See next page

PM: PDII-3 DHood _P3/1 3/9/92

DNatthews /92

OFFICIAL RECORD COPY PC Document Name: Calcon

Distribution:	
Docket File	
NRC PDR	
Local FDR	
PDII-3 R/F	
S. Varga	14-E-1
G. Lainas	14 - H - 1
D. Matthews	14-H-25
L. Berry	14-H-25
D. Hood	14-H-25
OGC-WF	15-B-18
E. Jordan	MNBB-3302
ACRS (10)	P=315
G.Galletti	
F. Rosa	7 - E - 4
A. Gill	7 - E - 4
O. Chopra	7 - E - 4
C. Barth	15-B-18