

AUG 10 1984


Docket No. 50-483

Union Electric Company
ATTN: Mr. Donald F. Schnell
Vice President - Nuclear
Post Office Box 149 - Mail Code 400
St. Louis, MO 63166
Gentlemen:

Thank you for your letter dated July 24, 1984, informing us of the steps you have taken to correct the noncompliance which we brought to your attention in Inspection Report No. 50-483/84-23 forwarded by our letter dated June 25, 1984. It is our understanding that in a telephone conversation with Mr. VanDenburgh of our staff, you agreed to evaluate the emergency boration flow with respect to the adequacy of the scaling of meters BG-FI-183A and BG-FI-183B. We will examine these matters during a subsequent inspection.

Your cooperation with us is appreciated.

Sincerely,



R. L. Spessard, Director
Division of Reactor Safety

cc: W. H. Weber, Manager, Nuclear
Construction
S. E. Miltenberger, Plant Manager
R. L. Powers, Assistant Manager
Quality Assurance

cc w/ltr dtd 7/24/84:
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Region IV
K. Drey
Chris R. Rogers, P.E.
Utility Division, Missouri
Public Service Commission

RIII CKV Wohld/1c 8-9-84 VanDenburgh 8-9-84	RIII CKV Eng 8-9-84	RIII CKV Williams 8-9-84	RIII CKV Farber 8-9-84	RIII PP for Forney 8/9/84	RIII CKV Reyes 8/9	RIII CKV Walker 8/9	RIII CKV Spessard 8/9
--	------------------------------	-----------------------------------	---------------------------------	------------------------------------	-----------------------------	------------------------------	--------------------------------

1501

8408140402 840810
PDR ADDCK 05000483
PDR

41