

APPENDIX A  
NOTICE OF VIOLATION

Northeast Nuclear Energy Company  
Waterford, Connecticut  
Millstone Unit No. 3

Docket 50-423  
License No. NPF-49

During an NRC inspection conducted on December 9-13, 1991, one violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1991), the violation is listed below:

10 CFR 50.71(e) States in part that, " Each person licensed to operate a nuclear power reactor pursuant to the provisions of 50.21 or 50.22 of this part shall update periodically, as provided in paragraphs (e)(3) and (4) of this section, the final safety analysis report (FSAR) originally submitted as part of the application for the operating license, to assure that the information included in the FSAR contains the latest material developed."

Contrary to the above, as of December 13, 1991 the licensee did not update the final safety analysis report (FSAR) Table 9.2-1, "Service Water System Flow Requirements," was not updated when the licensee revised the minimum service water flow requirements in 1985 to assure that the information included in the FSAR contained the latest material developed.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Northeast Nuclear Energy Company is hereby required to submit a written statement or explanation to the U. S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region I, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice of Violation within 30 days of the receipt date of the letter transmitting this Notice of Violation. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, consideration will be given to extending the response time.