



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
475 ALLENDALE ROAD  
KING OF PRUSSIA, PENNSYLVANIA 19406

JUN 08 1988

Docket No. 50-336  
File RI-88-A-005

[REDACTED]  
Dear [REDACTED]

The purpose of this letter is to inform you of our findings on your January 13, 1988 allegation made to Mr. W. Thomas of this office.

The allegation, as we understand it, was that persons assigned to serve as fire watches for you had expired qualifications. You also alleged that, in one case, a fire watch did not have access to all of the area to which he was assigned.

Your allegation has been examined onsite by the Millstone resident inspectors. No cases such as those you alleged were found. Our review found proper fire watch qualifications and access in all cases checked. Also, the program for qualification and assignment of fire watches has been found acceptable by NRC inspection.

Attempts to contact you on site to discuss your allegation were unsuccessful. However, based upon the above, unless we receive further specifics warranting follow-up, we will close your allegation as unsubstantiated.

Thank you for addressing your concern to us. If you have further information or input for the NRC, please contact me.

Sincerely,

*Ebe C. McCabe, Jr.*  
Ebe C. McCabe, Jr., Chief  
Reactor Projects Section 1B  
Division of Reactor Projects  
Tel: (215) 337-5231

bcc:  
W. Raymond  
A. Shropshire ✓

6/2