



PEACH BOTTOM—THE POWER OF EXCELLENCE

PHILADELPHIA ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION

R. D. 1, Box 208
Delta, Pennsylvania 17514

(717) 456-7014

D. B. Miller, Jr.
Vice President

March 13, 1992

Docket Nos. 50-277
50-278

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station Monthly Operating Report

Gentlemen:

Enclosed are twelve copies of the monthly operating report for Peach Bottom Units 2 and 3 for the month of February 1992 forwarded pursuant to Technical Specification 6.9.1.d under the guidance of Regulatory Guide 10.1, Revision 4.

Sincerely,

^{MJB}
DBM/AA+/TJN/DRM/MJB:cmc

Enclosure

- cc: R.A. Burricelli, Public Service Electric & Gas
- T.M. Gerusky, Commonwealth of Pennsylvania
- J. Lyash, USNRC Senior Resident Inspector
- R.I. McLean, State of Maryland
- T.T. Martin, Administrator, Region I, USNRC
- H.C. Schwemm, Atlantic Electric
- C.D. Schaefer, Delmarva Power
- INPO Records Center

CC0292.NRC

9203170347 920229
PDR ADOCK 05000277
R PDR

NRC Monthly Operations Summary
Peach Bottom Atomic Power Station
February 1992

UNIT 2

Unit 2 began and ended the month at nominal 100% power with no major evolutions.

UNIT 3

Unit 3 began the month at nominal 100% power. On February 7, power was reduced to approximately 60% to conduct feedwater control modification testing. Power was again reduced on February 8 to regenerate condensate deaerators. Both power reductions were of short duration and power was restored without incident. Unit 3 completed the month at nominal 100% power.

UNIT 2 REFUELING INFORMATION

1. Name of facility:

Peach Bottom Unit 2

2. Scheduled date for next refueling shutdown:

Reload 9 scheduled for September 5, 1992.

3. Scheduled date for restart following refueling:

Restart following refueling forecast for November 20, 1992.

4. Will refueling or resumption of operation therefore require a technical specification change or other license amendment?

No.

If answer is yes, what, in general, will these be?

5. Scheduled date(s) for submitting proposed licensing action and supporting information:

N/A

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

N/A

UNIT 2 REFUELING INFORMATION (Continued)

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
- (a) Core - 764 Fuel Assemblies
 - (b) Fuel Pool - 1896 Fuel Assemblies, 58 Fuel Rods
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
- The spent fuel pool storage capacity has been relicensed for 3819 fuel assemblies.
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present capacity:
- September 2003 without full core offload capability.
 - September 1997 with full core offload capability.

UNIT 3 REFUELING INFORMATION

1. Name of facility:

Peach Bottom Unit 3

2. Scheduled date for next refueling shutdown:

Reload 9 scheduled for September 4, 1993

3. Scheduled date for restart following refueling:

Restart following refueling scheduled for October 29, 1993

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

No

If answer is yes, what, in general, will these be?

N/A

5. Scheduled date(s) for submitting proposed licensing action and supporting information:

N/A

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

N/A

UNIT 3 REFUELING INFORMATION (Continued)

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
 - (a) Core - 764 Fuel Assemblies
 - (b) Fuel Pool - 1689 Fuel Assemblies, 6 Fuel Rods

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:

The spent fuel pool storage capacity has been relicensed for 3819 fuel assemblies.

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present capacity:

September 2004 without full core offload capability.

September 1998 with full core offload capability.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 277

UNIT PEACH BOTTOM UNIT 2

DATE FEBRUARY 15, 1992

COMPANY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON

SUPERVISOR

REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION

TELEPHONE (717) 456-7014 EXT. 3321

MONTH FEBRUARY 1992

LINE	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	1071	17	1062
2	1071	18	1071
3	1067	19	1063
4	1070	20	1071
5	1075	21	1071
6	1070	22	1071
7	1070	23	1067
8	1070	24	1067
9	1070	25	1071
10	1066	26	1071
11	1066	27	1067
12	1070	28	1071
13	1066	29	1063
14	1066		
15	1067		
16	1075		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 278

UNIT PEACH BOTTOM UNIT 3

DATE FEBRUARY 15, 1992

COMPANY PHILADELPHIA ELECTRIC COMPANY

M. J. BARDON
SUPERVISOR
REPORTS GROUP
PEACH BOTTOM ATOMIC POWER STATION

TELEPHONE (717) 456-7014 EXT. 3321

MONTH FEBRUARY 1992

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	1062	17	1070
2	1062	18	1066
3	1066	19	1062
4	1062	20	1075
5	1070	21	1062
6	1062	22	1071
7	988	23	1067
8	752	24	1067
9	994	25	1066
10	1067	26	1067
11	1062	27	1062
12	1062	28	1062
13	1066	29	1063
14	1058		
15	1066		
16	1066		

OPERATING DATA REPORT

DOCKET NO. 50 - 277

DATE FEBRUARY 15, 1992

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
 SUPERVISOR
 REPORTS GROUP
 PEACH BOTTOM ATOMIC POWER STATION
 TELEPHONE (717) 456-7014 EXT. 3321

OPERATING STATUS

1. UNIT NAME: PEACH BOTTOM UNIT 2
2. REPORTING PERIOD: FEBRUARY, 1992
3. LICENSED THERMAL POWER(MWT): 3293
4. NAMEPLATE RATING (GROSS MWE): 1152
5. DESIGN ELECTRICAL RATING (NET MWE): 1065
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 1098
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 1055

NOTES:

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	696	1,440	154,776
12. NUMBER OF HOURS REACTOR WAS CRITICAL	696.0	1,440.0	93,694.0
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	696.0	1,440.0	90,277.5
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	2,279,928	4,699,392	267,239,121
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	764,300	1,576,000	87,864,590
18. NET ELECTRICAL ENERGY GENERATED (MWH)	743,908	1,532,610	84,149,843

DATE FEBRUARY 15, 1992

	THIS MONTH	YR-TO-DATE	CUMULATIVE
19. UNIT SERVICE FACTOR	100.0	100.0	58.3
20. UNIT AVAILABILITY FACTOR	100.0	100.0	58.3
21. UNIT CAPACITY FACTOR (USING MDC NET)	101.3	100.9	51.5
22. UNIT CAPACITY FACTOR (USING DER NET)	100.4	99.9	51.1
23. UNIT FORCED OUTAGE RATE	0.0	0.0	16.4

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY		09/16/73
INITIAL ELECTRICITY		02/18/74
COMMERCIAL OPERATION		07/05/74

OPERATING DATA REPORT

DOCKET NO. 50 - 278

DATE FEBRUARY 15, 1992

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON

SUPERVISOR

REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION

TELEPHONE (717) 456-7014 EXT. 3321

OPERATING STATUS

- 1. UNIT NAME: PEACH BOTTOM UNIT 3
- 2. REPORTING PERIOD: FEBRUARY, 1992
- 3. LICENSED THERMAL POWER (MWT): 3293
- 4. NAMEPLATE RATING (GROSS MWE): 1152
- 5. DESIGN ELECTRICAL RATING (NET MWE): 1065
- 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 1098
- 7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 1035

NOTES:

- 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
- 10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	696	1,640	150,672
12. NUMBER OF HOURS REACTOR WAS CRITICAL	696.0	1,413.6	91,775.7
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	696.0	1,237.4	88,542.4
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	2,248,368	3,437,232	259,531,162
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	750,300	1,147,800	85,150,332
18. NET ELECTRICAL ENERGY GENERATED (MWH)	730,183	1,113,372	81,596,389

 DATE FEBRUARY 15, 1992

	THIS MONTH	YR-TO-DATE	CUMULATIVE
19. UNIT SERVICE FACTOR	100.0	85.9	58.8
20. UNIT AVAILABILITY FACTOR	100.0	85.9	58.8
21. UNIT CAPACITY FACTOR (USING MDC NET)	101.4	74.7	52.3
22. UNIT CAPACITY FACTOR (USING DER NET)	98.5	72.6	50.8
23. UNIT FORCED OUTAGE RATE	0.0	1.0	12.6
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY	-----	08/07/74
INITIAL ELECTRICITY	-----	09/01/74
COMMERCIAL OPERATION	-----	12/23/74

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50 - 277

UNIT NAME PEACH BOTTOM UNIT 2

DATE FEBRUARY 15, 1992

REPORT MONTH FEBRUARY, 1992

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON

SUPERVISOR

REPORTS GROUP

PEACH BOTTOM ATOMIC POWER STATION

TELEPHONE (717) 456-7014 EXT. 3321

NO.	DATE	TYPE (1)	DURATION (HOURS) (1)	REASON (2)	METHOD OF SHUTTING DOWN REACTOR (3)	LICENSEE EVENT REPORT #	SYSTEM CODE (4)	COMPONENT CODE (5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE

- | | | | |
|-----------------------------|---|--|---|
| (1) | (2) | (3) | (4) |
| F - FORCED
S - SCHEDULED | REASON
A - EQUIPMENT FAILURE (EXPLAIN)
B - MAINTENANCE OR TEST
C - REFUELING
D - REGULATORY RESTRICTION
E - OPERATOR TRAINING + LICENSE EXAMINATION
F - ADMINISTRATIVE
G - OPERATIONAL ERROR (EXPLAIN)
H - OTHER(EXPLAIN) | METHOD
1 - MANUAL
2 - MANUAL SCRAM.
3 - AUTOMATIC SCRAM.
4 - OTHER (EXPLAIN) | EXHIBIT G - INSTRUCTIONS
FOR PREPARATION OF DATA
ENTRY SHEETS FOR LICENSEE
EVENT REPORT (LER)
FILE (NUREG-0161)

(5)

EXHIBIT I - SAME SOURCE |

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50 - 278

UNIT NAME PEACH BOTTOM UNIT 3

DATE FEBRUARY 15, 1992

REPORT MONTH FEBRUARY, 1992

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

M. J. BARON
SUPERVISOR
REPORTS GROUP
PEACH BOTTOM ATOMIC POWER STATION
TELEPHONE (717) 456-7014 EXT. 3321

NO.	DATE	TYPE (1)	DURATION (HOURS) (2)	REASON (2)	METHOD OF SHUTTING DOWN REACTOR (3)	LICENSEE EVENT REPORT #	SYSTEM CODE (4)	COMPONENT CODE (5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
8	920207	S	0.0	H	4	N/A	CH	HTEXCH	FEEDWATER LEVEL CONTROL TESTING
9	920209	F	0.0	A	4	N/A	WC	DEMIX	REGENERATE CONDENSATE DEMINS.

(1)
F - FORCED
S - SCHEDULED

(2)
REASON
A - EQUIPMENT FAILURE (EXPLAIN)
B - MAINTENANCE OR TEST
C - REFUELING
D - REGULATORY RESTRICTION
E - OPERATOR TRAINING + LICENSE EXAMINATION
F - ADMINISTRATIVE
G - OPERATIONAL ERROR (EXPLAIN)
H - OTHER(EXPLAIN)

(3)
METHOD
1 - MANUAL
2 - MANUAL SCRAM.
3 - AUTOMATIC SCRAM.
4 - OTHER (EXPLAIN)

(4)
EXHIBIT C - INSTRUCTIONS
FOR PREPARATION OF DATA
ENTRY SHEETS FOR LICENSEE
EVENT REPORT (LLR)
FILE (NUREG-0161)

(5)
EXHIBIT I - SAME SOURCE