

March 12, 1992

Docket Nos. 50-352  
and 50-353

Mr. George J. Beck  
Manager-Licensing, MC 52A-5  
Philadelphia Electric Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

SUBJECT: REMOVAL OF CYCLE SPECIFIC PARAMETER LIMITS, LIMERICK GENERATING  
STATION, UNITS 1 AND 2 (TSCR 89-13) (TAC NOS. M76053 AND M76054)

On May 15, 1990, we issued Amendments Nos. 37 and 4 to Facility Operating  
License Nos. 39 and 85, respectively. Page 3/4 3-60 of the Limerick, Unit 2  
revised Technical Specifications (TS) had a typographical error. The  
allowable value for the high flow clamped rod block monitor should have been  
N+3 rather than N-3. The Unit 1 TS value was correct. A corrected Unit 2  
page 3/4 3-60 and overleaf page 3/4 3-59 is enclosed. I regret any  
inconvenience this may have caused you. If you have any questions, please  
call me at (301) 504-1402.

Sincerely, Original signed by  
Richard J. Clark

Richard J. Clark, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

DISTRIBUTION

Docket File	RClark	Wanda Jones	RBlough, RGN-I
NRC & Local PDRs	MO'Brien(2)	CGrimes	LDoerflein, RGN-I
PDI-2 Reading	OGC	ACRS(10)	
SVarga/JCalvo	DHagan	OPA	
CMiller	GHill(8)	OC/LFMB	

OFFICE	PDI-2/LA	PDI-2/PM	PDI-2/D		
NAME	MO'Brien	RClark:rb	CMiller		
DATE	3/17/92	03/12/92	3/12/92		

9203190356 920312  
PDR ADOCK 05000352  
P PDR

*DFOL*  
*111*

NRC FILE CENTER COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

March 12, 1992

Docket Nos. 50-352  
and 50-353

Mr. George J. Beck  
Manager-Licensing, MC 52A-5  
Philadelphia Electric Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

SUBJECT: REMOVAL OF CYCLE SPECIFIC PARAMETER LIMITS, LIMERICK GENERATING  
STATION, UNITS 1 AND 2 (TSCR 89-13) (TAC NOS. M76053 AND M76054)

On May 15, 1990, we issued Amendments Nos. 37 and 4 to Facility Operating License Nos. 39 and 85, respectively. Page 3/4 3-60 of the Limerick, Unit 2 revised Technical Specifications (TS) had a typographical error. The allowable value for the high flow clamped rod block monitor should have been N+3 rather than N-3. The Unit 1 TS value was correct. A corrected Unit 2 page 3/4 3-60 and overleaf page 3/4 3-59 is enclosed. I regret any inconvenience this may have caused you. If you have any questions, please call me at (301) 504-1402.

Sincerely,

Richard J. Clark, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

Mr. George J. Beck  
Philadelphia Electric Company

Limerick Generating Station,  
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire  
Sr. V.P. & General Counsel  
Philadelphia Electric Company  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Mr. Thomas Gerusky, Director  
Bureau of Radiation Protection  
PA Dept. of Environmental Resources  
P. O. Box 2063  
Harrisburg, Pennsylvania 17120

Mr. Rod Krich 52A-5  
Philadelphia Electric Company  
955 Chesterbrook Boulevard  
Wayne, Pennsylvania 19087-5691

Mr. James A. Muntz  
Superintendent-Technical  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Graham M. Leitch, Vice President  
Limerick Generating Station  
Post Office Box A  
Sanatoga, Pennsylvania 19464

Mr. Gil J. Madsen  
Regulatory Engineer  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. John Doering  
Plant Manager  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464

Library  
US Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Mr. George A. Hunger  
Project Manager  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Thomas Kenny  
Senior Resident Inspector  
US Nuclear Regulatory Commission  
P. O. Box 596  
Pottstown, Pennsylvania 19464

Mr. Larry Hopkins  
Superintendent-Operations  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Richard W. Dubiel  
Superintendent-Services  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464