

Georgia Power Company  
ATTN: Mr. J. T. Beckham, Jr.  
Vice President, Plant Hatch  
Nuclear Operations  
P. O. Box 1295  
Birmingham, AL 35201

SUBJECT: PLANT PERFORMANCE REVIEW (PPR) - HATCH

Dear Mr. Beckham:

On September 21, 1995, the NRC staff completed the semiannual Plant Performance Review (PPR) of Plant Hatch. The staff conducts these reviews for all operating nuclear power plants to develop an integrated understanding of safety performance. The results are used by regional management to facilitate planning and allocation of inspection resources. The PPR for Hatch involved the participation of all Regional Technical Divisions and NRR in evaluating inspection results and safety performance information for the period from March 1995 to September 1995. PPRs provide regional management with a current summary of licensee performance and serve as inputs to the NRC Systematic Assessment of Licensee Performance (SALP) and senior management meeting (SMM) reviews.

This letter advises you of our planned inspection effort resulting from the Hatch PPR review. It is provided to minimize the resource impact on your staff and to allow for scheduling conflicts and personnel availability issues to be resolved in advance of inspector arrival onsite. The enclosure details our inspection plan for the next six months. The basis for each inspection outside the core inspection program is provided so that you are aware of the reason for emphasis in these program areas. Resident inspections are not listed due to their ongoing and continuous nature.

We will inform you of any changes to the inspection plan. If you have any questions, please contact P. Skinner at (404) 331-6299.

Sincerely,  
Original signed by John N. Hannon (for)

9511160238 951012  
PDR ADOCK 05000321  
Q PDR

Ellis W. Merschoff, Director  
Division of Reactor Projects

Docket Nos.: 50-321, 50-366  
License Nos.: DPR-57, NPF-5

Enclosure: Inspection Plan

cc w/encl: (See page 2)

150012

1001

cc w/encl:

J. D. Woodard  
Senior Vice President  
Georgia Power Company  
Nuclear Operations  
P. O. Box 1295  
Birmingham, AL 35201

H. L. Sumner, Jr.  
General Manager, Plant Hatch  
Georgia Power Company  
Route 1, Box 439  
Baxley, GA 31513

D. M. Crowe  
Manager Licensing - Hatch  
Georgia Power Company  
P. O. Box 1295  
Birmingham, AL 35201

Ernest L. Blake, Esq.  
Shaw, Pittman, Potts and  
Trowbridge  
2300 N Street, NW  
Washington, D. C. 20037

Charles H. Badger  
Office of Planning and Budget  
Room 610  
270 Washington Street, SW  
Atlanta, GA 30334

Harold Reheis, Director  
Department of Natural Resources  
205 Butler Street, SE, Suite 1252  
Atlanta, GA 30334

Thomas Hill, Manager  
Radioactive Materials Program  
Department of Natural Resources  
4244 International Parkway  
Suite 114  
Atlanta, GA 30354

Chairman  
Appling County Commissioners  
County Courthouse  
Baxley, GA 31513

(cc w/encl cont'd - See page 3)

(cc w/encl cont'd)  
 Ernie Toupin  
 Manager of Nuclear Operations  
 Oglethorpe Power Corporation  
 2100 E. Exchange Place  
 Tucker, GA 30085-1349

Charles A. Patrizia, Esq.  
 Paul, Hastings, Janofsky & Walker  
 10th Floor  
 1299 Pennsylvania Avenue  
 Washington, D. C. 20004-9500

Distribution w/encl:  
 K. N. Jabbour, NRR  
 P. H. Skinner, RII  
 R. V. Crlenjak, RII  
 G. A. Hallstrom, RII  
 PUBLIC

NRC Senior Resident Inspector  
 U.S. Nuclear Regulatory Commission  
 11030 Hatch Parkway North  
 Baxley, GA 31513

SEND TO PUBLIC DOCUMENT ROOM?							<input checked="" type="radio"/> YES	<input type="radio"/> NO
OFFICE	RII:DRP	RII:DRP	RII:DRSS	RII:DRS				
SIGNATURE								
NAME	BBoriser	PSkinner	KBarr	R. C. BASTO	R. C. BASTO			
DATE	10/11/95	10/11/95	10/12/95	10/12/95	10/11/95	10/11/95	10/11/95	10/11/95
COPY?	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO

OFFICIAL RECORD COPY

DOCUMENT NAME: P:\HATCH.PPR

HATCH INSPECTION PLAN		
Inspection Title	Dates	# Insp
Maintenance Observations Core (Resident Core to be done monthly by DRS Inspectors for the next six months) Modules 62703/92902	Next six months	1
Surveillance Observations Core (Resident Core to be done monthly by DRS Inspectors for the next six months) Modules 61726/92902	Next six months	1
Engineering Core Inspection (Will concentrate on Engineering responsiveness to Operations) Module 37550	TBD*	3
Motor Operated Valve Inspection (Follow-up to LPCI injection valve corrective action and MOV program closeout) Module 92903	TBD*	1
Engineering Inspection - Regional Initiative (Inspection of lead shielding loading installed in control room) Module 37550	TBD*	1
Safeguards Core Inspection Module 81700	01/08/96	1
Radiological Effluents and Chemistry Core Inspection Module 84750/86750	01/08/96	1

\*Inspection dates to be determined. Inspections will be completed during the next six months.