

## UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20655

March 13, 1992

Docket Nos. 50-321 and 50-366

> Mr. W. G. Hairston, JII Senior Vice President -Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Dear Mr. Hairston:

SUBJECT: GENERIC LETTER 89-10, SUPPLEMENT 3, "CONSIDERATION OF THE RESULTS OF NPC-SPONSORED TESTS OF MOTOR-OPERATED VALVES," HATCH NUCLEAR PLANT, UNITS 1 AND 2 (TACs M77778/M77779)

By letters dated December 11. 1990, and March 15, 1991, you responded to Generic Letter (GL) 89-10, Supplement 3, regarding the ability of BWR motoroperated valves (MOVs) on certain high energy lines to fully close under guillotine line break conditions. Your submittals indicated that the MOVs, within the scope of Supplement 3, are those on the high pressure coolant injection systems, reactor core isolation cooling steam supply lines, and reactor water cleanup water supply lines. Your March 15, 1991, letter requested that the implementation schedule for Hatch Unit 1 be extended until the spring of 1993 maintenance/refueling outage because of the unavailability of qualified equipment. Your previous schedule reflected implementation during the fall 1991 outage. Your implementation schedule for Hatch Unit 2 remains unchanged (i.e., fall of 1992 outage).

The NRC staff has reviewed your responses, including your safety assessment, and finds that your implementation schedule for Hatch Units 1 and 2 is acceptable. However, within 45 days, you should confirm that all the piping systems containing MOVs identified by GL 89-10, Supplement 3, either: (1) have area temperature monitoring capable of detecting a leak, or (2) are visually inspected by physical walk-down at least once per day, or (3) have performed or commit to perform a qualified 100% volumetric examination of service sensitive weldments in affected piping locations not suitable to be addressed as described in items (1) or (2) above.

Furthermore, among the aspects you should address, when performing the MOV mudifications, are: (1) the structural limits of each MOV in light of the increased thrust and torque requirements based on industry experience and research testing, (2) the reduction in thrust delivered by the actuator that may occur as a result of the "rate of loading" phenomenon, (3) the reduction of motor output that may occur as a result of high ambient temperature,

2203120413 220313 PDR 120022

Mr. W. G. Hairston, III Georgia Power Company

## CC

Mr. Ernest L. Blake, Jr. Shaw, Pittman, Potts and Trowbridge 2300 N Street, NW. Washington, DC 20037

Mr. J. T. Beckham Vice President - Plant Hatch Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. S. J. Bethay Manager Licensing - Hatch Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Manager, Nuclear Plant Georgia Power Company Route 1, Box 439 Baxley, Georgia 31513

Resident Inspector U. S. Nuclear Regulatory Commission Route 1, Box 725 Baxley, Georgia 31513

Regional Administrator, Region II U. S Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Mr. Charles H. Badger Office of Planning and Budget Room 610 270 Washington Street, SW. Atlanta, Georgia 30334

Harold Reheis, Director Bepartment of Natural Resources 205 Butler Street, SE., Suite 1252 Atlanta, Georgia 30334

Chairman Appling County Commissioners County Courthouse Baxley, Georgia 31513 Edwin I Hatch Nuclear Plant

Mr. R. P. McDonald Executive Vice President -Nuclear Operations Georgia Power Company P. O. Box 1295 Birmingham, Alabama 35201

Mr. Alan R. Herdt, Chief Project Branch #3 U. S. Nuclear Regulatory Commission 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

Mr. Ernie Toupin Program Director of Power Production Oglethorpe Power Corporation 2100 East Exchange Place Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire Paul, Hastings Janofsky & Walker 12th Floor 1050 Connecticut Avenue, NW. Washington, DC 20036

Distribution
Docket File
NRC & Local PDRs
PDII-3 R/F
Hatch R/F
S. Varga
G. Lainas
D. Matthews
L. Cerry
K. Jabbour
ACRS (10)
L. Reyes, Rli
J. Worberg
C. Cheng
T. Gody, Jr.

## Mr. W. G. Hairston

(4) the capability of the valves to satisfy any leakage limits associated with your safety analyses when closing under design basis conditions (particularly where the torque switch is set assuming low valve factors, but is bypassed for a significant portion of the valve stroke), (5) your justification for the assumed stem friction coefficient, (6) your justification for the assumed differential pressure under which the MOVs may be called upon to operate in light of the intent of GL 89-10, (7) the inaccuracy of MOV diagnostic equipment in measuring delivered torque or thrust, (8) the assumed minimum voltage available to the motor as compared to your licensing commitments, and (9) the closing stroke time under design basis conditions in relation to Technical Specifications or safety analyses (particularly for dc motors). In addition to your own MOV tests, you will be expected to monit r the MOV tests performed by other organizations for information on the torque and thrust required to operate its valves under design basis inditions. You will be expected to take action to ensure MCV operability where those tests raise questions regarding the required torque or thrust estimates. With respect to the review of the NRC-sponsored MOV tests by the Electric Power Research Institute (EPRI), the NRC staff agreed with the evaluation by the Idaho National Engineering Laboratory (INEL) provided in EGG-SSRE-9926 (November 12, 1991), "Evaluation of EPRI Draft Report NP-9926 - Review of NRC/INEL Gate Valve Test Program."

During future inspections of the GL 89-10 program, the NRC staff will confirm your assumptions and calculations for the MOVs within the scope of Supplement 3 as well as other MOVs within the scope of GL 89-10.

This completes our action on TAC Nos. M77778 and M77779. Please contact me if you have any comments regarding this matter.

Sincerely,

Kahtan N. Jabbour, Project Manager Project Directorate II-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

cc: See next page

<u>Cistribution</u> See next page

LA: PDII-3 LBerry Lap 3 1/3/92 PM:PDII-3 KN KJabbour/rst 3/17/92 BC (EMER JNorberg 3-1/2/92

D:PDII-3 PCP DMatthews for

OFFICIAL RECORD COPY Document Name: C:HAGENLET