

NOTICE OF VIOLATION

Commonwealth Edison Company
Braidwood Station
Braceville, Illinois

Docket Nos. 50-456; 50-457
License Nos. NPF-72; NPF-77

As a result of an inspection conducted from August 22 through September 30, 1995, and in accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," the following violation was identified:

Technical Specification 3.3.1 requires that with a main control room air intake radiation monitor inoperable, within one hour switch to the redundant train of control room ventilation, or isolate the control room ventilation system and initiate operation of the control room make-up system.

Contrary to the above, on September 8, 1995, the OA main control room air intake radiation monitor was declared inoperable and the licensee failed to switch to the redundant train of control room ventilation, or isolate the control room ventilation system and initiate operation of the control room make-up system within one hour as required.

This is a Severity Level IV violation (Supplement I) (50-456/95013-01(DRP); 50-457/95013-01(DRP)).

Pursuant to the provisions of 10 CFR 2.201, Commonwealth Edison is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington D.C. 20555 with a copy to the U.S. Nuclear Regulatory Commission, Region III, 801 Warrenville Road, Lisle, Illinois, 60532, and a copy to the NRC Resident Inspector at the Braidwood Station within 30 days of the date of the letter transmitting this Notice of Violation. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois
this 8th day of November 1995

9511160372 951108
PDR ADOCK 05000456
Q PDR