



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
PO BOX 97
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

March 18, 1992
PY-CEI/NRR-1465 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Annual Personnel Exposure and
Monitoring Report

Gentlemen:

Attached is the Annual Personnel Exposure and Monitoring Report for the Perry Nuclear Power Plant for the 1991 calendar year as required by 10CFR20.407(a)(2) and 10CFR20.407(b).

If there are any questions, please feel free to call.

Sincerely,

Michael D. Lyster

MDL:SML:ss

Attachment

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Region III
Director, Office of Nuclear Regulatory Research

260005
9203230230 911231
PDR ADDCK 05000440
R PDR

Operating Companies
Cleveland Electric Illuminating
Twisted Edison

FE56
11

ANNUAL OCCUPATIONAL RADIATION EXPOSURE REPORT
PERSONNEL WHOLE BODY EXPOSURE FOR CALENDAR YEAR 1991

LICENSEE REPORTING:
CLEVELAND ELECTRIC ILLUM. CO.
PERRY NUCLEAR POWER PLANT
10 CENTER ROAD
PERRY, OHIO 44081

LICENSE NO.
NPF-58

ANNUAL DOSE RANGES * (REM)	NUMBER OF INDIVIDUALS IN EACH RANGE
-------------------------------	--

NO MEASURABLE EXPOSURE	958
MEASURABLE EXP. <0.100	255
0.10 - 0.25	148
0.25 - 0.50	102
0.50 - 0.75	48
0.75 - 1.00	28
1.00 - 2.00	19
2.00 - 3.00	0
3.00 - 4.00	0
4.00 - 5.00	0
5.00 - 6.00	0
6.00 - 7.00	0
7.00 - 8.00	0
8.00 - 9.00	0
9.00 - 10.00	0
10.00 - 11.00	0
11.00 - 12.00	0
12.00 +	0

TOTAL NUMBER OF INDIVIDUALS REPORTED: 1558
TOTAL DOSE REPORTED: 146.432 REM

The above information is submitted for the total number of individuals for whom personnel monitoring was provided during the calendar year including those individuals required to be reported under 10 CFR 20.202(a)(1).

* Individual values exactly equal to the values separating exposure ranges shall be reported in the higher range. Dose measurements were obtained from thermoluminescent dosimeters (TLDs).

MISC/5515/SS