

ENCLOSURE 1

NOTICE OF VIOLATION

TU Electric
Comanche Peak Steam Electric Station

Dockets: 50-445
50-446
Licenses: NPF-87
NPF-89

During an NRC inspection conducted on September 25-29, 1995, one violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," (60 FR 34381; June 30, 1995), the violation is listed below:

- 10 CFR 19.12 states in part, "All individuals working in or frequenting any portion of a restricted area shall be kept informed of . . . the purposes and functions of protective devices employed . . . shall be instructed in the appropriate response to warnings made in the event of any unusual occurrence or malfunction that may involve exposure to radiation or radioactive material"

Contrary to the above, as of September 28, 1995, TU Electric had failed to inform and instruct its employees as to the purposes, functions, and appropriate responses to devices with blue flashing lights installed in 44 locations throughout the plant to alert personnel in high noise areas of the need to evacuate the site during a radiological emergency.

This is a Severity Level IV violation (Supplement VIII) (445/9521-01; 446/9521-01).

The NRC has concluded that information regarding the reason for the violation, the corrective actions taken and planned to correct the violation and prevent recurrence is already adequately addressed in the enclosed report. However, you are required to respond to the provisions of 10 CFR 2.201 if the description therein does not accurately reflect your correct actions or your position. In that case, or if you choose to respond, clearly mark your response as a "Reply to a Notice of Violation," and send it to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice).

If you choose to respond, the response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if it necessary to include such information, it should clearly indicate the specific information that should not be placed in the PDR, and provide the legal basis to support the request for withholding the information from the public.

Dated at Arlington, Texas
this 8th day of November 1995