



ENTERGY

Entergy Operations, Inc.
P.O. Box B
Kilona, LA 70066
Tel 504 739 6774

R. F. Burski
Director
Nuclear Safety
Waterford 3

W3F1-95-0182
A4.05
PR

November 14, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Monthly Operating Report

Gentlemen:

Attached is the subject monthly report which covers the operating statistics for the month of October, 1995. This report is submitted per Section 6.9.1.6 of the Waterford 3 Technical Specifications for Facility Operating License No. NPF-38.

Very truly yours,

R.F. Burski
Director
Nuclear Safety

RFB/DFL/ssf
Attachment

cc: L.J. Callan, NRC Region IV
C.P. Patel, NRC-NRR
R.B. McGehee
N.S. Reynolds
F. Yost (Utility Data Institute, Inc.)
J.T. Wheelock (INPO Records Center)
NRC Resident Inspectors Office

200058

9511200010 951031
PDR ADDCK 05000382
R PDR

NRC MONTHLY OPERATING REPORT
SUMMARY OF OPERATIONS
WATERFORD 3
for October, 1995

The unit was in Refueling Outage #7 for the entire month, thus generating no power for the time-period.

PRESSURIZER SAFETY VALVE
FAILURES AND CHALLENGES
WATERFORD 3
for October, 1995

There were no pressurizer safety valve failures or challenges experienced during the month.

OPERATING DATA REPORT

DOCKET NUMBER : 50-382
 UNIT NAME : WATERFORD 3
 DATE OF REPORT : November 3, 1995
 COMPLETED BY : D. S. Freeman
 TELEPHONE : (504) 464-3352

OPERATING STATUS

- | | | |
|---|---|----------------------|
| 1. Reporting Period | : | <u>October, 1995</u> |
| Gross Hours in Reporting Period | : | <u>745</u> |
| 2. Currently Authorized Power Level (MWt) | : | <u>3,390</u> |
| Maximum Dependable Capacity (Net MWe) | : | <u>1,075</u> |
| Design Electrical Rating (Net MWe) | : | <u>1,104</u> |
| 3. Power Level to which Restricted (if any) (Net MWe) | : | <u>N/A</u> |
| 4. Reason for Restriction (if any) | : | <u>N/A</u> |

	<u>THIS MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
5. Number of Hours Reactor was Critical	0.0	5,912.7	74,635.5
6. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
7. Hours Generator was On-line	0.0	5,892.8	73,737.1
8. Unit Reserve Shutdown Hours	0.0	0.0	0.0
9. Gross Thermal Energy Generated (MWH)	0	19,919,377	244,248,986
10. Gross Electrical Energy Generated (MWH)	0	6,630,410	81,364,870
11. Net Electrical Energy Generated (MWH)	0	6,336,926	77,579,292
12. Reactor Service Factor	0.0	81.0	84.3
13. Reactor Availability Factor	0.0	81.0	84.3
14. Unit Service Factor	0.0	80.8	83.3
15. Unit Availability Factor	0.0	80.8	83.3
16. Unit Capacity Factor (using MDC)	0.0	80.8	81.5
17. Unit Capacity Factor (using DER)	0.0	78.7	79.3
18. Unit Forced Outage Rate	0.0	7.3	3.5

OPERATING DATA REPORT

DOCKET NUMBER : 50-382
UNIT NAME : WATERFORD 3
DATE OF REPORT : November 3, 1995
COMPLETED BY : D. S. Freeman
TELEPHONE : (504) 464-3352

OPERATING STATUS (Cont.)

19. Shutdowns Scheduled over next 6 months (type, date and duration of each) :

NONE

20. If Shutdown at end of report period, estimated date of startup: 11/6/95

21. Unit is in Commercial Operation.

	<u>THIS MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
22. Hours in Reporting Period	745	7,296	88,561
23. Unit Forced Outage Hours	0.0	463.0	2,673.2
24. Nameplate Rating (Gross MWe) :	<u>1,200</u>		
Max. Dependable Capacity (Gross MWe) :	<u>1,120</u>		

25. If changes occur in capacity ratings (Items 2 and 24) since the last report, give the reasons :

N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NUMBER : 50-382
UNIT NAME : WATERFORD 3
DATE OF REPORT : November 3, 1995
COMPLETED BY : D. S. Freeman
TELEPHONE : (504) 464-3352

Reporting Period : October, 1995

(NET MWe)

<u>DAY</u>	<u>Avg. Power Level</u>	<u>DAY</u>	<u>Avg. Power Level</u>
1	(14)	16	(10)
2	(14)	17	(6)
3	(14)	18	(6)
4	(14)	19	(5)
5	(14)	20	(3)
6	(14)	21	(8)
7	(14)	22	(9)
8	(10)	23	(9)
9	(7)	24	(6)
10	(5)	25	(5)
11	(5)	26	(9)
12	(8)	27	(12)
13	(10)	28	(10)
14	(10)	29	(8)
15	(10)	30	(9)
		31	(21)

INSTRUCTIONS :

On this form, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NUMBER : 50-382
 UNIT NAME : WATERFORD 3
 DATE OF REPORT : November 3, 1995
 COMPLETED BY : D. S. Freeman
 TELEPHONE : (504) 464-3352

REPORTING PERIOD : October, 1995

Number	Date (yyymmdd)	* Type	Duration (Hours)	** Reason	Shutdown Method	Cause, Comments and Corrective Actions
95-02	950922	S	745.00	C	4	Unit removed from service to begin Refuel Outage 7. Outage is continued from the previous period.

*

TYPE

F - Forced
S - Scheduled

METHOD

1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation from Previous Period
5 - Power Reduction
6 - Other (explain)

**

REASON

A - Equipment Failure (explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training and License Examination
F - Administrative
G - Operational Error (explain)
H - Other (explain)