

APPENDIX A
NOTICE OF VIOLATION

Public Service Company of New Hampshire
Seabrook Unit 2

Docket No. 50-444
License No. CPPR-136

As a result of the inspection conducted on May 29 - June 25, 1984, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 8, 1984 (49 FR 8583) the following violation was identified:

10 CFR 50, Appendix B, Criterion XIII and the Seabrook Station FSAR, Section 17.1.1.13, require that measures be established to control storage, cleaning and preservation of equipment to prevent damage and deterioration. For particular products, special protective environments, such as inert gas atmosphere, specific moisture content levels, and temperature levels, shall be provided. The Westinghouse Nuclear Service Division (WNSD) manual provides guidelines for the storage of NSSS components in accordance with ANSI N45.2.2 1972.

Contrary to the above, adequate storage and preservation of equipment located inside of Unit 2 containment is not being provided for the following NSSS components.

1. The secondary side of steam generator 2A and the pressurizer have not been provided with an air circulating system to control humidity, temperature and dew point.
2. Steam generators 2B, 2C, and 2D are provided with air circulation systems. However, humidity, temperature, and dew point measurements are not being performed to assure their preservation for future use.
3. Reactor vessel flange stud hole No. 16 was not covered and contained dirt and grit, and did not appear to be fully coated with Tectyl-506; removal of No. 17 hole cap revealed that it contained approximately 1½ inches of water. The Tectyl appeared to be worn off of the face of the flange in the areas adjacent to these stud holes.

This is a Severity Level IV Violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, Public Service Company of New Hampshire is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

B40B15025B B40724
PDR ADDCK 05000443
Q PDR

OFFICIAL RECORD COPY