

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

November 13, 1995

WO 95-0165


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P.-137
Washington, D. C. 20555

Subject: Docket No. 50-482: October, 1995, Monthly
Operating Report

Gentlemen:

Attached is the October, 1995, Monthly Operating Report for Wolf Creek
Generating Station. This submittal is being made in accordance with the
requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad


Attachment

cc: L. J. Callan (NRC), w/a
W. D. Johnson (NRC), w/a
J. F. Ringwald (NRC), w/a
J. C. Stone (NRC), w/a

9511200100 951031
PDR ADDCK 05000482
R PDR

P.O. Box 111 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/HC/VET



WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: October YEAR: 1995

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 128

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of October, 1995. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power, Mode 1, through the month of October, 1995.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

NONE

OPERATING STATUS

1. Reporting Period: October, 1995 Gross Hours in Reporting Period: 745
2. Currently Authorized Power Level (Mwt): 3565 Max. Depend. Capacity (MWe-Net): 1167
 Design Electrical Rating (MWe-Net): 1170
3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>745</u> | <u>7,184.7</u> | <u>73,152.8</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>745</u> | <u>7,161.1</u> | <u>72,315.7</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWh) | <u>2,637,097</u> | <u>25,119,287</u> | <u>240,151,605</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>918,721</u> | <u>8,689,358</u> | <u>83,453,573</u> |
| 11. Net Electrical Energy Generated (MWh) | <u>881,779</u> | <u>8,325,548</u> | <u>79,700,222</u> |
| 12. Reactor Service Factor | <u>100.0%</u> | <u>98.5%</u> | <u>82.1%</u> |
| 13. Reactor Availability Factor | <u>100.0%</u> | <u>98.5%</u> | <u>82.5%</u> |
| 14. Unit Service Factor | <u>100.0%</u> | <u>98.2%</u> | <u>81.2%</u> |
| 15. Unit Availability Factor | <u>100.0%</u> | <u>98.2%</u> | <u>81.2%</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>101.4%</u> | <u>98.1%</u> | <u>78.8%</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>101.2%</u> | <u>97.5%</u> | <u>76.5%</u> |
| 18. Unit Forced Outage Rate | <u>0.0%</u> | <u>1.8%</u> | <u>4.8%</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): _____
Refuel VIII outage is scheduled to begin approximately March 1, 1996.
20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

MONTH October, 1995

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)	
1	1183
2	1183
3	1183
4	1184
5	1183
6	1178
7	1183
8	1185
9	1185
10	1184
11	1183
12	1176
13	1182
14	1186
15	1186
16	1185

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)	
17	1186
18	1185
19	1176
20	1185
21	1186
22	1186
23	1186
24	1186
25	1186
26	1186
27	1172
28	1181
29	1187
30	1188
31	1187

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-483
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 11-7-95
 TELEPHONE 316-364-8831

No	Date	Type F: FORCED S: SCHEDULED	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
N/A	N/A	N/A	N/A	N/A	N/A	N/A

SUMMARY: The unit operated at or near 100% 1, for the month of October, 1995.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED
 5. REDUCED LOAD
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH October, 1995

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
N/A	N/A	N/A