

November 16, 1995

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555



Attn: Document Control Desk

Subject: Clarification of Braidwood Unit 1 Inspection Data Letter
Dated November 9, 1995

Braidwood Nuclear Power Station Unit 1
NRC Docket Nos. 50-456

Reference: D. Saccomando letter to the Nuclear Regulatory Commission
dated November 9, 1995, transmitting "Clarification of
Braidwood Unit 1 Inspection Data"

The purpose of this letter is to clarify the interim inspection of the Braidwood Unit 1 steam generator tubes as discussed in the Reference letter. Commonwealth Edison interprets its commitment to perform an interim inspection within 0.5 effective full power year as limiting the operation of Braidwood Unit 1 between eddy current inspection of the steam generator top-of-tube sheet for a time not to exceed 24 weeks at operating temperature above a T-Hot of 500°F during the forthcoming Cycle 6.

Commonwealth Edison intends to continue its evaluation of circumferential cracking data with the intention of determining appropriate cycle length for Braidwood Unit 1. It is anticipated that further discussions with the NRC will take place on this topic in the near future.

If you have any questions concerning this correspondence, please contact this office.

Sincerely,

Denise M. Saccomando
Senior Nuclear Licensing Administrator

cc: D. Lynch, Senior Project Manager-NRR
R. Assa, Braidwood Project Manager-NRR
H. Miller, Regional Administrator-RIII
C. Phillips, Senior Resident Inspector-Braidwood
Office of Nuclear Safety-IDNS

200141

K:\nla\bybwd\stnngen\restart1

9511200223 951116
PDR ADOCK 05000456
Q PDR

Aool
1/0