

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON D C 20566 March 16, 1992

Docket No. 50-333

Mr. Ralph E. Beedle
Executive Vice President - Nuclear
Generation
Power Authority of the State of
New York
123 Main Street
White Plains, New York 10601

Dear Mr. Beedle:

SUBJECT: RELIABILITY OF MANUAL BUS TRANSFERS BETWEEN ONSITE AND OFFSITE POWER SUPPLIES AND RESOLUTION OF 4.16 KV SWITCHGEAR DEFICIENCY - JAMES A. FITZPATRICK POWER PLANT (TAC NO. M76947)

By letter dated September 4, 1990, you submitted a report describing your long-term plans to correct a switchgear deficiency described in Safety System Functional Inspection (SSFI) Report Number 50-333/89-80. This deficiency involves the potential for exceeding the short circuit rating of certain 4160V switchgear if a postulated bolted three-phase electrical fault occurs while the Emergency Diesel Generators (EDGs) are operating in parallel with the Normal Station Service Transformer. By letter dated December 28, 1990, you submitted information regarding the reliability of manual bus transfers between the onsite and offsite power supplies. This issue involves the difficulty in performing manual bus transfers due to the phase shift experienced at FitzPatrick.

The NRC staff has reviewed the information provided by your staff and concludes that our concern about the reliability of manual bus transfers has been adequately resolved with the installation of a new transformer between the 345kV and 115kV systems at the Oswego Steam Station switchyard. Also, given the small core damage frequency contribution of postulated fault scenarios during the monthly diesel generator testing coupled with implementation of the recommended administrative measures discussed in the enclosed safety evaluation, the NRC staff concludes that no switchgear design modifications are necessary. The NRC staff also concludes that, given the inherent risks associated with manual bus transfers, transferring loads from the Normal Station Service Transformer to the Reserve Station Service Transformer to perform EDG testing is no longer required.

9203250273 920316 PDR ADOCK 05000333 PDR Crol COPY

230084

Bran C. McCk.

Brian C. McCabe, Project Manager

Project Directorate 1-1

Division of Reactor Projects - 1/11 Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure: See next page Mr. Ralph E. Beedle Power Authority of the State of New York James A. FitzPatrick Nuclear Power Plant

CC:

Mr. Gerald C. Goldstein Assistant General Counsel Power Authority of the State of New York 1633 Broadway New York, New York 10019

Resident Inspector's Office U. S. Nuclear Regulatory Commission Post Office Box 136 Lycoming, New York 13093

Mr. Radford Converse Resident Manager James A. FitzPatrick Nuclear Power Plant Post Office Box 41 Lycoming, New York 13093

Mr. J. A. Gray, Jr.
Director Nuclear Licensing - BWR
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Supervisor Town of Scriba Route 8, Box 382 Oswego, New York 13126

Mr. John C. Brons, Prosident Power Authority of the State of New York 123 Main Street White Plains, New York 10601

Charles Donaldson, Esquire Assistant Attorney General New York Department of Law 120 Broadway New York, New York 10271

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406 Ms. Donna Ross New York State Energy Office 2 Empire State Plaza 16th Floor Albany, New York 12223