

APPENDIX A

NOTICE OF VIOLATION

Public Service Electric and
Gas Company
Salem Units 1 and 2

Docket/License: 50-272/DPR-70
Docket/License: 50-311/DPR-75

As a result of the inspection conducted on June 9, 1984 - July 6, 1984 and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 8, 1984 (47 FR 8583), the following violation was identified:

- A. Technical Specification 6.8.1.c requires that written procedures covering surveillance and test activities of safety related equipment shall be established.

Contrary to the above, on July 5, 1984, it was determined that no procedure had been established to perform the functional testing of safety related equipment, mechanical snubbers, as required by Technical Specification Surveillance Requirement 4.7.9.c and e.

This is a Severity Level IV violation (Supplement 1) applicable to DPR-70.

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric and Gas Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8408150368 840725
PDR ADDCK 05000272
G PDR