



**DUKE POWER**

November 14, 1995

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 2  
Docket No. 50-414  
Special Report  
End of Cycle 7 Refueling Outage  
Steam Generator Tube Inspection Report

Pursuant to Catawba Technical Specification 4.4.5.5, part a, the following information is submitted:

1. The following quantities of steam generator tubes were removed from service by plugging:

<u>Steam Generator</u>	<u>Number of Tubes Plugged</u>
A	10
B	2
C	5
D	6

For further information, please contact Devereux Tower at (803) 831-3419.

Very truly yours,

W. R. McCollum, Jr.  
Vice President

DT/

ADD 1/0

U.S. Nuclear Regulatory Commission  
November 14, 1995  
Page 2

Attachments

xc: Mr. S. D. Ebnetter  
Regional Administrator, Region II

Mr. Robert E. Martin, Project Manager  
ONRR

Mr. Nick Economos, Inspector  
Region II

Mr. R. J. Freudenberger  
NRC Resident Inspector  
Catawba Nuclear Station

U.S. Nuclear Regulatory Commission  
November 14, 1995  
Page 3

bxc: D. B. Mayes  
Z. L. Taylor  
J. S. Forbes  
G. B. Swindlehurst  
C. B. Cauthen  
J. M. Baumann  
L. A. Reed  
ELL-EC050  
Group File: CN-801.01  
Master File: CN-801.01