



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

March 24, 1992

Docket Nos. 50-338  
and 50-339

LICENSEE: Virginia Electric and Power Company (VEPCO)  
FACILITY: North Anna Power Station, Unit Nos. 1&2 (NA-1&2)  
SUBJECT: MEETING SUMMARY OF MARCH 19, 1992

On March 19, 1992, Messrs. J. Hegner and P. Kemp of VEPCO met with L. Engle of NRR to discuss the current and top 10 NA-1&2 licensing actions. The actions discussed were:

1. North Anna 1 Steam Generator Repair Project. This action would confirm that the steam generator repair project can be conducted under 10 CFR 50.59.
2. TS 269 Surveillance Requirement Extension. The proposed amendment would allow a one-time extension of 18-month surveillances for Unit 1.
3. TS 218 Revised Settlement Monitoring. The proposed amendments would significantly reduce the number of survey points requiring periodic survey.
4. TS 263 Resistance Temperature Detector (RTD) Bypass. The amendments support removal of the RTD bypass lines which will be performed during the Unit 1 steam generator replacement project and the next Unit 2 refueling outage.
5. TS 227 Residual Heat Removal Autoclosure Interlock Removal. The proposed amendments would reduce the potential for inadvertent loss of decay heat removal.
6. TS 265 Specification 3.0.5. The amendments would modify Specification 3.0.5 to allow 1 hour to initiate actions, 7 hours to reach HOT STANDBY, 13 hours to reach HOT SHUTDOWN and 37 hours to reach COLD SHUTDOWN.
7. TS 236/245 Vital Bus Supply. The proposed request for TS 236 would provide a 2-hour action statement to re-energize a vital AC bus upon failure and a 24-hour action to be back on its inverter. The proposed request for TS 245 is a shutdown TS requiring that all 1E power be on the same train.

9203260267 920324  
PDR ADOCK 05000338  
P PDR

NRC FILE CENTER COPY

*[Handwritten signature]*  
10

March 24, 1992

- 8. IS 273 Service Water - 3.0.4 Applicability. The proposed amendments would allow mode changes when the component cooling water heat exchanger service water flows are throttled.
- 9. IS 274 Intermediate Range Trip. The proposed amendments would modify special tests from 25 to 35% rated thermal power to be consistent with TS 116/103.
- 10. UFSAR Revision No. 20. Continued improvement and upgrade of the UFSAR.

The impact of the recent NA-1 mid-cycle steam generator inspection on these actions and efforts which can be taken to expedite their completion was discussed at length.

/s/

Leon B. Engle, Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

**DISTRIBUTION:**

Docket File  
 NRC & Local PDRs  
 PDII-2 RDG  
 T. Murley/F. Miraglia  
 J. Partlow  
 S. Varga  
 G. Lainas  
 H. Berkow  
 L. Engle  
 D. Miller  
 OGC  
 E. Jordan, MNBB 3201  
 ACRS (10)  
 J. Wechselberger, EDO 17-G-21  
 M. Sinkule, RII

OFFICE	LA:PDII-2	PM:PDII-2	D:PDII-2		
NAME	D. Miller	L. Engle	H. Berkow		
DATE	3/12/92	3/12/92	3/12/92	1/1	1/1

OFFICIAL RECORD COPY  
FILENAME: NA03-19.MTR

Virginia Electric & Power Company

North Anna Power Station  
Units 1 and 2

cc:

Mr. William C. Porter, Jr.  
County Administrator  
Louisa County  
P.O. Box 160  
Louisa, Virginia 23093

C.M.G. Buttery, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P.O. Box 2448  
Richmond, Virginia 23218

Michael W. Maupin, Esq.  
Hunton and Williams  
P.O. Box 1535  
Richmond, Virginia 23212

Regional Administrator, RII  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Dr. W. T. Lough  
Virginia State Corporation Commission  
Division of Energy Regulation  
P.O. Box 1197  
Richmond, Virginia 23209

Mr. G. E. Kane, Manager  
North Anna Power Station  
P.O. Box 402  
Mineral, Virginia 23117

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. J. P. O'Hanlon  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. E. Wayne Harrell  
Vice President - Nuclear Services  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. Martin Bowling  
Manager - Nuclear Licensing  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Office of the Attorney General  
Supreme Court Building  
101 North 6th Street  
Richmond, Virginia 23219

Mr. W. L. Stewart  
Senior Vice President - Nuclear  
Virginia Electric and Power Co.  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Senior Resident Inspector  
North Anna Power Station  
U.S. Nuclear Regulatory Commission  
Route 2, Box 78  
Mineral, Virginia 23117