

NUREG/CR-5856
PNL-8022

Identification and Evaluation of PWR In-Vessel Severe Accident Management Strategies

Prepared by
J. S. Dukelow, D. G. Harrison, M. Morgenstern

Pacific Northwest Laboratory
Operated by
Battelle Memorial Institute

Prepared for
U.S. Nuclear Regulatory Commission

9203270010 920331
PDR NUREG
CR-5856 R PDR

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW, Lower Level, Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC bulletins, circulars, information notices, inspection and investigation notices; licensee event reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, international agreement reports, grant publications, and NRC booklets and brochures. Also available are regulatory guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG-series reports and technical reports prepared by other Federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions. *Federal Register* notices, Federal and State legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Administration, Distribution and Mail Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, for use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

NUREG/CR-5856
PNL-8022
RK

Identification and Evaluation of PWR In-Vessel Severe Accident Management Strategies

Manuscript Completed: February 1992
Date Published: March 1992

Prepared by
J. S. Dukelow, D. G. Harrison¹, M. Morgenstern²

Pacific Northwest Laboratory
Richland, WA 99352

Prepared for
Division of Systems Research
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555
NRC FIN B5996

¹Jason Associates, Idaho Falls, ID 83402

²Battelle Human Affairs Research Centers, Seattle, WA 98105-5428

Abstract

This report documents work performed for the NRC/RES Accident Management Guidance Program to evaluate possible strategies for mitigating the consequences of PWR severe accidents. The selection and evaluation of strategies was limited to the in-vessel phase of the severe accident, i.e., after the initiation of core degradation and prior to RPV failure. A parallel project at BNL has been considering strategies applicable to the ex-vessel phase of PWR severe accidents.

Contents

Abstract	iii
Executive Summary	vii
Acknowledgments	ix
1 Introduction	1.1
1.1 Organization of This Report	1.3
2 Critical Severe Accident Sequences and EPG Coverage	2.1
2.1 Methodology and Information Resources	2.1
2.2 Description of Plants	2.1
2.3 Identification of Critical Sequences	2.2
3 Water Addition to the Reactor Pressure Vessel	3.1
3.1 Description of the Strategy	3.1
3.2 Core Fragmentation and Hydrogen Generation	3.1
3.3 Recriticality Issues	3.1
3.4 Plant-specific Implementation	3.2
3.5 Evaluation of the Strategy	3.3
4 Depressurization of the Primary System	4.1
4.1 Description of the Strategy	4.1
4.2 Use in Steam Generator Tube Rupture and Interfacing System LOCAs	4.1
4.3 Natural Circulation-Induced Failure of the RCS	4.2
4.4 Trade-Offs Between FCI and DCH	4.2
4.5 Information Needs	4.3
4.6 Plant-Specific Implementation	4.3
4.7 Evaluation of the Strategy	4.5
5 Flooding Reactor Cavity to Cover RPV Lower Head	5.1
5.1 Description of the Strategy	5.1
5.2 Plant-Specific Implementation	5.1
5.3 Evaluation of the Strategy	5.1
6 Restoration of AC Power and Provision of Portable Pumping Capacity	6.1
6.1 Restoration of AC Power	6.1
6.2 Plant-Specific Implementation	6.2
6.3 Evaluation of the Strategy	6.2

6.4 Provision of Portable Pumping Capability	6.3
6.5 Plant-Specific Implementation	6.3
6.6 Evaluation of the Strategy	6.3
7 Prevention and Mitigation of RCP Seal Failures	7.1
7.1 Description of the Strategy	7.1
7.2 Plant-Specific Implementation	7.1
7.3 Evaluation of the Strategy	7.2
8 Maintaining Forced Circulation Through the Core	8.1
8.1 Description of the Strategy	8.1
8.2 Plant-Specific Implementation	8.2
8.3 Evaluation of the Strategy	8.3
9 Feed and Bleed as a Severe Accident Management Strategy	9.1
9.1 Secondary Feed and Bleed	9.1
9.2 Plant-Specific Implementation	9.1
9.3 Evaluation of the Strategy	9.1
9.4 Primary Feed and Bleed	9.1
9.5 Plant-Specific implementation	9.1
9.6 Evaluation of the Strategy	9.2
10 Creation of a Core Damage Assessment Capability	10.1
10.1 What is Meant by Core Damage Assessment Capability?	10.1
10.2 Plant-Specific Implementation	10.3
10.3 Evaluation of the Strategy	10.3
11 Human Factors Considerations in Severe Accident Management	11.1
11.1 Introduction	11.1
11.2 Approaches to Mitigate Human Factors Problems	11.1
11.3 Implementation of These Mitigating Approaches	11.1
12 Conclusions	12.1
13 References	13.1
Appendix A: Westinghouse Large, Dry Containment Plant - Zion	A.1
Appendix B: Westinghouse Ice Condenser Containment - Sequoyah	B.1
Appendix C: Combustion Engineering Large, Dry Containment - Calvert Cliffs 1	C.1
Appendix D: Babcock & Wilcox Large, Dry Containment - Oconee 3	D.1
Appendix E: Table of Acronyms	E.1

Executive Summary

The objectives of this report were twofold: first, to determine the current understanding and practice in the Pressurized Water Reactor (PWR) Emergency Procedure Guidelines (EPGs), as it may relate to severe accident management, and second, to identify and evaluate strategies for mitigating the effects of severe accidents during the in-vessel phase of the accident, which is defined as being after the initiation of core degradation and prior to the failure of the reactor vessel. It is well-known that the EPGs are success-oriented, and they indeed provide success paths to deal with many of the critical accident sequences discussed in the report. In addition, many of the preventive (i.e., tending to prevent the initiation of core melt) strategies identified in NUREG/CR-5474 have been implemented, either entirely or partially, in the EPGs. However, the EPGs are not designed to provide guidance to the operators in response to the severe core damage accidents in which nothing works (or not enough things work) and core damage initiates. The functional operating guidelines dealing with inadequate core cooling and containment integrity do offer some guidance that would be useful during the in-vessel phase of a severe accident.

The vendor EPGs provide minimal guidance for the evaluation of human factors issues that will impact the ability of control room operators and in-plant operations and maintenance personnel to carry out the actions required under accident conditions; e.g., high temperatures, moisture, and radiation levels, with possibly impaired visibility. The Westinghouse ERGs do note some of the points at which utilities may have difficult decisions as to the capability of non-control-room staff to implement in-plant actions.

The fact that an accident has progressed to initiation of core damage implies some or all of the following plant conditions:

1. Several major plant front-line or support systems are unavailable or degraded.
2. Environmental conditions in containment are degraded, implying difficulty in carrying out some desired plant system manipulations.
3. Quality of the operator's knowledge of plant status, and particularly core status, is deteriorating.
4. The core may still be critical.
5. AC power may be unavailable, with DC power degrading.
6. The situation in the control room may be chaotic, with personnel present who are not normally in the control room, and plant conditions that have been experienced only during training sessions, if at all.
7. Decision making responsibility and authority may not be clearly defined.

Even with these deteriorating conditions, there are clear actions that operators can take to prevent or mitigate further plant degradation. First and foremost, get the reactor subcritical, if it isn't already. Second, get water into the vessel by any means possible (although there is a hierarchy of preferred means). Third, if possible, maintain the secondary system as a heat sink for the primary system. Fourth, if electrical power is degraded or unavailable, do everything possible to restore it. Fifth, if the core is truly endangered, the operators should be prepared to sacrifice any other plant systems to the goal of minimizing the damage to the core and the threat to containment. Sixth, a number of relatively modest preventive and mitigative efforts may have a significant impact on plant risk. These include the flexibility to use portable AC power generators and portable self-powered pumps to supply water or power critical equipment.

Also included is the use of feed and bleed flow in the service water system to maintain cooling of the centrifugal charging pumps, hence maintaining RCP seal injection and/or RCP seal cooling.

The arguments supporting RCS depressurization prior to vessel breach are persuasive. Early depressurization gets the plant closer to the accident conditions it was designed for, but may accelerate core degradation by comparison with remaining at high pressure. The analysis of Hanson et al. (1990) strongly suggests that late depressurization is preferable to early depressurization. Early or late depressurization should significantly reduce the risk associated with high pressure melt ejection and direct containment heating.

Improved knowledge of the status of a degrading core might improve the quality of accident management. This improved knowledge will require calculational tools that can integrate plant data with knowledge of the plant design to choose those descriptions of plant status that are consistent with the data and the time history of the accident -- and do it all in real time.

Flooding the reactor cavity to the top of the RVP lower head may improve heat removal from the outer surface of the lower head enough to prevent creep-rupture failure of the lower head after relocation of part of the molten corium to the lower plenum.

Continuing to operate RCPs and maintain forced flow through the vessel (under conditions that put the RCPs at risk) may prevent or mitigate core damage or may buy time for actions to recover or protect containment or protect the public. For some LOCAs, this choice may increase the rate of inventory loss from the break, thus requiring increased makeup flow.

Thus, this work has identified several strategies, which extend beyond the EPGs into the severe accident regime, that will mitigate the seriousness of events and their consequences during the in-vessel phase of severe accidents. Further work in this area can be expected to better define the feasibility, effectiveness, and potential disadvantages of these strategies in the context of application to specific plants.

Acknowledgments

This work has been conducted for the Office of Nuclear Regulatory Research, Division of Systems Research, Reactor and Plant Systems Branch, under the direction and guidance of Dr. James T. Han.

Input to Section 6.0 and plant-specific information about CE reactors was provided in an earlier draft of this report by Rollie D. Warner of PNL.

The authors appreciate the careful review and useful comments provided by a number of reviewers, including: Gary Bair, Portland General Electric; Francis Buck, PNL; Eric Schmicman, PNL; Dr. Bryan Gore, PNL; Dr. Spence Bush, PNL; Peter Cybulskis, Battelle Columbus Laboratory; Professor Bill Kastenber and his colleagues at UCLA; and Dr. J. T. Han, NRC/RES.

1 Introduction

This report presents the results of work performed by the Pacific Northwest Laboratory (PNL) in support of the Accident Management Research Program (NRC 1989) developed by the U.S. Nuclear Regulatory Commission Office of Nuclear Regulatory Research (NRC/RES). The Accident Management Research Program is intended to improve "understanding of the physical progression of severe core damage accidents" and to use that improved understanding to "provide insights for accident management, particularly in the area of limiting potential radioactive releases and stabilizing conditions should the reactor vessel be breached." Further,

"[r]esearch activities will center on assessing the feasibility of various strategies that might be implemented by utilities to prevent or mitigate severe accidents, and on identifying those which should be considered for inclusion in utility accident management plans.... In all cases, the design and operational requirements for strategy execution will be evaluated, but emphasis will also be given to examining potential circumstances under which certain operator actions could worsen accident consequences or adversely impact the ability to achieve a long-term, stable state (NRC 1989)

Specifically, this report documents Tasks 1, 2, and 3 of work performed for NRC/RES by PNL in FY 1991 supporting the Accident Management Research Program. The objectives of this report were twofold: first, to determine the current understanding and practice in the Pressurized Water Reactor (PWR) Emergency Procedure Guidelines (EPGs), as it may relate to severe accident management; and second, to identify and evaluate strategies for mitigating the effects of severe accidents during the in-vessel phase of the accident, which is defined as being after the initiation of core degradation and prior to the failure of the reactor vessel. Mitigating strategies for the ex-vessel phase of PWR severe accidents have been considered by a parallel Accident Management Guidance Program project conducted at Brookhaven National Laboratory (BNL).

Task 1 required the identification of critical accident sequences and the extent to which strategies already exist to prevent them or mitigate their consequences in the EPGs of all three PWR owners groups. For purposes of comparison, a similar review of the EPGs is also made for the 20, largely preventive, strategies that were identified and evaluated during Fiscal Year (FY) 1989 by BNL and PNL, with that work having been reported in NUREG/CR-5474, *Assessment of Candidate Accident Management Strategies*.

We understand that the purpose of the EPGs and Emergency Operating Procedures (EOPs) is to address prevention of and recovery from inadequate core cooling (ICC) and not necessarily to provide definitive guidance for recovery from severe core damage accidents. At various points in this report it is concluded that guidance for coping with certain severe accident conditions is incomplete or nonexistent. This is not intended as a criticism of the EPGs, since their purpose is not to address severe accidents. This conclusion is simply a recognition that coping with severe accidents should properly be addressed in the context of accident management. In certain other cases guidance may exist for ICC recovery which might be appropriate to consider during a severe accident. In those cases, this guidance is identified and may be assessed as a severe accident management strategy in future tasks.

Critical accident sequences were defined to be those satisfying one of the criteria:

1. Sequences that contribute significantly to the risk of core melt.
2. Sequences that contribute significantly to risk characterized by other risk measures. For purposes of this report, the only "other risk measure" we have used is risk to the public, with early risk and latent (cancer) risk lumped together.
3. Sequences that represent significant challenges to safety functions.

4. Sequences that represent significant challenges to safety systems.

Figure 1.1 shows a top-level logic tree of safety purpose, safety objectives, and safety functions.

The critical accident sequence identification is based on plant-specific information, principally information from plant probabilistic risk assessments (PRAs), for four specific PWRs:

- Zion (Westinghouse PWR with large, dry containment)
- Sequoyah (Westinghouse PWR with ice condenser containment)
- Calvert Cliffs (Combustion Engineering PWR with large, dry containment)
- Oconee (Babcock & Wilcox PWR with large, dry containment)

These particular plants were chosen because of reasonably good availability of design and operational information and because each was the subject of a recent probabilistic risk assessment (PRA). Zion is the subject of the Zion Probabilistic Safety Study (Pickard, Lowe & Garrick 1982) and the NUREG-1150 supporting report that rebaselined that study for NUREG-1150 purposes (Wheeler 1986). Calvert Cliffs is the subject of an Interim Reliability Evaluation Program (IREP) PRA conducted for the NRC (Payne et al. 1984). The Sequoyah PRA is documented in NUREG-1150 supporting reports (Benjamin et al. 1987; Bertuccio et al. 1987). Oconee is the subject of a PRA jointly conducted by Duke Power and the Nuclear Safety Analysis Center (NSAC 1984). These PRAs were used to determine severe accident sequences and the associated risks; additionally, they provide succinct information on plant systems and system interactions in the context of those severe accident sequences.

Since all of the plants are PWRs and the two Westinghouse plants are very similar, except for the containment type, some of the information in this report is necessarily repetitive. Similarly, the EPGs were developed by the vendors and the owner's groups under common criteria provided by the NRC, and the same Westinghouse

Emergency Response Guidelines (ERGs) (High-Pressure Version) apply to both Zion and Sequoyah.

While the report includes sequences representing early challenges to containment systems, it does not attempt to enumerate sequences threatening containment during the ex-vessel phase of a severe accident. In this report, we use the terms "core melt risk" and "core melt frequency" interchangeably. This common usage can be justified by noting that the risk of an event is usually defined as being the probability of the event times the consequences of the event. The probability of a core melt is equal (to a very good approximation) to the core melt frequency and the consequence of a core melt is taken to be 1 (i.e., one core melt). Thus the core melt risk and the core melt frequency are numerically equal.

Tasks 2 and 3 called for the identification of a list of candidate strategies for management of the in-vessel phase of severe accidents and the evaluation of those strategies according to the criteria of feasibility, effectiveness, and possible adverse effects. The identification is to be based on a review of the existing literature on severe accidents. The list should include strategies to prevent or mitigate high risk consequences or high core damage frequency; strategies that can increase the availability of pressurized water reactor (PWR) safety functions by using existing equipment and water resources (perhaps in ways not intended by the plant designers); and relevant strategies on the list (the "B" list) provided to PNL with the Statement of Work. The "B" strategies referred to above are listed in Table 1.1.

Two additional criteria for the strategy selection were imposed: 1) They should not require major plant modifications, and 2) they should not currently be implemented in the emergency procedures guidelines (EPGs). Since preventive strategies have been previously considered in some detail (Luckas et al. 1990), the primary focus in this report is on strategies intended to mitigate a severe accident in progress (that is, an accident with core degradation) rather than strategies intended to prevent the initiation of core degradation. It should be noted, however, that prevention and mitigation can overlap. Strategies which mitigate core degradation may act to prevent breach the reactor pressure vessel (RPV) and thus might be considered preventive strategies for the ex-vessel phase of the severe accident.

Table 1.1 "B" strategies relevant to the in-vessel phase of PWR severe accidents

Strategy	Sections of this Report
Procedures and hardware changes, if necessary, to inject water into the reactor to terminate the core melt prior to vessel failure (e.g., primary feed and bleed).	3.0, 4.0, 9.0
Procedures and hardware changes, if necessary, for secondary side injection to prevent or terminate the core melt (e.g., secondary feed and bleed).	4.0, 9.0
Procedures to continue the use of vessel injection after vessel rupture.	3.0
Procedures and modifications, as necessary, to cross-construct corresponding safety injection systems between the units in multiple unit plants.	3.0, 6.0
Procedures to depressurize the reactor system using power operated relief valves (PORVs), safety relief valves (SRVs), and/or the high point vents.	4.0, 9.0
Procedures to depressurize the primary system using the steam generator, by opening atmospheric dump valves and providing make up with existing or alternate water sources (i.e., secondary feed and bleed).	4.0, 9.0
Procedures and hardware changes, if necessary, to inject additional borated water from alternate source(s) to maintain subcriticality.	3.0

The strategies proposed are evaluated on the basis of theoretical and analytical models described in the literature, on reports of experimental results, and on design and operational information on some four PWRs: Zion, Sequoyah, Calvert Cliffs, and Oconee. Figure 1.2 shows how the strategies proposed relate to the safety objectives and the safety functions. The reader will note that most of the strategies are "integral" in the sense that they impact several different safety functions.

1.1 Organization of This Report

Section 2.0 of this report discusses the methodology used to determine the critical sequences. Appendices A through D document the determination of critical sequences for Zion 1, Sequoyah 1, Calvert Cliffs 1, and Oconee 3, in that order, along with an evaluation of vendor EPG coverage.

The report is organized primarily according to candidate strategies, with subheadings providing descriptions of the strategies, discussing any related phenomenological or systems issues, and providing generic and plant-specific evaluations of the candidate strategies. The strategies discussed include the "B" List strategies (see Table 1.1 for coverage of the "B" strategies in this report) and the following strategies:

- Water Addition to the Reactor Pressure Vessel (Section 3.0)
- Depressurization of the Primary System (Section 4.0)
- Flooding the Reactor Cavity to Cover RPV Lower Head (Section 5.0)
- Reestablishment of AC Power (Section 6.0)

Introduction

- Provision of Portable Pumping Capability (Section 6.0)
- Prevention and Mitigation of Reactor Coolant Pump (RCP) Seal Failures (Section 7.0)
- Maintaining Forced Circulation through the Core (Section 8.0)
- Secondary Feed and Bleed (Section 9.0)
- Primary Feed and Bleed (Section 9.0)
- Creation of a Core Damage Assessment Capability (Section 10.0)

Section 11.0 contains a discussion of generic human factors issues which impact the implementation of all of the strategies discussed and evaluated in the report.

Some strategies are not discussed in detail because they are already the subject of extensive research under the Severe Accident Research Program or they seem to be adequately covered by the vendor EPGs and plant emergency operating procedures (EOPs).

The report identifies situations where phenomena are not well understood, but where a better understanding of the phenomena is not likely to have any impact on decisions made by operators or Technical Support Center staff during a severe accident. It will also consider generic human factors issues, including the training of operators and others with severe accident management responsibilities, personnel performance under severe accident conditions, and the ability of the operating crew to carry out in-plant actions under severe accident conditions.




FIGURE 1.1. Reactor Safety Top Level Logic Tree




FIGURE 1.2. Classification of Proposed Strategies

2 Critical Severe Accident Sequences and EPG Coverage

2.1 Methodology and Information Resources

This report is based upon available documentation of generic research on severe accident phenomenology, available documentation of design and operational details of the four specific plants considered in evaluating the proposed accident management strategies, and the operations and plant systems experience of the authors and some of their colleagues. Information sources specifically relied upon include:

- NUREG-1150 and its supporting reports, particularly those directly relevant to Zion and Sequoyah,
- the plant-specific PRAs described in the previous section,
- initial submissions of the Final Safety Analysis Reports (FSARs) for the four plants, including consideration of later amendments for some of the plants,
- vendor emergency procedures guidelines,
- portions of the plant Emergency Operating Procedures for the four plants,
- many of the papers on the Three Mile Island, Unit 2 (TMI-2) accident in special Volume 87 of *Nuclear Technology*, August, October, November, and December 1989, and
- other open literature papers and reports on severe accident phenomenology, accident management policy, and plant systems responses to specific accidents.

This was a lot of material for the time and resources available for this project; the authors would appreciate being informed of any omissions or errors in the descriptions, evidence, and conclusions in this report.

2.2 Description of Plants

The four plants (by three vendors) are similar in many ways. This section will note some of the differences between the plants that have an impact on the selection of critical accident sequences and on the extent to which a particular strategy might be implemented successfully at a given plant.

Zion is a Westinghouse "high pressure" plant with a large dry containment. The term "high pressure" means that it has a fully qualified, safety-related charging system. The charging system is designed to provide relatively small amounts of coolant makeup flow to the reactor coolant system (RCS) during normal operation. With a safety-related charging system, Zion can take credit for the ability of the charging system to supply makeup flow to the RCS during small-break loss of coolant accidents (LOCAs) proceeding at pressures higher than the shutoff head of the high pressure injection system (HPSI). At the time of performance of the Zion PRAs, Zion was unusually sensitive to the effects of common-cause failures in the Service Water (SW) and Component Cooling Water (CCW) system, with almost 80% of the core melt risk being related to failures of the CCW system.

The Sequoyah plant is also a Westinghouse "high pressure" plant, but one with an ice condenser containment. These containments are smaller than the large, dry containment and have a lower design pressure. They depend on a large collection of baskets of ice to condense steam released from a LOCA, thus protecting the containment from the full effect of the LOCA blowdown. This is a pressure suppression containment, similar in intent to the BWR pressure suppressor pool containments. Ice condenser containments are generally considered to more vulnerable to containment failure in a variety of accident sequences than large, dry containments. Since this report is dealing with the in-vessel phase of severe accidents, that vulnerability doesn't have much impact on our work.

The Calvert Cliffs plant is a Combustion Engineering PWR with a large, dry containment. It has a non-safety-related charging system; one effect of this is that the Calvert Cliff IREP PRA (Payne 1984) did not give any credit for the ability of the charging system to provide high-pressure makeup flow during small-break LOCAs and similar accident sequences. In addition, the shutoff head of the high pressure injection pumps is lower than usual for PWRs (1275 psi versus 1600 psi) and the pressurization of the accumulators is also lower than usual (200 psi versus 600 psi). The net effect of these design features and the lack of credit for the charging system is that the Calvert Cliffs PRA is dominated by accident sequences remaining at so high a pressure that no makeup coolant can be provided, leading to eventual uncover of the core and core melt. Calvert Cliffs was also sensitive to Vital DC bus failures, with these failures causing a plant trip, a demand for safety system functioning, and at the same time degrading several of the safety systems (making them more vulnerable to additional independent failures).

The Oconee plant is a Babcock & Wilcox PWR with a large, dry containment and a non-safety-related charging system. By contrast with the other two vendors, B&W uses once-through steam generators (OTSGs), which have a significantly smaller inventory of water on the shell side (secondary side) of the steam generator than the U-tube steam generators (SGs) used by Westinghouse and Combustion Engineering. Without the

thermal inertia provided by larger mass of water in the SG shell, OTSGs allow less time for operator response to accident sequences involving loss of feedwater. On the other hand, Oconee has a more robust emergency electrical power system than most plants and has a Standby Shutdown Facility (SSF) which provides a completely redundant and independent means of injecting coolant into both the steam generators and the core.

2.3 Identification of Critical Sequences

Identification of critical accident sequences was affected by both plant differences and differing assumptions and methodologies used in performance of the PRAs. The Zion PRA was performed by Pickard, Lowe, & Garrick using the Large Event Tree/Small Fault Tree methodology. The resulting accident sequences have a somewhat different flavor than the sequences from the other three PRAs, performed using the Small Event Tree/Large Fault Tree methodology. Each methodology has advantages and disadvantages; in theory, although the description of accident sequences will be different, the bottom-line assessments resulting should be equivalent. Tables 2.1, 2.2, 2.3, and 2.4 summarize the critical accident sequences identified for the four plants. Full descriptions of the sequences, of the EPG coverage of the sequences, and of the EPG coverage of the "A" list sequences from NUREG/CR-5474 are provided in Appendices A, B, C, and D.

Table 2.1 Summary table of coverage of Zion critical accident sequences by Westinghouse Emergency Response Guidelines

Sequence	Description	Full Coverage ^(a)	Partial Coverage ^(b)	No Coverage	Comments
Z-1	Loss of CCW; induced RCP seal LOCA		X		AOPs probably cover loss of CCW
Z-2	Small-break LOCA; failure of high pressure recirculation core cooling	X			
Z-3	Large-break LOCA; failure of low pressure recirculation	X			
Z-4	Same as Z-3 with medium-break LOCA initiator	X			
Z-5	Degraded AC power; AFW failure; failure of primary feed and bleed; AC recovery <4 hr		X		
Z-6	Large-break LOCA; failure of LPI	X			
Z-7	Same as Z-5 but 4 hr < AC recovery <8 hr		X		
Z-8	Degraded AC power; loss of CCW and SW until AC recovered between 1 hr and 4 hrs			X	
Z-9	Same as Z-8 but with unrecoverable failure of SW			X	
Z-10	Degraded AC power; Loss of CCW and SW; no AC power recovery in 8 hr; failure of containment systems			X	
Z-11	Same as Z-8 but with AC recovery between 4 hrs and 8 hrs; containment systems succeed			X	
Z-12	Degraded AC power; Loss of SW; RCP seal LOCA			X	
Z-13	Same as Z-12 but fan coolers fail directly due to loss of AC Power			X	
Z-14	Interfacing System LOCA		X		
Z-15	Loss of LC bus 112 causing loss of secondary heat sink and failure of primary feed and bleed		X		
Z-16	Same as Z-11 with the SW system common-cause portion of Z-12			X	AOPs probably cover loss of SW
Z-17	Degraded AC power which fails CCW and induces RCP seal LOCA; available AC allows SW and containment systems to succeed				AOPs probably cover loss of CCW
Z-18	Pressurized thermal shock	X			
Z-19	Anticipated transients without SCRAM	X			
Z-20	Steam Generator Tube Rupture	X			

(a) In general, if the ERG steps provided succeed, the sequence will not proceed to core melt.

(b) The accident sequence is considered in the ERG, but the guidance provided may not prevent core degradation.

Table 2.2 Summary table of coverage of Sequoyah critical accident sequences by Westinghouse Emergency Response Guidelines

Sequence	Description	Full Coverage ^(a)	Partial Coverage ^(b)	No Coverage	Comments
S-1	Small-break LOCA; failure of recirculation phase core cooling	X			
S-2	Loss of CCW; induced RCP seal LOCA; failure of ECC and containment spray	X			AOPs probably cover loss of CCW
S-3	Small-break LOCA; failure of recirculation phase core cooling (due to LP pump failures)	X			
S-4	Sequence S-3 with additional failure of containment spray	X			
S-5	Station blackout; induced RCP seal LOCA; no ECC or containment systems available	X			
S-6	Intermediate-break LOCA; loss of HP recirculation phase core cooling	X			
S-7	Loss of DC bus I; independent failure of AFW; failure of feed and bleed (due to DC bus loss)			X	AOPs probably cover loss of Vital DC
S-8	Loss of DC bus II; the rest identical to S-7			X	AOPs probably cover loss of Vital DC
S-9	Intermediate- or large break LOCA; failure of ice condenser; containment failure, then core melt		X		
S-10	Interfacing system LOCA; additional failures leading to core melt		X		
S-11	SGTR; additional failures leading to core melt	X			
S-12	RPV overpressurization at cold shutdown	X			
S-13	RCS overcooling transient at power	X			
S-14	Loss of secondary heat sink	X			
S-15	Pressurizer flooding	X			
S-16	Anticipated transients without SCRAM	X			
S-17	Loss of SW system, causing eventual loss of AFW, CCW, and containment spray			X	AOPs probably cover loss of SW

(a) In general, if the ERG steps provided succeed, the sequence will not proceed to core melt.

(b) The accident sequence is considered in the ERG, but the guidance provided may not prevent core degradation.

Table 2.3 Summary table of coverage of Calvert Cliffs critical accident sequences by Combustion Engineering Emergency Procedure Guidelines CEN-152

Sequence	Description	Full Coverage ^(a)	Partial Coverage ^(b)	No Coverage	Comments
C-1	Anticipated transient without SCRAM causing immediate RCS failure and early containment failure		X		
C-2	Loss of DC bus 11 degrades secondary heat sink and safety systems; subsequent AFW failure leads to core melt		X		AOPs probably cover loss of DC bus
C-3	Small-small LOCA; failure of HP recirculation phase core cooling	X			
C-4	Sequence C-3 with additional failure of containment sprays in recirc mode	X			
C-5	Loss of secondary heat sink; failure of primary feed and bleed		X		
C-6	ATWS with boration failure or stuck open PORV	X			
C-7	Transient followed by loss of secondary heat sink	X			
C-8	Loss of offsite power; transient-induced LOCA; HPSI and containment systems fail		X		Plant-specific guidance needed for LOSP
C-9	Loss of offsite power; AFW failure		X		Plant-specific guidance needed for LOSP
C-10	Station blackout; RCS boiloff causes core melt			X	AOPs may provide Station blackout guidance
C-11	Transient requiring pressure relief; loss of secondary heat sink	X			
C-12	Small-small LOCA; loss of HPSI secondary heat sink	X			
C-13	Loss of offsite power; failure of AFW and containment systems		X		Plant-specific guidance needed for LOSP
C-14	Interfacing systems LOCA; additional failures resulting in core melt	X			No caution against initiating passive cooling when LOCA is outside containment
C-15	SGTR; additional failures resulting in core melt	X			
C-16	Overpressurization at cold shutdown	X			
C-17	RCS overcooling transient at power	X			
C-18	Pressurizer flooding	X			
C-19	Loss of SW train 12; trips plant; degrades safety system			X	AOPs probably cover loss of SW
C-20	Loss of Salt Water system; degrades CCW, SW, and ECC pump room coolers			X	AOPs probably cover loss of Salt Water System

(a) In general, if the EPG steps provided succeed, the sequence will not proceed to core melt.

(b) The accident sequence is considered in the ERG, but the guidance provided may not prevent core degradation.

Table 2.4 Summary table of coverage of Oconee critical accident sequences by Babcock & Wilcox Abnormal Transient Operating Guidelines

Sequence	Description	Full Coverage ^(a)	Partial Coverage ^(b)	No Coverage	Comments
O-1	Loss of LP Service Water; degrades HPI pumps and CCW; induced RCP and LOCA		X		
O-2	Large-break LOCA; failure to transfer to LP recirculation phase core cooling	X			
O-3	ATWS followed by immediate LOCA and failure to reach long-term stable cooling mode	X			
O-4	Small-break LOCA; depletion of BWST followed by failure to transfer to recirc cooling		X		Partial guidance on need to preserve BWST inventory
O-5	Large FW or Condensate line break causes loss of secondary heat sink; feed and bleed fails; emergency FW from Standby Shutdown Facility fails	X			
O-6	Loss of Instrument Air causes partial loss of secondary heat sink; HPI and Emergency FW are not initiated	X			
O-7	SGTR followed by HPI failure	X			
O-8	Loss of main FW; failure of EFW; operators fail to initiate primary feed and bleed or recover EFW	X			
O-9	SGTR with stuck-open SG relief valve; BWST inventory is not maintained		X		Partial guidance on need to preserve BWST inventory
O-10	RPV rupture precludes core reflooding			X	
O-11	Interfacing system LOCA		X		No clear guidance on identifying and responding to interfacing system LOCAs
O-12	Station blackout; failure steam-driven EFW pump stuck-open relief valve	X			

(a) In general, if the ATOG steps provided succeed, the sequence will not proceed to core melt.

(b) The accident sequence is considered in the ERG, but the guidance provided may not prevent core degradation.

3 Water Addition to the Reactor Pressure Vessel

3.1 Description of the Strategy

At almost all stages of almost all conceivable severe accidents, addition of water to the core is beneficial. In a few accident sequences, however, particularly when the capability of adding water to the core is regained after a period of zirconium burning and other core degradation processes, the negative effects of water addition (massive hydrogen generation and structural degradation of the core) may be substantial. However, the operators will rarely have enough information about the state of the core to identify those exceptional situations. On balance, the operators should always add as much water as possible to a degrading core whenever they can, as the likely benefits outweigh the more speculative possible disadvantages. For operators to choose not to add water because of potential negative impact, is to give up the opportunity to terminate the core degradation processes of an ongoing accident. The issue of how the operators can know the status of a degrading core is discussed in more detail in Section 10.0.

There are situations, particularly early in an accident, when the operators may want to throttle or terminate containment spray in order to preserve inventory in the refueling water storage tank for injection into the core. This will postpone the need to switch over to recirculation mode cooling of the core and containment. These situations are easier to identify; if the containment environment can be maintained in the acceptable range with the containment fan coolers alone or with the fan coolers and throttled spray flow, then it is desirable to do so. Operators may also need to throttle or terminate water addition to the core in the event of overcooling or overfilling of the RCS. The controlling concern is the prevention of pressurized thermal shock (PTS), which may threaten the integrity of the RPV. If PTS is a concern, then the operators have at least managed to cool the core and maintain RCS inventory.

Other issues related to water addition are discussed in Sections 4.0, 6.0, 8.0, and 9.0.

3.2 Core Fragmentation and Hydrogen Generation

If the core has been uncovered, has dried out, and portions of it heated up to more than 1700 K, then addition of water may, as it did at TMI-2 (starting at minute 174 of the accident), cause massive zirconium burning, hydrogen generation, and the creation of a large porous rubble bed (Broughton et al. 1989; Kuan et al. 1989). This is one of the situations in which the rate of water addition can affect the course of the accident. Small amounts of water will cause only limited zirconium burning, since the process will be steam-starved. Large amounts may limit the amount of zirconium burning by quenching the heat and reducing its temperature below 1200 K. In-between amounts of water offer the worst of all possibilities, enough steam to burn all of the available zirconium, but not enough water to quench the reaction (Kuan and Hanson 1991). As before, operators will have difficulty identifying this condition and determining that a given amount of water addition in that situation is too much or too little. On balance, the appropriate operational decision in this situation is to add as much as possible.

The resulting fragmentation of fuel rods and fuel pellets is likely to create a rubble bed, as in the TMI-2 accident, sitting atop a consolidated pool of molten corium (corium is a molten or previously molten mixture of steel, control rod materials, zirconium, uranium, and oxides of all of these materials). Depending on the size and porosity of the rubble bed and depending on the availability of water, the rubble bed may or may not be coolable. If not, then it will gradually melt, enlarging the underlying corium pool. This process may be terminated by one or more relocations of molten corium to the lower plenum of the vessel.

3.3 Recriticality Issues

In the situation described in Section 3.2, control rod materials will have been removed from the rubble bed

by melting and relocation, leading to incorporation of these materials into the consolidated pool or the corium crust supporting the molten corium pool. If the water added to the vessel percolates through the rubble bed, providing moderation, then recriticality may be an issue (Cokin and Diamond 1979). On the other hand, an unmoderated recriticality of the molten, consolidated portion of a degrading core cannot occur at U-235 enrichments characteristic of a PWR.

Just as with an anticipated transient without scram (ATWS) sequence (in which control rod material is also missing from the core region), if sufficiently borated water is added, the rubble bed can be maintained subcritical. Problems might arise if the operators find it necessary to add unborated water directly to the RCS or if, during recirculation phase core cooling, borated water in the containment sump has been diluted by the addition of unborated water. At present, there appears to be no consensus as to whether operators should add water to a degrading core if the only source of water for that purpose is unborated or borated but diluted to lower than desired boron concentrations. How might borated water in the containment sump become diluted? The physical process of loss of RCS water from a break with flashing of some or all of the RCS coolant lost followed by condensation of the resulting steam on containment structures or containment spray droplets is equivalent to distillation of the RCS coolant. The boron and other chemicals in the RCS coolant may be partially removed from the RCS coolant by this process and precipitated out somewhere in containment. Unless the boron is re-entrained by containment spray flow on its way to the sump, the net result may be gradual removal of boron from the recirculating coolant. Once precipitated out, the boron is difficult to put back in solution. Keeping it in solution in the borated water storage tanks requires heating.

In the event that it was necessary to add unborated water to containment during the recirculation phase of core cooling or that recirculating coolant has become diluted by flashing and condensation, a possible mitigating strategy would be the pre-placement of open bins of dry borated chemicals in the neighborhood of the containment sump. As water levels around the sump flood the bins during recirculation-phase cooling, dis-

solving the solid boron, soluble boron will be added to the recirculating coolant.

Finally, the energetics of a recriticality need to be considered. Recriticality transients in a degrading core would be unconstrained, that is, subject to more or less free expansion as the transient deposits energy in the critical array. This expansion and Doppler feedback will introduce negative reactivity and terminate the transient. The total energy deposited by the transient is a function of the rate of positive reactivity addition that initiates the transient. Recriticalities in fuel or waste process plants are typically unconstrained and initiated by the addition of material to a vessel or by gravitation assembly of a critical mass. Neither process produces very high rates of positive reactivity input; such criticalities have typically been limited to between 10^{17} and 10^{19} total fissions, released in one or a series of pulses. This is a relatively modest amount of energy; 10^{19} fissions is equivalent to 320 MJoules (i.e., 3.2×10^8 Joules) of energy, which is 700 times smaller than the 200 GJoules (2.0×10^{11} Joules) of energy deposited in fuel in the first Chernobyl reactivity transient. Approximately a second later 1000 GJoules (10^{12}) was deposited in the second Chernobyl transient. Lucas, et al. (1987d) estimate 473 MJoules and 662 MJoules as the 5% and 95% confidence limits for the steam explosion energy release required to fail the upper head bolts of a U.S. vendor PWR reactor vessel. The Chernobyl accident (which was a reactivity-driven accident, as opposed to the decay-heat-removal-driven TMI-2 accident) inspires caution, in that the first pulse was shut down by introduction of negative reactivity feedback (mainly Doppler), but as the power dropped, a combination of cooling of fuel fragments by rapid transfer of heat to reactor coolant together with expulsion of coolant produced a large positive reactivity insertion that led to the larger (five times larger) second power spike. Similar two-stage processes seem possible in the context of severe accident recriticalities. A modest recriticality transient might disperse corium exposing the corium array to coolant and leading to positive reactivity insertions due to improved moderation and Doppler effect (i.e., cooling fuel fragments reduces the Doppler broadening of uranium neutron absorption resonances). It appears this possibility has not been investigated in any detail.

3.4 Plant-specific Implementation

Plant-specific details impact the implementation of this strategy primarily in determining the ability to use primary feed and bleed cooling and the ability to depressurize the RCS. For instance, at Calvert Cliffs, the low shutoff head of the high pressure injection pumps (1275 psi) and the low pressurization (200 psi) of the plant's safety injection tanks (i.e., accumulators) make it somewhat more difficult to add water to the core in high pressure accident sequences than at other plants.

At Zion, if the plant can be depressurized below 600 psi, water can be added to the vessel from the accumulators, using the blanket gas to provide the driving pressure. Zion has four accumulators with a capacity of approximately 10,000 gallons each. In addition, the RWST can provide water by gravity feed and has a capacity of approximately 389,000 gals. Procedures now exist that allow the operators to refill the RWST from outside water sources.

Both of these water sources can be treated with boric acid through the Make-up Water System. There are three boric acid tanks each with a capacity of approximately 11,000 gallons. The boric acid is transferred via two boric acid transfer pumps each with a capacity of 75 gpm. These pumps can be diesel-driven. If the plant emergency diesel generators were not working, the transfer pump could be driven by a relatively small portable generator if the proper interface were available.

At Oconee, unit cross-connections can have both positive and negative impacts. The ability to obtain emergency feedwater, service water, and electric power from other units provides valuable opportunities for recovering vital safety functions (there do not appear to be any unit interconnections for safety injection). However, sharing turbine and auxiliary buildings could allow an internally initiated flood of one unit to affect another unit.

The Standby Shutdown Facility (SSF) at Oconee does provide a unique and independent capability to maintain sufficient inventory in the reactor coolant system (RCS) to sustain natural circulation. The SSF reactor coolant volume control system (RCVCS) is designed to provide makeup water to the RCS and provide reactor

coolant pump (RCP) seal injection. The spent fuel pool can be used as a suction source of makeup water if the normal makeup system is not available. There is sufficient boric acid water available in the spent fuel pool to allow the SSF to maintain hot shutdown conditions for all three units for approximately three days. The spent fuel pool water level would be drawn down to approximately 1 foot above the top of the spent fuel racks after this 3 day period. The RCVCS components are provided motive and control power via an independent electrical power system, which uses a dedicated diesel generator.

3.5 Evaluation of the Strategy

As indicated above, adding water to the vessel as soon, as often, and in as great a quantity as possible should be the operator's primary strategy for responding to severe accidents. Feasibility of the strategy is an issue; with the exception of some ATWS sequences, inability to add water to the core at some critical juncture is what turns a transient or a loss of coolant accident (LOCA) into a severe accident. Many of the other strategies discussed in this report and most of the strategies discussed in Luckas et al. (1990) represent attempts to prevent the loss of RCS inventory or to find some functioning makeup water source and delivery system that can replace lost RCS inventory.

Effectiveness of the strategy will depend on when and how the water is added and on the previous course of the accident. In a degrading core, when the pool of molten corium reaches a certain mass, its size and the surrounding crust of frozen corium and metal will render it effectively impervious to quenching and cool-down by water added to the core region. However, the water added to the vessel at this juncture can still have beneficial effects: slowing the core melt progression, scrubbing fission products, and perhaps mitigating the fuel-coolant interaction (FCI) at the time of relocation of the molten corium to the RPV lower plenum. Finally, presence of water at the time of core relocation to RPV lower plenum may permit quenching of a sufficiently porous rubble of fragmented corium, as appears to have happened at TMI-2.

Water Addition

As indicated above, the potential adverse effects of water addition are speculative. In addition, the operator would seldom have sufficient information on the status of core degradation to identify those precise situations in which water addition (or addition of the wrong

amount or wrong kind of water) will exacerbate the accident sequence. Consequently, whenever possible, water should be added to the vessel, as soon and as rapidly as possible.

4 Depressurization of the Primary System

4.1 Description of the Strategy

Depressurization of the primary system during a degraded core accident or a potentially degraded core accident carries four major potential benefits:

1. During the depressurization transient, flashing of water to steam in the core region will cool fuel, cladding, and core internals,
2. depressurization may permit addition of water to the core using low pressure water sources,
4. depressurization should reduce the threat of induced LOCAs or steam generator tube ruptures due to natural circulation within the RCS of high pressure, superheated steam,
3. and it may prevent or mitigate direct heating of the containment atmosphere upon melt-through of the RPV.

Depressurization also has two major potential disadvantages: after the flashing transient is complete, core degradation will proceed essentially adiabatically (see the note in Section 4.3 below) and hence more rapidly. Depressurization may also significantly increase the probability of an energetic FCI (at the time of relocation of molten corium to the lower head of the RPV).

Depressurization as an accident mitigation strategy is being extensively investigated at the Idaho National Engineering Laboratory as part of the NRC Severe Accident Research Program (Chambers et al. 1989; Golden et al. 1989; Hanson et al. 1990). Hanson et al. (1990) considered (i.e., by modeling the events using SCDAP/RELAP5) two different depressurization strategies applied to the Surry TMLB¹ accident (station blackout with AFW failure). The first strategy required (early) depressurization at the time of SG dryout. The second required (late) depressurization after core dryout and heatup (operators latch open the PORVs when core exit temperatures indicate 922 K). Both strategies successfully depressurized the RCS to around 1 MPascal (approximately 150 psi), considered low enough to prevent

direct containment heating. Early depressurization accelerated the time of core melting and RPV failure, because of earlier core uncover and the ineffectiveness of low pressure steam as a heat transfer agent (see the note in Section 4.3). Because the RCS was essentially full at the time of depressurization, the depressurization transient took longer and cladding got hot enough at the time of accumulator injection to cause significant zirconium burning, hydrogen generation, and relocation of clad and fuel. For late depressurization, the RCS inventory at the time depressurization begins is much smaller, leading to a shorter transient and lower clad temperatures at the time of accumulator injection. As a result, accumulator injection quenches the core, delaying core degradation and minimizing hydrogen production. On the basis of their analysis, Hanson et al. recommend late depressurization.

Licensing authorities in the Federal Republic of Germany have adopted depressurization as a severe accident management tool, basing their decision partly on the domination of core damage risk by high pressure core melt and vessel failure sequences (98% of the core damage risk, as determined in PRAs). In addition, the high pressure sequences are considered to increase the risk of early containment failure (Kersting 1990). A review of PRAs for the Sequoyah, Zion, Calvert Cliffs, and Oconee plants suggests a similar, if not as overwhelming, preponderance of risk-significant high pressure vessel breach sequences (Payne et al. 1984; Benjamin et al. 1987; Wheeler 1986; NSAC 1984).

4.2 Use in Steam Generator Tube Rupture and Interfacing System LOCAs

Certain types of severe accidents essentially require depressurization. For steam generator tube ruptures (SGTRs) and interfacing system LOCAs (Event V) which threaten to proceed to core degradation, depressurization is a major strategy for reducing the leakage from the primary system to the secondary system (during an SGTR) or to the auxiliary building (during Event V) by reducing the pressure difference driving the leakage. Indeed, for an SGTR, primary system pressure may be

reduced below secondary system pressure in order to backfill the primary system from the secondary; this also stops the leakage from primary to secondary, with the disadvantage of introducing unborated water into the primary system.

4.3 Natural Circulation-Induced Failure of the RCS

For severe accidents proceeding at high pressure, such as small-break LOCAs or transient-induced accidents, the volumetric enthalpy of steam is high enough that significant amounts of heat can be removed from the core by natural circulation of steam. [Note: As pressure increases, steam density, thermal conductivity, Reynolds number, and Prandtl number all increase, swamping small decreases in dynamic viscosity and mass-specific enthalpy. The net effect is an approximately 85-fold increase in the effectiveness of steam as a heat transfer medium as pressure increases from 1 bar (approx. one atmosphere) to 150 bars (El-Wakil 1971, p.244)]. In this event, natural circulation loops may transfer enough heat to the higher elevation portions of the primary system to cause a breach of the primary system (probably at the pressurizer surge line) large enough to depressurize the primary system. This scenario is speculative, but has been supported by small-scale experiments and detailed code analyses (Cha et al. 1989; Bayless 1988; NRC 1987). Cha et al. investigated the sensitivity of natural circulation flows in a high pressure degrading core accident in order to try to understand why the TMI-2 accident showed little evidence of this phenomenon. Their models suggested that pressure variations and evaporation rates during the course of the accident had no impact on the natural circulation flows predicted by the codes, while higher water levels tended to reduce the strength of the flow, but not eliminate it entirely.

Analysis of a Surry TMLB' accident sequence (station blackout with loss of AFW) by Bayless (1988) using SCDAP/RELAP5 support the conclusions:

1. Natural circulation of superheated steam is likely to occur in the TMLB' sequence;
2. its occurrence is relative insensitive to modelling uncertainties;

3. it extends the core heatup transient by transporting heat from the core to structures high in the RPV and (perhaps) to piping high in the RCS;
4. it leads to creep-rupture failure of the pressurizer surge line or one of the hot legs prior to RPV failure;
5. the RCS depressurization induced by surge line or hot leg failure leads to accumulator injection which quenches the core.

From the accident management viewpoint, the importance of the high pressure superheated steam natural circulation phenomenon is that, even if the operators wanted to implement a strategy of maintaining high RCS pressure (say, with the goal of preventing a steam explosion when the molten core relocates to the lower plenum), it might not be possible.

4.4 Trade-Offs Between FCI and DCH

Direct containment heating (DCH) is postulated to occur when a reactor vessel fails while the primary system is at high pressure. The high delta-p driving the flow of molten corium through the breach causes it to fragment into an aerosol. The large surface area of the aerosol enhances heat transfer to the containment atmosphere and (exothermic) oxidation of the metallic components of the corium. An obvious mitigating strategy is to depressurize the core to reduce the pressure driving the dispersal and fragmentation of the corium.

On the other hand, some researchers believe that energetic fuel-coolant interactions (FCI) are significantly more likely at low pressure than at high pressure (Berman 1988). The partial core relocation at TMI-2 occurred at high pressure and produced only a mild FCI. For the in-vessel phase of a severe accident, this is mainly an issue at the time of relocation of molten corium to the lower plenum. The concern is that an energetic FCI could fail the RPV in such a way as to create a missile that directly penetrates the containment, causing a large radiation release. This scenario, called alpha-failure of containment, and fuel-coolant interaction in general, have been extensively studied for a variety of fuels and coolants, both experimentally and

theoretically. Papers by Theofanous et al. (Theofanous et al. 1987; Abolfadl and Theofanous 1987; Amarasooriya and Theofanous 1987; Lucas et al. 1987) review the evidence for and against creation of a sufficiently energetic missile, reaching the conclusion that the probability of alpha-failure is acceptably low. Numerous Letters to the Editor responding to the Theofanous et al. papers (Berman 1988; Marshall 1988; Corradini 1988; Hopewell 1989; Fletcher and Thyagaraja 1989; Corradini 1989; Young 1989) and Theofanous et al. responses to those letters (Theofanous 1988a; Theofanous 1988b; Theofanous 1988c; Theofanous 1989a; Theofanous and Amarasooriya 1989; Theofanous 1989b; Theofanous 1989c) suggest that scientific consensus has not yet been reached on these issues.

It should be noted that Theofanous et al. limit their consideration to single FCI events and consider only the probability of alpha-failure of containment. Thus, they do not consider the possibility that a small FCI might disperse the remaining molten corium, providing the mechanism for both significant premixing and the triggering of a second and larger FCI. Also, their calculation of the probability of alpha-failure involves steadily decreasing quantities of FCI energy available to be directed upward in the vessel, to cause failure of the upper head, and to invest the upper head with sufficient upward-directed kinetic energy to fail containment. Finally, left out of consideration is the possibility that an FCI sufficiently energetic to fail the lower and/or upper heads may also disperse molten corium into containment as fine aerosol with the potential to cause direct containment heating.

4.5 Information Needs

An "ideal" strategy for dealing with a degraded core might be to maintain the primary system at high pressure while the core degraded, somehow avoid a natural circulation-induced failure high in the primary system (which would quickly depressurize the RCS), identify when the core had relocated to the lower plenum, and then depressurize prior to breach of the lower head so as to mitigate DCH. By stopping the core into the lower plenum while the RCS is at high pressure, the probability of an energetic FCI is minimized. However, there are

some problems with this scenario. Natural circulation of superheated steam may depressurize the primary system independently of the operator's intent. Even if unintended depressurization doesn't occur, the operator may not have enough information about the state of the degrading core to know what actions to take and when. Finally, even if the operator could identify the moment of core relocation, there might not be sufficient time to depressurize the RCS prior to vessel failure. These problems seriously compromise this "ideal" strategy.

There is a lot of information available to the operators during a severe accident; the problem is that it's not necessarily the information the operator really needs. However, the information is tied together by the fact that all of the measurements are of a system of known dimensions and compositions undergoing a more or less understood evolution subject to the laws of physics and chemistry. The appropriate calculational tools would permit the comparison of plant data against predictions calculated from possible plant damage configurations and significantly improve the operators' understanding of the severe accident progression. These questions are considered in more detail in Section 10.0.

4.6 Plant-Specific Implementation

The potential tools for depressurizing the RCS are 1) heat removal through the steam generators, 2) emergency core cooling system (ECCS) flows, 3) PORVs, 4) letdown flow, 5) RPV head vents, 6) charging pumps, and 7) pressurizer spray. The difficulty is that if the operators are considering depressurization of the RCS during a severe accident (with the core degrading), most likely the plant reached this state because of the unavailability or ineffectiveness of some or all of these tools.

Depressurization using normal pressurizer spray will only be effective if water in the cold leg is subcooled and there is a sufficient pressure difference between the cold leg and pressurizer dome to drive the flow in the spray line (i.e., the RCP in that loop is running). If not, there will be an auxiliary spray flow path, most likely from the charging pump discharge header, which may be able to supply sub-cooled water to the spray valves. The reactor head vents are quite small, intended only for bleeding non-condensable gases from the RCS. The normal

charging and letdown flows are also relatively small, but can be increased several-fold by starting additional charging pumps or opening the letdown flow control valves. The letdown flow reduces both mass and enthalpy in the RCS, thus tending to depressurize the system. The charging pumps add water to the RCS, increasing the inventory in the RCS. However, the water added is significantly subcooled, thus tending to lower the average enthalpy. The ECCS systems can add significant amounts of subcooled water to the RCS, combining the benefits of depressurization, makeup of RCS inventory, and quenching of hot components. The PORVs remove water mass and enthalpy from the RCS, thus depressurizing the RCS, but also tending to uncover or further uncover the core because of the reduction in RCS inventory. Hanson et al. (1990) note a relatively high probability (on the order of $p=0.3$) that a PORV block valve will be closed, because of problem leakage through the PORV. In the event of a station blackout, such closed PORV block valves cannot be opened, preventing use of that PORV as a relief and depressurization pathway. In addition, Hanson et al. note that their late depressurization strategy might require air system modifications to support the frequent cycling of the PORVs prior to initiation of depressurization.

If available, the steam generators are the preferred tool for depressurizing the primary system. The steam generators and the secondary system are designed to remove enthalpy from the primary system; this can be done without some of the disadvantages of dumping large quantities of primary system mass and enthalpy to containment (through PORVs and head vents) or through the letdown flow.

The Calvert Cliffs IREP PRA assumes throughout that, in transient-initiated and small break LOCA accidents, the PORVs are not capable of lowering the RCS pressure below the shutoff head of the high pressure safety injection/recirculation (HPSI/R) pumps (1275 psi) soon enough to prevent core damage. For this reason, most of the core melt risk-significant accident sequences are high-pressure sequences involving the inability to implement primary feed and bleed cooling. Since the time window for action is wider, the Calvert Cliffs PORVs should be adequate to depressurize the RCS during core degradation.

If it is decided that depressurization is necessary and all of the tools discussed above are unavailable or have been unable to effect depressurization, then operators can attempt to create a hole in the primary system pressure boundary. A speculative possibility, if AC power is available, would be to attempt to run an RCP to destruction, thus creating a seal LOCA or some other disruption of the pressure boundary near the RCP. The actual or potential disadvantages of this action include the destruction of a valuable piece of equipment, creation of a LOCA or other damage to the RCS, and possibly providing an ignition source for hydrogen in containment. As such, this action would be taken, if at all, only after careful consideration by the emergency staff in the Technical Support Center.

For the Zion plant, the procedure recommended in the EOP to depressurize the RCS is to use normal pressurizer spray. If pressurizer spray is not available then the RCS should be depressurized using a PORV. If no PORV is working, pressure can be reduced using auxiliary spray, combined with letdown to prevent overfilling the RCS. Since procedures for refilling the RWST are in place at Zion, normal or auxiliary spray should be available. Note that the RCS cannot be depressurized quickly using the pressurizer spray alone, since it only gradually reduces the average enthalpy of primary system inventory.

For the Oconee plant, decisions on operator actions to deal with inadequate core cooling, including depressurization, are based upon fuel cladding temperature, as measured by the core exit thermocouples. If the temperature of the cladding (T_{clad}), based on the average of the five highest reading core exit thermocouple temperatures, is greater than 1800°F, the operator is directed to depressurize the once-through steam generators (OTSGs) as quickly as possible and to depressurize the RCS using the PORV until low pressure injection (LPI) is able to restore core cooling and the core exit thermocouple temperatures indicate a return to saturation temperature.

If a T_{clad} greater than 1400°F but less than 1800°F is indicated by the core exit thermocouple temperatures and primary to secondary heat transfer has not been established, direction is given to open the pressurizer

PORV and depressurize the RCS until the high pressure injection (HPI), LPI, and core flood tanks (CFTs) return the core exit thermocouple temperatures to saturation temperature. If primary to secondary heat transfer is established, direction is given to maintain this heat transfer mode by cycling the pressurizer PORV to keep the RCS pressure 25-60 psi greater than the OTSG pressure.

The OTSG shell-side pressure can be lowered by adjusting the turbine bypass valves (TBVs), while maintaining SG level, until secondary T_{sat} is 40 to 60°F lower than the core exit thermocouple temperature. If primary-to-secondary heat transfer cannot be established, the OTSGs can be further depressurized until the secondary T_{sat} is 90 to 110°F lower than the core exit thermocouple temperature.

For an SGTR with the RCPs running, the RCS is depressurized using the pressurizer sprays. Cooldown is accomplished using the TBVs. Steaming is initiated on the faulted OTSG until the secondary pressure is below 1000 psig and the OTSG level is below 95%. If steaming is not possible, the faulted OTSG can be drained to the condenser to avoid overflowing. The RCS is also depressurized, while maintaining subcooling, to minimize the tube leak rate driving force.

4.7 Evaluation of the Strategy

Reactor Coolant System depressurization involves potential disadvantages and uncertainties:

- Because steam at low pressures is a much less effective heat transfer medium than high-pressure steam, depressurization will cause uncovered core heat-up to proceed essentially adiabatically.
- Available evidence suggests depressurization may increase the probability of "triggering" a steam explosion (energetic FCI) (Berman 1988) at the time of molten core relocation, although it may reduce the amount of "pre-mixing" and, hence, the size of the resulting FCI (Abolfadl and Theofanous 1987).

- Depressurization of the RCS using PORVs while the core is degrading is likely to degrade conditions in containment, which will increase pressure, temperature, hydrogen content, and radionuclide contamination. This may prevent the operating staff from entering containment.
- If containment integrity has been compromised, RCS depressurization may also degrade conditions in the Auxiliary Building or cause releases to the environment.

and potential advantages:

- Depressurization below the shutoff head of ECCS pumps or below the nitrogen pressure in the accumulators may allow addition of water to the RPV using these sources.
- Depressurization will reduce the thermal and pressure challenges to the RCP seals.
- Depressurization will reduce the loss of RCS inventory out any breaches in the RCS pressure boundary.
- Depressurization may prevent or mitigate high pressure melt ejection (HPME) and DCH. This can be particularly important at plants with lower containment design pressures, such as Sequoyah (ice condenser containment).
- Depressurization will reduce the structural challenge to an RPV weakened by high temperature creep, potentially avoiding RPV breach.

On balance, the potential for early failure of a highly contaminated containment, due to the likelihood and potential consequences of HPME and DCH, strongly recommends depressurization as a strategy for mitigating a degrading core. This is particularly true in cases where depressurization will allow water to be injected into the reactor vessel.

PORV and depressurize the RCS until the high pressure injection (HPI), LPI, and core flood tanks (CFTs) return the core exit thermocouple temperatures to saturation temperature. If primary to secondary heat transfer is established, direction is given to maintain this heat transfer mode by cycling the pressurizer PORV to keep the RCS pressure 25-60 psi greater than the OTSG pressure.

The OTSG shell-side pressure can be lowered by adjusting the turbine bypass valves (TBVs), while maintaining SG level, until secondary T_{sat} is 40 to 60°F lower than the core exit thermocouple temperature. If primary-to-secondary heat transfer cannot be established, the OTSGs can be further depressurized until the secondary T_{sat} is 90 to 110°F lower than the core exit thermocouple temperature.

For an SGTR with the RCPs running, the RCS can be pressurized using the pressurizer sprays. Cooldown is accomplished using the TBVs. Steaming is initiated on the faulted OTSG until the secondary pressure is below 1000 psig and the OTSG level is below 95%. If steaming is not possible, the faulted OTSG can be drained to the condenser to avoid overfilling. The RCS is also depressurized, while maintaining subcooling, to minimize the tube leak rate driving force.

4.7 Evaluation of the Strategy

Reactor Coolant System depressurization involves potential disadvantages and uncertainties:

- Because steam at low pressures is a much less effective heat transfer medium than high-pressure steam, depressurization will cause uncovered core heat-up to proceed essentially adiabatically.
- Available evidence suggests depressurization may increase the probability of "triggering" a steam explosion (energetic FCI) (Berman 1988) at the time of molten core relocation, although it may reduce the amount of "pre-mixing" and, hence, the size of the resulting FCI (Abolfadl and Theofanous 1987).

- Depressurization of the RCS using PORVs while the core is degrading is likely to degrade conditions in containment, which will increase pressure, temperature, hydrogen content, and radionuclide contamination. This may prevent the operating staff from entering containment.
- If containment integrity has been compromised, RCS depressurization may also degrade conditions in the Auxiliary Building or cause releases to the environment.

and potential advantages:

- Depressurization below the shutoff head of ECCS pumps or below the nitrogen pressure in the accumulators may allow addition of water to the RPV using these sources.
- Depressurization will reduce the thermal and pressure challenges to the RCP seals.
- Depressurization will reduce the loss of RCS inventory out any breaches in the RCS pressure boundary.
- Depressurization may prevent or mitigate high pressure melt ejection (HPME) and DCH. This can be particularly important at plants with lower containment design pressures, such as Sequoyah (low condenser containment).
- Depressurization will reduce the structural challenge to an RPV weakened by high temperature creep, potentially avoiding RPV breach.

On balance, the potential for early failure of a highly contaminated containment, due to the likelihood and potential consequences of HPME and DCH, strongly recommends depressurization as a strategy for mitigating a degrading core. This is particularly true in cases where depressurization will allow water to be injected into the reactor vessel.

5 Flooding Reactor Cavity to Cover RPV Lower Head

5.1 Description of the Strategy

Flooding the reactor cavity up to the level of the top of the RPV lower head might prevent breach of the RPV after relocation of the molten corium to the lower plenum. Failing that, this strategy might mitigate DCH by quenching and scrubbing the release of molten corium to the cavity.

This strategy would work to prevent RPV breach, if it worked, by changing the outside surface of the RPV from an adiabatic boundary to one with boiling and natural convection heat removal. With an adiabatic boundary (due to the reflective metal insulation on the outside of the vessel), heat will accumulate in the metal of the lower head, raising its temperature and lowering its strength. With heat removal on the outside surface, a frozen corium crust should tend to grow at the vessel-corium interface. This corium crust will tend to insulate the vessel from the high temperatures of the molten corium mass.

If the lower head failed anyway, the mass of water in the cavity would tend to quench the corium ejected through the breach. The phenomenology is complex, however. High pressure melt ejection into a pool of water may result in an energetic fuel-coolant interaction combined with substantial generation of hydrogen from oxidation of metals in the corium.

5.2 Plant-Specific Implementation

Some of the factors affecting the feasibility of this strategy in preventing RPV breach are:

- The amount of erosion of the vessel by a jet of molten corium impinging on the lower head as the molten corium relocates to the lower plenum.
- The heat transfer coefficient between the molten pool, the inside surface of the RPV, and the reactor vessel internals.

- The amount of quenching and fragmentation of the corium when it relocates and the resulting porosity of the mixed molten/frozen corium mass.
- The thermal conductivity of the molten corium, frozen corium, and RPV metal.
- The heat transfer mode (nucleate boiling, film boiling, etc.) at the outside RPV surface and the resulting surface heat transfer coefficient.
- Access of water in the flooded reactor cavity to the surface of the RPV and pathways for removal of the steam generated at the RPV surface (i.e., how tight is the RPV insulation?).
- Ability of the operators to successfully flood the reactor cavity to the level of the lower head of the RPV.

For the Zion plant, the best way to flood the cavity is to use containment spray, drawing water from the RWST tank. This method can supply water over an extended period of time since the RWST can be refilled. One of the containment spray pumps is driven by its own diesel driven pump. As of 1986, it was still dependent on AC for SWS cooling of the diesel and for control. The NRC has recommended that the system be modified to make the diesel and pump independent of AC power. If the RWST has been refilled with unborated water, it can be borated through the make-up water system from three boric acid tanks via boric acid transfer pumps. This system is AC dependent. This strategy is relatively simple to implement at Zion.

5.3 Evaluation of the Strategy

Although the factors described in the previous section are complex, they should be amenable to quantitative analysis. Henry et al. (1991a, 1991b) have performed scoping experiments using small-scale vessels of two different thickness, both with and without reflective metal

insulation, to assess some of the phenomenological issues. The heat source was molten iron thermite dropped into the bottom of the vessel. For their experimental setup, heat removal at the outside vessel surface proceeded by nucleate boiling and there was a sufficient supply of water infiltrating through the insulation seams that the heat flux was limited by thermal conduction through the vessel wall and not by the boiling heat transfer processes on the outside surface of the vessel.

M. Saito et al. (1990) developed a mathematical model for the melt/freeze phenomena occurring when a stream of molten metal falls onto a steel plate and compared the predictions of their model with experimental results. They compared predictions assuming 1) melting of the steel plate combined with crust formation as the molten metal froze against it and 2) the model assuming no crust formation. Experimental results were better predicted by the crust formation model. The crust will form an insulating layer tending to retard melting of the plate. They calculated a threshold temperature for the molten metal above which no crust would form, implying more rapid melt attack on the plate. For a molten UO_2 jet, a temperature well above 4000 K was required to inhibit crust formation. A recent UCLA preprint (Park and Dhir 1991) describes two-dimensional transient and steady-state analyses of this strategy, including the heat

loss by radiation to the upper regions of the reactor vessel and the unwetted portions of the vessel lower head. They concluded that: 1) melting of the unwetted portion of vessel wall is predicted for vessel wall emissivities greater than 0.2 (however, the melting is not expected to propagate further than half the vessel thickness) and 2) for a range of parameters studied, flooding of the cavity may provide an effective means of retaining the core in the vessel.

The issue of whether ejection of the molten corium into a pool of water in the reactor cavity would have unacceptable consequences shares the complexity of FCI issues in general. A potential disadvantage of the strategy, if it succeeded in preventing failure of the lower head of the RPV is that maintenance of the molten corium within the RPV might lead to late failures of steam generator tubes, with concomitant contamination of the secondary system.

Flooding the reactor cavity to some depth (perhaps less than the level of the lower head) is widely cited as a potential or settled strategy for the mitigation of HPME and DCH (Hanson et al. 1990; Kasterberg et al. 1990; Kersting 1990; Espesfält 1989; Lehner et al. 1988).

6 Restoration of AC Power and Provision of Portable Pumping Capacity

6.1 Restoration of AC Power

For station blackout accidents, and to a lesser extent for loss of AC power transients that have proceeded to core degradation, almost all potentially beneficial strategies require electrical power. Thus, strategies to restore either offsite AC power or emergency AC power (or in the loss of offsite AC power transient, protecting against subsequent loss of the emergency diesel generators [EDGs]) are of the highest urgency.

Strategies to restore AC power will depend on the nature of the original transient and the estimated time to recovery (taking into account the uncertainties in time to recovery). It is important to recognize that each failure reduces safety margin and raises the conditional probability that additional failures will cause core damage, core melt, and/or containment failure. This means that a plant suffering a loss of offsite AC power with successful start and operation of the emergency diesel generators may want to arrange for delivery of backup generating capacity as insurance against subsequent failure of the diesel generators. The expected duration of the loss of offsite AC power would obviously figure in this decision.

A utility with multiple nuclear units could purchase a single, centrally located skid- or truck-mounted diesel or gas turbine generator to provide last-resort AC power backup to all of its plants. This generator should be able to reach any plant in the system within a couple of hours. Single unit utilities might join with neighboring nuclear utilities to cooperatively purchase such emergency generators. At least one company (in the Chicago area) maintains sizeable inventories of diesel generators, gas turbine generators, and package boilers. These are available on a 24-hour basis for rent, with delivery by truck or air freight. With appropriate planning this implies availability at any plant in the East within 12 hours and at any plant on the West Coast within 16 hours. A recent call to this company established availability of 18 rental gas turbine generators light enough for airlifting, ranging in power from 900 kW to 3250 kW, and 9 diesel generators, from 500 kW to 2500 kW.

Much smaller portable generators would be capable of supporting critical tasks, such as maintaining DC power to the auxiliary feedwater pump and turbine or maintaining reactor coolant pump seal injection and cooling.

Finally, commercially available uninterruptible power systems (UPSs) and power conditioning systems, could help the essential plant systems ride out short outages and bus failures. Essential AC power systems, which use inverters to produce AC power from Essential DC power busses, serve the same function. Some critical equipment and instrumentation might be protected using commercially available UPSs, which can protect against both electrical line transients and short outages. The protection against line transients is important; without it, operators may restore AC power and discover that critical plant equipment was damaged by the initiating electrical transient and is still unavailable, even though AC power has been restored. An example of critical instrumentation deserving of such protection are the steam generator level sensors. In a station blackout, after depletion of the batteries, it should still be possible to manually operate the turbine-driven auxiliary feedwater (AFW) pump, but knowledge of the steam generator level will be required to manually control that level using the turbine-driven AFW pump.

To assure the feasibility of such backup generation, a utility would need to inventory available portable backup generation; this would include the sources described in the previous paragraph, as well as skid-, truck-, and trailer-mounted generators used by industrial, commercial, and institutional organizations in the utility's service area. A utility might even offer incentives to organizations that generate part or all of their own electricity to use portable generators that would be available to the utility in an emergency. Additionally, the utility would need to plan how to tie such capacity into the plant's AC distribution system, including provisions for bypassing failed switchyard equipment or failed busses in the plant. If the accident has resulted in (or may result in) releases to the environment, the contingency planning should permit operation of the emergency generator at some "stand-off" distance from the plant.

6.2 Plant-Specific Implementation

For the Zion plant, the operators will first attempt to load the emergency AC bus to the EDGs from the control room. If the EDGs start but the emergency AC bus cannot be loaded from the control room, personnel would attempt to load the bus locally. If the EDGs do not start automatically, interlocks must be defeated and the diesels started manually. If the diesels do not start, the operators would attempt to power the emergency AC bus from any available and appropriate AC power supply.

The DC power systems of the three Oconee units are linked through an isolating diode arrangement so that each unit provides a DC power backup for the other units. The DC power systems supply instrumentation and control power through an inverter and are backed for essential loads by the 120-V AC regulated power system. The availability of DC power aids in the recovery of AC power. The wider variety and higher reliability of AC power sources at the Oconee plant render station blackout accidents significantly less likely than at other plants.

At Oconee, emergency AC power can be furnished from several sources, including:

- for certain loss of load transients, turbine runback will allow the Oconee plant's own generator to continue to supply plant auxiliary loads,
- six 230-kV transmission lines serving Oconee from three directions,
- either of the other two nuclear units,
- 100-kV transmission line from the two combustion turbine generators at the Lee Steam Station,
- 13.8-kV underground line from a quick-starting on-site Keowee Hydroelectric 87,500-kVA Generating Unit, and
- 230-kV overhead line from another Keowee Hydroelectric Generating Unit.

The primary emergency AC power source at Oconee is the two hydroelectric units rather than by diesel generator sets. These hydroelectric units are more reliable than diesel generators. More importantly, their large capacity makes it possible to provide emergency power to virtually any load. Thus, load shedding is much more limited and load sequencing is unnecessary. The reliability of the emergency AC power system is further enhanced by the availability of the two Lee Steam Station combustion turbine generators dedicated to Oconee, with separate supply lines to a separate standby transformer.

6.3 Evaluation of the Strategy

Taking action to increase the flexibility and reliability of electrical power supply sources is clearly feasible. The decision on whether and how to implement it in a specific case will need to balance bringing in backup generating capacity from out of town at great expense against the downside risk of continuing to operate with degraded electrical power supply. The probability of additional failures or slow recovery of the lost offsite power may be quite small but the downside consequences are quite large. There are no obvious disadvantages, other than cost, to this strategy, although procedural modifications and additional training would be needed to implement the strategy effectively.

For the Zion plant, the restoration of AC power has a major impact on a number of recovery sequences, as described in the Zion PRA rebaselining report (Wheeler 1986). The impact of restoration is highly time dependent. For example, in one scenario, loss of offsite power followed by loss of Auxiliary Feedwater results in loss of secondary cooling, which is followed by an independent loss of feed and bleed capability due to human error. The restoration of AC power within four hours results in the successful functioning of the containment systems. Restoration later than four hours results in degraded performance of containment systems and higher probability of containment failure. Timely restoration of AC power in certain scenarios increases the probability of containment success by two orders of magnitude.

6.4 Provision of Portable Pumping Capability

Another potential approach to mitigation of station blackout and loss of offsite AC power accidents is the use of portable pumps that are not powered from the plant electrical busses. These pumps could pump water from plant water sources or from offsite water sources (i.e., lakes, rivers, etc.). There is no shortage of portable pumps at or near most nuclear plant sites, so what is needed is pre-planning of access to the pumps and contingent connections to plant piping systems.

For accidents, such as loss of offsite AC, station blackout, loss of main and auxiliary feedwater, what has been lost is not access to water but pumping capability. Provision of portable, independently-powered, pumping capacity can prevent or mitigate severe accident scenarios arising from these initiators. It is necessary to:

1. ensure that the needed motive force is available—even under station blackout conditions, and
2. pre-stage the equipment necessary to allow previously analyzed cross-connections to be implemented quickly enough to be useful in an emergency, and
3. implement appropriate changes to procedures and training
4. assure that the connection of these pumps does not violate containment at a time of potential core degradation.

Equipment needed includes:

Piping - Fire hoses or equivalent (mostly pre-staged at the required locations)

Pumps - Fire trucks (pumper trucks) or pre-staged portable pumps

Connectors - Manifolds or "spiders" on appropriate tanks, pump suction headers, or at natural bodies of water, with connectors appropriately matched to the buses and pumps to be used.

This strategy will tend to provide only low pressure pumping capacity, limited by the pumps available and the pressure limits of the flexible hoses. Higher pressures and higher flows would imply bigger pumps, bigger drivers, and pre-positioned hard piping. Thus, utilization of this strategy will primarily address supporting systems. It would tend to require depressurization of the RCS or the steam generators. Nevertheless, even in high-pressure scenarios, these portable low pressure pumps could be used to refill water tanks and to provide cooling to ECCS equipment and RCP seal injection flow, etc.

6.5 Unit-Specific Implementation

The Zion plant has implemented some aspects of this strategy. The plant has extensive provisions for available cross-connections between the two units, there are two fire system connections. The first is a hard-piped connection between the Fire Protection (FP) system and the emergency diesel generator jacket water cooling system. Upon loss of Service Water, this backup system can be valved in from the control room. The second FP system cross-connection allows FP system flow to the centrifugal charging pump cooling system. This second application uses pre-staged fire hose and connectors and is incorporated into the Abnormal Operating Procedures (AOP-4.1, Rev. 2, 7/31/90). Ample quantities of water are available and the ability to refill the RWST makes this strategy very attractive at Zion.

This strategy can be very useful even if only a limited pumping capability is provided. For example, portable pumps might be used to provide cooling for the diesel generators and/or the diesel powered containment spray pump. The ability to keep the diesels operating might make it possible to restore the service water system (SWS) or continue containment spray.

6.6 Evaluation of the Strategy

Pre-stage portable pumping capacity with judiciously planned cross-connections between plant systems and water sources result in:

Restoration of AC Power

1. A relatively inexpensive upgrade of plant safety and flexibility.
2. Pumping power that is independent of offsite AC and emergency AC.
3. Increased flexibility, which could mitigate other off-normal plant conditions:
 - spent fuel pool level loss
 - refueling cavity seal loss
 - outage and maintenance activities that require unusual system isolations
 - increase redundancy for existing safety systems (e.g., jacket water cooling for the EDGs)

Other than the pressure limitations, there are no obvious disadvantages to implementing this strategy. It should be possible to use existing piping with fully qualified containment penetrations as the pathway for delivering water to the target systems inside containment. The piping connections needed to assure quick connection of the portable pumps are relatively modest. Certainly any such changes increase the complexity of the plant and would require changes in procedures and additional training. In addition, each added connection to plant piping systems and each new cross-connection between plant systems may introduce possible plant evolutions with un-analyzed safety impacts. These potential problems can be minimized by assuring that these cross-connects will be used only under clearly identified and specified circumstances, which can include severe accidents in which the potential consequences of the accident swamp the uncertainties involved in using the cross-connect.

7 Prevention and Mitigation of RCP Seal Failures

7.1 Description of the Strategy

This section describes some strategies from a paper by Cheng (1989) for preventing RCP seal failures subsequent to loss of Component Cooling Water (CCW) or loss of service water. If seal injection is still available (i.e., the centrifugal charging pumps are still available), feed and bleed operation of the CCW may maintain sufficient cooling of the centrifugal charging pumps (CCPs) to protect the seals. If not, alternate cooling water for the CCPs needs to be established. If neither of the above is possible, then an emergency cooldown of the primary system will mitigate the effects of RCP seal failure.

7.2 Plant-Specific Implementation

Cheng's paper describes analysis of preventive and initiative strategies implemented for the Taiwanese Maanshan plant, a 3-loop Westinghouse PWR. The methods described should be generally applicable to other Westinghouse plants and to other PWRs.

Cheng notes that experiments and analyses by Westinghouse, the Energy Technology Engineering Center, Atomic Energy of Canada Limited, and Electricite de France all suggest that RCP seal failures under loss of seal injection or seal cooling will occur later and result in lower LOCA flow rates than generally assumed in safety analyses and PRAs. He also discusses potential recovery actions discovered while performing a Level-1 PRA on the Maanshan plant.

If the initiating event is loss of service water (i.e., CCW pumps are still available), causing loss of shell side heat removal in the CCW system heat exchangers, then feed and bleed operation of the CCW may remove enough heat to keep the CCPs operating, hence maintaining RCP seal injection flow. This is accomplished by feeding cold water from the condensate storage tank into the CCW surge tank, where it mixes with the hot CCW system inventory. The mixed water is pumped through the heat exchanger where some is drained off through the

shell vent valve and the rest continues to the various emergency loads, particularly the charging pumps.

If there is not a CCW pump available, or if the CCPs begin to overheat, then the operator should try to establish alternate sources for cooling water to the CCPs. At Maanshan, water from a demineralized water storage tank (DST) can be lined up by hose to supply cooling water to the ECCS pumps and the containment spray pumps. If operation of the CCPs can be maintained, no seal LOCA is expected and the operator can proceed to a natural circulation cooldown.

If the CCPs fail (early or eventually), then the operator should initiate depressurization and cooldown of the RCS, either a normal natural circulation cooldown or an emergency cooldown, as necessary. During the cooldown, the operators can establish alternate cooling of the RHR pumps from the DST and alternate RCP seal injection using the hydrotest pump. The alternate seal injection may prevent or mitigate development of the seal LOCA. Alternate cooling to the RHR pumps may allow makeup to the RCS (after the depressurization) even if the seal LOCA develops.

The analysis of core damage frequency in the Zion PRA rebaselining (Wheeler 1986) assumes that a 300 gpm leak will develop per pump one hour after loss of service water cooling to the seals. Once this seal LOCA occurs it is assumed that the core will be uncovered in one hour.

Reduction of RCS pressure will reduce the leakage through the seals and reduction of temperature will reduce the thermal degradations of materials. The use of feed and bleed of CCW to protect the charging pumps can in turn protect the RCP seals. That protection can also extend to the capability to perform primary feed and bleed cooling. At Zion, the 550 gpm charging pumps have a maximum discharge head of 2670 psig. Since the lift setting for the safety relief valves is 2435 psig, the feed and bleed capability exists even if no PORVs are available. Procedures for feed and bleed operations are in place at Zion.

If AC power is restored after having been lost, flow to the seals should be restored slowly to prevent thermal shock to the seals, bearings and pump shafts. The operators should defeat the automatic loading of the charging pumps onto the AC busses, so that flow to the RCP seals can be controlled by the operators.

The Oconee PRA assumed that seal leakage could reach approximately 100 gpm per RCP within about an hour if the RCPs continue to operate without seal injection and either the seal return line is isolated or component cooling fails. If the RCPs were tripped within 15 minutes, seal leakage is estimated to be substantially less, no more than 15 gpm per RCP after about an hour.

Low pressure service water (LPSW) provides motor cooling to the RCPs, CCW cools the RCP thermal barriers, and HPI cools the RCP seals. LPSW also provides cooling for the HPI pump motors and the CCW heat exchangers. In the event of LPSW failure, backup cooling flow could be made available either from the LPSW of Units 1 and 2 or from the high pressure service water (HPSW), which supplies the fire protection headers in all three units. The HPSW normally takes suction from the condenser circulating water crossover line, but a

100,000 gallon elevated storage tank can provide a backup water supply. The operator recovery actions to provide backup flow to LPSW require local manual operations of cross-connection and/or isolation valves.

In addition, the Standby Shutdown Facility (SSF) can be used to provide RCP seal cooling independent of the above systems. The spent fuel pool can be used as a suction source for RCP seal injection and RCS makeup.

In CE plants, CCW provides cooling to the RCP mechanical seals, but not seal injection.

7.3 Evaluation of the Strategy

The strategies discussed in this section are mostly preventive strategies, aimed at preventing or mitigating RCP seal LOCAs in accident sequences involving failures of the CCW system. Their implementation uses existing plant equipment and parts of these strategies are already implemented at the plants considered in this report. The only obvious disadvantage is the potential for damage to the RPV and RCS piping from the emergency cooldown, if it is needed.

8 Maintaining Forced Circulation Through the Core

8.1 Description of the Strategy

This section considers the maintenance of forced flow under conditions that might "normally" require shut-down of the RCPs. During the TMI-2 accident, operators shut down the last operating RCP at 100 minutes into the accident because of vibrations caused by the two phase fluid it was pumping. Prior to this shutdown, the TMI-2 core was being successfully cooled by the forced circulation of the two phase coolant. Upon pump shut-down, the core quickly uncovered, started to heat up, and then to degrade. When RCP flow was reestablished at 174 minutes into the accident, core degradation had proceeded so far that the consolidated region of molten core was not coolable and the region of the core above it fragmented due to thermal shock and zirconium burning into a porous debris bed.

Competing criteria affect whether RCPs should continue to operate after a LOCA. The pump head may cause inventory to be lost through the break as a liquid flow, rather than a steam flow. Since steam flow will be limited by sonic choking of the flow, liquid break flow will result in greater inventory loss. If the pumps are tripped, then the RCS will be stagnant or naturally circulating, if pressure drops in the RCS to less than the saturation pressure corresponding the average specific enthalpy in the system, then water will start flashing throughout the system. The resulting steam will tend to collect in system high points, perhaps interrupting any natural circulation. If the RCPs are running, the steam resulting from the flashing will tend to circulate with the rest of the coolant as a two phase mixture.

In the absence of serious vibration, operators should attempt to maintain some level of forced circulation, if only to buy time for other mitigative strategies. Consideration should be given to "toggling" or "bumping" the RCPs, i.e., starting an RCP, bringing it up to full speed, then tripping it off and letting it coast down. This process should be continued as long as possible, perhaps rotating between several of the RCPs. As noted, running the pumps may cause the break flow to be liquid, increasing the rate of inventory loss. This will also cause

the system to depressurize faster, eventually allowing makeup from the accumulators and the low pressure injection systems.

Karassik (1989) recommends that operators continue running steam-bound boiler feed pumps until proper suction conditions can be re-established. This recommendation goes counter to accepted practice of stopping a steam-bound pump immediately and not restarting it until proper suction conditions exist. He notes that he knows of no authenticated case of a high pressure boiler-feed pump seizing at full speed because of a flashing suction. When pumps have seized, it has been while coasting down after being tripped. He proposes three theoretical reasons for this assertion. First, with the pump running, there is sufficient driving torque to pull through momentary contacts between shaft and bearing caused by vibration. Second, the continuing presence of fluid (albeit, steam) in the pump body tends to damp out vibrations. Third, as a pump coasts down after being tripped, it may pass through a critical frequency, at which the resonance vibration will be worse than usual because it is undamped by liquid in the pump. By continuing to operate the pump under these conditions, it is simply being operated as a steam compressor. In another context, Karassik notes that cavitating flow conditions in a pump can be mitigated somewhat by adding a small amount of non-condensable gas to the pumped fluid (Karassik et al. 1976). In some low-pressure accident scenarios, operators would have access to the nitrogen remaining in the accumulators after the water in the accumulators has been blown-down into the RCS. Karassik notes that this strategy for mitigating cavitation is rarely used because of the difficulty in injecting just the right amount of non-condensable gas.

A related consideration is the possibility that continued operation of the RCPs, even just "bumping" them occasionally, may bias the flow and heat transfer regimes in the RCS toward natural circulation and other regimes offering significant levels of heat removal through the steam generators. Recently, di Marzo et al. (1988) described a thermal hydraulic regime occurring in small-break LOCAs. This regime, which they call Interruption and Resumption Mode (IRM), was demonstrated

in a test facility prototypical of a B&W PWR. The authors make the following observations about this thermal hydraulic regime:

1. It cannot be predicted on the basis of local conditions in the RPV, the loop seals, the OTSG, or the hot and cold legs; the RCS has to be treated integrally.
2. The (flow) interruption phase of IRM involves the growth of saturated or superheated steam bubbles in the vessel downcomer or the cold legs that are, temporarily, insulated from subcooled coolant.
3. The (flow) resumption phase of IRM involves the breakdown of that insulation and rapid condensation of the bubbles, with the resulting mild water-hammer causing resumption of flow through the loop seals, the candy cane, and the OTSG.
4. The system shows signs of chaotic dynamics. "Tests repeated at the same initial conditions showed that bifurcations which alter the transient trajectory can occur."
5. The resumption phase produces efficient heat transfer in the OTSG, which is capable of removing all of the heat that had built up in the system during the interruption phase.
6. Increased water level in the shell-side of the OTSGs reduces the amplitude and the duration of these oscillatory flows.

Relevance of IRM to the present evaluation is speculative. It is possible that continued operation of the RCPs and continued forced circulation in the RCS (even in "bumping" mode) may bias the system toward flow regimes such as natural circulation, "reflux" cooling, or IRM which offer effective heat transfer through the steam generators. More work is needed on the true limiting conditions for RCP operation and the impact of continued operation on loop thermal hydraulics under accident conditions.

8.2 Plant-Specific Implementation

At the Zion plant, RCPs could be manually started and allowed to coast down using normal procedures. There are no specific restrictions in the procedures; however, if seal cooling has been lost and reestablished, it is important to throttle back the charging pumps so that the seal and pump shafts are not damaged by thermal shock. Thermal shock of the RCP shafts could result in shaft deformation which could in turn damage the RCP by causing severe vibrations.

The obvious advantage of this strategy is that it can delay further core degradation and this, in turn, may provide the time to restore other functions that could limit the severity of the accident. Since there has been no study reported on the effects of "bumping" the Zion RCPs, it is difficult to assess the trade-off between using this technique to delay further core damage vs. the possibility of disabling the pumps, thus making them unavailable should plant conditions change so that they could be restarted. If this strategy were implemented on one pump at a time, rotating among the pumps, the chances that all pumps would be damaged beyond use seems very remote.

At the Oconee plant, during a loss of offsite power, the RCPs are load shed. However, with the large capacity of the Keowee hydroelectric units, load shedding is less extensive than for plants which use EDGs.

The Babcock and Wilcox (B&W) abnormal transient operating guidelines (ATOG) provide directions on the best methods of operating the RCPs. The RCPs are tripped during a small break loss of coolant accident (LOCA) if the subcooling margin is lost. However, as long as the pumps continue to run the core will be cooled by the steam and water mixture circulating through the core. If the pumps are tripped at a later time, when little liquid remains in the RCS, the steam and water remaining in the vessel and loops will separate. Steam will collect in the high points and water will collect in low points. If enough water does not collect in the vessel, the core will be uncovered, will not be

adequately cooled, and core damage will result. Based on the above rationale, the B&W ATOG states that the RCPs must be tripped immediately when the subcooling margin is lost, but if the RCPs are not tripped immediately (within 2 minutes of loss of subcooling margin) they should not be tripped at a later time and at least one RCP in each loop should be operated. If severe inadequate core cooling (ICC) conditions exist the B&W ATOG directs that the RCPs must be restarted even if mechanical damage can occur. The ATOG also suggests "bumping" the RCPs (i.e., start and run a RCP for 10 seconds then shut it off) to start/restart natural circulation. If there is enough water in the RCS this should initiate natural circulation. Under saturation conditions "bumping" may or may not start natural circulation, but it will help depressurize the RCS by condensing reactor coolant steam in the steam generators and allow more HPI to flow into the system. If natural circulation does not start after four "bumps" over an hour period, then the ATOG directs running one RCP as long as one OTSG is available as a heat sink.

At Sequoyah and Zion, cooling of the pump motor windings is provided by air flow induced by an impeller attached to the pump shaft. This cooling air is cooled by a heat exchanger after it has passed over the windings (thus, the heat exchanger is really keeping the air in the pump enclosure cool). A routine of "bumping" the pumps and letting them coast down would expose the windings to 5-10 seconds of high heating (because of high startup amperage) followed by a couple of minutes of cooling with no electrical current in the windings. It may be possible to continue this routine indefinitely.

The Combustion Engineering EPGs CEN-15² (p. 1-51ff) provides guidance for tripping and restarting RCPs that tends to keep RCPs running in all sequences except the large break LOCA and a specific size range of hot leg LOCA.

The Generic Issue document for RCP Trip/Restart found in the Executive volume of the Westinghouse Owners Group ERGs (1983) gives the clearest description of the Westinghouse Owners Group approach to use of the RCPs during severe accidents. Basically, they recommend continuing to operate the RCPs during all upset and accident situations, except for the initial response to certain SBLOCAs, for which case several possible RCP trip criteria are described. These trip

criteria are preemptive, in the sense that they provide for an early trip of the RCPs in SBLOCA scenarios in which a later, inadvertent trip of the RCPs would lead to rapid core uncover and cladding heatup. The criteria are chosen so that they will require an RCP trip in the specific SBLOCA scenarios, but not require an RCP trip in SGTR and non-LOCA transients. The document notes that best estimate analysis shows acceptable peak cladding temperature for all LOCAs and transients, without tripping the RCPs, but the conservative Appendix K criteria require RCP trip for the specific range of SBLOCA sequences. In any case, RCP operation is required in the event of inadequate core cooling (core exit thermocouple readings above 1200°F and secondary system depressurization not succeeding) or imminent pressurized thermal shock (when the RCPs are used to mix the cold safety inject flow with previously stagnant hot RCS inventory). If the RCPs have been tripped in response to a SBLOCA and the sequence later degrades to inadequate core cooling, the ERGs require restart of one or more RCPs, even if the RCS is highly voided.

8.3 Evaluation of the Strategy

The rapidity with which the situation at TMI-2 deteriorated after minute 100 of the accident when the last RCP was tripped off, suggests careful consideration of RCP operation guidelines that focus more on protecting the core than protecting the RCP. The worst thing that can happen from continuing to operate the RCPs in cavitating and steam-binding conditions is catastrophic failure of one or more of the pumps. To the extent that this (or these) failures create LOCAs, they will tend to depressurize the RCS, leading toward the low pressure, large-LOCA sequences that all contemporary PWRs were designed to accommodate.

Certainly, the thought that one or more RCPs were destroyed in an accident that might have been controlled by other means while protecting the RCPs would not be a pleasant one for the utility management. However, as discussed in Section 6.3, accident management decisions should be made with appropriate consideration of the downside risk of the various alternatives. If the accident sequence has led to cavitation or steam binding conditions in one or more of the RCPs, then the conditional probability of core melt is already much larger than

under normal conditions. This higher conditional probability leads to significantly higher economic and public safety risks in the only relevant context, that of the accident situation the operators are facing at that moment. These higher risks should tend to tilt decision criteria away from protection of valuable assets, such as the RCPs, and toward protection of the core, the containment, and the environment surrounding the plant.

The Westinghouse Emergency Response Guidelines, the CE CEN-152, and the B&W ATOG all reflect a heightened awareness of the need, under some accident conditions, to operate RCPs under conditions of cavitation, flashing, and vibration that would normally require their shutdown.

9 Feed and Bleed as a Severe Accident Management Strategy

9.1 Secondary Feed and Bleed

This strategy will not be described in detail since it is generally covered adequately by the EPGs and EOPs.

9.2 Plant-Specific Implementation

Vendor EPGs and plant EOPs and abnormal operating procedures (AOPs) use secondary feed and bleed as a strategy for continuing to cool the RCS through the steam generator, in the event that the main condenser is not available. Secondary feed and bleed, dumping steam to the atmosphere and supplying feedwater from any available source, is preferred to primary feed and bleed, which amounts to an operator-induced LOCA.

Secondary feed and bleed procedures are included in the Zion EOPs.

At the Oconee 3 plant, the TBVs are used for steaming the OTSGs and feedwater is typically provided by emergency feedwater. Backups to the emergency feedwater system include: 1) cross-connections from Units 1 and 2, 2) service water, and 3) SSF auxiliary service water system (ASWS). The SSF ASWS takes suction from the Unit 2 condenser circulating water line and is a completely independent backup source.

9.3 Evaluation of the Strategy

As noted previously, RCS heat rejection to the secondary through the steam generators is the preferred strategy. It requires a pathway for RCS heat removal through at least one steam generator. If possible, this is done with heat removal from the secondary through the main condenser and with normal feedwater supply. If heat cannot be rejected at the main condenser, then steam is dumped to the atmosphere and secondary inventory is made up using whatever feedwater sources are available (secondary feed and bleed). If secondary feed and bleed is successful, it should prevent core melt.

A potential adverse effect of this strategy is the possibility that feed and bleed cooling of the secondary will subject steam generator tubes to thermal shock causing an induced SGTR sequence, with its implication of containment bypass.

9.4 Primary Feed and Bleed

This strategy will not be described in detail since it is generally covered adequately by the EPGs and EOPs.

9.5 Plant-Specific Implementation

The Calvert Cliffs IREP PRA assumes throughout that, in transient-initiated and small break LOCA accidents, the PORVs are not capable of lowering the RCS pressure below the shutoff head of the HPSLR pumps (1275 psi). For this reason, most of the core melt risk-significant accident sequences are high pressure sequences involving an inability to implement primary feed and bleed cooling. One possible way of raising this shutoff head a bit would be to align the discharge of the low pressure injection pumps or the containment spray pumps to the suction of the high pressure pump, which should raise the shutoff head of the HPSLR pump to around 1425 psi. This strategy would appear to be feasible both in the injection phase and the recirculation phase of an accident, but would require complicated operator manipulations of cross-connecting lines.

Primary feed and bleed procedures are included in the Zion EOPs. As already noted in Section 7.2, feed and bleed cooling in the CCW system may maintain cooling to the charging pumps, thus maintaining the capability for primary feed and bleed using the charging pumps and the PORVs or the letdown flow.

For the Oconee plant, if secondary side heat removal is not established, the Oconee ATOG directs the establishment of HPI cooling. This is accomplished by initiating HPI, opening the pressurizer PORV, and

running one RCP per loop (as long as adequate sub-cooling margin is maintained).

Finally, some plants (Combustion Engineering System-80 plants) have no PORVs. For these plants, depressurization must be implemented using heat removal through the steam generators or by means of feed and bleed cooling using the charging pumps, pressurizer spray, and letdown system.

9.6 Evaluation of the Strategy

Primary feed and bleed is a major contingent method of removing heat from the primary system. Its feasibility

and effectiveness depend on the availability of bleed pathways and sources of inventory makeup. At some plants for some accident sequences primary feed and bleed may be blocked by the inability to depressurize the plant sufficiently to permit sufficient inventory makeup. The major disadvantage of primary feed and bleed cooling is that it amounts to an operator-created LOCA, contaminating, heating, and pressurizing containment, and requiring inventory makeup to prevent core uncover and core degradation.

10 Creation of a Core Damage Assessment Capability

10.1 What is Meant by Core Damage Assessment Capability?

This is intended to be a collection of tools for assessing and drawing conclusions about the state of the core and the RCS by evaluating the available information in its entirety. It is not intended to require extensive modifications or additions to plant instrumentation.

After TMI-2, the NRC required utilities to significantly upgrade their ability to identify and evaluate inadequate core cooling. All PWRs were eventually required to have in place redundant, qualified, Class 1E instrumentation to determine subcooled margin, temperatures at the core exit, and RPV coolant level. Anderson (1989) has described industry responses to these NRC initiatives. Combustion Engineering developed a heated junction thermocouple (HJTC) instrument for measuring RPV coolant level. Westinghouse developed a differential pressure-based level detector, the Reactor Vessel Level Instrumentation System (RVLIS). After review and testing by the NRC, these systems were given preliminary, generic approval and have been adopted by many CE and W owners. National Nuclear Corp. developed and tested at the Farley plant a level detector based on ex-vessel neutron detector measurements. This was reviewed by the NRC and judged not to provide consistent and reliable measurement of vessel levels under all conditions of interest. A few plants have installed level detectors, developed by Technology for Energy Corp., based on strings of gamma thermometers arrayed in a vertical probe, providing indications of liquid or vapor conditions at a number of discrete elevations. This system has been reviewed and approved by the NRC. Babcock & Wilcox (B&W) plants are using differential pressure-based detectors to determine both RPV and hot leg/candy cane levels.

Utilities have tended to bring display of these instruments into the control room through the Safety Parameter Display System. Utilities and vendors have been required to test and modify the level instruments and core exit thermocouples, as necessary to assure adequate reliability and accuracy.

Regulatory Guide 1.97 (NRC 1980) states implementation approaches that the NRC is prepared to accept for the provision of instrumentation to monitor conditions in the plant and its environs during and following an accident. The objectives of this monitoring are:

1. provide information needed for the operators to take pre-planned manual actions to accomplish safe plant shutdown;
2. determine whether post-accident actions and systems are performing their intended functions;
3. provide information to the operators to permit them to determine if a gross breach of barriers to radioactivity release might occur or has occurred;
4. furnish data on the operation of important plant systems; and
5. provide information on the release of radioactive materials.

The Reg Guide requires that the instruments be designed so that they are always on scale during and after an accident. They are required to survive the accident environment for the length of time their function is required. The Guide identifies the minimum number of variables to be monitored by control room operating personnel during and after an accident. It classifies instruments into five types and three categories. For the most important variables, Type A and Category 1, the Guide requires that the data monitoring function not be susceptible to single failures; that the instruments be energized from station standby power; and that continuous indication be provided and recorded. Plants going into operation after June 1983 are required to meet the requirements of the Reg Guide; plants going into operation before that time are required to meet the requirements with some modifications.

Taken together, these post TMI-2 actions are intended to assure that a rich body of information about the plant will be available to help operators and Technical Support Center staff determine the appropriate course of

action during and after an accident. There remain, however, numerous difficulties with assessing the status of a degrading core. In-core instrumentation is mostly designed to provide information about neutron flux levels and mid-core or core exit temperatures; while it is important to know that the reactor is subcritical, these flux levels do not directly tell the operator much about the status of a degrading core. Thus, the operator is left with trying to draw conclusions about core damage progression from measurements of various parameters taken at some distance from the core.

All is not lost, however. Forensic analysis of signals from the ex-vessel flux detectors during the first four hours of the TMI-2 accident yielded a picture of reactor vessel level consistent with that derived from the analysis of other plant data (Wu et al. 1989). This was possible because the ex-vessel detectors responded directly to gamma radiation generated in the shutdown core and to photo-neutrons generated by interaction of the gamma radiation with deuterium in the coolant. For both these signals, the source strength and the shielding are affected by coolant level in the core and in the downcomer. Adams and Berta (1980) indicate that self-powered neutron detectors (SPNDs) can also provide qualitative indication of RCS coolant density and vessel level. These SPNDs, present in the core of some PWRs, will indicate directly if the reactor has not been shutdown. If it has been shutdown, the neutron signal will go off-scale low, although there is some indication that extremely sensitive amplifiers ("pico-amplifiers") can measure this signal. With the reactor shut down, the SPNDs become much more sensitive to temperature variation than they are to neutron fluctuations. As with the ex-vessel flux detectors, forensic analysis of SPND signals provided a picture of in-core temperatures during the heat-up, dry-out, and melt-down of the TMI-2 core (Broughton et al. 1989) that is consistent with data from the core exit thermocouples.

As indicated above, all plants have core exit thermocouples (CETs). They can provide valuable information about the condition of a degrading core, although Adams and McCreery (1984) report a substantial time lag and clad temperature under-representation in the detection of cladding heat-up by the core exit thermocouples in the Loss-of-Fluid Test (LOFT) facility. They attribute the time lag to a film of water coating the thermocouple, which has to be boiled away by the

superheated steam exiting the core before the thermocouple can respond. The under-representation is attributed to intervening heat transfer from the steam to cladding and core internals high in the core prior to the steam arriving at the CET.

Because of the joint sensitivity of flux detectors to both neutrons and gammas, a flux detector located under the RPV (or a gamma detector low in the reactor cavity) would respond very strongly to relocation of molten corium to the lower plenum. Prior to relocation, both neutrons and gammas are substantially shielded from the detector by the water in the lower plenum. After relocation, there is little shielding for either the gammas or photo-neutrons. Ex-vessel flux detectors, located outside the vessel (at, above, or below the core mid-plane), show a similar response, although much reduced, to core relocation. The source range monitors at TMI-2 showed a doubling of response at 224 minutes into the accident, which correlated with temperature and pressure indications of the relocation of molten corium to the RPV lower plenum.

Mass and energy accounting combined with flow rates, pressures, and temperatures throughout the RCS and containment can potentially provide a very complete picture of break sizes and RCS inventory. Hydrogen and gamma spectroscopy analysis of RCS coolant samples can indicate cladding oxidation, clad failure, and fuel pellet temperatures.

Implementation of this strategy would involve the creation of calculational tools allowing the kinds of forensic analyses done after the TMI-2 accident to be completed in real-time during a future accident. This would be analogous to tomography, in which a detailed picture of plant status is "unfolded" from a collection of integral measurements. Specific subroutines can be developed to calculate 1) containment pressure and temperature response to LOCA blowdowns, 2) heat transfer to vessel, RCS, and in-containment structures, 3) hydrogen generation as a function of clad temperature and steam supply, 4) ex-vessel flux detector response to neutron and gamma sources and vessel and downcomer level, etc. The results of these calculations and other plant data can be integrated with an expert system which incorporates physical, chemical, and temporal relationships that have to be satisfied during any developing accident. Use of the expert system would enforce a consistent (i.e.,

consistent with the plant design, prior history of the transient or accident, and the laws of physics and chemistry) interpretation of the available data.

For some phenomena, collections of measurements may be determined by the geometric configuration of the core and the recent history of water level, coolant density, pressure, etc. This would be true of the collection of ex-core and in-core flux measurements, for instance. Artificial neural networks (ANNs) have been used successfully in similar applications of adaptive pattern recognition. Similarly ANNs could be used to create or "capture" functional relationships between plant parameters and measured variables, on the one hand, and output variables descriptive of plant status during an accident. An artificial neural network is "trained" or "learns" these relationships by exposing its input and output "leads" to the matching input-output data vectors and letting the learning algorithm gradually build the mathematical fit that ties the corresponding input and output together. This approach has been used successfully to identify patterns in noisy visual data or audio data. Such patterns might be, for example, letters in optical character recognition, "targets" in radar or television or sonar signals, or phonemes (or syllables) in speech recognition. In the nuclear plant severe accident context, the types of patterns we would like to be able to identify include:

1. the type of accident underway, as a function of the set of alarms and the values of basic plant variables and
2. the condition of the core as a function of flux, thermocouple flow, pressure, and level measurements.

As these words were being written a journal article arrived in the mail (Klopp 1990) discussing industry approaches to Individual Plant Examinations (IPEs) and to accident management planning. On the issue of calculational tools, Klopp discusses several possible approaches being considered. These include:

1. Placing the Modular Accident Analysis Program (MAAP) code at each on-site and off-site emergency response facility.

2. Tying MAAP in with the plant computer, so that the input decks are written automatically to reflect current plant status.
3. Creating a "library" of MAAP runs that would depict the (calculated) plant response to a large number of severe accident scenarios.
4. Finally, "[w]e are currently conducting feasibility studies on the potential use of artificial intelligence (AI) systems (including neuron hybrids) as a means of collecting and presenting such a mass of information.... The AI system could "learn" the library content, complete with identifiers for various key conditions, and be available to serve as a backup to on-line MAAP runs."

The neuronic hybrids referred to by Klopp would be AI systems containing ANNs as pattern recognizing components. The ANN components typically require lengthy training, but, once trained, respond very rapidly to any given input. As with natural neural networks (i.e., nervous systems), they sometime make mistakes but perform very well with noisy or degraded input data, conditions not unlikely during a severe accident.

10.2 Plant-Specific Implementation

Westinghouse plants have ex-vessel flux detectors and movable in-core fission chamber flux detectors. The movable detectors could apparently be "parked" below the vessel to detect relocation. There are also core exit thermocouples.

Babcock & Wilcox plants have ex-vessel flux detectors, fixed in-core SPNDs, and core exit thermocouples. Many of the diagnostic criteria in the B&W Abnormal Transient Operating Guidelines (ATOG) emergency response guidelines (B&W 1982, B&W 1985) are based on core exit thermocouple readings.

Combustion Engineering plants have ex-vessel flux detectors, fixed in-core SPNDs, and core exit thermocouples.

10.3 Evaluation of the Strategy

The creation of calculational tools to help operators and technical support staff understand the evolution of a severe accident is widely recommended, but, to date, not implemented. The proposed system described in Section 10.1 is more extensive than previous recommendations, but uses components which are well-understood, or on the way to being well-understood. The calculation modules or subroutines are identical to, or simplified versions of, modules used in today's accident analysis codes. The uses and limitations of expert systems are becoming reasonably well-understood and the knowledge needed to build reliable and logically valid expert systems is becoming more wide-spread throughout industry, academia, and the regulatory community. Artificial neural networks build on a body of research dating back 50 years and have been the subject of intensive and widespread research for the last ten years.

A substantial effort would be required to knit the tools described together with data derived from experiments and code analyses to form an integrated tool that could help operators and technical support personnel understand, in real time, an evolving accident. The challenge is to create a tool that can do for the operators in real time what the TM¹-2 forensic analysis did in months and years of experimentation, reflection, code development, and analysis. The potential benefits of transferring the developing understanding of severe accident phenomena from the research community to operating plants are also substantial.

11 Human Factors Considerations in Severe Accident Management

11.1 Introduction

While considerable effort has been expended to study the behavior of nuclear power plants under severe accident conditions and to develop strategies to deal with this class of accidents, less attention has been paid to the human's role in carrying out the severe accident strategies being developed. In fact, many of the human factors considerations discussed below are significant enough to jeopardize the success of any severe accident strategy. Among the most significant problems are:

- The information available to plant personnel in the control room and Emergency Response Center during a severe accident about conditions within the core and in containment is often very limited and may be unreliable.
- The implementation of severe accident strategies may require the auxiliary operators, maintenance personnel, instrumentation technicians, and others to perform tasks, such as diagnosing faults and locally operating equipment under extreme conditions, without adequate technical data, prior training, or experience.
- Managers at all levels in the organization will be faced with decision-making situations unique to severe accidents.
- Firm criteria will be needed for when (or if) decision-making authority passes from the operating crew on duty at the time of the accident to the management and technical personnel assembling in the Technical Support Center during the accident.
- The lack of procedures and reliable technical information about plant behavior under severe accident conditions fundamentally changes the roles of plant personnel and the decision-making process.
- Personnel may be required to work under conditions of high physiological stress including heat,

noise, high radiation levels, high humidity, toxic fumes, smoke, and/or communications overload.

11.2 Approaches to Mitigate Human Factors Problems

The following approaches can make a major contribution to an effective severe accident management program:

1. Development of decision aids for determining when to invoke severe accident strategies.
2. Development, testing, validation, and verification of Job Performance Aids (JPAs) for severe accident mitigation.
3. Development of a training program for choosing and implementing severe accident strategies.
4. The design, development, and testing of special equipment and tools to be used by personnel working under hazardous conditions associated with severe accidents.

11.3 Implementation of These Mitigating Approaches

Since severe accidents by definition go beyond the design-basis accidents and off-normal events covered by technical guidelines and procedures, the mechanisms that have been developed for utilities to respond to emergencies may require extensive adaptation to the unique circumstances of severe accidents. These adaptations will include the development of job performance aids that differ in their basic orientation from conventional EOPs. Existing decision aids such as the Safety Parameter Display System (SPDS) may require modification of the organizational structure developed on the basis of NUREG-0654 for responding to emergency events.

Approach #1: Decision Aids for Declaring Severe Accident Status

One of the most important factors in implementing any strategy for severe accident management is deciding when and who makes the decision that it is time to deal with the situation at hand as a severe accident. This key decision will determine when the focus of activities will shift from "normal" procedures for dealing with emergencies and off-normal events to implementing strategies to deal with core melt, core displacement, and severe challenges to containment integrity. The lack of reliable information on the status of the core can make this a very difficult decision. Thus, problem recognition becomes a matter of making a judgment based on multiple data sources, most of which are indirect and of unknown validity.

Since humans are relatively poor at making complex decisions under conditions of stress and limited information (although humans are arguably better at it than anything else but post facto investigating commissions), a useful approach would be to develop decision aids. Any dependence of these decision aids on particular computational resources or plant instrumentation needs careful consideration, since both may be unavailable in some severe accidents such as station blackouts. There are several possible approaches to this dependence. A series of graphs or nomographs could be developed that represent various severe accident scenarios. These would be based on plant data that would be available at some point in the event sequence, such as data trends over time (e.g., temperature, pressure, status of injection systems, etc.). Calculations can be implemented in programs that run on programmable calculators or battery-powered portable computers.

In order to develop a problem recognition decision aid, a process of knowledge engineering must take place. This includes identifying the relevant physical parameters in the plant, time constants for consideration, alternate sources of data should the plant information systems fail, and development of decision rules. This latter step would be based both on analyses of past severe accidents, on-going research, and modeling exercises. As with all decision aids, the feasibility of a severe accident problem recognition aid depends on the thoroughness of analysis. Since all possible contingencies cannot be anticipated, the development of decision aids

should concentrate on heuristics, i.e., general rules for assessing the plant state. The effectiveness of such decision aids can be evaluated in exercises in which persons attempt to diagnose plant status and take actions using such decision aids.

The goal in the development of this decision aid would be to design, develop, and test relatively simple decision aids in the form of graphs, nomographs, decision matrices, decision trees, simple thermal hydraulic calculations, or similar devices that would be independent of the availability of plant computers or plant power.

Approach #2: Job Performance Aids for Accident Mitigation

Once it is recognized that a severe accident is in progress, steps must be taken to minimize the probability of major releases that endanger public safety. It is unlikely that elaborate step-by-step written procedures would be useful in severe accident scenarios, even if they could be developed. Rather, the strategy should be to develop JPAs to facilitate accident management by aiding both the inductive and deductive reasoning processes of the decision-makers. The step-by-step sequences of actions used in conventional operating procedures should be minimized. The tendency to skip or alter steps will be enhanced by the stressful circumstances of the accident; the in-plant environment may not be conducive to prolonged occupation by operators or provide the conditions for detailed actions.

The most appropriate JPA would resemble the expert systems that have proved so effective for medical diagnostics. These JPAs guide the person's thinking by a series of questions and instructions. These systems also include the capability to supply to the user the logic behind each sequence should the user ask for it. If implemented on computers, they can provide multiple possible diagnoses and an estimate of the likelihood of each being true. These JPAs should be located with the systems and equipment in the locations where they are most likely to be used.

More conventional JPAs would be used for more conventional tasks. For example, in using alternative means for pumping water, instructions may be required for making unconventional cross-over connections and starting the pump. These instructions should be located

with or on the pump and should make heavy use of graphics to illustrate the process. Any special tools must also be prepositioned. Detailed task analysis of personnel actions for each accident mitigation strategy will help to identify the most appropriate form of JPA to facilitate personnel response. Within this context, the severity of the environment will need to be considered, since multiple human resources may be required to provide breaks for others who have worked up to their threshold level of exposure to heat, smoke, radiation, or noise. In this context, one of the plants considered in this report has a procedure for connecting a portable pump to one of the plant systems. The necessary flexible hoses for making the connections are on location and color coded, red for the supply flow path and green for the drain flow. This color-coding might still be difficult to use in conditions of poor visibility.

Approach #3: Develop Training Programs for Severe Accident Management

Power plant personnel receive a diversity of training. For purposes of this discussion, it will be assumed that the training received by the operators and other technical personnel is sufficient for normal conditions and emergencies that do not meet the definition of a severe accident. Included in this training are information and exercises designed to facilitate emergency response.

A training strategy for severe accident mitigation would encompass operating personnel and their supervisors, management, and support personnel; each of these staff categories will have functions in a severe accident that may differ from their responsibilities during non-severe accident conditions.

Training for personnel directly involved with severe accident management would emphasize an understanding of the physical and chemical processes associated with severe accident scenarios. It would form the basis for understanding the mitigation strategies and for the decisions on which strategies to implement. This type of training would differ fundamentally from conventional training by emphasizing the ability to conceptualize what is going on in the vessel and in containment, based on a limited number of clues, some of which are of dubious reliability. An important feature of the training would be imparting knowledge of which data sources are most likely to be reliable under a given set of conditions

and which are most likely to be unreliable. The training would also develop skills in pattern recognition using limited data and help create a "cognitive mapping" of the most likely status of the core and the RCS.

A training program that is somewhat analogous to the type needed for severe accident management is the "confidence course" type training developed by the military. The basic idea is that a group of people are presented with a very difficult task and are given very limited, seemingly inadequate resources. Their task is to devise innovative strategies to achieve their goals. This type of training could be developed for severe accident scenarios.

Training of management personnel—those not directly responsible for operating the plant—represents a different set of problems. People who have studied the response of management under severe accident conditions agree that many managers who function well under normal conditions are ill-equipped to handle severe accident situations. Medvedev (1991) argues that the plant manager and the operating crew chief at Chernobyl continued to order inappropriate responses to the accident for approximately 24 hours, because they were unwilling to believe accurate reports of conditions in the plant. Most experts agree that the most important functions of managers are to act as filters, buffers, and facilitators for the operational personnel who are dealing with the accident directly. The problem is that there has been little or no research on the type of training needed to develop effective strategies for these managers.

Approach #4: The design, development, and testing of special tools and equipment to be used by personnel working under hazardous conditions associated with severe accidents

Experiences at TMI-2 and during the fire at Browns Ferry give us some insight into the type of conditions that could be expected during severe accidents.

During the fire at Browns Ferry, personnel were dispatched to the equipment room in the reactor building to lift leads and install jumpers. They encountered dense smoke and toxic fumes that reduced visibility to inches. The requirement to wear breathing apparatus made movement within confined areas difficult. It was difficult to find the right cabinet and even more difficult

to identify the correct lead to lift or jumper. Communications with the control room were almost impossible, so it was hard to determine that the correct actions had been taken.

During the TMI-2 accident, personnel were dispatched to the auxiliary building and into the reactor building a number of times to operate controls, read thermocouple voltages and take readings of radiation levels. Radiation levels reached high levels ($> 1,000$ mR/hr) and temperatures in the auxiliary building reached 170°F . The investigators noted that radiation protection procedures were extremely lax and that actions of the people while in high radiation areas violated technical specifications. Had the radiation protection rules been followed, entry into the auxiliary building would have been prevented or severely restricted.

As the specific approaches and JPAs to be used by personnel in performing the tasks are developed, information on the environment in which personnel may have to work will also be described. As these environments are

identified their impact on human performance can be assessed. The need for special tools and equipment to protect personnel and make it possible for them to perform the required tasks will also be identified. An example of this type of personal protective equipment is the "cool suit" developed for use in the post-TMI recovery effort. PNL recently submitted a draft report to the NRC entitled "Review of the Impact of Environmental Factors on Human Performance." This report supports the preparation of performance specifications for both special tools and personal equipment that may be required for severe accident management.

Prior to the decision to actually begin the development of special tools and equipment, a detailed and exhaustive search should be made of items already developed for other industries and the military.

In any case, it is vital that good task and human performance information be obtained so that the performance specifications reflect the real requirements of the human element of strategy implementation.

12 Conclusions

The objectives of this report were twofold: first, to determine the current understanding and practice of the Pressurized Water Reactor (PWR) Emergency Procedure Guidelines (EPGs), as it may relate to severe accident management; and second, to identify and evaluate strategies for mitigating the effects of severe accidents during the in-vessel phase of the accident, which is defined as being after the initiation of core degradation and prior to the failure of the reactor vessel. It is well-known that the EPGs are success-oriented, and they indeed provide success paths to deal with many of the critical accident sequences discussed in the report. In addition, many of the preventive (i.e., tending to prevent the initiation of core melt) strategies identified in NUREG/CR-5474 have been implemented, either entirely or partially, in the EPGs. However, the EPGs are not designed to provide guidance to the operators in response to the severe core damage accidents in which nothing works (or not enough things work) and core damage initiates. The functional operating guidelines dealing with inadequate core cooling and containment integrity do offer some guidance that would be useful during the in-vessel phase of a severe accident.

The vendor EPGs provide minimal guidance for the evaluation of human factors issues that will impact the ability of control room operators and in-plant operations and maintenance personnel to carry out the actions required under accident conditions; e.g., high temperatures, moisture, and radiation levels, with possibly impaired visibility. The Westinghouse ERGs do note some of the points at which utilities may have difficult decisions as to the capability of non-control-room staff to implement in-plant actions.

The fact that an accident has progressed to initiation of core damage implies some or all of the following plant conditions:

1. Several major plant front-line or support systems are unavailable or degraded.
2. Environmental conditions in containment are degraded, implying difficulty in carrying out some desired plant system manipulations.

3. Quality of the operator's knowledge of plant status, and particularly core status, is deteriorating.
4. The core may still be critical.
5. AC power may be unavailable, with DC power degrading.
6. The situation in the control room may be chaotic, with personnel present who are not normally in the control room and plant conditions that have been experienced only during training sessions, if at all.
7. Decision making responsibility and authority may not be clearly defined.

Even with these deteriorating conditions, there are clear actions that operators can take to prevent or mitigate further plant degradation. First and foremost, get the reactor subcritical, if it isn't already. Second, get water into the vessel by any means possible (although there is a hierarchy of preferred means). Third, if possible, maintain the secondary system as a heat sink for the primary system. Fourth, if electrical power is degraded or unavailable, do everything possible to restore it. Fifth, a number of relatively modest preventive and mitigative efforts may have a significant impact on plant risk. These include the flexibility to use portable AC power generators and portable self-powered pumps to supply water or power critical equipment. Also included is the use of feed and bleed flow in the service water system to maintain cooling of the centrifugal charging pumps, hence maintaining RCP seal injection and/or RCP seal cooling. Sixth, if the core is truly endangered, the operators should be prepared to sacrifice any other plant systems to the goal of minimizing the damage to the core and the threat to containment.

The arguments supporting RCS depressurization prior to vessel breach are persuasive. Early depressurization gets the plant closer to the accident conditions it was designed for, but may accelerate core degradation by comparison with remaining at high pressure. The analysis of Hanson et al. (1990) strongly suggests that late depressurization is preferable to early depressurization,

Conclusions

preferable in the sense of leading to delayed initiation of core degradation and lower hydrogen generation. Early or late depressurization should significantly reduce the risk associated with high pressure melt ejection and direct containment heating.

Improved knowledge of the status of a degrading core might improve the quality of accident management. This improved knowledge will require calculational tools that can integrate plant data with knowledge of the plant design to choose those descriptions of plant status that are consistent with the data and the time history of the accident--and do it all in real time.

Flooding the reactor cavity to the top of the RVP lower head may improve heat removal from the outer surface of the lower head enough to prevent creep-rupture failure of the lower head after relocation of part of the molten corium to the lower plenum.

Continuing to operate RCPs and maintain forced flow through the vessel (under conditions that put the RCPs at risk) may prevent or mitigate core damage or may buy time for actions to recover or protect containment or protect the public. For some LOCAs, this choice may increase the rate of inventory loss from the break, thus requiring increased makeup flow.

Thus, this work has identified several strategies, which extend beyond the EPGs into the severe accident regime, that will mitigate the seriousness of events and their consequences during the in-vessel phase of severe accidents. Further work in this area can be expected to better define the feasibility, effectiveness, and potential disadvantages of these strategies in the context of application to specific plants.

13 References

- Abolfadl, M. A. and T. G. Theofanous, (1987), "An Assessment of Steam-Explosion-Induced Containment Failure. Part II: Premixing Limits", *Nuclear Science and Engineering*, Vol. 97, 282-295, December 1987.
- Adams, J. P. and V. T. Berta, (1980), "Response of LOFT SPNDs to Reactor Coolant Density Variations During a LOCA Simulation", *Transactions of the American Nuclear Society*, TANSO, Vol. 35, pp. 334-336, November 1980.
- Adams, J. P. and G. E. McCreery, (1984), "Limitations of Detecting Inadequate Core Cooling with Core Exit Thermocouples", *Transactions of the American Nuclear Society*, Vol. 46, pp. 474-476, American Nuclear Society, La Grange Park, IL, June 1984.
- Amarasooriya, W. H. and T. G. Theofanous, (1987), "An Assessment of Steam-Explosion-Induced Containment Failure. Part III: Expansion and Energy Partition", *Nuclear Science and Engineering*, Vol. 97, 296-315, December 1987.
- Anderson, J. L., (1989), "Technical Note: Instrumentation Systems for Detecting Inadequate Core Cooling", *Nuclear Safety*, Vol. 30, No. 4, October-December 1989.
- Babcock & Wilcox, *Abnormal Transient Operating Guidelines*, B&W Technical Documents #74-1123297-00 and #74-1123298-00, March 1982.
- B&W Owners Group Operator Support Committee, (1985), *Emergency Operating Procedures Technical Bases Document*, B&W Technical Document #74-1152414-00, July 1985.
- Bayless, P. D., (1988), *Analyses of Natural Circulation During a Surry Station Blackout Using SCDAP/RELAP5*, NUREG/CR-5214, EG&G Idaho, Idaho Falls, Idaho, October 1988.
- Behr, V. L., et al., (1987), *Containment Event Analysis for Postulated Severe Accidents: Sequoyah Power Station Unit 1*, NUREG/CR-4700, Vol. 2, Sandia National Laboratory, February 1987.
- Benjamin, A. S. et al., (1987), *Evaluation of Severe Accident Risks and the Potential for Risk Reduction: Sequoyah Power Station, Unit 1 (DRAFT)*, NUREG/CR-4551, Vol. 2, Sandia National Laboratory, February 1987.
- Berman, Marshall, "Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'", *Nuclear Science and Engineering*, Vol. 100, 149-162, October 1988.
- Bertucio, R. C., et al., (1987), *Analysis of Core Damage Frequency from Internal Events: Sequoyah Unit 1*, NUREG/CR-4550, Vol. 5, Sandia National Laboratory, February 1987.
- Broughton, J. A., et al., (1989), "A Scenario of the Three Mile Island Unit 2 Accident", *Nuclear Technology*, Vol. 87, pp. 34-53, August 1989.
- Cha, Y. S., et al., (1989), *Numerical Simulation of Natural Circulation Phenomena in a PWR During TMLB Transients Prior to Core Damage*, NUREG/CR-5247, Argonne National Laboratory, May 1989.
- Chambers, Rosanna, D. J. Hanson, R. J. Dallman, and Fuat Odar, "Depressurization to Mitigate Direct Containment Heating", *Nuclear Technology*, Vol. 88, 239-250, December 1989.
- Cheng, Shih-Kuei, (1989), "Seal Loss-of-Coolant Accident and Recovery Actions Following Loss of Component Cooling Water", *Nuclear Technology*, Vol. 84, pp. 305-314, March 1989.
- Cokinos, D. and D. J. Diamond, (1979), "Recriticality due to Clad-Free Pellet Rearrangements in a PWR", *Transactions of the American Nuclear Society*, Vol. 33, pp. 844-845, American Nuclear Society, La Grange Park, IL, November, 1979.
- CEN-152 Rev. 1, *Combustion Engineering Emergency Procedure Guidelines*, developed by the Combustion Engineering Owners Group, 1982.

References

- CEN-152, *Combustion Engineering Emergency Procedure Guidelines, Rev. 3, SVB 1*, developed by Combustion Engineering Owners Group, 1985.
- Corradini, M. L., "Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'", *Nuclear Science and Engineering*, Vol. 100, 171-174, October 1988.
- Corradini, M. L., "Response to 'Comments on Fuel-Coolant Premixing Modeling'", *Nuclear Science and Engineering*, Vol. 103, 103-104, September 1989.
- di Marzo, M., et al., (1988), "The Phenomenology of a Small Break LOCA in a Complex Thermal Hydraulic Loop", *Nuclear Engineering and Design*, Vol. 110, pp. 107-116, 1988.
- Emergency Operating Procedures Technical Bases Document*, B&W Owners Group Operator Support Committee, 1985.
- El-Wakil, M. M., *Nuclear Heat Transport*, International Textbook Co., Scranton, Pennsylvania, 1971.
- Espelfalt, Ralf, (1989), "Severe Accident Mitigation Program for the Forsmark and Ringhals Plants", *Nuclear Engineering and Design*, Vol. 117, pp. 19-24, 1989.
- Fletcher, D. F. and A. Thyagaraja, "Comments on Fuel-Coolant Premixing Modeling", *Nuclear Science and Engineering*, Vol. 103, 101-102, September 1989.
- Golden, D. W., et al., (1989), *Depressurization as an Accident Management Strategy to Minimize the Consequences of Direct Containment Heating (DRAFT)*, NUREG/CR-5447, EGG-2574, Idaho National Engineering Laboratory, September 1989.
- Hanson, D. J., et al., (1990), *A Systematic Process for Developing and Assessing Accident Management Plans*, NUREG/CR-5543, Idaho National Engineering Laboratory, March 1990.
- Henry, R. E., et al., (1991a), "Cooling of Core Debris Within the Reactor Vessel Lower Head", preprint, Fauske & Associates, Inc., Burr Ridge, Illinois.
- Henry, R. E., et al., (1991b), "Cooling of Core Debris Within the Reactor Vessel Lower Head", Transactions of the ANS, Vol. 63, pp. 260-261, American Nuclear Society, La Grange Park, IL, June 1991.
- Hopenfeld, J., "Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'", *Nuclear Science and Engineering*, Vol. 103, p. 100, September 1989.
- Karassik, Igor J., et al., editors, (1976), *Pump Handbook*, P. 2-170, McGraw-Hill, New York, 1976.
- Karassik, Igor J., (1989), "Resist seizure of flashed pump with new operating procedure", *Power*, pp. 55-57, August 1989.
- Kastenberg, W. E., et al., (1990), *Proceedings of a Workshop on Severe Accident Management for PWRs (DRAFT)*, prepared by the UCLA Dept. of Nuclear Engineering for the U. S. Nuclear Regulatory Commission.
- Kersting, E., "Investigation of Accident Management Measures for PWR, Presentation made to UCLA Workshop on PWR Severe Accident Management, Westwood, California, May 13-15, 1990.
- Klopp, George T., (1990), "Accident Management Program Evolution at Commonwealth Edison", *Nuclear Plant Journal*, Vol. 8, No. 5, pp. 46-54, September-October 1990.
- Kuan, P. et al., (1989), "Thermal Interactions During the Three Mile Island Unit 2 2-B Coolant Pump Transient", *Nuclear Technology*, Vol. 87, pp. 977-989, December, 1989.
- Kuan, P. and D. J. Hanson, (1991), "Managing Water Addition to a Degrad Core", preprint of a paper to be published in the Proceedings of the 19th Water Reactor Safety Information Meeting, held at Bethesda, Maryland, October 28-30, 1991.
- Lehner, J. R., et al., (1988), *Severe Accident Insights Report*, NUREG/CR-5132, Brookhaven National Laboratory, April 1988.

- Lucas, G. E., W. H. Amarasooriya, and T. G. Theofanous, (1987), "An Assessment of Steam-Explosion-Induced Containment Failure. Part IV: Impact Mechanics, Dissipation, and Vessel Head Failure", *Nuclear Science and Engineering*, Vol. 97, 316-326, 1987.
- Luckas, W. J., J. J. Vandenkieboom, and J. R. Lehner, (1990), *Assessment of Candidate Accident Management Strategies*, NUREG/R-5474, Brookhaven National Laboratory, March 1990.
- Marshall, Billy W, Jr., "Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'", *Nuclear Science and Engineering*, Vol. 100, 165-170, October 1988.
- Medvedev, Grigoriy, *Chernobyl Notebook*, Basic Books, New York, 1991.
- Nuclear Safety Analysis Center, (1984), *Oconee PRA: A Probabilistic Risk Assessment of Oconee Unit 3*, NSAC-60, Cosponsored by NSAC, EPRI, and Duke Power Co., June 1984.
- Park, H. and V. Dhir, (1991), "Effect of Outside Cooling of the Thermal Behavior of a Pressurized Water Reactor Vessel Lower Head", preprint, UCI A Mechanical, Aerospace, and Nuclear Engineering Department, Los Angeles, California, 1991.
- Payne, Arthur C., Jr., et al. (1984), *Interim Reliability Evaluation Program: Analysis of the Calvert Cliffs Unit 1 Nuclear Power Plant*, NUREG/CR-3511, Sandia National Laboratory, March 1984.
- Pickard, Lowe & Garrick, (1982), *Zion Probabilistic Safety Study, Rev. 1*, for Commonwealth Edison Company, September 1982.
- Saito, M., et al., (1990), "Melting Attack of Solid Plates by a High Temperature Liquid Jet - Effect of Crust Formation", *Nuclear Engineering and Design*, Vol. 121, pp. 11-23.
- Theofanous, T. G., B. Najafi, and E. Rumble, (1987), "An Assessment of Steam-Explosion-Induced Containment Failure. Part I: Probabilistic Aspects", *Nuclear Science and Engineering*, Vol. 97, 259-281, 1987.
- Theofanous, T. G. (1988a), "Response to 'Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'' by Marshall Berman", *Nuclear Science and Engineering*, Vol. 100, 162-165, October 1988;
- Theofanous, T. G. (1988b), "Response to 'Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'' by B. W. Marshall, Jr.", *Nuclear Science and Engineering*, Vol. 100, p. 171, October 1988.
- Theofanous, T. G. (1988c), "Response to 'Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV'' by M. L. Corradini", *Nuclear Science and Engineering*, Vol. 100, 174-175, October 1988.
- Theofanous, T. G. (1989a), "Response to 'Comments on 'An Assessment of Steam-Explosion-Induced Containment Failure. Parts I-IV''", *Nuclear Science and Engineering*, Vol. 103, 100-101, September 1989.
- Theofanous and Amarasooriya, "Response to 'Comments on Fuel-Coolant Premixing Modeling'", *Nuclear Science and Engineering*, Vol. 103, 102-103, September 1989.
- Theofanous, T. G. (1989b), "Response to 'Comments on Fuel-Coolant Premixing Modeling'", *Nuclear Science and Engineering*, Vol. 103, p. 105, September 1989.
- Theofanous, T. G. (1989c), "Response to 'Comments on the Fuel-Coolant Premixing Debate'", *Nuclear Science and Engineering*, Vol. 103, 107-108, September 1989.

References

- U.S. Nuclear Regulatory Commission, (1980a), *Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants*, NUREG-0654, November 1980.
- U.S. Nuclear Regulatory Commission, (1980b), *Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident*, Regulatory Guide 1.97, December 1980.
- U.S. Nuclear Regulatory Commission, 1987, *Uncertainty Papers on Severe Accident Source Terms*, NUREG-1265, May 1987.
- U.S. Nuclear Regulatory Commission, 1989, *Staff Plans for Accident Management Regulatory and Research Programs*, SECY-89-012, January 18, 1989.
- Westinghouse Owners Group, *Emergency Response Guidelines*, September 1, 1983.
- Wheeler, T. A., (1986), *Analysis of Core Damage Frequency from Internal Events - Zion Unit 1*, NUREG/CR-4550, Vol. 7, Sandia National Laboratory, October 1986.
- Wu, Horng-yu, (1989), "Analysis of the Source Range Monitor During the First Four Hours of the Three Mile Island Unit 2 Accident", *Nuclear Technology*, Vol. 84, pp. 167-181, February 1989.
- Young, M. F., "Comments on the Fuel-Coolant Premixing Debate", *Nuclear Science and Engineering*, Vol. 103, 106-107, September 1989.

Appendix A

Westinghouse Large, Dry Containment Plant - Zion

Appendix A

Westinghouse Large, Dry Containment Plant - Zion

A.1 Critical Accident Sequences

Critical accident sequences for a large, dry containment reactor were determined using information from NUREG/CR-4550, Vol. 7, Core Damage Frequency from Internal Events. This NUREG report documents the probabilistic risk assessment (PRA) performed on Zion Unit 1 in support of NUREG-1150. Additional information was inferred from the Westinghouse Owner's Group Emergency Response Guidelines (ERGs), High-Pressure Version, Revision 1, September 1, 1983. Zion is one of the Westinghouse "high-pressure" plants; that is, it has a safety related, fully qualified, charging system available to inject water in accidents where the reactor coolant system (RCS) pressure stays near the relief valve setpoints.

A.1.1 Core Melt Risk

The following 17 sequences were identified in the Zion PRA as dominating the risk of core melt:

- Z-1 Loss of component cooling water (CCW), causing loss of cooling to the RCP seal thermal barriers and eventually inducing an RCP seal LOCA. In addition, loss of CCW flow to the charging and safety injection (SI) pumps will cause their failure. Containment cooling remains available, but core damage results from an inability to replace primary coolant. This sequence accounts for 79.4% (!) of the total core damage frequency (CDF) calculated in the PRA. The sequence leads to early core damage and vessel failure with the RCS at high pressure, with containment systems functioning.
- Z-2 Small-break LOCA (<2 in.) followed by failure of the recirculation system to provide high-pressure SI into the primary system. The dominant contributor to this sequence is human error in switching the low-pressure suction lines from injection to recirculation. This sequence accounts for 2.6% of the CDF and leads to late core damage and high pressure RPV failure with containment systems functioning.
- Z-3 Large-break LOCA followed by an independent failure of low-pressure SI into the primary system during the recirculation phase. The dominant contributor is human error in realigning the low-pressure injection (LPI) system suction valves from injection to recirculation. This sequence accounts for 3.2% of the CDF and leads to a late, low pressure RPV failure with containment systems functioning.
- Z-4 This sequence is identical to sequence Z-3 except the initiating event is a medium-break LOCA. It accounts for 3.2% of the CDF.
- Z-5 Loss of AC power; independent failure of auxiliary feedwater (AFW) system; failure of feed and bleed; failure to restore offsite power in 1 h but recovery before 4 h. The dominant contributors to this sequence are human error in implementing feed and bleed and random failures of the AFW system. This sequence accounts for 1.4% of the CDF and leads to early, high pressure RPV failure with containment systems functioning because of the restoration of AC power.

Appendix A

- Z-6 Large-break LOCA and failure of LPI. The primary contributor is human error in leaving certain motor-operated valves (MOV's) closed after testing the LPI system. This sequence accounts for 0.9% of the CDF and leads to early, low pressure failure of the RPV with containment systems functioning.
- Z-7 This sequence is the same as sequence Z-5 except AC power is restored between 4 and 8 h. This sequence accounts for 0.3% of the CDF and leads to early, high pressure failure of the RPV. AC power is restored early enough to allow successful functioning of containment systems.
- Z-8 Loss of AC power, causing loss of CCW and service water system (SWS); power restored in more than 1 h and less than 4 h. An RCP seal LOCA is induced. CCW/SWS are recovered after restoration of AC power; however, core melt has already occurred. The dominant contributors are hardware and maintenance failures in CCW, SWS, and diesel generators (DGs). This sequence accounts for 0.2% of the CDF and leads to early, high pressure RPV failure with successful functioning of containment systems.
- Z-9 Same as sequence Z-8 except for the unrecoverable failure of the SWS. An RCP seal LOCA is caused by loss of CCW, which is caused by the unrecoverable loss of the SWS. The permanent loss of the SWS also results in failure of containment systems. Dominant contributors to this sequence are common-cause failures of the SWS. This sequence accounts for 0.2% of the CDF and leads to early, high pressure failure of the RPV and early containment failure.
- Z-10 Loss of AC power, causing loss of CCW and SWS followed by induced RCP seal LOCA; failure to restore power in 8 h, causing failure of containment sprays and fan coolers. This sequence accounts for 0.1% of the CDF and leads to early, high pressure RPV failure and early containment failure.
- Z-11 Loss of AC power, causing loss of CCW and SWS; AC power restored after 4 h and before 8 h. This sequence is similar to sequence Z-8. An RCP seal LOCA does occur and restoration of AC power does not occur soon enough to prevent core melt. AC power is restored in time to prevent failure of containment. This sequence accounts for 0.1% of the CDF and leads to early, high pressure RPV failure with successful functioning of containment systems.
- Z-12 Loss of offsite AC power and partial failure of emergency AC power with no recovery within 8 h, causing failure of SWS. This sequence is similar to sequence Z-10 except that RCP seal LOCA and the loss of CCW are caused by loss of SWS. The failure to restore AC power within 8 h results in complete loss of containment systems. This sequence accounts for 0.1% of the CDF and results in early, high pressure failure of the RPV and early failure of containment.
- Z-13 Same as sequence Z-12 except containment fans fail directly as a result of the loss of AC power rather than as a result of a loss of cooling to the chillers. Since AC power is not restored in 4 h, an RCP seal LOCA will occur. This sequence accounts for 0.07% of the CDF and leads to early, high pressure failure of the RPV with partial success of containment systems.
- Z-14 Interfacing systems LOCA. In this sequence two MOVs in the residual heat removal (RHR) system fail to isolate low-pressure piping from the high-pressure RCS. Although the simultaneous failure of two MOVs is a low probability event, it was included because this failure directly bypasses containment. This sequence accounts for 0.07% of the CDF and can lead to either early or late failure of the RPV. Containment is already bypassed at the time of core damage initiation.
- Z-15 Failure of DC bus 112 causing loss of one power-operated relief valve (PORV) and loss of AC bus 143 and failure of AFW. Failure of DC bus 112 causes loss of main feedwater (MFW) and a reactor trip. Containment

systems succeed. Although feed and bleed might be feasible without any functioning PORVs, this sequence includes loss of feed and bleed because of the loss of one PORV and the relatively high probability of operator error in operating PORVs. This sequence accounts for 0.03% of the CDF and leads to early, high pressure failure of the RPV with containment systems functioning.

- Z-16 Same as sequence Z-11 with the SWS common-mode portion of sequence Z-12. SWS failure causes failure of CCW. Since SWS cannot be restored, the CCW and injection pumps will not operate and an RCP seal LOCA occurs. This sequence accounts for 0.03% of the CDF and leads to early, high pressure failure of the RPV and early failure of containment due to loss of SWS and CCW.
- Z-17 Loss of offsite power and degraded emergency AC power, causing CCW failure; failure to recover full AC power or start faulted DGs in 8 h. In this sequence, an RCP seal LOCA occurs in a manner similar to sequence Z-8. This sequence is comprised of degraded AC power scenarios which allow the SWS and containment fans and cooling systems to succeed. This sequence accounts for 0.03% of the CDF and leads to early, high pressure failure of the RPV with successful functioning of containment systems.

A.1.2 Public Risk

Accident sequences that resulted in the failure of containment systems are considered to present a risk to the public. These sequences are Z-9, Z-10, Z-12, Z-13, and Z-14.

A.1.3 Challenges to Safety Functions

There are six critical safety functions identified in the Westinghouse ERGs:

- (1) Reactor subcriticality.
- (2) Core cooling.
- (3) Reactor pressure vessel (RPV) integrity.
- (4) Primary system heat sink (i.e., the secondary system).
- (5) Containment integrity.
- (6) Primary system inventory.

All 17 sequences in the Zion PRA represent a threat to some of the critical safety functions. Other events that would also pose a threat to the safety functions are pressurized thermal shock (PTS), anticipated transient without scram (ATWS), and steam generator tube rupture (SGTR).

A.1.4 Threats to Safety Systems

Each of the 17 sequences in the Zion PRA poses a threat to safety systems. The PRA sequences represent the combination of failures of a number of safety systems. Some events involving the failures of support systems also represent a threat to safety systems, i.e., failure of CCW or SWS, station blackout, and SGTR. In addition, seismic events, fires, and internal flooding threaten safety systems.

A.2 ERG Coverage of the Critical Accident Sequences

A.2.1 Methodology

Critical accident sequences were identified in NUREG/CR-4550, Vol. 7, Analysis of Core Damage Frequency from Internal Events: Zion Unit 1. Each sequence was analyzed to determine what components and systems were affected (in many cases this was included in the PRA). The Westinghouse Owner's Group ERGs were analyzed to determine if they provided information and direction to adequately handle or at least provide some help in responding to the critical accident sequences. The Westinghouse ERGs contain both event- and safety function-based guidelines, and both types were included in the analysis. The event-based guidelines have EXX-y.z numbering; the safety function-based guidelines have FX-y.z numbering (where X represents various letters and y and z represent various numbers).

The analysis showed that the ERGs provide significant guidance, particularly for those sequences that have a large human error component (such as sequences Z-2 and Z-3). This is not surprising since the ERGs provide guidance for the development of Emergency Operating Procedures (EOPs), which, by definition, specify appropriate operator actions in various situations and scenarios. In addition to the PRA sequences summarized below, there are other events (e.g., SGTR, ATWS, and PTS) that also represent threats to public safety, safety functions and safety systems. These threats are identified in Sections A.1.2 through A.1.4. For these threats, the ERGs contain specific guidance.

A.2.2 Summary of ERG Guidance for Each of the Sequences in the Zion PRA

Sequence Z-1 (Loss of CCW)

The Function Restoration (FR) Procedures FR-C.1 and FR-C.2 deal with inadequate core cooling and degraded core cooling. The guidance in these procedures is limited to attempts to restore systems that will provide coolant to the core. The only steps that would temporarily provide a limited amount of coolant are those for depressurizing and injecting the coolant into the vessel from the Si accumulators. At this point the FR Procedures exit to the event-based procedure, E-1, LOSS OF REACTOR OR SECONDARY COOLING. No additional help was found in this procedure.

Sequence Z-2 (Small-break LOCA and high-pressure recirculation failure)

Both FR Procedures and Optimal Recovery Guidelines (ORGs), which are the event-based guidelines, provide steps to reestablish high-pressure safety injection (HPSI).

Sequence Z-3 (Large-break LOCA and low-pressure recirculation failure)

The ERGs contain steps to establish and verify low-pressure injection. Although these steps do not explicitly state that the operators should ensure that the suction valves are in the proper position, steps can be taken to initiate injection by the LPI system.

Sequence Z-4 (Medium-break LOCA and low-pressure recirculation failure)

Same as sequence Z-3.

Sequence Z-5 (Loss of AC power, failure of AFW, failure of feed and bleed, and power not recovered in 1 h)

Guidelines for loss of all AC power are contained in Section ECA-0.0 of the ERGs. The guidelines rely on the ability to reestablish AFW or, failing that, to depressurize and use feed and bleed. No guidance is given for the conditions in this accident sequence.

Sequence Z-6 (Large-break LOCA and LPI failure)

As is the case with other sequences in which the primary factor contributing to the probability of the sequence is human error, the ERGs provide steps to initiate the system required (i.e., the LPI system). The ERGs contain steps for dealing with a large-break LOCA (ERG E-1), and these would be effective once LPI were restored. The actual testing of MOVs and the proper lineup for the MOVs after testing should be contained in a normal operating procedure or a surveillance procedure.

Sequence Z-7 (Loss of AC power, failure of AFW, failure of feed and bleed, and power not recovered in 8 h)

Sequence Z-8 (Loss of AC power, temporary loss of CCW and SWS, power and systems restored between 1 and 4 h, but not before core damage occurs)

Sequence Z-9 (Loss of AC power, permanent loss of SWS and CCW)

Guidelines for loss of power are contained in Section ECA-0.0 of the ERGs. However, the ERGs do not provide guidance for the combination of conditions described in these three sequences.

Sequence Z-10 (Loss of power, loss of CCW and SWS, power not restored in 8 h)

This sequence results in both core damage and a severe challenge to containment. The ERGs do not provide any help in dealing with the loss of all component cooling and service water systems. Likewise, the ERGs provide no guidance for dealing with maintaining containment integrity without sprays and cooling fans. Presumably plant AOPs provide guidance for response to loss of AC power, CCW, and SWS.

Sequence Z-11 (Loss of AC power, temporary loss of CCW and SWS, power and systems restored between 4 and 8 h, but not before core damage occurs)

Sequence Z-12 (Loss of offsite power and partial failure of emergency AC power, permanent loss of SWS, and power not recovered in 8 h)

Sequence Z-13 (Loss of offsite power and partial failure of emergency AC power, loss of SWS, containment fans failed, and power not restored in 8 h)

Guidelines for loss of power are contained in Section ECA-0.0 of the ERGs. However, the ERGs do not provide guidance for the combination of conditions described in these three sequences.

Sequence Z-14 (Interfacing systems LOCA)

ERG ECA-1.2, LOCA OUTSIDE CONTAINMENT, provides procedural guidance for actions to identify and isolate a LOCA outside containment. The major action categories in ECA-1.2 are:

Appendix A

- (1) Verify proper valve alignment.
- (2) Identify and isolate break.
- (3) Verify that the break is isolated.

If the operator succeeds in isolating the LOCA, control transfers to ERG E-1, LOSS OF REACTOR OR SECONDARY COOLANT; if the LOCA cannot be isolated, then control transfers to ECA-1.1, LOSS OF EMERGENCY COOLANT RECIRCULATION, since there will not be any inventory in the containment sump to provide recirculation capability. Diagnosing the interfacing LOCA, identifying the location, and isolating the break are difficult tasks, and the ERGs provide only minimal guidance.

Sequence Z-15 (Loss of DC bus 112, failure of AC bus 148, and failure of AFW)

ERG E-0, REACTOR TRIP OR SAFETY INJECTION, and ECA-0.0, LOSS OF ALL AC POWER, provide guidance on switching from normal to both emergency AC and DC buses given loss of main and auxiliary feedwater. The ERGs contain guidance in a number of places on the operation of PORVs.

Sequence Z-16 (Loss of AC power and permanent loss of SWS)

No ERG guidance is available beyond handling the initial power failure and subsequent loss of SW and CCW. As AC power is not restored before 4 h, an RCP seal LOCA occurs and coolant continues to be lost with no guidance that will prevent core damage. Recovery of AC power within 8 h results in containment success.

Sequence Z-17 (Loss of AC power, CCW failure, and power not restored in 8 h)

Guidelines for loss of power are contained in Section ECA-0.0 of the ERGs. However, the ERGs do not provide guidance for the combination of conditions described in this sequence.

A.3 ERG Coverage of "A" Strategies

The "A" strategies were studied extensively by Brookhaven National Laboratory and Pacific Northwest Laboratory during FY 1989. The results of this study are documented in NUREG/CR-5474, Assessment of Candidate Accident Management Strategies. This section uses the strategy numbering system of NUREG/CR-5474 and evaluates the extent to which the Westinghouse ERGs cover the proposed strategies.

Strategy 2.1 (Reduce Containment Spray Flow Rate to Conserve Water for Core Injection)

ERG ECA-1.1, LOSS OF EMERGENCY COOLANT RECIRCULATION, provides for terminating flow to containment sprays and throttling core injection flow to conserve refueling water storage tank (RWST) inventory, in situations in which the operators cannot establish recirculation flow. The same ERG also provides for the use of all available fan coolers to reduce the need for containment spray.

Strategy 2.2 (Enable Early Detection, Isolation, or Otherwise Mitigate the Effects of an Interfacing Systems LOCA)

The Section A.2 evaluation of Sequence Z-14 describes the ERG coverage of the interfacing systems LOCA.

Strategy 2.3.2 (Refill Refueling Water Storage Tank with Borated Water)

Step 2 of ERG ECA-1.1, LOSS OF EMERGENCY COOLANT RECIRCULATION, requires the operator to add makeup to the RWST to extend the time it can be used as a suction source. The ERG notes that details of makeup water sources will be plant-specific, but the reactor makeup water control system and the spent fuel pit cooling system would be typical sources.

Strategy 2.4 (Ensure Appropriate Recirculation Switchover and Manual Intervention Upon Failure of Automatic Switchover)

ERG E-1, LOSS OF REACTOR OR SECONDARY COOLANT, and ES-1, TRANSFER TO HOT LEG RECIRCULATION, contain steps to establish and verify recirculation. ECA-1.1, LOSS OF EMERGENCY COOLANT RECIRCULATION, contains steps for manual establishment of recirculation.

The ERG ECA-1.1 gives detailed guidance on response to a failure to establish recirculation flow. It is entered from:

1. ERG E-1, LOSS OF REACTOR OR SECONDARY COOLANT, Step 12, which requires verification of the capability to use cold leg recirculation flow. However, a note in Step 12 specifies that verification implies verifying the availability of the required equipment and not its proper alignment.
2. ES-1.3, TRANSFER TO COLD LEG RECIRCULATION, Step 3, which requires alignment of the safety injection system for recirculation.
3. ES-1.2, LOCA OUTSIDE CONTAINMENT, Step 3, requires transfer to EDA-1.1 if the LOCA outside containment cannot be isolated (in this case, "appropriate" recirculation switchover is not to switch over, since there is no inventory in the containment sump).

Strategy 2.5 (Ensure Adequate Plant Heat Removal Capability by Emergency Connection(s) of Existing or Alternate Water Sources)

ECA-1.1, Step 16, instructs the operator to try to add water to the RCS from an alternate source. The ERG notes that the possible alternate sources will be plant-specific and offers the reactor makeup water control system, delivered using the normal charging pumps and the centrifugal charging pumps (i.e., the safety-related charging pumps), as a typical alternate source.

There are steps in E-1 that have non-specific guidance to use non-safety related pumps and coolant sources. No specific guidance on the use of sources such as rivers, lakes, or reservoirs was found in the ERGs.

Strategy 3.2.1 (Enable Emergency Bypass or Change of Protective Trips for Injection Pumps)

No ERG steps specifically implementing this strategy were found, but it is consistent with guidance to operate the RCPs in situations requiring them to protect the core, even though the normal support conditions for RCP operation are not met.

Strategy 3.3.2 (Use Non-Safety Related Charging Pumps for Core Injection)

ECA-1.1, Step 16, instructs the operator to try to add water to RCS from an alternate source. The ERG notes that the possible alternate sources will be plant-specific and offers the reactor makeup water control system, delivered using the

normal charging pumps (which are non-safety-related) and the centrifugal charging pumps (i.e., the safety-related charging pumps), as a typical alternate source. ERG E-1 makes reference to switching to alternative means if charging pumps are not running. The operator is then directed to "plant specific information" for means of reestablishing necessary charging flow.

Strategy 3.4 (Use Alternate Seal Injection (e.g., Hydrotest Pump) When Reactor Coolant Pump Seal Cooling is Lost)

No ERG guidance implementing this proposed strategy was found. The general approach taken in the ERGs to loss of RCP seal cooling is to trip the RCPs, secure the seal cooling system block valves, attempt to cool down the RCS, and exercise extreme care when reestablishing seal cooling flow in order to prevent damage to the RCP by thermal stresses. Most causes of seal cooling failure (i.e., loss of AC power, loss of CCW, and loss of SW) would affect alternate sources of seal cooling also.

Strategy 3.5 (Use Condensate Pumps or Startup Feedwater Pumps for Steam Generator Injection)

ERG FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK, Step 2, instructs the operator to attempt to establish AFW flow to one steam generator (SG). If that is unsuccessful, Steps 5 and 7 direct the operator to try to establish SG feed flow using the MFW pumps (Step 5) or the condensate pumps (Step 7).

Strategy 4.1 (Conserve Battery Capability by Shedding Non-Essential Loads)

ERG ECA-0.0, LOSS OF ALL AC POWER, Step 14, directs the operator to conserve DC power by shedding non-essential DC loads as soon as practical.

Strategy 4.2 (Use Portable Battery Chargers or Other Power Sources to Recharge Station Batteries) ECA-0.0, Step 14, also states "consideration should also be given to securing a portable diesel powered battery charger to ensure DC power availability."

Strategy 4.3 (Enable Emergency Replenishment of the Pneumatic Supply for Safety Related Air Operated Components)

ERG ECA-0.1, LOSS OF ALL AC POWER RECOVERY WITHOUT SI REQUIRED, makes reference to determining the availability of instrument air and loading an air compressor if necessary.

Strategy 4.4 (Enable Emergency Bypass or Change of Protective Trips for Emergency Diesel Generators)

ECA-0.1, Step 7, directs the operator to dispatch personnel to locally restore AC power using plant-specific procedures. The ERG has no explicit recommendation to bypass or change DG protective trips.

Strategy 4.5 (Enable Emergency Cross-tie of AC Power Between Two Units or to an On-site Gas Turbine Generator)

No reference was found for this strategy in the ERGs.

Strategy 4.7 (Use Diesel-Driven Firewater Pump for ... Steam Generator Injection or Containment Sprays)

ERG FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK, directs the operator to try to re-establish feed flow to one SG using the AFW system, the MFW system, or the condensate system (in that order). No mention was found of the possibility of using the diesel-driven firewater pump for SG feed flow.

Strategy 5.1 (Reopen Main Steam Isolation Valves and Turbine Bypass Valves to Regain the Main Condenser as a Heat Sink)

ERG FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK, Steps 5 and 7, and E-1, LOSS OF REACTOR OR SECONDARY COOLANT, mention attempts to establish SG coolant flow, using first the MFW system and then the Condensate system, but no specific reference is made to attempting to establish a flow loop by manually opening the main steam isolation valve(s) (MSIV) or turbine bypass valves (TBVs).

Strategy 6.1 (Provide Additional Supply of Borated Makeup Water for Long-Term Accident Control)

ERG FR-S.1, RESPONSE TO NUCLEAR POWER GENERATION/ATWS, Note on Step 13, directs the operator to continue boration to obtain adequate shutdown margin during subsequent actions. Furthermore, "boration should continue by other means, if possible." Other than this step, there is no apparent guidance for securing additional or alternate sources of borated water.

Appendix B

Westinghouse Ice Condenser Containment - Sequoyah

Appendix B

Westinghouse Ice Condenser Containment - Sequoyah

Critical accident sequences for an ice condenser plant were determined using the information contained in a number of NUREG/CR reports supporting the development of NUREG-1150. These reports document the probabilistic risk assessment performed on Sequoyah Unit 1. They include (with abbreviated titles):

- NUREG/CR-4550, Vol. 5 - Core Damage Frequency from Internal Events.
- NUREG/CR-4551, Vol. 2 - Severe Accident: Risks and the Potential for Risk Reduction.
- NUREG/CR-4700, Vol. 2 - Containment Event Analysis for Postulated Severe Accidents.

Additional information was inferred from the emergency procedures guidelines in the Westinghouse Owners Group Emergency Response Guidelines (High-Pressure Version), Revision 1, September 1, 1983. Sequoyah is one of the Westinghouse "high-pressure" plants; that is, it has a safety-related, fully qualified, charging system available to inject water in accidents where the RCS pressure stays near the relief valve setpoints.

B.1 Critical Accident Sequences

B.1.1 Core Melt Risk

Eight accident sequences account for approximately 93% of the core melt risk calculated in the NUREG-1150 PRA for the Sequoyah plant, as reported in NUREG/CR-4550, Vol. 5:

- S-1 S₂H₂ - A small-break LGCA, followed by failure of core injection in the recirculation phase. Electrical power and containment heat removal and spray are available. The major contributing cause of this accident is operator failure to switch over to recirculation flow. This sequence accounts for 34% of the core melt risk and leads to high pressure failure of the RPV.
- S-2 T_{CCW} - Failure of the CCW system, which leads eventually to a reactor coolant pump seal LGCA and failure of emergency injection and containment spray. Electrical power is available, but neither containment heat removal nor containment spray function are. The major contributing cause of this accident is common cause failure of the CCP pumps. This sequence accounts for 31% of the core melt risk and leads to late, high pressure failure of the RPV and late containment failure.
- S-3 S₂H₃ - A small-break LGCA, followed by failure of the low-pressure recirculation system (i.e., failure of the low head pumps, which take water from the containment sump and deliver it to the suction header of the high-head recirculation pump, or failure of the associated valves). Electrical power and containment heat removal and spray are available. This sequence accounts for 11% of the core melt risk and leads to high pressure failure of the RPV with successful functioning of containment systems.

Appendix B

- S-4 S_1H_3F - This is sequence S-3 followed by failure of containment spray. Electrical power is available, but neither containment heat removal nor containment spray are. The major cause of this sequence is common cause failure of low-pressure recirculation and containment spray (in recirculation mode). This sequence accounts for 9% of the core melt risk and leads to high pressure failure of the RPV and late failure of containment.
- S-5 $T_1D_3WD_1F$ - This is a station blackout, causing an RCP seal LOCA (due to loss of seal cooling and seal injection flow). Because of the loss of all AC power, core injection, containment heat removal, and containment spray are not available. The cause of this sequence is the initial loss of offsite power transient, followed by independent or common cause failure of the emergency AC power system. This sequence accounts for 3.3% of the core melt risk and leads to a late, high pressure failure of the RPV and late containment failure.
- S-6 S_1H_2 - An intermediate-break LOCA, followed by loss of high-pressure recirculation flow. This leads to an inability to inject water into the core during the recirculation phase, causing a core melt. Unlike the previous five sequences, however, the RPV is expected to be at low pressure by the time core melt has progressed to the point of RPV breach for this sequence. Electrical power, containment heat removal, and containment spray are available. The major contributing cause is operator failure to switch over to recirculation flow. This sequence accounts for 1.9% of the core melt risk and leads to a low pressure failure of the RPV with successful functioning of containment systems.
- S-7 $T_{DCI}L_1P_1$ - Loss of DC bus I, followed by independent failures in the AFW system (the loss of the DC bus causes failure of one of the PORVs). Loss of AFW requires feed & bleed cooling, which fails because only one PORV is available. Electrical power is available, except for the failed DC bus, as are containment heat removal and containment spray. The major contributor to this sequence is the initiating loss of DC bus. This sequence accounts for 1.3% of the core melt risk and leads to an early, high pressure failure of the RPV with successful functioning of the containment systems.
- S-8 $T_{DCII}L_1P_1$ - Loss of DC bus II. The rest of the description of this sequence is identical to that for sequence S-7.

B.1.2 Public Risk

Sequences important from the public risk standpoint for Sequoyah include S-2, S-4, S-5, and the following sequences:

- S-9 Intermediate- or large-break LOCA followed by failure of the ice condenser system. Containment will fail because of the failure of the ice condenser. Because of flashing in the sump, core injection may fail in the recirculation phase of the accident. NUREG/CR-4550, Vol. 5 assigns a conditional probability = 0.13 that core recirculation fails given containment failure. NUREG/CR-4551, Vol. 2, reviews assigned probabilities in the range from 0.03 to 0.4 to failure of core heat removal due to containment failure.
- S-10 Event V (interfacing system LOCA) followed by additional failures resulting in core damage. Because of the LOCA outside containment, containment is already breached at the time of initiation of core damage.
- S-11 SGTR followed by additional failures resulting in core damage. As with sequence S-10, containment is already breached at initiation of core damage.

B.1.3 Challenges to Safety Functions

The safety functions defined in the Westinghouse ERGs (High-Pressure Version) are:

- (1) Reactor subcriticality.
- (2) Core cooling.
- (3) RPV integrity.
- (4) Primary system heat sink (i.e., the secondary system).
- (5) Containment integrity.
- (6) Primary system inventory.

All of the enumerated sequences, resulting in core damage and perhaps containment failure, involve challenges to one or more safety functions. Other sequences that challenge safety functions are:

S-12 PTS challenges RPV integrity.

S-13 Excessive heat transfer from primary system to the secondary system due to shell-side depressurization challenges reactor subcriticality, RPV integrity, and eventually other safety functions S-14 Loss of SG heat sink challenges the primary system inventory and core cooling safety functions.

S-15 Pressurizer flooding (i.e., solid primary coolant system) challenges primary system and RPV integrity.

S-16 ATWS challenges the reactor subcriticality, RPV integrity, and core cooling safety functions.

B.1.4 Threats to Safety Systems

Each of the 16 sequences developed above poses a threat to one or more safety systems. The PRA sequences all involve the failure of one or more safety systems. In addition to the developed sequences, seismic events, fires, and internal flooding all threaten safety systems.

The most significant threat to safety systems is the station blackout, sequence S-5, since it eliminates all safety injection (except for the accumulators), the charging pumps, containment spray and heat removal, RCP seal injection and seal cooling, two trains of AFW, all pumps, and all MOVs.

Another significant accident sequence for Sequoyah is the loss of CCW sequence S-2, which causes the eventual loss of all safety injection, the charging pumps, the RCP seals, containment spray, and containment heat removal.

A final sequence posing a threat to safety systems is:

S-17 loss of the service water system, causing the loss of room cooling, loss of cooling for the AFW pump motors, and loss of shell-side flow in the heat exchangers for the CCW and containment spray (in the recirculation mode).

B.2 ERG Coverage of the Critical Accident Sequences

Sequence S-1 (Small-break LOCA with loss of recirculation phase injection)

Emergency Response Guideline E-1 describes how to respond to a small-break LOCA, including possible repressurization of the RCS because the safety injection flow is excessive or the SG heat sink is lost. ERG ES-1.3 governs the transfer to recirculation core injection when the RWST tank has reached the switchover setpoint. ES-1.3 has six steps; Caution 1 for Step 1 notes that Steps 1 through 3 must be done as quickly as possible, because of the limited amount of water in the RWST below the switchover setpoint. ERG ECA-1.1, LOSS OF EMERGENCY COOLANT RECIRCULATION, provides guidance in the event of loss of recirculation phase safety injection. It gives three possible symptoms of loss of recirculation flow:

- (1) Loss (failure to open) of both sump recirculation isolation valves.
- (2) Loss (failure to start) of both low-head SI pumps.
- (3) Inadequate sump inventory due to LOCA outside containment or depletion of RWST without a corresponding increase in sump level.

There is no clear indication how the operator will find his/her way to ECA-1.1 if the loss of emergency recirculation is due to operator failure to switch over when required. ECA-1.1 has five major action categories:

- (1) Continue attempts to restore emergency coolant recirculation.
- (2) Increase/conservate RWST level.
- (3) Try to add makeup to RCS from an alternate source.
- (4) Depressurize SGs to cool down and depressurize RCS.
- (5) Maintain RCS heat removal.

Recommendations supporting Action 2 include eliminating unnecessary containment spray and throttling safety injection flow. The only alternate source suggested is the normal plant water control system with injection via the charging pumps. The 24 steps of ECA-1.1 provide relatively detailed guidance for the operator facing loss of recirculation injection flow.

Sequence S-2 (Loss of component cooling water)

Although the Reference Plant Description recognizes the importance of the CCW system, there is no direct guidance in the ERGs for response to Loss of CCW. Presumably, each plant has Abnormal Operating Procedures (AOPs) instructing the operator on response to a loss of CCW. The functional ERGs FR-C.1, RESPONSE TO INADEQUATE CORE COOLING, and FR-C.2, RESPONSE TO DEGRADED CORE COOLING, provide three major actions:

- (1) Reinitiation of high-pressure safety injection (which will not work in this case).
- (2) Rapid secondary depressurization (which might help temporarily).

- (3) RCP restart and/or opening pressurizer PORVs (which also might help temporarily).

Sequence S-3 (Small-break LOCA with loss of low-head recirculation trains)

The evaluation given for ERG coverage of sequence S-1 applies here also.

Sequence S-4 (Sequence S-3 with loss of containment spray)

The evaluation given for ERG coverage of sequence S-1 applies here with the added note that Step 4 of ECA-1.1 requires the operator to start both the normal and emergency fan coolers, which will provide some containment heat removal and steam condensation.

Sequence S-5 (Station blackout)

The ERGs ECA-0.0, ECA-0.1, and ECA-0.2 address loss of all AC power, both when safety injection is required and when it is not. Westinghouse states that these guidelines specifically address the generic aspects of Items a, e, f, and g of NRC Generic Letter 81-04, "Emergency Procedures and Training for Station Blackout". The three guidelines run to about 250 pages.

ECA-0.0 has five major action categories:

- (1) Perform immediate actions; i.e., checking RCS isolation, verifying secondary heat sink.
- (2) Restore AC power.
- (3) Maintain plant conditions for optimal recovery.
- (4) Evaluate the energized AC emergency bus (after recovery of emergency AC).
- (5) Select appropriate recovery guideline after restoration of AC power.

The guidelines note 10 to 15 key operations involving proposed local (i.e., outside the control room) operator actions that utilities must evaluate based on plant-specific constraints such as availability and accessibility of equipment, personnel available for in-plant operations, communications capabilities, and personnel safety.

Step 5 of ECA-0.0 instructs the operators to take actions to restore emergency AC power from the control room. Step 7 requires local operator actions to restore emergency AC power. The ERGs provide no guidance when evaluation of the loss of offsite power and the loss of emergency AC suggests that none of these actions are likely to be successful in a timely manner. If the station blackout proceeds to core damage, it continues to be imperative to restore AC power. Most plausible mitigative actions during the in-vessel phase of a core melt require AC power.

Sequence S-6 (Intermediate-break LOCA with failure of high-head recirculation)

The evaluation of ERG coverage given for sequence S-1 applies here.

Sequences S-7 and S-8 (Loss of vital DC bus)

Appendix B

The ERGs provide no direct guidance for this sequence. Presumably, the plant AOPs provide guidance for the loss of vital support systems.

Sequence S-9 (Intermediate-break, or larger, LOCA with failure of the ice condenser)

This sequence challenges containment integrity because the (clean) steam and water (and no hydrogen) from the break may overpressurize the containment. The functional ERG FR-Z.1, RESPONSE TO HIGH CONTAINMENT PRESSURE, specifies the following major action categories:

- (1) Verify containment isolation and heat removal.
- (2) Check for and isolate faulted steam generator.
- (3) Check for excessive containment hydrogen and determine appropriate action.

Action 3 is not relevant to this sequence (at least, not until cladding damage occurs). Actions 1 and 2 may mitigate this sequence, depending on the size and location of the break and the extent of the ice condenser failure.

Sequence S-10 (Event V with additional failures leading to core damage)

ERG ECA-1.2, LOCA OUTSIDE CONTAINMENT, provides procedural guidance for actions to identify and isolate a LOCA outside containment. The major action categories in ECA-1.2 are:

- (1) Verify proper valve alignment.
- (2) Identify and isolate break.
- (3) Verify that the break is isolated.

If the operator succeeds in isolating the LOCA, control transfers to ERG E-1, LOSS OF REACTOR OR SECONDARY COOLANT; if the LOCA cannot be isolated, then control transfers to ECA-1.1, LOSS OF EMERGENCY COOLANT RECIRCULATION, since there will not be any inventory in the containment sump to provide recirculation capability. Diagnosing the interfacing LOCA, identifying the location, and isolating the break are difficult tasks, and the ERGs provide only minimal guidance.

Sequence S-11 (SGTR with additional failures leading to core damage)

Guidance for responding to an SGTR is provided by ERGs E-3, STEAM GENERATOR TUBE RUPTURE; ES-3.1, POST-SGTR COOLDOWN USING BACKFILL; ES-3.2, POST-SGTR COOLDOWN USING BLOWDOWN; ES-3.3, POST-SGTR COOLDOWN USING STEAM DUMP; ECA-3.1, SGTR WITH LOSS OF REACTOR COOLANT - SUBCOOLED RECOVERY DESIRED; ECA-3.2, SGTR WITH LOSS OF REACTOR COOLANT - SATURATED RECOVERY DESIRED; and ECA-3.3, SGTR WITHOUT PRESSURIZER PRESSURE CONTROL. The guidance is extensive; the seven ERGs run to approximately 750 pages.

The major action categories in ERG E-3 are:

- (1) Identify and isolate ruptured SG(s).
- (2) Cool down to establish RCS subcooling margin.
- (3) Depressurize RCS to restore inventory.
- (4) Terminate safety injection to stop primary-to-secondary leakage.

- (5) Prepare for cooldown to a cold shutdown condition.

Although they provide adequate guidance for terminating the SGTR with the plant in a safe condition, these ERGs, as all the others, are success-oriented and do not say much about mitigation of accident sequences in which additional failures have led to the initiation of core damage.

Sequence S-12 (PTS challenging PV integrity)

The functional ERGs FR-P.1, RESPONSE TO IMMINENT PRESSURIZED THERMAL SHOCK CONDITION, and FR-P.2, RESPONSE TO ANTICIPATED PRESSURIZED THERMAL SHOCK CONDITION, provide guidance for the management of overcooling conditions and over-pressurization at low temperatures.

Sequence S-13 (Excessive heat removal from the primary system)

The functional ERGs FR-P.1, RESPONSE TO IMMINENT PRESSURIZED THERMAL SHOCK CONDITION, and FR-P.2, RESPONSE TO ANTICIPATED PRESSURIZED THERMAL SHOCK CONDITION, provide guidance for the management of overcooling conditions and over-pressurization at low temperatures.

Sequence S-14 (Loss of secondary heat sink)

The functional ERGs, FR-H.1, RESPONSE TO LOSS OF SECONDARY HEAT SINK; FR-H.2, RESPONSE TO STEAM GENERATOR OVERPRESSURE; FR-H.3, RESPONSE TO STEAM GENERATOR HIGH LEVEL; FR-H.4, RESPONSE TO LOSS OF NORMAL STEAM RELEASE CAPABILITIES; FR-H.5, RESPONSE TO STEAM GENERATOR LOW LEVEL, provide responses to a variety of events threatening immediate or incipient loss of secondary heat sink.

Sequence S-15 (Pressurizer flooding)

The functional ERG FR-I.1, RESPONSE TO HIGH PRESSURIZER LEVEL, provides guidance for the event of pressurizer level increasing and incipient solid primary system.

Sequence S-16 (ATWS)

The functional ERGs FR-S.1, RESPONSE TO NUCLEAR POWER GENERATION/ATWS, and FR-S.2, RESPONSE TO LOSS OF CORE SHUTDOWN, guide the operator in responding to ATWS conditions.

Sequence S-17 (Loss of service water)

The ERGs provide no guidance on operator response to loss of service water.

B.3 ERG Coverage of the "A" Strategies

Since the same Westinghouse Emergency Response Guides (High Pressure version) apply to Sequoyah as Zion, information about ERG coverage of the "A" Strategies can be found in Section A.3.

Appendix C

Combustion Engineering Large, Dry Containment - Calvert Cliffs 1

Appendix C

Combustion Engineering Large, Dry Containment - Calvert Cliffs 1

Critical accident sequences for a Combustion Engineering (CE) large, dry containment plant, were determined mainly from the information contained in NUREG/CR-3511, Interim Reliability Evaluation Program: Analysis of the Calvert Cliffs Unit 1 Nuclear Power Plant, Volume 1. Main Report. The degree of coverage of these critical sequences and of the "A" strategies by the CE EPGs was determined by reviewing CEN-152, Combustion Engineering Emergency Procedures Guidelines, Rev. 3.

C.1 Critical Accident Sequences

C.1.1 Core Melt Risk

NUREG/CR-3511 cites the following accident sequences as dominating the Calvert Cliffs-1 (CC-1) core melt frequency. Many of these sequences are impacted by the low shutoff head of the CC-1 HPI pumps (1275 psia), which causes feed and bleed cooling to fail in many high-pressure accident situations.

- C-1 ATWS(PSF) - An ATWS occurs that leads to primary system failure. This sequence is considered likely to lead to containment failure from overpressure and/or hydrogen burn. This sequence contributes 20% of the core melt frequency and leads to early RPV failure and early containment failure.
- C-2 T_{DC} - Failure of DC bus 11 causes a trip of the plant, failure of the power conversion system, failure of AFW pump 13, and degradation of the safety systems. The plant scrams successfully, but AFW fails subsequently due to additional independent failures. With no secondary heat sink, core inventory boils off through the PO. Vs. Containment fails due to overpressure or a hydrogen burn. This sequence contributes 16% of the core melt frequency and leads to early, high pressure failure of the RPV and early containment failure.
- C-3 S₂H - Small-small-break LOCA followed by successful scram, AFW operation, and HPSI operation. When the refueling water tank depletes and switchover occurs, high-pressure safety recirculation fails leading to core uncover and core melt. Containment systems succeed and cool containment early on, but containment fails due to overpressure or hydrogen burn. This sequence contributes 11% of the total CMF and leads to early, high pressure RPV failure and early containment failure.
- C-4 S₂FH - Same as sequence C-3 with the additional failure of the containment sprays in the recirculation mode. The core melts due to lack of recirculation phase makeup; the containment fan coolers provide some containment cooling, but containment fails due to hydrogen burn and/or overpressure. This sequence contributes 9% of total core melt risk and leads to early, high pressure RPV failure and early containment failure.
- C-5 T-L - Loss of the power conversion system (PCS) causes a plant trip, which is followed by an independent loss of AFW. The reactor scrams successfully and containment systems work, but feed & bleed cooling fails due to

- the low head of the HPI pumps. RCS inventory boils off through the PORVs and the core melts. Containment fails due to hydrogen burn and/or overpressure. This sequence contributes 6% of the CMF and leads to an early, high pressure failure of the RPV and early failure of containment.
- C-6 T₄KU/T₄KQ/T₃KU/T₃KQ - These sequences involve a transient with failure to scram followed by either failure of boration or a stuck-open PORV. The core melts, because power continues to be generated or because pressure stays too high for successful HPSI makeup to the RCS. Containment fails by hydrogen burn and/or overpressure. These sequences contribute 13% of the total CMF and leads to early, high pressure failure of the RPV and early failure of containment.
- C-7 T₄ML - A transient is followed by loss of the PCS and AFW systems. The reactor scrams and containment systems function. Because of the loss of secondary heat sink, the RCS boils off through the PORVs and core melt ensues. Containment fails eventually due to hydrogen burn or overpressure. This sequence contributes 5% of the CMF and leads to early, high pressure failure of the RPV and early or eventual failure of containment.
- C-8 T₁QD*CC* - Loss of offsite power followed by a transient-induced LOCA; AFW works but HPSI and the containment systems fail. The core melts due to lack of RCS makeup; containment is expected to fail due to overpressure. This sequence contributes 4% of the total CMF and leads to early, high pressure failure of the RPV and early containment failure.
- C-9 T₁L - Loss of offsite power followed by failure of AFW. Because of the loss of secondary heat sink the RCS boils off through the PORVs. Containment fails due to overpressure and/or hydrogen burn. This sequence accounts for 4% of the CMF and leads to early, high pressure failure of the RPV and eventual failure of containment.
- C-10 SBO - Station blackout followed by successful operation of the turbine driven AFW pumps until battery depletion some 4 h into the accident. RCS boiloff causes core melt; because of the station blackout no containment systems are available. Containment fails from overpressure. This sequence accounts for 3% of the CMF and leads to late, high pressure failure of the RPV and late failure of containment.
- C-11 T₃ML - A transient requiring pressure relief is followed by loss of the PCS and AFW. The reactor scrams and containment systems succeed. Loss of secondary heat sink causes boil off of the RCS through the PORVs. Containment fails due to hydrogen burn and/or overpressure. This sequence contributes 1% of the CMF and leads to early, high pressure failure of the RPV and eventual failure of containment.
- C-12 S₂D* - A small-small-break LOCA followed by loss of HPSI and eventual core melt due to no RCS makeup during the injection phase of the accident. Containment systems succeed but containment eventually fails due to overpressure and/or hydrogen burn. This sequence accounts for 1% of the CMF and leads to high pressure failure of the RPV and eventual failure of containment.
- C-13 T₁LCC* - A loss of offsite power followed by failure of AFW and the containment systems. The RCS inventory boils off through the PORVs due to loss of the secondary heat sink. Containment fails due to overpressure. This sequence accounts for 1% of the CMF and leads to early, high pressure failure of the RPV and eventual failure of containment.

C.1.2 Public Risk

Using data from Table 8.3 of the CC-1 PRA, NUREG/CR-3511, Vol. 1, the most significant contributors to public risk are those sequences dominating the probability of early containment failures leading to large releases.

NUREG/CR-3511 indicates that the probability of containment failure due to steam explosion is dominated by two sequences:

- C-3, S2H, Small-small-break LOCA with loss of recirculation injection.
- C-4, S2HF, Sequence C-3 with additional failure of containment spray.

The probability of early failures due to overpressure or hydrogen burn is dominated by five sequences:

- C-1, ATWS(PCS), ATWS with immediate RPV failure.
- C-2, TDCL, Loss of DC bus 11 followed by loss of AFW.
- C-3, S2H, Small-small-break LOCA with loss of recirculation injection.
- C-4, S2HF, Sequence C-3 with additional failure of containment spray.
- C-6, miscellaneous ATWS sequences without early RPV failure.

In addition to the sequences noted above, the following two sequences are considered significant to public risk:

- C-14 Event V (interfacing system LOCA) followed by additional failures resulting in core damage.
- C-15 SGTR followed by additional failures resulting in core damage.

C.1.3 Challenges to Safety Functions

In the Combustion Engineering Owners Group EPGs, CEN-152, there are ten safety functions identified as necessary to mitigate events and contain radioactivity. These safety functions are divided into four classes as follows:

- (1) Anti-Core Melt Safety Functions.
 - (a) Reactivity control.
 - (b) RCS inventory control.
 - (c) RCS pressure control.
 - (d) Core Heat Removal.
 - (e) RCS Heat Removal.

- (2) Containment Integrity Safety Functions.
 - (a) Containment isolation.
 - (b) Containment temperature and pressure control.
 - (c) Combustible gas control.
- (3) Indirect Radioactivity Release Control.
- (4) Maintenance of Vital Auxiliaries.

The previously enumerated sequences, all of which result in core damage and perhaps containment failure, involve challenges to one or more safety functions. Other sequences that challenge safety functions are:

- C-16 PTS challenges RPV integrity.
- C-17 Excessive heat transfer from primary system to the secondary system due to SG shell side depressurization challenges reactor subcriticality, RPV integrity, and eventually other safety functions.
- C-18 Pressurizer flooding (i.e., solid primary coolant system) challenges primary system and RPV integrity.

C.1.4 Threats to Safety Systems

The most significant threat to safety systems is the station blackout, sequence C-10. It eliminates all safety injection (except for the accumulators), the charging pumps, containment spray and heat removal, RCP seal injection and seal cooling, two trains of AFW, all pumps, and all motor-operated valves.

Also significant for Calvert Cliffs is the loss of DC bus 11, sequence C-2, causing a plant trip, failure of the PCS and the AFW motor-driven pump 13, with degradation of the safety systems. Failure of DC bus 21 has similar, although not quite as serious, consequences.

Additional sequences threatening safety systems are:

- C-19 Failure of service water system train 12 causes loss of main feedwater pump lube oil cooling and condensate booster pump lube oil cooling, resulting in a plant trip. Safety systems affected by train 12 failure are the containment air coolers 13 and 14 and DG 12.
- C-20 The salt water system provides secondary (shell-side) cooling of the CCW system and the service water system and cooling for the ECCS pump room coolers.

Finally, seismic events, fires, and internal flooding all threaten safety systems.

C.2 CEN-152 Coverage of the Critical Accident Sequences

The critical accident sequences identified in the preceding section were evaluated to determine if they were adequately covered by the CEN-152 guidelines. CEN-152 contains Optimal Recovery Guidelines (ORGs) and Functional

Recovery Guidelines (FRGs). The ORGs are event-based and require operator diagnosis of the event; the FRGs are symptom-based and are entered if operators are unable to diagnose the event or if the appropriate ORG does not successfully manage the event.

This review verified that the generic procedural steps of CEN-152 act to mitigate many of the dominant severe accidents sequences for Calvert Cliffs-1. However, the Introduction to CEN-152 notes: "... guidance for the management of degraded core conditions is not included. There is insufficient analytical base for this guidance."

Maintenance of vital auxiliaries is listed as the last class of safety functions; however, loss of offsite power was fourth out of seven items in the dominant sequence list. Also the loss of DC bus 11 (special transient initiator) was third on the list. This could be construed to imply that not enough attention is placed on maintenance of vital auxiliaries in CEN-152. In actual practice, maintenance of vital auxiliaries is considered immediately after reactivity control and then concurrently with each safety function.

Specific information regarding the coverage of the numbered sequences: (all page and section references are from CEN-152, Rev. 3, unless otherwise indicated)

Sequence C-1 (ATWS causing primary system failure)

Sequence C-6 (Other ATWS sequences)

The CEN-152 Functional Recovery Guideline (FRG) on REACTIVITY CONTROL (pp. 10-50 to 10-75) directs the operator to take the reactor subcritical by attempting (in the order given):

- (1) Manual insertion of the control rods.
- (2) Boration of the RCS using the chemical volume and control system.
- (3) Boration using the safety injection system.
- (4) Control element assembly drive down (manually energize control assemblies and drive them into the core using normal control rod insertion mechanisms).

The FRG stresses the importance of continuing to attempt to establish subcriticality.

Sequence C-2 (Loss of DC bus 11 with loss of secondary heat sink)

Sequence C-5 (Loss of secondary heat sink)

Sequence C-7 (Loss of secondary heat sink)

Sequence C-9 (Loss of offsite power followed by loss of secondary heat sink)

Sequence C-11 (Transient requiring pressure relief followed by loss of secondary heat sink)

Sequence C-13 (C-9 with additional loss of containment systems)

Appendix C

The EPG on LOSS OF FEEDWATER RECOVERY (pp. 8-1 to 8-20) provides instructions for re-establishment of feedwater flow and appears through the associated safety function status check to be able to lead the operator into setting up feed and bleed cooling, when necessary.

Sequence C-3 (Small-break LOCA with recirculation failure)

Sequence C-4 (C-3 with additional containment spray failure)

Sequence C-12 (Small-break LOCA with loss of HPSI)

The EPG on LOCA RECOVERY (pp. 5-1 to 5-30), Step 46, directs the operator to verify automatic switchover to recirculation flow and to manually initiate recirculation if automatic switchover fails. It provides no guidance in the event both automatic switchover and manual initiation fail. The FRG on containment temperature and pressure control contains instructions for the use of the containment fan coolers in either normal or emergency mode, but no specific instructions on what to do if containment spray fails.

Sequence C-8 (Loss of offsite power with induced LOCA, followed by HPI and containment systems failures)

CEN-152 provides no generic guidance on the maintenance of vital auxiliaries, indicating instead that plant-specific guidance is needed. The EPG on recovery of a LOCA and the FRGs are intended to help the operator diagnose and respond to the inadequate core cooling that results from the failure of the FiPI system.

Sequence C-10 (Station blackout)

CEN-152 provides no explicit guidance for station blackout situations, rather indicating that restoration of vital AC and DC power require plant-specific actions and criteria. CEN-152 guidelines for LOSS OF FEEDWATER RECOVERY (Ch. 8) and LOSS OF FORCED CIRCULATION RECOVERY (Ch. 9) both assume availability of electrical power.

Sequence C-14 (Interfacing system LOCA)

The break identification chart (p. 5-23) provides the logic for identifying a LOCA outside containment; procedural control stays with the EPG on recovery of a LOCA (Section 5 of CEN-152). Most of the subsequent steps assume a break in containment; in particular, Step 46, which initiates the switch over to recirculation flow, does not caution against initiating recirculation flow when the LOCA is outside containment.

Sequence C-15 (SGTR)

The EPG on recovery of a SGTR (Section 6 of CEN-152) provides specific guidance for this event.

Sequence C-16 (PTS)

Section 1.7.1 of CEN-152 provides guidance on PTS.

Sequence C-17 (Excessive primary-to-secondary heat transfer)

The EPG on recovery of an excess steam demand event (Section 7 of CEN-152) provides guidance for these overcooling or steamline break events.

Sequence C-18 (Pressurizer flooding)

Most of the ORGs and the FRGs contain specific guidance on the maintenance of appropriate pressurizer level.

Sequence C-19 (Failure of service water system train 12) Sequence C-20 (Failure of the salt water system)

CEN-152 contains no guidance on maintenance of vital auxiliaries, indicating that such guidance should be plant-specific.

C.3 CEN-152 Coverage of the "A" Strategies

Strategy 2.1 (Reduce Containment Spray Flow Rate to Conserve Water for Core Injection)

Specific guidance provided only to reduce or terminate flow upon pressure drop in containment.

Strategy 2.2 (Enable Early Detection, Isolation, or Otherwise Mitigate the Effects of an Interfacing Systems LOCA)

More guidance is needed in the EPG to make the strategy successful. As noted in the Section C.4.2 summary of EPG coverage of Sequence C-14, the break identification chart provides logic for identifying and Interfacing Systems LOCA, but the EPG on LOCA RECOVERY (Ch. 5) assumes the break is in containment.

Strategy 2.3.2 (Refill Refueling Water Storage Tank with Dewatered Water)

Not covered in the EPGs.

Strategy 2.4 (Ensure Appropriate Recirculation Switchover and Manual Intervention Upon Failure of Automatic Switchover)

EPG guidance is adequate. The LOCA RECOVERY ORG (Ch. 5), Step 46, has the operator:

- (1) continuously monitoring RWT level,
- (2) verifying initiation of recirculation if the level falls to 10%, and
- (3) manually initiating recirculation, if necessary.

Appendix C

Strategy 2.5 (Ensure Adequate Plant Heat Removal Capability by Emergency Connection(s) of Existing or Alternate Water Sources)

The EPGs do not provide adequate guidance.

Strategy 3.2.1 (Enable Emergency Bypass or Change of Protective Trips for Injection Pumps)

The EPGs do not provide adequate guidance.

Strategy 3.3.2 (Use Non-Safety Related Charging Pumps for Core Injection)

EPG guidance is adequate.

Strategy 3.4 (Use Alternate Seal Injection (e.g., Hydrotest Pump) When Reactor Coolant Pump Seal Cooling is Lost)

The EPGs do not provide any guidance.

Strategy 3.5 (Use Condensate Pumps or Startup Feedwater Pumps for Steam Generator Injection)

No guidance is provide for recovery of feedwater using Condensate pumps or Startup Feedwater Pumps.

Strategy 4.1 (Conserve Battery Capability by Shedding Non-Essential Loads)

Strategy 4.2 (Use Portable Battery Chargers or Other Power Sources to Recharge Station Batteries)

Strategy 4.3 (Enable Emergency Replenishment of the Pneumatic Supply for Safety Related Air Operated Components)

Strategy 4.4 (Enable Emergency Bypass or Change of Protective Trips for Emergency Diesel Generators)

Strategy 4.5 (Enable Emergency Crosstie of AC Power Between Two Units or to an Onsite Gas Turbine Generator)

CEN-152 provides no guidance for these five strategies, but rather indicates that plant-specific actions and criteria are required.

Strategy 4.7 (Use Diesel-Driven Firewater Pump for ... Steam Generator Injection or Containment Sprays)

The EPGs do not provide any guidance.

Strategy 5.1 (Reopen Main Steam Isolation Valves and Turbine Bypass Valves to Regain the Main Condenser as a Heat Sink)

Guidance is provided in the CEN-152 LOF guideline, but not in as much depth as in the Combustion Engineering Advanced Technology Manual.

Strategy 6.1 (Provide Additional Supply of Borated Makeup Water for Long-Term Accident Control)

The EPGs do not provide any guidance.

Appendix D

Babcock & Wilcox Large, Dry Containment - Oconee 3

Appendix D

Babcock & Wilcox Large, Dry Containment - Oconee 3

Critical accident sequences for the Babcock & Wilcox (B & W) large, dry containment plant were determined using the information contained in the Oconee PRA (NSAC-60), which documents the probabilistic risk assessment performed on Oconee Unit 3. Additional information was inferred from the Abnormal Transient Operating Guidelines (ATOGs) and the Emergency Operating Procedures Technical Basis document.

Oconee Unit 3 has two unique, plant-specific features that directly impact the determination of critical sequences. One feature is the standby shutdown facility (SSF), which is a separate, bunkered installation that provides a secure means for attaining and maintaining hot shutdown conditions for all three Oconee units. The SSF was primarily designed to provide core cooling for incidents of industrial sabotage, fires, and flooding but can also be used to provide an alternative means of cooling after other types of events. The SSF can provide a backup supply of feedwater to the steam generators for secondary-side heat removal and can inject and maintain sufficient inventory in the reactor coolant system (RCS) to sustain natural circulation and cool the reactor coolant pump (RCP) seals. The SSF also has its own electrical power system, with a dedicated diesel generator. This facility provides an additional level of backup to numerous safety functions, not found at most plants, and thus affects the probability of a core melt event occurring for many sequences.

The other unique feature is the emergency power sources for Oconee: the Keowee Hydroelectric Station and the Lee Steam Station combustion turbines. Power from Keowee is provided by an overhead path, which connects one of the two Keowee units to the Keowee main stepup transformer, which in turn is connected to the 230-kV switchyard to provide power through the Oconee Unit 3 startup transformers (CT3). If the overhead path is unavailable, either Keowee unit can be connected to a 13.8-kV underground path that provides power to Oconee transformer CT4. These sources of emergency electrical power were determined in the Oconee PRA to be more reliable than a diesel generator set. However, should both Keowee units be unavailable for emergency power generation, either of two Lee Steam Station combustion turbines can provide power to Oconee transformer CT5 via a 100-kV overhead path. This level of redundancy and diversity in the emergency electrical power system is uncommon and results in a highly reliable emergency power source. Therefore, the impacts of a loss of offsite power (and the probability of a station blackout) are greatly diminished in the Oconee PRA.

D.1 Critical Accident Sequences

D.1.1 Core Melt Risk

Ten accident sequence groups account for approximately 89% of the core melt risk calculated in the Oconee PRA:

O-1 T₁₂BU - The normally operating low-pressure service water (LPSW) system fails to provide cooling to the HPI pumps, which provide RCP seal injection, and to the CCW system, which provides RCP seal cooling. The RCP seal injection/cooling recovery actions that fail include:

- (1) Using the LPSW system, by cross-connecting it with either the high-pressure service water (HPSW) system or the LPSW system of another Oconee unit.

- (2) Opening the local HPI pump LPSW discharge piping and cycling the HPI pumps to prevent pump overheating.
- (3) Initiating the SSF, which can provide RCP cooling injection, in time (within 30 minutes of HPI failure as a result of HPI pump motor cooling failure) to prevent RCP seal leakage.

Thus, the operations staff fails to reestablish a source of cooling prior to the initiation of RCP seal leakage, without the ability to make up the loss of inventory since the HPI system relies upon LPSW cooling. This sequence accounts for 28% of the core melt risk from internal initiators.

O-2 AX_A - A large-break LOCA is followed by success of the LPI system and the core flood tanks, but the operations staff either fails to implement low-pressure recirculation from the emergency sump within 30 minutes or fails to throttle the high flow conditions that may develop during recirculation, thus causing the LPI pumps to cavitate. These sequences account for 15% of the core melt risk from internal initiators.

O-3 TWS - In these sequences the turbine trips, but (because an insufficient number of control rods drop into the core to render the reactor subcritical) the reactor fails to shutdown. At this point one of two sequences can occur that result in core melt:

- (1) The main feedwater system fails to continue supplying the steam generators and either borated water is not injected to render the reactor subcritical in time to initiate a stable cooled state or a long-term stable cooling mode is not maintained.
- (2) The reactor core is within a certain regime, with respect to core life and its effect on moderator temperature coefficient (coefficient less than 95%), such that a pressure transient large enough to cause a RCS LOCA occurs and either the injection systems fail to provide inventory makeup or the long-term stable cooling mode is not maintained.

These sequences account for 11% of the core melt risk from internal initiating events.

O-4 SY₅X₅ - A small-break LOCA is followed by successful HPI. The small-break LOCA also causes the initiation of the reactor building sprays, whose operation is not terminated after they are automatically actuated and the reactor building pressure is reduced. Eventually (in 2 h) the reactor building sprays deplete the borated water storage tank (BWST) injection-water inventory. High-pressure recirculation from the emergency sump fails due primarily to operations staff error. This sequence accounts for 9% of the core melt risk from internal initiators.

O-5 T₁₀BU - A large feedwater or condensate line break results in a loss of main and emergency feedwater because the main and emergency feedwater share water sources. The operations staff then fails to implement HPI cooling (i.e., feed and bleed) and emergency feedwater from the SSF is not initiated within 30 minutes. This sequence accounts for 9% of the core melt risk from internal initiators.

O-6 T₆BU - A loss of instrument air occurs (as the initiating event, as a result of a loss of offsite power, or as a result of system faults after a reactor/turbine trip). Main feedwater and the emergency feedwater system motor-driven pumps are not available because the instrument air is lost. The emergency feedwater system steam-driven pump, which can operate using remote manual actions, fails to continue operation after depletion of the upper surge tank (i.e., another suction source is not provided by the operations staff). The feedwater systems are not recovered and neither HPI cooling nor emergency feedwater from the SSF is initiated. This sequence accounts for 9% of the core melt risk from internal initiating events.

- O-7 RU_R - A steam generator tube rupture (SGTR) is followed by an HPI failure to maintain RCS inventory. The HPI failure is the result of operations staff error or hardware faults associated with the HPI suction valves, the BWST itself, or the single BWST suction valve (LP-28). This sequence accounts for 2% of the core melt risk from internal initiators.
- O-8 T_2BU - A loss of main feedwater occurs and the emergency feedwater system fails as a result of operation: staff errors or hardware failures (dominated by insufficient level in the upper surge tank for suction requirements). The operations staff then fails to initiate feed and bleed cooling or recover a source of feedwater by restoring main feedwater or providing a suction source from the other two Oconee units. This sequence accounts for 2% of the core melt risk from internal initiating events.
- O-9 RX_{RO} - A steam generator tube rupture occurs. If a main steam relief valve on the affected steam generator fails to close, recirculation from the sump is not an option since the break is effectively outside containment. In this scenario, long-term cooling fails because the injection-phase inventory is not maintained by continually refilling the BWST so as to allow extended injection and decay heat removal using the low-pressure system. If the secondary-side remains intact (i.e., the main-steam relief valve closes), core melt commences if low-pressure injection and recirculation fail to function during the recirculation or decay heat removal mode of operation. The LPI system can fail as a result of various hardware faults, operations staff errors, or failures of the LPSW system that cools the LPI pumps. These sequences account for 2% of the core melt risk from internal initiating events.
- O-10 VR - This sequence is unique in that it is a single event: a disruptive rupture of the reactor pressure vessel (RPV) by a failure mode that precludes core reflooding. Thus, none of the safety systems are effective after the initiating event. This sequence accounts for 2% of the core melt risk from internal initiators.

All other sequences individually contribute less than 2% of the core melt risk from internal initiating events.

D.1.2 Public Risk

Sequences important from the public risk standpoint for Oconee include most of the sequences important to core melt risk. Sequence O-8 is the only sequence that does not appear to make a contribution to public risk. This is primarily due to the fact that this sequence does not directly affect the performance of the containment systems. The following sequence also becomes important to public risk:

- O-11 ISLOCA - The interfacing system LOCA occurs when an interface between the high-pressure RCS and the LPI system is breached. The resultant LOCA allows the RCS water and any water injected for makeup to flow out the reactor building, thus bypassing containment. Mitigation fails directly as a result of the breach (e.g., the LPI pumps are damaged) or fails later because there is no water in the sump for recirculation. The dominant location for an interfacing system LOCA is at the suction line from the RCS.

D.1.3 Challenges to Safety Functions

The safety functions derived from the Oconee PRA and the abnormal transient operating guidelines are as follows:

- (1) RCS integrity.
- (2) RPV integrity.
- (3) Reactor subcriticality.
- (4) RCS heat removal (via secondary system).

- (5) RCS pressure relief.
- (6) Core heat removal.
- (7) RCS makeup.
- (8) Long-term heat removal.
- (9) Reactor building cooling (heat removal).

All of the enumerated sequences, resulting in core melt and perhaps containment failure and public risk, involve challenges to one or more of these safety functions.

D.1.4 Threats to Safety Systems

The most significant threat to safety systems at Oconee Unit 3 is the loss of LPSW, Sequence O-1, since numerous systems rely on this system for cooling, including:

- (1) The motors of the pumps in the HPI, emergency feedwater, and reactor coolant systems.
- (2) The heat exchangers of the decay heat removal system.
- (3) The heat exchangers of the CCW system.

Other sequences that threaten numerous safety systems include sequences O-5 and O-6. An additional sequence posing a threat to safety systems is:

O-12 T₅QU - A loss of offsite power is followed by local power failures, resulting in a loss of all AC power (i.e., a station blackout). The only system available for RCS heat removal is the steam-driven emergency feedwater pump, which fails through hardware faults or operations staff errors. Once all feedwater is lost, the safety relief valves are challenged and eventually open to discharge liquid, after which one or more valves fail to reclose. The induced LOCA cannot be mitigated due to the loss of all AC power.

D.2 ATOG Coverage of the Critical Accident Sequences

The Abnormal Transient Operating Guidelines (ATOGs) are symptom-based guidelines and as such do not distinguish the events by their initiating events. Rather, the symptoms or plant conditions are used to guide the actions of the operations staff. The ATOG used in this study was developed prior to the full implementation of the SSF, therefore, there is no reference to the SSF in the ATOG.

Sequence O-1 (Loss of LPSW causing RCP seal leakage without makeup)

A loss of LPSW event is not addressed directly in the ATOG. In the INADEQUATE CORE COOLING guideline a step instructs the operations staff to trip a RCP if the LPSW is lost and not restored to the RCP motor within 30 minutes. The need for RCP seal cooling is not clearly indicated in the guidance and the only reference to the reliance of numerous systems on the LPSW system is in the system auxiliary diagram (SAD) section, which lists the components required to support each of the systems.

Sequence O-2 (Large-break LOCA with failure of low-pressure recirculation)

A large-break LOCA will probably result in an overheating transient condition for which guidance is provided in the LACK OF HEAT TRANSFER guideline (guideline III-B). An indication of a large LOCA is that the RCS pressure drops and the core flood tanks are discharging to the RCS. CP-101 provides instructions for long-term core cooling following a major LOCA. There are instructions to align to the sump for recirculation if the BWST low level alarms

(i.e., level drops to 6 ft) and also provides instruction to throttle LPI valves to prevent pump cavitation. Should low-pressure recirculation fail, the operations staff will enter the INADEQUATE CORE COOLING guidance.

Sequence O-3 (Transient without scram)

The guidance related to transient without scram events deals primarily with the steps for control rod insertion and boration to shutdown the reaction. Should main feedwater fail, emergency feedwater would be actuated to prevent an overheating transient from occurring. In the case where both main feedwater and emergency feedwater fail, HPI cooling would be initiated as directed by the LACK OF HEAT TRANSFER guideline (guideline III-B) and the sequence is similar to sequence O-5. If a LOCA is induced, the same guideline is used and the sequence is similar to sequence O-2.

Sequence O-4 (Small-break LOCA without high-pressure recirculation)

The guidelines that address the potential for RCS inventory losses do not provide instructions for shutting down the reactor building sprays to conserve the BWST inventory used by the HPI system to provide makeup to the RCS. Guidance is provided for initiating high-pressure recirculation, using the LPI system to provide pump suction. Should high-pressure recirculation fail, the operations staff will enter the INADEQUATE CORE COOLING guidelines. At this point, if failed systems cannot be recovered, the operations staff will attempt to decrease the pressure of the RCS by opening the PORV and high point vents in order to make the core flood tanks and LPI system available for core cooling.

Sequence O-5 (Large feedwater/condensate line break with failure of HPI cooling)

A large feedwater line break, which fails both main feedwater and emergency feedwater, will result in an overheating transient (i.e., a lack of heat transfer, guideline III-B). This event is addressed in the ATOG and is one of the scenarios discussed in depth in Part II of the ATOG. The guidance expects the loss of natural circulation to occur for an extended loss of feedwater. The corrective actions for a loss of all feedwater are to attempt to restore feedwater; failing to do so, starting HPI cooling. Direction is given to actuate two HPI pumps and run them at full capacity while manually opening the PORV. In addition, all but one RCP should be tripped, thus reducing the heat load while still maintaining forced core cooling. Upon losing all subcooling margin, all RCPs are tripped. Upon failure of HPI cooling, the operations staff will enter the INADEQUATE CORE COOLING guidelines. At this point, if failed systems cannot be recovered, the operations staff will attempt to decrease the pressure of the RCS by opening the PORV and high point vents in order to make the core flood tanks and LPI system available for core cooling.

Sequence O-6 (Loss of instrument air with failure of primary or secondary cooling)

The loss of instrument air results in a reliance on the emergency feedwater system steam-driven pump for secondary-side heat removal. Upon failure of this pump, the sequence and guidance is essentially the same as the loss of all feedwater, described in O-5 as an overheating transient.

Sequence O-7 (SGTR with failure of HPI)

There is a specific guideline (guideline III-D) for the occurrence of a SGTR and the SGTR scenario is discussed in detail in Part II of the ATOG. Identification of the tube rupture is probably from the steam line or condenser air ejector radiation alarm. If the primary-to-secondary heat transfer is excessive, the operations staff is directed to follow EXCESSIVE HEAT TRANSFER, guideline III-C, as expeditiously as possible and then to return to the SGTR guideline after heat transfer is stabilized. Guideline III-C results in the isolation of the faulted steam generator and the use of the functioning steam generator for secondary-side heat removal. Upon return to the SGTR guideline, the

Appendix D

operations staff begins to cooldown and depressurize. If the HPI system fails, the operations staff will enter the INADEQUATE CORE COOLING guidance. At this point, if failed systems cannot be recovered, the operations staff will attempt to decrease the pressure of the RCS by opening the PORV and high point vents in order to make the core flood tanks and LPI system available for core cooling.

Sequence O-8 (Loss of MFW with failure of primary or secondary cooling)

A loss of main and emergency feedwater will result in an overheating transient. This sequence and related guidance is essentially the same as that given for O-5.

Sequence O-9 (SGTR with failure of long-term heat removal)

There is a specific guideline for the occurrence of a steam generator tube rupture, which is one of the scenarios discussed in detail in Part II. Indication of an SGTR is probably given by the steam line or condenser air ejector radiation alarm. If the primary-to-secondary heat transfer is excessive, which would be the case if a main steam relief valve is stuck open, the operations staff is directed to follow EXCESSIVE HEAT TRANSFER, guideline III-C, as expeditiously as possible and then to return to the SGTR guideline after heat transfer is stabilized. Guideline III-C results in the isolation of the faulted steam generator and the use of the functioning steam generator for secondary-side heat removal. Upon return to the SGTR guideline, the operations staff begins a rapid cooldown if the SGTR leak rate is greater than the capacity of one normal makeup pump. There is no guidance mentioned in Part I of the ATOG to continually replenish the BWST to avoid entering the recirculation phase if the main steam relief valve is stuck open; it is, however, recognized in Part I of the ATOG that recirculation from the sump during a SGTR is not possible and means to replenish the BWST, a strategy need to be established. If long-term heat removal fails, the operations staff will enter the INADEQUATE CORE COOLING guidance. At this point, if failed systems cannot be recovered, the operations staff will attempt to decrease the pressure of the RCS by opening the PORV and high point vents in order to make the core flood tanks and LPI system available for core cooling.

Sequence O-10 (RPV rupture)

Due to the catastrophic nature of this event no actions can be taken to mitigate the accident or release. The ATOG does not address this event since there are no mitigating actions that could be taken. Actions to limit the potential for this type event are implied by trying to avoid thermal shock and brittle fracture operational regimes. Steps include throttling the HPI flow when subcooling margin is restored and restarting a RCP. Starting the RCP will mix the HPI water with reactor coolant, thus raising the temperature of the water and preventing brittle fracture.

D.3 ATOG Coverage of the "A" Strategies

Strategy 2.1 (Reduce Containment Spray Flow Rate to Conserve Water for Core Injection)

The ATOG does not recommend a strategy to reduce or terminate the reactor building sprays to conserve the water available to the core injection systems from the BWST. The need to provide for replenishing the BWST is referred to in the case of a SGTR, where the RCS inventory does not reach the sump. The ATOG emphasizes being in the decay heat removal mode before depleting the BWST.

Strategy 2.2 (Enable Early Detection, Isolation, or Otherwise Mitigate the Effects of an Interfacing Systems LOCA)

The ATOG provides direct guidance on identifying and isolating various types of LOCAs. For isolatable LOCAs, the locating symptoms and isolating valves are identified. Five LOCAs are identified as non-isolatable: SGTR, open pressurizer safety valves, HPI injection line break, RCP pump seal LOCA, and RCS instrumentation line break. For these, locating symptoms are provided. Specific guidance is provided for the occurrence of a SGTR.

Strategy 2.3.2 (Refill Refueling Water Storage Tank with Borated Water)

The ATOG recognizes the need to replenish the BWST in situations where there is not adequate inventory in the sump. This is directly addressed for the case of SGTRs, though the source(s) of this additional borated water is not identified.

Strategy 2.4 (Ensure Appropriate Recirculation Switchover and Manual Intervention Upon Failure of Automatic Switchover)

The ATOG recognizes the need to verify that the switch over to recirculation is achieved. Two general causes of recirculation failure are identified: loss of sump water and loss of both suction paths from the sump. The loss of sump water can occur because the RCS inventory does not accumulate in the sump (e.g., during a SGTR) or the sump water is diluted from a non-borated source, which requires the sump water to be borated and the dilution to be terminated. The loss of both suction paths can occur as a result of clogging or if both sump valves fail to open. The clogged valves may be cleared by back flushing the line. If the valves fail to open, local manual operation of the valves is suggested. However, it is recognized that local attempts to open these valves may not be possible because the radiation levels may be too high.

Strategy 2.5 (Ensure Adequate Plant Heat Removal Capability by Emergency Connection(s) of Existing or Alternate Water Sources)

The Oconee SSF can provide a backup supply of feedwater to the steam generators for secondary-side heat removal and can inject and maintain sufficient inventory in the RCS to sustain natural circulation and cool the RCP seals. The SSF also has its own electrical power system, with a dedicated diesel generator. This facility provides an additional level of backup to numerous important safety systems. The ATOG used in this study does not identify this backup system because the SSF was not fully implemented at Oconee at the time the ATOG was developed.

Strategy 3.2.1 (Enable Emergency Bypass or Change of Protective Trips for Injection Pumps)

This strategy is not discussed in the ATOG.

Strategy 3.3.2 (Use Non-Safety Related Charging Pumps for Core Injection)

The ATOG specific rules for initiating HPI state that if one HPI pump fails to start then the makeup pump is put in service, taking suction from the BWST. In addition, the SSF also provides an independent backup to the HPI system.

Strategy 3.4 (Use Alternate Seal Injection (e.g., Hydrotest Pump) When Reactor Coolant Pump Seal Cooling is Lost)

If RCP seal cooling is lost, the operations staff will trip the RCPs and attempt to recover seal cooling. The SSF provides a backup to this function and essentially implements the strategy at the Oconee Nuclear Station.

Appendix D

Strategy 3.5 (Use Condensate Pumps or Startup Feedwater Pumps for Steam Generator Injection)

At Oconee, this strategy is essentially implemented since the SSF can be used to provide feedwater to the steam generators for secondary-side heat removal. Since the SSF has a dedicated diesel generator, this feedwater source is not dependent on site AC power.

Strategy 4.1 (Conserve Battery Capability by Shedding Non-Essential Loads)

This strategy is not discussed in the ATOG.

Strategy 4.2 (Use Portable Battery Chargers or Other Power Sources to Recharge Station Batteries)

This strategy is not discussed in the ATOG.

Strategy 4.3 (Enable Emergency Replenishment of the Pneumatic Supply for Safety Related Air Operated Components)

This strategy is not discussed in the ATOG.

Strategy 4.4 (Enable Emergency Bypass or Change of Protective Trips for Emergency Diesel Generators)

This strategy does not apply since the Keowee Hydroelectric Station is the emergency AC power source for the Oconee Nuclear Station.

Strategy 4.5 (Enable Emergency Crosstie of AC Power Between Two Units or to an Onsite Gas Turbine Generator)

The emergency power source for all three Oconee units is the Keowee Hydroelectric Station, which supplies power via a 230-kV line to the Oconee switchyard. In addition, the Lee Steam Station combustion turbines can provide backup emergency AC power if the Keowee Hydroelectric Station is unavailable. A crosstie between Oconee units is thus not necessary.

Strategy 4.7 (Use Diesel-Driven Firewater Pump for ... Steam Generator Injection or Containment Sprays)

The strategy for using a pump that is independent of on-site AC power for steam generator injection is essentially implemented at Oconee since the SSF can be used to provide the feedwater and has its own dedicated diesel generator. The ATOG does not discuss the use of an independent source for reactor building sprays.

Strategy 5.1 (Reopen Main Steam Isolation Valves and Turbine Bypass Valves to Regain the Main Condenser as a Heat Sink)

This strategy is not discussed in the ATOG.

Strategy 6.1 (Provide Additional Supply of Borated Makeup Water for Long-Term Accident Control)

This strategy is similar to the strategy involving replenishing the RWST borated water inventory.

Appendix E

Table of Acronyms

Appendix E

Table of Acronyms

AC	alternating current	HPE	high-pressure melt ejection
AFW	auxiliary feedwater	HPSI	high-pressure safety injection
AI	artificial intelligence	HPSI/R	high-pressure safety injection/recirculation mode
ANN	artificial neural network	HPSW	high-pressure service water
AOP	Abnormal Operating Procedures	ICC	inadequate core cooling
ASWS	Auxiliary Service Water system	IPE	Individual Plant Evaluations
ATOG	Abnormal Transient Operating Guideline	IREP	Interim Reliability Evaluation Program
ATWS	anticipated transient without scram	IRM	Interruption and Resumption Mode
B&W	Babcock & Wilcox	JPA	job performance aid
BNL	Brookhaven National Laboratory	kVA	kilovolt amp
BWST	Borated Water Storage Tank	LOCA	loss of coolant accident
CC-1	Calvert Cliffs-1	LOF	loss of feedwater
CCP	centrifugal charging pumps	LOFT	Loss-of-Fluid Test
CCW	Component Cooling Water system	LOSP	Loss of Offsite power
CE	Combustion Engineering	LPI	Low Pressure injection
CEOG	Combustion Engineering Owners' Group	LPSW	Low Pressure Service Water system
CET	core exit thermocouple	MAAP	Modular Accident Analysis Code
CFT	core flood tank	MFW	Main Feedwater
DC	direct current	MOV	motor-operated valve
DCH	direct containment heating	MSIV	Main Steam Isolation Valve
DG	diesel generator	NRC	Nuclear Regulatory Commission
DST	demineralized water storage tank	NRC/RES	Office of Nuclear Regulatory Research
ECCS	emergency core cooling system	NSAC	Nuclear Safety Analysis Center
EDG	emergency diesel generator	ORG	Optimal Recovery Guideline
EOP	Emergency Operating Procedure	OTSG	once-through steam generator
EPG	Emergency Procedures Guideline	PCS	Power Conversion System
ERG	Emergency Response Guideline	PNL	Pacific Northwest Laboratory
FCI	fuel-coolant interaction	PORV	Pilot (or Power) Operated Relief Valve
FP	Fire Protection system	PRA	probabilistic risk assessment
FR	Functional Restoration	PTS	pressurized thermal shock
FRG	Functional Recovery Guideline	PWR	pressurized water reactor
FSAR	Final Safety Analysis Report		
FY	fiscal year		
HJTC	heated junction thermocouple		
HPI	high-pressure injection		

Appendix E

RCP	Reactor Coolant Pump	SPND	self-powered neutron detector
RCS	Reactor Coolant System	SRV	safety relief valve
RCVCS	Reactor Coolant Volume Control System	SSF	Standby Shutdown Facility
RHR	Residual Heat Removal system	SSF	Standby Shutdown Facility
RPV	Reactor Pressure Vessel	SW	Service Water system
RVLIS	Reactor Vessel Level Instrumentation system	SWS	Service Water system
RWST	Refueling Water Storage Tank	TBV	Turbine Bypass Valve
RWST	refueling water storage tank	TMI-2	Three Mile Island, Unit 2
SAD	system auxiliary diagram	U-235	uranium-235 isotope
SBO	station blackout	UPS	uninterruptible power system
SCRAM	scram, a rapid shutdown of the reactor	USNRC	U.S. Nuclear Regulatory Commission
SG	steam generator		
SGTR	steam generator tube rupture	W	Westinghouse
SI	safety injection	WOG	Westinghouse Owners Group
SPDS	Safety Parameter Display system		

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

	Jary Blair Portland General Electric Trojan Nuclear Power Plant 71700 Columbia River Highway Rainier, OR 97048		Dr. Pui Kuan EG&G Idaho, Inc. P.O. Box 1625 Idaho Falls, ID 83415-1576
	Peter Cybulskis Battelle Memorial Institute 505 King Avenue Columbus, OH 43201		Dr. Sudarshan K. Loyalka Dept. of Nuclear Engineering U of Missouri-Columbia Columbia, MO 65201
	Dr. Richard Denning Battelle Memorial Institute 505 King Avenue Columbus, OH 43201		Dr. Norm McCormick Dept. of Mechanical Engineering Univ of Washington Seattle, WA 98195
	Dr. Vijay Dhir Univ. of California, Los Angeles Mechanical, Aerospace, and Nuclear Engineering Department 405 Hilgard Ave. Los Angeles, CA 90024-1957	5	Mike Morgenstern Battelle HARC P.O. Box 5395 4000 N.E. 41st Street Seattle, WA 98105-5428
5	Donald G. Harrison Jason Associates 255 B Street, Suite 203 Idaho Falls, ID 83402		Walter Scott 2537 Cordova Court Richland, WA 99352
	Dr. William Kastenberg Univ. of California, Los Angeles Mechanical, Aerospace, and Nuclear Engineering Department 405 Hilgard Ave. Los Angeles, CA 90024-1957		

ONSITE

25 Pacific Northwest Laboratory
Francis Buck
Dr. Spencer H. Bush
Laurin Dodd
James Dukelow (10)
Dr. Bryan Gore (3)
Jim Jamison
James Livingston
Tim Mitts
Robert Moffitt
Dr. Billy Shipp
Eric Schmieman
Larry Sherfey
Rollie Warner
Kevin Winegardner

NRC FORM 335 12-89 NRC-1150 2001-2200		U.S. NUCLEAR REGULATORY COMMISSION		REPORT NUMBER (Assigned by NRC Add'l. Supp. Rev. and Addendum Numbers if any)	
BIBLIOGRAPHIC DATA SHEET <i>(See instructions on the reverse.)</i>				NUREG/CR-5896 PNL-8022	
7. TITLE AND SUBTITLE Identification and Evaluation of PWR In-Vessel Severe Accident Management Strategies				3. DATE REPORT PUBLISHED: MONTH YEAR March 1992	
				4. FIN OR GRANT NUMBER FIN 85996	
8. AUTHOR(S) J. S. Dukelow, D. G. Harrison ¹ , M. Morgenstern ²				6. TYPE OF REPORT Technical	
				7. PERIOD COVERED (Include Dates)	
9. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address, if contractor, provide name and mailing address.) Pacific Northwest Laboratory Richland, WA 99352 Jason Associates, Idaho Falls, ID 83402 ² Battelle Human Affairs Research Centers, Seattle, WA 98105-5428					
9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.) Division of Systems Research Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555					
10. SUPPLEMENTARY NOTES					
11. ABSTRACT (200 words or less) This reports documents work performed for the NRC/RES Accident Management Guidance Program to evaluate possible strategies for mitigating the consequences of PWR severe accidents. The selection and evaluation of strategies was limited to the in-vessel phase of the severe accident, i.e., after the initiation of core degradation and prior to RPV failure. A parallel project at BNL has been considering strategies applicable to the ex-vessel phase of PWR severe accidents.					
12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.) Nuclear reactor safety Severe accidents Accident management Risk assessment				13. AVAILABILITY STATEMENT Unlimited	
				14. SECURITY CLASSIFICATION (This Page) Unclassified	
				(This Report) Unclassified	
				15. NUMBER OF PAGES	
16. PRICE					

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH-CLASS RATE
POSTAGE & FEES PAID
USNRC
PERMIT No. G-87

1205555139531 1 1A1RK
USPS NRC-OADM
DIV - FOIA & PUBLICATIONS SVCS
TO - PDR-NUREG
DC 20555
WASHINGTON