

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Robert C. Hagan
Vice President Engineering

November 17, 1995

ET 95-0126

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555


Reference: Letter WM 95-0129, dated August 30, 1995, from N. S. Carns, to USNRC
Subject: Docket No. 50-482: Clarification of Relief Request I2R-15

Gentlemen:

This letter clarifies Relief Request I2R-15 which was submitted as part of the Inservice Inspection Program. The Reference submitted the Inservice Inspection Program for the second ten year interval. Relief Request I2R-15 concerns a request for relief from the requirements of ASME Section XI, IWF-5000 for the visual examination of snubbers. The justification provided in the relief request stated that the requirements of ASME Section XI, IWF-5000 were redundant to the requirements of the snubber inspection program required by the Wolf Creek Generating Station Technical Specification. However, License Amendment No. 89, which was issued on October 2, 1995, relocated the technical specification requirements for a snubber inspection program to the Updated Safety Analysis Report. The relocated snubber inspection program continues to require the visual examinations of safety-related snubbers as discussed in the relief request. Any potential changes made to the snubber inspection program will be made in accordance with the requirements of 10 CFR 50.59.

If you have any questions concerning this matter, please contact me at (316) 364-8831, extension 4553, or Mr. Richard D. Flannigan, at extension 4500.

Very truly yours,



Robert C. Hagan

RCH/jra

cc: L. J. Callan (NRC)
W. D. Johnson (NRC)
J. F. Ringwald (NRC)
J. C. Stone (NRC)

9511210205 951117
PDR ADOCK 05000482
PDR

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/H/VET

ADH 1/0