

APPENDIX A

NOTICE OF VIOLATION

Power Authority of the State of New York
James A. Fitzpatrick Nuclear Power Plant

Docket No. 50-333
License No. DPR-50

As a result of the inspection conducted on May 21-25, 1984, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), published in the Federal Register on March 8, 1984 (49 FR 8583), the following violation was identified:

- A. 10 CFR 71.111 states, "The licensee shall prescribe activities affecting quality by documented instructions, procedures, or drawings."

Contrary to the above, the licensee did not have a procedure prescribing the quality assurance activities of waste classification, waste characterization and labeling described in 10 CFR 61 which was effective December 27, 1983.

This is a Severity Level IV violation (Supplement V).

Pursuant to the provisions of 10 CFR 2.201, the Power Authority of the State of New York is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

OFFICIAL RECORD COPY

DL50-333/84-09 - 0002.0.0
07/20/84

B408150539 B40727
PDR ADOCK 05000333
9 PDR