



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 82  
License No. DPR-59


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Power Authority of the State of New York (the licensee) dated February 25, 1983, as supplemented May 3, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 82, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief  
Operating Reactors Branch #2  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: August 3, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 82

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise the Appendix "A" Technical Specifications as follows:

Remove

239

Insert

239

### B. Crescent Area Ventilation

Crescent area ventilation and cooling equipment shall be operable on a continuous basis whenever specification 3.5.A, 3.5.B, and 3.5.C are required to be satisfied.

1. From and after the date that more than one unit cooler serving ECCS components in the same compartment are made or found to be inoperable, all ECCS components in that compartment shall be considered to be inoperable for purposes of specification 3.5.A, 3.5.C, and 3.5.D.

### C. Battery Room Ventilation

Battery room ventilation shall be operable on a continuous basis whenever specification 3.9.E is required to be satisfied.

1. From and after the date that one of the battery room ventilation systems is made or found to be inoperable, its associated battery shall be considered to be inoperable for purposes of specification 3.9.E.

### B. Crescent Area Ventilation

Unit coolers serving ECCS components shall be checked for operability once/3 months

1. When it is determined that two unit coolers serving ECCS components in the same compartment are made or found inoperable, reactor operation may continue for 7 days unless one is made operable earlier.
2. Temperature indicator controllers shall be calibrated once/operating cycle.
3. If 3.11.B.1 cannot be met, the reactor shall be placed in a cold condition within 24 hours.

### C. Battery Room Ventilation

Battery room ventilation equipment shall be checked for operability once/week.

1. When it is determined that one battery room ventilation system is inoperable, the remaining ventilation system shall be checked for operability and daily thereafter.
2. Temperature transmitters and differential pressure switches shall be calibrated once/operating cycle.