



Southern Nuclear Operating Company

the southern electric system

J. D. Woodard
Vice President
Farley Project

March 27, 1992

Docket No. 50-364

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Joseph M. Farley Nuclear Plant - Unit 2
Interim Plugging Criteria

Gentlemen:

In a telephone conversation on March 23, 1992, the Farley NRC Staff Project Manager requested that Southern Nuclear Operating Company (Southern Nuclear) undertake four actions which had previously been discussed with the Staff. The NRC requests and Southern Nuclear's positions are provided below.

1. NRC Request

The licensee's eddy current test guidelines (Attachment 7 to letter dated February 7, 1992) shall be revised to require that all flaw indications (as defined in Section A.3.1 of Appendix A to WCAP-12871, Revision 2) be recorded, regardless of voltage amplitude.

Southern Nuclear Position

Southern Nuclear will record all flaw indications regardless of voltage amplitude.

2. NRC Request

RPC flaw indications not found by the bobbin due to masking effects (due to denting, artifact indications, noise) shall be plugged or repaired. Tubes with greater than 5.0 volt dents (as measured with the bobbin) shall be plugged or repaired if they are found to exhibit RPC flaw indications.

Southern Nuclear Position

RPC flaw indications not found by the bobbin due to masking effects (due to denting, artifact indications, noise) will be plugged or repaired. Tubes with greater than 5.0 volt dents (as measured with the bobbin) will be plugged or repaired if they are found to exhibit RPC flaw indications.

310004

9203310214 920327
PDR ADOCK 05000364
P FDR

ADD 1/1

3. NRC Request

The licensee shall inform the Staff, prior to Cycle 9 operation, of any unexpected inspection findings relative to the assumed characteristics of the flaws at the TSPs. This includes any detectable circumferential indications or detectable indications extending outside of the TSP thickness. The licensee's safety evaluation of these unexpected findings shall also be provided.

Southern Nuclear Position

Southern Nuclear will inform the NRC, prior to Cycle 9 operation, of any unexpected inspection findings relative to the assumed characteristics of the flaws at the TSPs. This includes any detectable circumferential indications or detectable indications outside the TSP thickness. Any applicable safety evaluations for unexpected findings will be provided to the NRC.

4. NRC Request

The Staff's approval of the proposed interim repair limit is contingent on the licensee's being able to demonstrate that acceptance of all indications satisfying the 1.0 volt criterion will not create potential for leakage in excess of the 1.0 gpm licensing basis for a postulated SLB occurring at EOC 9. The licensee is requested to submit the results of the SLB leakage analysis prior to restart from the eighth refueling outage.

Southern Nuclear Position

The predicted SLB leakage will be reported to the Staff prior to restart from the eighth refueling outage for Unit 2. Southern Nuclear understands and accepts that the Staff's approval of the interim repair limit is contingent on the demonstration that the predicted SLB leakage at EOC 9 will not exceed 1 gpm.


The above positions are applicable only to the Unit 2 ninth operating cycle upon approval of the interim plugging criteria.

In addition to the above, revised Technical Specification pages to correct editorial errors in pages 3/4 4-17 and B3/4 4-3a submitted by Southern Nuclear letter dated February 20, 1992 are attached. The changes to these pages restore existing wording to portions of the pages which were not revised in support of the interim plugging criteria. These changes have no impact on the significant hazards evaluation included with Southern Nuclear's February 20, 1992 letter.

If there are any questions, please advise.


Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY


J. D. Woodard

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 27th DAY OF March, 1992


Notary Public

My Commission Expires: 8-24-92

JDW/REM:map

Attachment

cc: Mr. S. D. Ebner
Mr. S. T. Hoffman
Mr. G. F. Maxwell