



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA
VOGTLE ELECTRIC GENERATING PLANT, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 91
License No. NPF-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Vogtle Electric Generating Plant, Unit 1 (the facility) Facility Operating License No. NPF-68 filed by the Georgia Power Company, acting for itself, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the licensees), dated May 12, 1995, as supplemented by letters dated July 6 and October 2, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9511270090 951117
PDR ADOCK 05000424
P PDR


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-68 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 91, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. GPC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Change

Date of Issuance: November 17, 1995



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

GEORGIA POWER COMPANY
OGLETHORPE POWER CORPORATION
MUNICIPAL ELECTRIC AUTHORITY OF GEORGIA
CITY OF DALTON, GEORGIA
VOGTLE ELECTRIC GENERATING PLANT, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 69
License No. NPF-81

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Vogtle Electric Generating Plant, Unit 2 (the facility) Facility Operating License No. NPF-81 filed by the Georgia Power Company, acting for itself, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, and City of Dalton, Georgia (the licensees), dated May 12, 1995, as supplemented by letters dated July 6 and October 2, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-81 is hereby amended to read as follows:

Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 69 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. GPC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: November 17, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 91

FACILITY OPERATING LICENSE NO. NPF-68

DOCKET NO. 50-424

AND

TO LICENSE AMENDMENT NO. 69

FACILITY OPERATING LICENSE NO. NPF-81

DOCKET NO. 50-425

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

Remove Page

3/4 6-2

Insert Page

3/4 6-2

CONTAINMENT SYSTEMS

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of less than or equal to L_a , 0.20% by weight of the containment air per 24 hours at a pressure not less than P_a , 37 psig, or
- b. A combined leakage rate of less than $0.60 L_a$ for all penetrations and valves subject to Type B and C tests, when pressurized to a pressure not less than P_a , 37 psig.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With either the measured overall integrated containment leakage rate exceeding $0.75 L_a$ or the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the overall integrated leakage rate to less than $0.75 L_a$, and the combined leakage rate for all penetrations subject to Type B and C tests to less than $0.60 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 Except as modified by NRC-approved exemptions, the containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 ± 10 month intervals* during shutdown at a pressure not less than P_a , 37 psig, during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection;

* The Type A test scheduled for VEGP Unit 1 during 1R6 will be rescheduled to the 1997 refueling outage.