

ATTACHMENT TO LICENSE AMENDMENT NO. 141

FACILITY OPERATING LICENSE NO. DPR-40

DOCKET NO. 50-285

Revise Appendix "A" Technical Specifications as indicated below. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

<u>REMOVE PAGES</u>	<u>INSERT PAGES</u>
iii	iii
viii	viii
2	2
7	7
8	8
1-2	1-2
Figure 1-3	-
1-8	1-8
1-10	1-10
2-20	2-20
2-22	2-22
2-39	2-39
2-50a	2-50a
2-50b	2-50b
2-50c	2-50c
Figure 2-4	-
Figure 2-5	-
Figure 2-6	-
Figure 2-7	-
Figure 2-9	-
2-54	2-54
2-55	2-55
2-56	2-56
2-57	2-57
2-57a	2-57a
2-57b	2-57b
2-57c	2-57c
2-57d	2-57d
2-57e	2-57e
2-62	2-62
3-63a	3-63a
4-4	4-4
5-4	5-4
5-5	5-5
-	5-17a

- (a) Specifications 1.1 and 2.10.4 and Bases 2.10.3 and 2.10.4
The total unrodded planar radial peaking factor and the unrodded integral radial peaking factor are provided in the COLR.
 - (b) Specifications 1.1 and 1.3, Figure 1-3, and Table 1-1
Reference to Figure 1-3 is deleted since the coefficients of the thermal margin/low pressure (TM/LP) reactor trip limit of these specifications as well as the Figure are provided in the COLR.
 - (c) Specifications 2.3, 2.8, 2.14, and 4.4.2 and Bases 2.3 and 2.8
The refueling boron concentration for these specifications is provided in the COLR.
 - (d) Specifications 2.10.2, 2.10.4, and 2.14 and Figure 2-4
The power dependent insertion limits (PDIL) for these specifications are provided in the COLR.
 - (e) Specifications 2.10.3, 2.10.4, and 3.10 and Figure 2-6
The limiting conditions for operations (LCO) for excore monitoring of linear heat rate (LHR) for these specifications are provided in the COLR.
 - (f) Specification 2.10.3 and Figure 2-7
The LCO for departure from nucleate boiling (DNB) monitoring for this specification is provided in the COLR.
 - (g) Specification 2.10.4, Figure 2-5, and Bases 2.10.3 and 2.10.4
The allowable peak LHR as a function of burnup for this specification is provided in the COLR.
 - (i) Specification 2.10.4
The core inlet temperature limit for this specification is provided in the COLR.
 - (j) Specification 2.10.4, Figure 2-9, and Bases 2.10.4
The total unrodded planar radial peaking factor, the unrodded integral radial peaking factor, and the core power limitations are provided in the COLR.
- (3) Specification 5.5.1.6 is revised to require Plant Review Committee review of all changes to the COLR.