

NUREG/CR-4551
SAND86-1309
Vol. 2, Rev. 1, Part 3

Evaluation of Severe Accident Risks: Quantification of Major Input Parameters

Experts' Determination of Structural Response Issues

Prepared by
R. J. Breeding, F. T. Harper, T. D. Brown, J. J. Gregory,
A. C. Payne, E. D. Gorham, W. Murfin, C. N. Amos

Sandia National Laboratories
Operated by
Sandia Corporation

Prepared for
U.S. Nuclear Regulatory Commission

9204060038 920331
PDR NUREG
CR-4551 R PDR

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW., Lower Level, Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC bulletins, circulars, information notices, inspection and investigation notices; licensee event reports, vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, international agreement reports, grant publications, and NRC booklets and brochures. Also available are regulatory guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG-series reports and technical reports prepared by other Federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions. *Federal Register* notices, Federal and State legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Administration, Distribution and Mail Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Nerfnik Avenue, Bethesda, Maryland, for use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Evaluation of Severe Accident Risks: Quantification of Major Input Parameters

Experts' Determination of Structural Response Issues

Manuscript Completed: November 1991
Date Published: March 1992

Prepared by
R. J. Breeding, F. T. Harper, T. D. Brown, J. J. Gregory,
A. C. Payne, E. D. Gorham, W. Murfin¹, C. N. Amos²

Sandia National Laboratories
Albuquerque, NM 87185-5800

Prepared for
Division of Safety Issue Resolution
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555
NRC FIN L1272

¹Technadyne Engineering Consultants, Inc., Albuquerque, NM

²Science Applications International Corporation, Albuquerque, NM

ABSTRACT

This report records part of the vast amount of information received during the expert judgment elicitation process that took place in support of the NUREG-1150 effort sponsored by the U.S. Nuclear Regulatory Commission. The results of the Structural Response Expert Panel Elicitation are presented in this part of Volume 2 of NUREG/CF-4551. The Containment Loads Expert Panel considered eight issues:

1. Static failure pressure and mode at Zion;
2. Static failure pressure and mode at Surry;
3. Static failure pressure and mode at Peach Bottom;
4. Reactor Building bypass at Peach Bottom;
5. Static failure pressure and mode at Sequoyah;
6. Ice condenser failure due to detonations at Sequoyah;
7. Drywell and wetwell failure due to detonations at Grand Gulf;
8. Pedestal failure due to erosion at Grand Gulf.

The report begins with a brief discussion of the methods used to elicit the information from the experts. The information for each issue is then presented in five sections: (1) a brief definition of the issue, (2) a brief summary of the technical rationale supporting the distributions developed by each of the experts, (3) a brief description of the operations that the project staff performed on the raw elicitation results in order to aggregate the distributions, (4) the aggregated distributions, and (5) the individual expert elicitation summaries. The individual expert elicitation summaries were written soon after the elicitation and were sent to the experts for review. They represent the raw results as received directly from the experts.

CONTENTS

| | | |
|------|--|-------|
| 1. | INTRODUCTION..... | i.1 |
| 2. | EXPERT CREDENTIALS..... | 2.1 |
| 3. | METHODOLOGY..... | 3.1 |
| 3.1 | Introduction..... | 3.1 |
| 3.2 | Steps to Elicit Expert Judgment..... | 3.2 |
| 3.3 | Selection of Issues..... | 3.2 |
| 3.4 | Selection of Experts..... | 3.8 |
| 3.5 | Elicitation Training..... | 3.8 |
| 3.6 | Presentation of Issues..... | 3.10 |
| 3.7 | Preparation and Discussion of Analyses..... | 3.11 |
| 3.8 | Elicitation..... | 3.11 |
| 3.9 | Recomposition and Aggregation of Results..... | 3.12 |
| 3.10 | Review..... | 3.13 |
| 3.11 | Documentation..... | 3.13 |
| 4. | ELICITATION MEETINGS..... | 4.1 |
| 5. | ISSUE DESCRIPTIONS AND ELICITATION RESULTS..... | 5.1-1 |
| 5.1 | Issue 1. Containment Failure at Zion..... | 5.1-1 |
| 5.2 | Issue 2. Containment Failure at Surry..... | 5.2-1 |
| 5.3 | Issue 3. Peach Bottom Containment Failure..... | 5.3-1 |
| 5.4 | Issue 4. Effect of Wetwell Rupture on ECCS Survivability and Reactor Building Integrity at Peach Bottom..... | 5.4-1 |
| 5.5 | Issue 5. Containment Failure at Sequoyah Due to Static Pressure..... | 5.5-1 |
| 5.6 | Issue 6. Sequoyah Containment Failure Due to Detonation..... | 5.6-1 |
| 5.7 | Issue 7. Containment Failure Due to Wetwell Deteriorations at Grand Gulf..... | 5.7-1 |
| 5.8 | Issue 8. Pedestal Failure at Grand Gulf..... | 5.8-1 |

FIGURES

1. Back-End Documentation for NUREG-1150.....xv

Issue 1

1-1. Zion Containment Failure Pressure.....5.1-3

Issue 2

2-1. Cumulative Failure Probabilities.....5.2-11
2-2. Conditional Probabilities of Leak.....5.2-11
2-3. Conditional Probabilities of Catastrophic Rupture.....5.2-12
2-4. Conditional Probabilities of Rupture.....5.2-12

Issue 5

5-1. Cumulative Failure Probability.....5.5-10
5-2. Conditional Probability for Failure Mode:
Leak, No Bypass.....5.5-10
5-3. Conditional Probability for Failure Mode:
Leak, Bypass.....5.5-11
5-4. Conditional Probability for Failure Mode:
Rupture, No Bypass.....5.5-11
5-5. Conditional Probability for Failure Mode:
Rupture with Bypass.....5.5-12
5-6. Conditional Probability for Failure Mode:
Catastrophic Rupture.....5.5-12

Issue 6

6-1 Failure of the Upper Plenum Due to Detonation..... 5.6-6
6-2 Failure of Ice Condenser Due to Detonation..... 5.6-8

Issue 7

7-1 Aggregate Containment Failure Distributions.....5.7-12
7-2 Aggregate Drywell Failure Distributions.....5.7-12

FIGURES (Continued)

| | | |
|-----|---|--------|
| 7-3 | Aggregate Smoothed Containment Failure Distributions..... | 5.7-13 |
| 7-4 | Aggregate Smoothed Drywell Failure Distributions..... | 5.7-13 |
| A-1 | Averaged Failure Probabilities for Levels 1 Through 3..... | 5.7-22 |

Issue 8

| | | |
|-----|--|--------|
| C-1 | Grand Gulf Reactor Pedestal Configuration..... | 5.8-11 |
| C-2 | Drawing C-1048A..... | 5.8-12 |
| C-3 | Probability of Pedestal Failure..... | 5.8-16 |

TABLES

| | | |
|-----|---|-----|
| 1. | NUREG-1150 Analysis Documentation..... | xvi |
| 1-1 | Structural Response Issues Considered for Expert Judgment Elicitation..... | 1.3 |
| 3-1 | Issues Presented to the In-Vessel Panel..... | 3.4 |
| 3-2 | Issues Presented to the Containment Loads Panel..... | 3.5 |
| 3-3 | Issues Presented to the Structural Response Panel..... | 3.6 |
| 3-4 | Issues Presented to the Molten Core-Concrete Interaction Panel..... | 3.7 |
| 3-5 | Issues Presented to the Source Term Panel..... | 3.7 |

Issue 1

| | | |
|-----|---|-------|
| 1-1 | Expert A..... | 5.1-4 |
| 1-2 | Expert B..... | 5.1-5 |
| 1-3 | Expert C..... | 5.1-6 |
| 1-4 | Aggregate..... | 5.1-7 |
| 1-5 | Zion Static Failure Pressure Joint Distribution for Containment Failure Pressure and Mode..... | 5.1-8 |

TABLES (Continued)

Issue 2

| | | |
|-----|--|--------|
| A-1 | Surry Static Failure Pressure as Received from Expert A..... | 5.2-3 |
| B-1 | Surry Static Failure Pressure as Received from Expert B..... | 5.2-4 |
| C-1 | Surry Static Failure Pressure as Received from Expert C..... | 5.2-5 |
| D-1 | Surry Static Failure Pressure as Received from Expert D..... | 5.2-6 |
| C-2 | Joint Interval Probabilities and Modifications to Total Cumulative Probabilities..... | 5.2-7 |
| D-2 | Joint Interval Probabilities and Modifications to Total Cumulative Probabilities..... | 5.2-9 |
| 2-1 | Aggregate: Surry Static Failure Pressure..... | 5.2-10 |
| 2-2 | Surry Static Failure Pressure Failure Mode Probabilities for Rapid Pressure Rise..... | 5.2-17 |

Issue 3

| | | |
|-----|--|--------|
| 3-1 | Average of Experts: Cases 1 and 2..... | 5.3-6 |
| 3-2 | Peach Bottom Front-End Information: Cases 1 and 2..... | 5.3-7 |
| 3-3 | Average of Experts: Case 3A..... | 5.3-9 |
| 3-4 | Average of Experts: Case 3B..... | 5.3-10 |
| 3-5 | Case 4 Results..... | 5.3-11 |
| A-1 | Results for Expert A: Cases 1 and 2..... | 5.3-20 |
| A-2 | Expert A: Cases 1 and 2 Data Conversion..... | 5.3-21 |
| A-3 | Expert A's Conditional Probabilities: Cases 1 and 2..... | 5.3-22 |
| A-4 | Results for Expert A: Case 3A..... | 5.3-23 |
| A-5 | Expert A: Case 3A Data Conversion..... | 5.3-24 |
| A-6 | Expert A's Conditional Probabilities: Cases 3A..... | 5.3-25 |

TABLES (Continued)

Issue 6 (continued)

| | | |
|-----|--|--------|
| A-1 | Anchor Bolt Failure (Ice Condenser Bypass)..... | 5.6-13 |
| A-2 | Membrane Failure of the Containment Cylinder Containment Wall Above Ice Condenser (No Ice Condenser Bypass)..... | 5.6-14 |
| A-3 | Membrane Failure of the Containment Cylinder Lower Part of Containment (Ice Condenser Bypass)..... | 5.6-14 |
| A-4 | Ice Condenser Panel Blowout (Loss of Ice Condenser Function)..... | 5.6-15 |

Issue 7

| | | |
|-----|--|--------|
| 7-1 | Containment Failure: Distributions for Expert A..... | 5.7-4 |
| 7-2 | Containment Failure: Distributions for Expert B..... | 5.7-4 |
| 7-3 | Containment or Drywell Failure Distributions for Expert C..... | 5.7-5 |
| 7-4 | Containment Failure: Aggregate Distributions..... | 5.7-6 |
| 7-5 | Drywell Failure: Distributions for Expert A..... | 5.7-7 |
| 7-6 | Drywell Failure: Distributions for Expert B..... | 5.7-9 |
| 7-7 | Drywell Failure: Aggregate Distributions..... | 5.7-10 |
| A-1 | Case 1A--Failure of Containment Above Drywell, Due to Detonation Above Drywell..... | 5.7-18 |
| A-2 | Case 1B--Failure of Containment at Annulus, Due to Detonation in the Annulus..... | 5.7-18 |
| A-3 | Case 1C--Failure of Drywell/Wetwell Structure Due to Detonation in Wetwell Annulus..... | 5.7-19 |
| A-4 | Case 1A: Independent CDFs for Each Failure Level..... | 5.7-20 |
| A-5 | Case 1B: Independent CDFs for Each Failure Level..... | 5.7-21 |
| A-6 | Case 1C: Independent CDFs for Each Failure Level..... | 5.7-21 |
| B-1 | Drywell Leakage..... | 5.7-25 |

TABLES (Continued)

Issue 7 (continued)

| | | |
|-----|--|--------|
| B-2 | Drywell Rupture..... | 5.7-25 |
| B-3 | Conditional Probabilities of Drywell Failure..... | 5.7-26 |
| B-4 | Joint Cumulative Probability of Drywell Failure..... | 5.7-26 |
| C-1 | Containment/Drywell Failure Probabilities Very Small Leakage (Level 1)..... | 5.7-30 |
| C-2 | Containment/Drywell Failure Probabilities Small Leakage (Level 2)..... | 5.7-30 |
| C-3 | Containment/Drywell Failure Probabilities Large Leakage (Level 3)..... | 5.7-31 |

Issue 8

| | | |
|-----|--|--------|
| 8-1 | Issue Case Structure..... | 5.8-1 |
| 8-2 | Experts' Results and Aggregated Distribution..... | 5.8-3 |
| A-1 | Probability of Pedestal Failure..... | 5.8-8 |
| B-1 | Reduction in Yield Strength vs. T(°F)..... | 5.8-9 |
| B-2 | Probability of Pedestal Failure vs. Average Temperature in the Outer Rebar Group..... | 5.8-10 |

TABLES (Continued)

Issue 3 (continued)

| | | |
|-----|--|--------|
| A-7 | Results for Expert A: Case 3B..... | 5.3-26 |
| A-8 | Expert A: Case 3B Data Conversion..... | 5.3-27 |
| A-9 | Expert A's Conditional Probabilities: Case 3B..... | 5.3-28 |
| B-1 | Results of Expert B: Cases 1 and 2..... | 5.3-33 |
| B-2 | Results of Expert B: Case 3A..... | 5.3-34 |
| B-3 | Results of Expert B: Case 3B..... | 5.3-35 |
| C-1 | Results of Expert C: Cases 1 and 2..... | 5.3-43 |
| C-2 | Expert C: Cases 1 and 2 Data Conversion..... | 5.3-44 |
| C-3 | Expert C's Conditional Probabilities: Cases 1 & 2..... | 5.3-45 |
| C-4 | Results of Expert C: Case 3A and 2..... | 5.3-46 |
| C-5 | Expert C: Case 3A Data Conversion..... | 5.3-47 |
| C-6 | Expert C's Conditional Probabilities: Case 3A..... | 5.3-48 |
| C-7 | Results of Expert C: Case 3B and 2..... | 5.3-49 |
| C-8 | Expert C: Case 3B Data Conversion..... | 5.3-50 |
| C-9 | Expert C's Conditional Probabilities: Case 3B..... | 5.3-51 |

Issue 4

| | | |
|-----|---|-------|
| 4-1 | Probability of Reactor Building Bypass for WWR--Expert A..... | 5.4-2 |
| 4-2 | Probability of Reactor Building Bypass for WWR--Expert B..... | 5.4-3 |
| 4-3 | Failure Probabilities for Seven Cases for WWR--Expert C..... | 5.4-3 |
| 4-4 | Probability of Reactor Building Bypass for WWR--Expert C..... | 5.4-4 |
| 4-5 | Probability of Reactor Building Bypass for WWR--Aggregate..... | 5.4-4 |

TABLES (Continued)

Issue 4 (continued)

A-1 Descriptions of Equivalent Static Pressures..... 5.4-8
 A-2 Probability of Reactor Building Bypass--Expert A..... 5.4-9

Issue 5

5-1 Sequoyah Static Failure Probabilities
 for Expert A..... 5.5-3
 5-2 Sequoyah Static Failure Probabilities
 for Expert B..... 5.5-4
 5-3 Sequoyah Static Failure Probabilities
 for Expert C..... 5.5-5
 5-4 Conversion of Expert A's Elicitation
 Values from Table 5-1. 5.5-6
 5-5 Conversion of Expert B's Elicitation Values
 from Table 5-2..... 5.5-7
 5-6 Conversion of Expert C's Elicitation Values
 from Table 5-3..... 5.5-8
 5-7 Aggregate Static Failure Probabilities
 for Sequoyah..... 5.5-9
 5-8 Interval Probability Densities.....5.5-15
 5-9 Expert B's Joint Probability Densities.....5.5-16
 5-10 Failure Mode Probabilities for Rapid Pressure
 Rise Failure Pressure = 0.5 psig.....5.5-20

Issue 6

5-1 Distributions for Expert A..... 5.6-3
 6-2 Distributions for Expert B..... 5.6-4
 6-3 Distributions for Expert C..... 5.6-5
 6-4 Aggregate Distribution for Failure
 of Upper Plenum. 5.6-5
 6-5 Aggregated Distribution for Failure
 of Ice Condenser..... 5.6-7

FOREWORD

This is one of many documents that constitute the technical basis for the NUREG-1150 document produced by the NRC Office of Nuclear Regulatory Research. This document's purpose is to present the results of the Structural Response Expert Panel. The document consists of the distributions and associated technical rationale provided by the expert panels for the phenomenological questions posed by the NUREG-1150 analysts.

Figure 1 identifies all the documents that present the results of the accident progression analysis, the source term analysis, the consequence analysis, and the overall risk integration. Three interfacing programs performed this work: the Accident Sequence Evaluation Program (ASEP), the Severe Accident Risk Reduction Program (SARRP), and the PRA Phenomenology and Risk Uncertainty Evaluation Program (PRUEP). Table 1 is a list of all of the original primary documentation (published in 1987) and the corresponding revised documentation that supports the current version of NUREG-1150.

The current NUREG/CR-4551 covers the analysis included in the original NUREG/CR-4551 and NUREG/CR-4700. The accident progression event trees originally documented in NUREG/CR-4700 are now documented in the appendices of Volumes 3 to 7 of NUREG/CR-4551.

Originally, NUREG/CR-4550 was published without the designation "Draft for Comment." Thus, the final revision of NUREG/CR-4550 is designated Revision 1. The label Revision 1 is used consistently on all volumes, including Volume 2 which was not part of the original documentation. NUREG/CR-4551 was originally published as a "Draft for Comment"; so, in its final form, no Revision 1 designator is required to distinguish it from the previous documentation.

There are several other reports published that are closely related to NUREG/CR-4551:

NUREG/CR-5380, SAND88-2988, S. J. Hyman, "A User's Manual for the Post Processing Program PSTEVNT," Sandia National Laboratories, Albuquerque, NM, 1989.

NUREG/CR-5360, SAND89-0943, H.-N. Jow, W. B. Murfin, and J. D. Johnson, "XSOR Codes User's Manual," Sandia National Laboratories, Albuquerque, NM, 1989.

NUREG/CR-4624, BMI-2139, R. S. Denning et al., "Radionuclide Release Calculations for Selected Severe Accident Scenarios," Volumes I-V, Battelle's Columbus Division, Columbus, OH, 1986.

NUREG/CR-5062, BMI-2160, M. T. Leonard et al., "Supplemental Radionuclide Release Calculations for Selected Severe Accident Scenarios," Battelle Columbus Division, Columbus, OH, 1988.

NUREG/CR-5331, SAND89-0072, S. E. Dingman et al., "MELCOR Analyses for Accident Progression Issues," Sandia National Laboratories, Albuquerque, NM, 1989.

NUREG/CR-5253, SAND88-2940, R. L. Iman, J. C. Helton, and J. D. Johnson, "PARTITION: A Program for Defining the Source Term/Consequence Analysis Interfaces in the NUREG-1150 Probabilistic Risk Assessments User's Guide," Sandia National Laboratories, Albuquerque, NM, 1989.

NUREG/CR-5382, SAND88-2695, J. C. Helton et al., "Incorporation of Consequence Analysis Results into the NUREG-1150 Probabilistic Risk Assessments," Sandia National Laboratories, Albuquerque, NM, 1989.

NUREG/CR-5174, SAND88-1607, J. M. Jriesmeyer and L. N. Smith, "A Reference Manual for the Event Progression Analysis Code (EVENTRE)," Sandia National Laboratories, Albuquerque, NM, 1989.

NUREG/CR-5262, SAND88-3093, R. L. Iman, J. D. Johnson, and J. C. Helton, "PRAMIS: Probabilistic Risk Assessment Model Integration System User's Guide," Sandia National Laboratories, Albuquerque, NM, May 1990.

SUPPORT DOCUMENTS TO NUREG-1150




Figure 1. Back-End Documentation for NUREG-1150.

Table 1. NUREG-1150 Analysis Documentation

Original Documentation

| NUREG/CR-4550 | | NUREG/CR-4551 | | NUREG/CR-4700 | |
|--|---------------------------|--|-----------------------|---|-----------------------|
| Analysis of Core Damage Frequency From Internal Events | | Evaluation of Severe Accident Risks and the Potential for Risk Reduction | | Containment Event Analysis for Potential Severe Accidents | |
| Vol. | 1 Methodology | Vol. | 1 Surry Unit 1 | Vol. | 1 Surry Unit 1 |
| | 2 Summary (Not Published) | | 2 Sequoyah Unit 1 | | 2 Sequoyah Unit 1 |
| | 3 Surry Unit 1 | | 3 Peach Bottom Unit 2 | | 3 Peach Bottom Unit 2 |
| | 4 Peach Bottom Unit 2 | | 4 Grand Gulf Unit 1 | | 4 Grand Gulf Unit 1 |
| | 5 Sequoyah Unit 1 | | | | |
| | 6 Grand Gulf Unit 1 | | | | |
| | 7 Zion Unit 1 | | | | |

Revised Documentation

| NUREG/CR-4550, Rev. 1, Analysis of Core Damage Frequency | | NUREG/CR-4551, Rev. 1, Eval. of Severe Accident Risks | |
|--|---|---|---|
| Vol. 1 | Methodology | Vol. 1 | Part 1, Methodology; Part 2, Appendices |
| 2 | Part 1 Expert Judgment Elicit. Expert Panel Part 2 Expert Judgment Elicit. Project Staff | 2 | Part 1 In-Vessel Issues Part 2 Containment Loads and MCCI Issues Part 3 Structural Issues Part 4 Source Term Issues Part 5 Supporting Calculations Part 6 Other Issues Part 7 MACCS Input |
| 3 | Part 1 Surry Unit 1 Internal Events Part 2 Surry Unit 1 Internal Events App. Part 3 Surry External Events | 3 | Part 1 Surry Analysis and Results Part 2 Surry Appendices |
| 4 | Part 1 Peach Bottom Unit 2 Internal Events Part 2 Peach Bottom Unit 2 Int. Events App. Part 3 Peach Bottom Unit 2 External Events | 4 | Part 1 Peach Bottom Analysis and Results Part 2 Peach Bottom Appendices |
| 5 | Part 1 Sequoyah Unit 1 Internal Events Part 2 Sequoyah Unit 1 Internal Events App. | 5 | Part 1 Sequoyah Analysis and Results Part 2 Sequoyah Appendices |
| 6 | Part 1 Grand Gulf Unit 1 Internal Events Part 2 Grand Gulf Unit 1 Internal Events App. | 6 | Part 1 Grand Gulf Analysis and Results Part 2 Grand Gulf Appendices |
| 7 | Zion Unit 1 Internal Events | 7 | Part 1 Zion Analysis and Results Part 2 Appendices |

ACRONYMS AND INITIALISMS

| | |
|-------|--|
| ADS | automatic depressurization system |
| AICC | adiabatic isochoric complete combustion |
| AIChE | American Institute of Chemical Engineers |
| ANL | Argonne National Laboratory |
| ANOVA | analysis of variance |
| ANS | American Nuclear Society |
| APET | accident progression event tree |
| ASEP | Accident Sequence Evaluation Program |
| ASME | American Society of Mechanical Engineers |
| ATWS | anticipated transient without scram |
| | |
| BNL | Brookhaven National Laboratory |
| BPNL | Battelle Pacific Northwest Laboratory |
| BWR | boiling water reactor |
| | |
| CGI | core-concrete interaction |
| CDF | cumulative distribution function |
| CL | containment load |
| CR | catastrophic rupture |
| CRD | control rod drive |
| | |
| DBA | design basis accident |
| DCH | direct containment heating |
| DDT | deflagration-to-detonation transition |
| DF | decontamination factor |
| DOE | Department of Energy |
| | |
| EPRI | Electric Power Research Institute |
| | |
| FCI | fuel-coolant interaction |
| FAI | Fauske and Associates, Inc. |
| FSAR | final safety analysis report |
| | |
| HPME | high pressure melt ejection |
| | |
| IC | ice condenser |
| IDCOR | Industry Degraded Core Rulemaking |
| INEL | Idaho National Engineering Laboratory |
| | |
| KFK | Kernforschungszenitum, Karlsruhe |
| | |
| LOCA | loss-of-coolant accident |
| LMFBR | liquid-metal fast breeder reactor |
| LMR | liquid-metal reactor |
| LSD | least significant difference |
| LWR | light water reactor |
| | |
| MAAP | Modular Accident Analysis Program |
| MCCI | molten core-coolant interactions |
| | |
| NRG | Nuclear Regulatory Commission |

ORNL Oak Ridge National Laboratory
 PORV power-operated relief valve
 PRA probabilistic risk analysis
 PWR pressurized water reactor

 RCP reactor coolant pump
 RCS reactor coolant system
 RPV reactor pressure vessel
 RF release fraction
 RMA Risk Management Associates

 SAARP severe accident risk reduction program
 SAIC Science Applications International Corporation
 S&L Sargent & Lundy
 S&W Stone and Webster
 SGTR steam generator tube rupture
 SLC standby liquid control
 SNL Sandia National Laboratories
 SRV safety relief valve

 TVA Tennessee Valley Authority

 UHI upper head injection
 USC University of Southern California

 UCHB unconditional hydrogen burn
 UP upper plenum

1. INTRODUCTION

The United States Nuclear Regulatory Commission (NRC) has prepared NUREG-1150¹ to examine the risk of accidents in a selected group of nuclear power plants. The three main objectives of NUREG-1150 are given below.

1. Prepare a current assessment of the severe accident risks of five nuclear power plants that will:
 - Provide a "snapshot" of risks reflecting plant design and operational characteristics, related failure data, and severe accident phenomenological information extant in March 1988;
 - Update the estimates of NRC's 1975 risk assessment, the Reactor Safety Study;²
 - Include quantitative estimates of risk uncertainty, in response to a principal criticism of the Reactor Safety Study; and
 - Identify plant-specific risk vulnerabilities, in context of the NRC's individual plant examination process.
2. Summarize the perspectives gained in performing these risk analyses, with respect to:
 - Issues significant to severe accident frequencies, consequences, and risks;
 - Uncertainties for which the risk is significant and which may merit further research;
 - Comparisons with NRC's safety goals;
 - The potential benefits of a severe accident management program in reducing risk; and
 - The potential benefit of other plant modifications in reducing risk.
3. Provide a set of methods for the prioritization of potential safety issues and related research.

In support of NUREG-1150 and as part of the Accident Sequence Evaluation Program (ASEP) and the Severe Accident Risk Reduction Program (SARRP), Sandia National Laboratories (SNL) has directed the production of Level 3 probabilistic risk assessments (PRAs) for the Surry, Sequoyah, Peach Bottom, and Grand Gulf nuclear power plants. (Level 1 PRAs contain accident sequence analyses developed to the point of core damage; Level 2 PRAs include Level 1 and accident progression analyses; and Level 3 PRAs include Level 1, Level 2, and consequence analyses.) A PRA for the fifth NUREG-1150 plant, Zion, has been prepared by EG&G Idaho, Inc., of the Idaho National Engineering Laboratory (INEL) (Level 1) and Brookhaven National Laboratory (BNL) (Levels 2 and 3). Two of these analyses (Surry and Peach Bottom) include external events.

Expert judgment elicitation is an integral part of the methods used to produce the PRAs in support of NUREG-1150. Expert judgment is used where applicable experimental data or complete analyses are inadequate. Such situations are common in analysis of rare events and complicated severe accident phenomena. The purpose of this report is to provide the results and technical rationale obtained from the Structural Response Expert Panel. The expert judgment methodology is presented in detail in NUREG/CR-4551 Volume 1.

Expert judgments are expressions of opinion, based on knowledge and experience, that experts make in responding to technical problems. Specifically, the judgments represent the expert's state of knowledge at the time of response to the technical question. Expert judgment is not restricted to the experts' answer but includes the experts' mental processes (definitions, assumptions, and algorithms) for arriving at answers.

Expert judgment is necessarily used in all technical fields. Because these judgments are often implicit, they are sometimes not acknowledged as being expert judgments. For example, expert judgment is frequently used implicitly, even unconsciously, when researchers make decisions about defining problems, establishing boundary conditions, or screening data. By contrast, expert judgment is obtained explicitly, through formal processes.

Risk assessment frequently needs explicit expert judgment as a source of data, particularly if one or more of the following situations exist:

1. No other data (analytical or experimental) for predicting the outcome of phenomena are available;
2. High variability characterizes the data;
3. Experts question the applicability of the data;
4. Existing data need to be supplemented, interpreted, or incorporated with model or code calculations;
5. Analysts need to determine the state of knowledge about what is currently known, what is not known, and what is worth learning.

The issue selection process consisted of accumulating an extensive list of potential issues by plant or across plants and then evaluating the significance of each issue. Expert panel members participated in the issue selection by reviewing the issues selected and rejected for the expert judgment process and recommended the addition, deletion, or modification of issues from the initial list.

Eight structural response issues were considered important enough to be the subject of a formal expert judgment elicitation. Table 1-1 lists these issues.

Section 2 of this report briefly outlines the expert selection process and gives a short biographical sketch of each expert. Section 3 describes the fundamental expert judgment elicitation methodology. Section 4 lists the

meetings held for the Structural Response Expert Panel and the people who gave presentations at the meetings. Section 5 constitutes the bulk of this report and contains a description of each issue considered, a summary of the technical rationale applied by the experts to the issue, a description of the method used to aggregate the expert's distributions, the aggregated distributions, and written accounts of each individual response to the question. The individual expert's narrative includes the distributions and the detailed rationale behind the distributions. Each account was written by the substantive expert who assisted with the elicitation. In all cases, the experts were given ample opportunity to review these written accounts and approve them. In a few cases, the experts did not respond and were informed that their lack of response would be assumed to be tacit approval of the write-up.

Table 1-1
Structural Response Issues Considered for
Expert Judgment Elicitation

| <u>Issue No.</u> | <u>Title</u> | <u>Applicable Plants</u> |
|------------------|--|--------------------------|
| 1 | Static failure pressure and mode at Zion | Zion |
| 2 | Static failure pressure and mode at Surry | Surry |
| 3 | Static failure pressure and mode at Peach Bottom | Peach Bottom |
| 4 | Reactor Building bypass at Peach Bottom | Peach Bottom |
| 5 | Static failure pressure and mode at Sequoyah | Sequoyah |
| 6 | Ice condenser failure due to detonations at Sequoyah | Sequoyah |
| 7 | Drywell and wetwell failure due to detonations at Grand Gulf | Grand Gulf |
| 8 | Pedestal failure due to erosion at Grand Gulf | Grand Gulf |

REFERENCES

1. U.S. Nuclear Regulatory Commission, "Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants." Vol. 1, Office of Nuclear Regulatory Research, Washington, D.C., NUREG-1150, June 1989.
2. U.S. Nuclear Regulatory Commission, "Reactor Safety Study--An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants," U.S. Nuclear Regulatory Commission, WASH-1400 (NUREG-75/014), Washington D.C., 1975.

2. EXPERT CREDENTIALS

The objective for selecting the panel members was to obtain experts with as much expertise as possible in the field of Nuclear Power Plant Containment/Reactor Building Structural Response. The project attempted to include a wide diversity of expertise that encouraged alternative points of view. The selection of experts should preclude stakeholders in the findings of NUREG-1150 from participating as members of the expert panel. This led to several criteria in selecting the experts:

1. Experts should have to demonstrate experience by authoring publications, hands-on experience, and consulting or managing research in the areas related to the issues;
2. Experts should have to represent a wide variety of experience as is obtained in universities, consulting firms, laboratories, nuclear utilities, or government agencies;
3. The experts should have to represent as wide a perspective of the issues as possible;
4. The experts should be willing to be elicited under the methodology to be used.

To ensure proper representation, letters were sent to many organizations requesting nominations for experts to serve on the in-vessel, containment loads, molten core/containment interaction, structural response, and source term panels. Some of the organizations that received these letters are listed below:

Atomic Energy of Canada LTD.
Battelle Columbus Division
Bechtel Western Power Company
Brookhaven National Laboratory
Commonwealth Edison
Electric Power Research Institute
General Electric
Idaho National Engineering Laboratory (EG&G Idaho, Inc.)
Illinois Department of Nuclear Safety
International Technology Corporation
MHB Technical Associates
New York Power Authority
NUMARC
Oak Ridge National Laboratory
Philadelphia Electric Co.
Sandia National Laboratories
Stone and Webster Engineering Corporation
Systems Energy Resources, Inc.
Tennessee Valley Authority
U.S. Nuclear Regulatory Commission
Virginia Electric Power Co.
Westinghouse Electric Corp.

It was impossible to satisfy each criterion entirely for every expert/issue combination. Nevertheless, we were pleased with the high quality and objectivity of the experts. The experts chosen for the structural response issues were:

| | |
|---------------------|--|
| David Clauss | Sandia National Laboratories |
| Charles Miller | City College of New York |
| Kam Mokhtarian | Chicago Bridge & Iron Co. Na-Con, Inc. |
| Joe Rashid | ANATECH Research Corp. |
| Subir Sen | Bechtel Power Corp. |
| Richard Toland | United Engineers and Construction |
| Walt von Rieseemann | Sandia National Laboratories |
| Adolph Walser | Sargent & Lundy |
| Joe R. Weatherby | Sandia National Laboratories |
| Don Wesley | IMPELL |

Brief biographical sketches of the experts are presented below.

Structural Response Expert Panel

DAVID CLAUSS

David Clauss joined Sandia National Laboratories in 1980. He is a project leader on a containment integrity program for NRC that involves determining structural strength of concrete and steel containment models when subjected to stress from seismic, pressure, and temperature overloading. When conducting tests, he specified test objectives and environment, planned instrumentation, calculated structural response, and interpreted results. Previously, he performed both heat transfer and structural analysis in support of design efforts for a post-accident heat removal experiment. He also investigated structural problems arising during fabrication and operation of solar panels and conducted thermal stress analysis for combustor tubes for a downhole steam generator used in enhanced oil recovery. He received a B.S. (1979) and a M.S. (1980) in Mechanical Engineering from the University of Michigan.

CHARLES MILLER

(No biographical sketch provided.)

KAM MOKHTARIAN

Kam Mokhtarian is a Senior Engineer with Chicago Bridge & Iron Company. He holds a Masters Degree in Structural Engineering from Northwestern University. His background is mostly in the design and analysis areas of nuclear structures. He has served in a number of supervisory assignments related to design and analysis of containment vessels, reactor vessels, and other pressure vessels. He has served on a number of NRC's peer review groups, related to structural safety of containment vessels. He is the author of a number of papers related to design of shell structures. He is a member of the American Society of Mechanical Engineers' (ASME's) Boiler & Pressure Vessel Code Committee and has served on a number of projects with the Pressure Vessel Research Committee of the Welding Research Council.

JOE RASHID

(No biographical sketch provided.)

SUBIR SEN

(No biographical sketch provided.)

RICHARD TOLAND

Richard Toland is the Chief Structural Engineer of the Stearns Catalytic Division of United Engineers and Constructors (UE&C), Philadelphia, PA. He holds a Ph.D in Applied Mechanics from the University of Delaware. In the past 10 years at UE&C, he has worked primarily in support of the design development of nuclear power plants, including containment structures. Dr. Toland has performed special containment ultimate capability studies of the Indian Point 2 & 3, Seabrook and Brunswick 1 & 2 containment systems. He provided expert witness testimony before the Atomic Safety and Licensing Board in the reopened Indian Point hearings, and he has made presentations on containment capability before the NRC, the Advisory Committee on Reactor Safety and Brookhaven National Laboratory. Dr. Toland participated in the Industry Degraded Core Rulemaking (IDCOR) Task 10 on containment capability and more recently, UE&C's design and construction of the 1/6th scale reinforced concrete containment structure for the NRC and Sandia National Laboratories, a significant task in the NRC's support of containment capability research. He has also recently supported studies of containment concepts for DOE's proposed New Production Reactor (NPR). Before joining UE&C, Dr. Toland was a section leader at the Lawrence Livermore National Laboratory where he directed a program on long-term life characteristics of high performance pressure vessels and their reliability under sustained loads. He presently serves on technical committees for the American Concrete Institute, the American Society of Civil Engineers and the American Society for Testing and Materials.

WALTER A. VON RIESEMANN

Dr. von Rieseemann joined Sandia National Laboratories in July 1960. Since 1977, he has been the Supervisor of the Containment Technology Division. He received an M.S. in Civil Engineering from the University of Illinois in 1959, and a Ph.D in Civil Engineering from Stanford University in 1968. As a Supervisor, he is involved in programs for the Nuclear Regulatory Commission (NRC), the Department of Energy (DOE), and the Electric Power Research Institute (EPRI) dealing with the safety of light water reactors (LWRs). In the past he has also directed programs on quantification testing of component and fire protection research. At present he is directing containment integrity programs for the NRC that involve structural strength of containments when subjected to static and dynamic internal overpressurization loads and to earthquake loads, and the behavior of penetrations including electrical penetrations when subjected to severe accident loads. These programs involve the testing of scale models and are a multi-year, multi-million dollar activity.

ADOLPH WALSER

Adolf Walser is an associate in the architect/engineering firm of Sargent & Lundy in Chicago. He received his diploma in civil engineering from the Federal Technical University (ETH) in Zurich in 1949. He worked in Switzerland and other countries as a structural design engineer until 1958 when he moved to the United States. He became chief engineer and later manager of the Post-tensioning Department at Joseph T. Ryerson & Son, Inc., in Chicago. In 1967 he joined Sargent & Lundy where he worked as a structural design engineer, later as supervisor of the special structures section and presently as Senior Structural Project Engineer primarily on nuclear power plants. His responsibilities include design and analysis and project engineering of structures such as containments, special structures and other parts of nuclear power plants. He is a Fellow of the American Concrete Institute and a member of the Technical Committee on concrete pressure components for nuclear service of ACI/ASME. He has authored or co-authored more than 25 papers on the subject of design, analysis, and construction of containments and other structures.

J. RANDALL WEATHERBY

J. Randall Weatherby is a Senior Member of Technical Staff at Sandia National Laboratories. He holds a PhD in Mechanical Engineering from Texas A&M University. Randall joined Sandia in February 1986. As a structural analyst, he has supported Sandia's programs in reactor safety. He participated in the analysis and testing of a 1:6-scale reinforced concrete containment structure for the NRC.

DON WESLEY

(No biographical sketch provided.)

3. METHODOLOGY

3.1 Introduction

This section contains a summary of the methodology used to elicit expert judgment from the expert panels. An in-depth discussion of the methodology is contained in Volume 1 of NUREG/CR-4551.

The methodology used in the expert judgment process for NUREG-1150 was designed to obtain subjective estimates of unknown physical quantities and frequencies in a manner that best uses the available expertise and accurately reflects the collective uncertainty about these values. Several principles guided the development of the methods:

1. The assessments should be limited to issues on which alternative sources of information such as experimental or observational data, or validated computer models are not available.
2. The issues analyzed using expert judgment should have the potential to make a significant impact on the estimates of risk and uncertainty in risk.
3. The decomposition of complex issues into simpler assessments is made in order to improve the quality of the resulting information.
4. Issues should be presented to the experts without ambiguity and without the potential for preconditioning or biasing responses.
5. Experts should be trained in the practice of expressing knowledge and beliefs as probability distributions.
6. Discussion of issues and alternative beliefs should take place in structured and controlled meetings that encourage the exploration of alternative beliefs while inhibiting pressure to conform.
7. Elicitation of expert opinion should be conducted using techniques and instruments that reflect the state of the art in subjective probability assessment.
8. The aggregation of judgments from various experts should preserve the uncertainty that exists among alternative points of view. Equal weight should be assigned to the assessment for each expert to represent the uncertainty completely.

NUREG-1150 does not attempt to reduce uncertainty in risk analysis, nor does it attempt to find a best estimate. This study is an attempt to produce an unbiased picture of uncertainty in risk. The study tries to discover the range in risk inherent in the range of plausible assumptions about phenomenology and initial and boundary conditions. The risk corresponding to the most (subjectively) plausible assumptions has a higher likelihood of being accepted by a randomly chosen expert in accident

phenomena. The risk corresponding to less plausible assumptions nevertheless has some likelihood of being accepted by any expert, and may indeed be the most acceptable for some experts. Experts are sometimes wrong, and the "true" risk could lie outside the ranges found in this study.

3.2 Steps to Elicit Expert Judgment

The principles identified above, the criticism of the draft NUREG-1150 expert judgment efforts, and the findings of precursor studies employing expert judgment^{1,2} provided guidance for the design of the NUREG-1150 expert judgment elicitation process. The process evolved into ten steps:

1. Selection of issues;
2. Selection of experts;
3. Elicitation training;
4. Presentation and review of issues;
5. Preparation of expert analyses by panel members;
6. Discussion of analyses;
7. Elicitation;
8. Recomposition and aggregation;
9. Review by the panel of experts;
10. Documentation.

The methodology was implemented in a three-meeting format, with much additional work being accomplished between meetings. Steps 1 and 2 were accomplished before the first meeting of the expert panel. Step 3, elicitation training, took place in the first meeting, which lasted one-half day. The presentation and review of issues, Step 4, was done during the second meeting, which, in order to reduce travel costs, took place immediately after the first meeting. Step 5 was accomplished between the second and third meetings (in some cases the expert panels met for additional discussions during this time). Discussion and elicitation, Steps 6 and 7, were discussed in the third meeting, which usually took place three months after the first and second meetings (the accident sequence frequency group and the structural response group met two months after the first two meetings). The final steps, 8, 9, and 10, were accomplished after the third meeting.

3.3 Selection of Issues

The NUREG-1150 program attempts to show the range and distribution of risk due to uncertainty in the inputs. Some of that uncertainty is phenomenological, some is stochastic, and some is because of limited background of data. There are an enormous number of input points, and all are uncertain to some extent. It was thus impossible to treat all questions and issues with the same degree of thoroughness. The criteria used to select issues for detailed uncertainty analysis were:

- High impact on risk. If an issue was highly uncertain, but variation across its entire range would not cause a big change in risk, there would be little need for a detailed treatment. The likely impact on risk was determined by the outcome seen in the draft version of NUREG-1150, by smaller scale side calculations, by the opinions of the expert panels, and by examination of previous PRAs.

- Interest within the reactor safety community. Some issues were thought not to be major determinants of uncertainty in risk, but had nevertheless been the subject of intense investigation and debate. The reason for including these issues in the analysis was to confirm this opinion.
- To improve on the treatment in Draft NUREG-1150. Some issues had not appeared to be important in the draft version; however, it was recognized that the treatment there was less than optimum. Such issues were included to determine whether an improved treatment would change those insights.
- The issue was uncertain. Even if an issue is important for the magnitude of risk, if the outcome is certain there is no impact on the uncertainty in risk.

Issues meeting any of these criteria were listed by the NUREG-1150 staff. The preliminary list of issues was presented to a panel of experts, along with reasons for their inclusion. A list of other issues was also presented, along with reasons for their exclusion. The expert panel was asked to review the list of issues, and to add or delete issues. The expert panels were the same ones that would be asked for quantification of the uncertain issues. An understanding of the limited time and resources available generally militated against an unwarranted or overly generous expansion of the issues.

Those issues that were selected for quantification by the external expert panels fell into three broad classes: uncertain issues affecting the sequence frequency calculation, uncertain issues affecting the response of the containment and its systems, and uncertain issues affecting the radiological source term. There were more issues affecting containment than for the other classes, and there was a further breakdown into issues related to the in-vessel phenomenology, containment loads, structural response, and molten core-concrete interactions. Tables 3-1 through 3-5 show the issues presented to the containment and radiological source term expert panels, along with the reasons for including the issue.

Table 3-1
Issues Presented to the In-Vessel Panel

| <u>Issue No.</u> | <u>Title</u> | <u>Reason for Inclusion</u> |
|------------------|--|--|
| 1 | Temperature-induced pressurized water reactor (PWR) | Large hot leg failure could preclude direct containment heating; depressurizes RCS and precludes steam generated tube rupture (SGTR) |
| 2 | Temperature-induced PWR SGTR | SGTR gives direct path to environment, with large release of radionuclides |
| 3 | In-vessel hydrogen production in boiling water reactors (BWRs) | Hydrogen burning has potential for causing release to environment |
| 4 | Temperature-induced bottom head failure in BWRs | Mode of bottom head failure determines subsequent accident progression |
| 5 | In-vessel hydrogen production in PWRs | Hydrogen burning has potential for causing release to environment |
| 6 | Temperature-induced bottom head failures in PWRs | Mode of bottom head failure determines subsequent accident progression |

Table 3-2
Issues Presented to the Containment Loads Panel

| <u>Issue No.</u> | <u>Title</u> | <u>Reason for Inclusion</u> |
|------------------|--|---|
| 1 | Hydrogen phenomena at Grand Gulf | Early failure of drywell or wetwell has potential for causing large source term |
| 2 | Hydrogen burn at vessel breach at Sequoyah | Early failure of containment or bypass of ice condenser has potential for causing large source term |
| 3 | BWR reactor building failure due to hydrogen burns | Bypass of reactor building has potential for increasing source terms |
| 4 | Loads at vessel breach at Grand Gulf | Failure of containment at vessel breach has potential for causing large source terms |
| 5 | Loads at vessel breach at Sequoyah | Same as Issue 4 |
| 6 | Loads at vessel breach at Surry | Same as Issue 4 |
| 7 | Loads at vessel breach at Zion | Same as Issue 4 |

Table 3-3
Issues Presented to the Structural Response Panel

| Issue No. | Title | Reason for Inclusion |
|-----------|--|--|
| 1 | Static failure pressure and mode at Zion | Containment failure is the most important determinant of source terms |
| 2 | Static failure pressure and mode at Surry | Same as Issue 1 |
| 3 | Static failure pressure and mode at Peach Bottom | Same as Issue 1 |
| 4 | Reactor Building bypass at Peach Bottom | Bypass of Reactor Building has potential for allowing large release of radionuclides |
| 5 | Static failure pressure and mode at Sequoyah | Same as Issue 1 |
| 6 | Ice condenser failure due to detonations at Sequoyah | Failure or bypass of ice condenser has potential for large source terms |
| 7 | Drywell and wetwell failure due to detonations at Grand Gulf | Failure of drywell bypasses suppression pool. Failure of wetwell allows large release to environment |
| 8 | Pedestal failure due to erosion at Grand Gulf | Pedestal failure is a major factor in subsequent accident progression |

Table 3-4
Issues Presented to the Molten Core-Concrete Interaction Panel

| Issue No. | Title | Reason for Inclusion |
|-----------|--|---|
| 1 | Mark I drywell melt-through at Peach Bottom | Drywell meltthrough bypasses suppression pool; controversial issue |
| 2 | Mark II containment failure via pedestal failure at Grand Gulf | Pedestal failure could lead to early containment failure; controversial issue |

Table 3-5
Issues Presented to the Source Term Panel

| Issue No. | Title | Reason for Inclusion |
|-----------|---|---|
| 1 | In-vessel fission product release and retention | Release and retention are major determinants of source term |
| 2 | Ice condenser decontamination factor (DF) at Sequoyah | Ice condenser is principal decontamination mechanism in blackouts |
| 3 | Revolatilization from RCS/RPV | Revolatilization could negate effects of high retention; highly uncertain issue |
| 4 | Core-concrete containment (CCI) release | If in-vessel release is low, CCI release could be high; uncertain issue |
| 5 | Release of RCS and CCI species from containment | Aerosol agglomeration may be major source of cleanup in blackout; highly uncertain issue |
| 6 | Late sources of iodine at Grand Gulf | Appeared as important issue in Draft NUREG-1150 |
| 7 | Reactor Building DF at Peach Bottom | Natural decontamination processes could reduce source term; uncertain and controversial issue |
| 8 | Release during direct containment heating | Uncertain and controversial issue; direct heating is also associated with early containment failure |

3.4 Selection of Experts

Experts were chosen to ensure a balance of viewpoints. To this end, experts from industry groups, engineering and consulting firms, the Federal Government, and the national laboratories were included in the panel. A brief summary of their credentials was presented in Section 2.

3.5 Elicitation Training

Training in probability assessment techniques is an integral part of the expert opinion methodology used in NUREG-1150. Each panel of experts that participated in the expert opinion process attended a half-day training session. This session constituted the first meeting of each panel. The training was given by consultants from the field of probability assessment and decision analysis. The trainer for the Structural Response Expert Panel was Steve Hora, University of Hawaii, Hilo.

The purpose of training in probability assessment is to facilitate the elicitation process. Experts in various fields of science are often not trained in probability theory and the techniques of probability elicitation. The expertise possessed by the scientists and engineers on the panels is called substantive expertise and thus they are called substantive experts. Expertise about probability elicitation is called normative expertise and the participants in the expert opinion process schooled in probability assessment are known as normative experts. Both substantive expertise (knowledge of the problem domain being studied) and normative expertise (knowledge of techniques for encoding beliefs into probability distributions) are required for a successful expert opinion process.

During probability training, experts are exposed to various techniques for probability elicitation and the difficulties that accompany probability elicitation. Once trained, substantive experts are better able to express their knowledge in the form of probabilities and the resulting elicitations will be of a better quality. The resulting assessments are better calibrated in the sense that they accurately reflect the expert's knowledge and uncertainty. A by-product of the training is that the experts become more comfortable with the concept of subjective probability and more confident in expressing their beliefs in probability distributions.

Another benefit of training is that the time spent by the experts preparing for the issues is used more effectively because the experts can direct their analyses to the questions that must be addressed in the elicitation sessions. Further, the elicitation sessions run smoothly since the normative and substantive experts are working with the same definitions and the same understanding of the desired product.

3.5.1 Training Topics

The training sessions conducted for NUREG-1150 covered several related topics. These topics included the expert opinion process itself and the need for expert opinion, the elicitation techniques for the probabilities of various types of quantities and events or phenomena, the psychological aspects of probability assessments, and the decomposition of complex issues.

Each training session began with an overview of the goals of the expert opinion process and background material on the development of that process. The process was reviewed in some detail so that the substantive experts would be aware of what would be required of them and how their elicitations would be used. Because the formalized use of expert opinion was new to many of the participants, some were initially uneasy with the concept of expert opinion and the uses that it might be put to. Gaining the confidence of these experts through familiarization with the process was essential to the success of the expert opinion effort.

There are many different types of assessments that might be required of the experts. The type of assessment depends upon the nature of the physical quantity or phenomena under study. During the training sessions, the experts were introduced to assessment instruments for continuous quantities, discrete quantities, zero-one events, and dependent events. At appropriate points in the training, the experts were asked to make assessments using the methods under discussion. Using practice assessments develops confidence and ensures that the substantive experts understand the tasks that they will be required to perform. In order to make the training more interesting and more relevant, examples were used that reflected nuclear power risk issues.

Since many of the assessments would require the development of a probability distribution for a continuous quantity, the experts were given training in both the direct assessment techniques (assessing probabilities of given intervals of values) and bisection techniques (assessing values of the variable having given cumulative probabilities) for continuous variables. Later, in the elicitation sessions, these techniques would be used interchangeably by the normative experts.

A discussion of stochastic and parametric uncertainties and how they are differentiated in an uncertainty analysis was also provided. The concept of calibration of experts and calibration functions was also introduced. However, mathematical calibration of experts was not attempted in the NUREG-1150 expert opinion process.

Psychological aspects of probability elicitation received much attention in the training because failure to recognize and deal with psychological biases can impair the quality of the resulting assessments. One of the psychological aspects discussed is the tendency to give subjective probability distributions that are too narrow and thus understate the uncertainty or, conversely, overstate knowledge. This phenomena is often called "overconfidence," since the effect is that expressed probability distribution expresses greater certainty than is warranted. Other psychological aspects of subjective probability assessment that were discussed include anchoring, which is the tendency to assume an initial position and fail to give sufficient credit to other sources of information; representativeness, which is the tendency to give too much credit to other situations that are similar in some aspects but not others; the tendency to overestimate the probabilities of rare events; and problems with group behavior such as personality dominance. Whenever possible, examples of these difficulties were presented and the experts being trained were asked to participate in demonstrations.

At the end of the training session, the participants were given an assessment training quiz containing 16 assessment tasks using the direct and bisection methods of assessment. The participants were asked to complete the training quiz during that evening and return the next morning to discuss the results. The purpose of the training exercise was two-fold: to give the substantive experts experience with the elicitation instruments and to provide feedback on the quality of the individual's assessments. As expected, most participants found that their assessed distributions expressed overconfidence. Once aware of this tendency, it is easier for the substantive experts to correct for this bias.

Problem decomposition was the last major segment of the training session. Problem decomposition is the process of creating a model of a complex assessment that allows the experts to make a series of simpler assessments. The simpler assessments are mathematically recomposed through the model. The net result is that the resulting probability distribution is a better expression of the expert's knowledge than if the expert had been asked to make an assessment of the initial issue without the aid of a decomposition.

Training in decomposition was conducted by presenting examples of decompositions that had been developed for the NUREG-1150 study. Several types of decompositions were shown and the process of recombining the assessments was discussed. Comments from the participants indicated that the use of problems from the nuclear safety area enhanced the value of the decomposition training.

3.6 Presentation of Issues

During the second part of the second meeting, plant analysts presented the issues to the expert panel. The purposes of the presentations were to ensure that there was a common understanding of the issue being addressed; ensure that the experts would be responding to the same elicitation question; permit unimportant issues to be excluded and important issues to be included; allow modification or decomposition of the issue; and provide a forum for the discussion of alternative data sources, models, and forms of analysis.

Each presentation included a suggested decomposition of the problem. Problem decomposition has been used in the NUREG-1150 expert judgment process as a mechanism to improve the quality of the subjective assessments. Problem decomposition improves the quality of assessments by structuring the analysis so that the expert is required to make a series of simpler assessments rather than one complex assessment. Experimental studies^{3,4} have shown that decomposition often improves the accuracy of assessments. Improvement occurs because the experts are responding to questions that are less difficult to answer. The experts must state their reasoning explicitly by being more introspective about their assumptions of the analysis and thus consider alternatives that they might otherwise ignore. Some improvement may be due to cancellation of errors which occurs when errors of underestimation are offset by comparable errors of overestimation. Decomposition also provides a form of self documentation since the expert's thought process is made explicit in the decomposition.

Plant analysts usually presented the suggested decompositions without the suggested probabilities or distributions to avoid preconditioning or biasing the experts. For many of the issues, the proposed decomposition brought about lively discussions that illuminated the alternative approaches to analyzing the issue. The plant analyst also presented data sources, models, and reports that were relevant to the issue, and provided references to other sources of information.

Capturing uncertainty in the experts' opinions requires that the various experts be permitted to follow alternative analyses. Since the process was designed to take advantage of the diversity of approaches, experts were encouraged to seek their own decompositions or to modify decompositions that were suggested by the analysts. Criticism of the decompositions was encouraged and the experts were assisted in producing decompositions that better matched their interpretations of the issues.

3.7 Preparation and Discussion of Analyses

Two or three months were allowed between the initial presentations of the issues and the elicitation sessions. During this period, the experts studied the issues. Some experts chose to alter the proposed decompositions or create new decompositions and made preliminary evaluations of the subjective probabilities represented in their decompositions of the issues. The elicitation meeting provided a forum for discussion of alternative views of the issue. Presentations from both the panel members and invited observers of the meetings were encouraged. These sessions generated a substantial amount of discussion and interchange of information that often led the experts to make revisions of their prepared analyses. In some instances, the panel members prepared documentation that amounted to brief reports. It became apparent in the elicitation sessions that this interchange was an important source of information for the experts.

3.8 Elicitation

The discussion of each issue was followed by elicitation meetings between the experts and a team composed of one normative analyst and one substantive analyst. Documentation of the experts' assumptions and reasoning was produced during the elicitation meetings. Normally, each meeting consisted of three participants (one panel member, a normative expert, and a substantive expert) and lasted about two hours. However, in a few cases where there were more experts to be elicited than available normative experts, two experts were elicited in a single session.

The elicitation sessions served several purposes. The first was to obtain from the experts the decomposition and assessments of the problems. The experts were required to explain their thinking to the assessment team of one normative and one substantive expert. During the discussion of the elicitation process, the expert being elicited was questioned about stated beliefs and asked to reflect on, and explain the reasoning behind, the values that he or she had provided. In many cases, the resulting decompositions and probability distributions differed somewhat from the initial assessments.

The role of the normative experts was to assist the expert in codifying the experts' beliefs and to ensure that the assessment was complete and consistent in a probabilistic sense so that the assessments could be recomposed at a later time. Normative experts have the ability to draw from the experts the important details being elicited. Their talent for becoming involved in the technical aspects of issues, which are not their basic area of expertise, is a crucial factor in facilitating the experts' abilities to develop logically consistent assessments. Such individuals are necessary in any expert judgment elicitation process.

The role of the substantive expert was to assist the expert by answering questions related to the issue and to ensure that technical reasoning was complete and to the point. He also served as a technical advisor to the normative expert to assist him in questioning the expert in a direction consistent with the technical needs and constraints of the plant analysis teams.

Much of the documentation of the experts' assumptions and reasoning was completed during the assessment meetings. However, some follow-up work was necessary after the elicitation sessions to fill in voids in the logic provided by the experts, or to obtain values that were incomplete.

Documentation of the elicitations is provided in Section 5 of this report. Note that while the experts participating for each issue are identified, the individual assessments are kept anonymous, and the experts are identified as Experts A, B, C, etc.

3.9 Recomposition and Aggregation of Results

Each member of the expert panels produced a distribution for each case of each issue. For some issues, several dependent variables were requested, and a separate distribution was elicited for each variable. If all the experts had worked with identical case structures, and if all had produced their results in the same form, the task of aggregation would have been simply a matter of taking the numerical average of all the distributions for each case. However, some experts used idiosyncratic case structures. On some issues, the experts expanded the case structure beyond what was tractable in the accident progression event trees (Section 4) or the XSOR codes (Section 5). On some issues, experts gave their results in different forms.

For the purposes of aggregation, it was absolutely required that the case structure be small enough to fit into the containment event trees and XSOR codes and that the case structure and dependent variables be the same between experts. If the case structure was impractically large and complex, it was reduced if possible by an analysis of variance (ANOVA). The ANOVA compared the variance in the dependent variable attributable to the differences between cases and the variance attributable to the differences among experts to the unexplained variance in the dependent variable. For many issues it was found that the differences between cases were not significant compared to the differences between experts; that is, the large and complex case structure had little effect on the dependent variable. A mathematical procedure was then used to determine which of the cases could be safely combined.

If different experts used different cases, they were first encouraged to resolve their differences; if they failed to do so it was necessary to find some common ground. The cases common to all experts were of course retained. The remaining cases were inspected, and the most important ones were retained. If an expert did not have one of these cases, but did have a closely analogous case, the analog was used for the missing case. If the expert did not have a case closely related to the missing case, then the average of the case for all other experts was used for his missing case. It was recognized that this procedure would reduce the range of uncertainty, so the substitution was resorted to as little as possible. For some issues, missing data could be filled in by interpolation or ratios of existing cases.

If the experts produced different dependent variables, some analysis was required to put all the outputs into the same form. Whenever this was done the experts involved might find the final form of their data difficult to reconcile with what had been produced in the elicitation. Therefore, analytical alteration of results was resorted to as little as possible, and attempts were made to explain the reasons for and methods of analysis to the experts.

After each of the experts' distributions were in the same format, they were aggregated by averaging. The experts' outputs were almost always in the form of cumulative distribution functions (CDFs), that is, curves or tables of the probability that the independent variable would be no greater than some specific value. The aggregation was carried out by averaging all the experts' probability values for each value of the independent variable. The aggregated results were thus also CDFs.

3.10 Review

Following the recomposition of the assessments and the modification of the documentation accompanying each assessment, the written analyses of each issue were returned to each panel expert, normative expert, and substantive expert associated with the issue for review. This review process ensured that potential misunderstandings were identified and resolved and that the documentation, which is given in Section 5 of this report, correctly reflects the judgment of the experts involved.

3.11 Documentation

Clear, comprehensive documentation is crucial for ensuring that the expert opinion process is accepted as credible. There must be no question as to the openness and impartiality of the process. Users and reviewers of the results must be able to trace the development of aggregated assessments from the information presented to the experts to the rationale that motivates each expert to generate his particular assessments, and through the process of aggregating the individual assessments into a final result, including any manipulation of the assessments needed for aggregation. To this end, the issue discussions were recorded on video cassette. Such recording provides evidence of the exact conversations and presentations made before the panel. Written notes were taken by both the normative and substantive experts. Each expert was encouraged to personally document his

rationale for his elicitation immediately at the end of the session. By far the most important documentation is each expert's in-depth discussion of his reasoning for his assessments. The discussion should contain the technical foundation of information (experience, issue presentation, existing data or analyses) from which the rationale for the assessment is derived.

REFERENCES

1. A. Mosleh, V. M. Bier, and G. Apostolakis, "Methods for the Elicitation and Use of Expert Opinion in Risk Assessment," NUREG/CR-4962, PLG-0533, Pickard, Lowe & Garrick, Inc., August 1987.
2. A. Tversky and D. Kahneman, "Judgement under Uncertainty: Heuristics and Biases," Science, 85, pp. 1124-31 (1974).
3. J. S. Armstrong, Long-Range Forecasting: From Crystal Ball to Computer, John Wiley & Sons, New York, 1985.
4. J. S. Armstrong, W. B. Denniston, and M. M. Gordon, "The Use of the Decomposition Principle in Making Judgments," Organizational Behavior and Human Performance, 14, pp. 257-63 (1975).

4. ELICITATION MEETINGS

The first two meetings (the elicitation training and the presentation and review of the technical issues) for the Structural Response Expert Panel were held from November 30 to December 2, 1987. Presentations to the Structural Response Expert Panel were made by the following people:

Nestor Ortiz, SNL
Steve Hora, University of Hawaii, Hilo
Frederick Harper, SNL
Eric Haskin, SNL
Roger Breeding, SNL
Adolph Walser, Sargent & Lundy
Walt von Riesenmann, SNL
Arthur Payne, SNL
Kam Mohktarian, CB&I
Morris Reich, BNL
Walt Murfin, Technadyne
David Clauss, SNL
Marty Sherman, SNL
Elaine Gorham, SNL
Subir Sen, Bechtel
Tom Brown, SNL

The elicitation meeting for the Structural Response Expert Panel was held from January 15 to 21, 1988.

Normative experts for Structural Response elicitation sessions were:

Ralph Keeney, USC
Detlof von Winterfeldt, USC
Richard John, USC.

5. ISSUE DESCRIPTIONS AND ELICITATION RESULTS

The results of the expert panel elicitations are presented in detail here. A brief description of each issue is given, the individual expert assessments and rationale for the assessments are discussed, and the aggregated results or resolutions for each issue are presented.

5.1 Issue 1. Containment Failure at Zion

Experts consulted: Charles Miller, City College of New York; Adolph Jalsler, Sargent & Lundy; Joe R. Weatherby, Sandia National Laboratories.

Issue Description

What distribution characterizes the failure pressures for static loading of the Zion containment? What conditional probabilities describe the failure modes for each pressure?

The Zion containment is a prestressed, post-tensioned concrete cylinder with a shallow-domed roof. The foundation is a reinforced concrete slab. The containment is lined with welded 0.25-in. plate steel. The post-tensioning system is composed of 63 dome tendons, 216 vertical tendons, and 555 hoop tendons. The design pressure and temperature are 47 psig and 217°F. The free volume is about 26,000,000 ft³.

Three pressure rise cases were described in the original definition of the issue:

1. Pressure Spike at Vessel Breach,
2. Late Deflagration, and
3. Late, Gradual Pressure Rise.

Typical rise times for cases 1 and 2 would be in the order of a few seconds. While very high atmospheric temperatures might be observed for a fraction of a minute in case 1, the bulk temperature of the steel liner which forms the pressure boundary is not expected to exceed 300 to 350°F for any of the cases.

The initial definition of a large hole or rupture was an opening larger than 1.0 ft², which resulted in depressurization in less than 2 h. A small hole or leak was anything smaller than 1.0 ft² which did not result in depressurization in less than about 2 h. A review of this matter showed that large dry containments would depressurize in 2 h for hole sizes on the order of 0.3 to 0.5 ft². Thus, a small hole or leak should have been on the order of 0.1 ft², and 1.0 ft² is definitely a large hole or rupture. The panel members were asked to reconsider the distributions they provided in light of this redefinition of the hole size. Some of them adjusted

their distributions for this or for some other reason. The failure mode "Catastrophic Rupture" (CR) was added at the time of elicitation. The containment failure implied by this failure mode is complete failure of a substantial portion of the containment pressure boundary, with possible disruption of the piping systems that penetrate or are attached to the containment wall. No similar gross structural failure is implied by the "Rupture" failure mode.

Summary of Results

The three panel members considering this issue all agreed that the three cases could be considered together since the pressure rise times were slow enough that the effects were all static. It was pointed out to the experts that the development of a leak would not arrest the pressure rise for cases 1 and 2, but they did not choose to provide separate distributions for these two cases. However, some of the experts allowed for the possibility that the development of a leak would not arrest the pressure rise by providing rupture and CR probabilities for pressures greater than the pressure for which they thought the development of a leak was certain. The experts further agreed that there was no need to differentiate between cases on the basis of temperature. The temperatures described were all low enough that there was no appreciable structural effect, i.e., no significant changes in material properties. Two of the experts based their conclusions on an analysis of the mid-section of the cylindrical portion of the containment (hoop failure); the reinforcing and concrete details in the cylinder-basemat junction area were such that both of them ruled out the possibility of shear failure in that location. The third expert, however, considered that shear failure was of importance, and made his analysis accordingly.

Since the fission products are released aboveground for a hoop failure of the cylinder and belowground for a shear failure at the cylinder-basemat junction, source terms for the hoop and shear rupture mode will differ significantly. Thus, the modes need to be considered separately during the containment analysis. It was considered unnecessary though to introduce a fifth mode to distinguish shear failure by leak, since leak failure at vessel breach is not expected to be risk dominant. All forms of leak (hoop and shear failures) are binned together.

The joint probability (density) distributions of the three experts are given in Tables 1-1 through 1-3. Based on a hoop strain analysis, Expert A concluded that failure would probably occur between 120 psig and 145 psig. Half of his probability lies between 130 and 140 psig. The leak failure mode was judged more likely to occur at the lower pressures and rupture more likely at the higher pressures. Expert B's analysis led him to conclude that the failure would be a leak in the cylindrical portion of the containment or a leak or a rupture at the cylinder-basemat junction. He placed the bulk of his hoop failure probability around the pressure at which the tendons reach their ultimate strength, 136 psig. The highest probability of shear failure also lies in the 125 to 150 psig range. Expert C concluded that hoop failure was certain to occur between 128 and 137 psig, and that leaks and ruptures are much more likely than

catastrophic ruptures. The initial failure will probably be a small liner tear, which will increase in length if development of a leak does not arrest the pressure rise.

Table 1-4 gives the aggregate distribution. Table 1-5 gives the probability (density) of failure and the joint probability for the four failure modes. The marginal probabilities of failure are 0.48 for leak, 0.18 for hoop rupture, 0.05 for shear rupture, and 0.29 for catastrophic rupture. The three experts' opinions were aggregated as explained in the next section. The median of the average distribution is about 133 psig, and most failures at this pressure result in a leak. The 5% and 95% failure pressures are 94 psig and 170 psig, respectively. Figure 1-1 below shows a plot of the aggregate cumulative probability distribution for failure pressure with the individual experts' distributions.




Figure 1-1. Zion Containment Failure Pressure.

Table 1-1
Expert A

| Pressure (psig) | Cumulative Failure Probability | Conditional Probabilities for Failure Mode | | | |
|--------------------|--------------------------------------|--|-------------------|--------------------|-------------------------|
| | | Leak | Rupture (Hoop) | Rupture (Shear) | Catastrophic Rupture |
| 50 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 70 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 80 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 90 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 100 | 0.010 | 1.000 | 0.000 | 0.000 | 0.000 |
| 110 | 0.020 | 1.000 | 0.000 | 0.000 | 0.000 |
| 120 | 0.220 | 0.670 | 0.280 | 0.000 | 0.000 |
| 130 | 0.420 | 0.460 | 0.380 | 0.000 | 0.160 |
| 140 | 0.900 | 0.130 | 0.340 | 0.000 | 0.530 |
| 150 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 160 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 170 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 180 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 190 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 200 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 225 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |

Table 1-2
Expert B

| Pressure (psig) | Cumulative Failure Probability | Conditional Probabilities for Failure Mode | | | |
|--------------------|--------------------------------------|--|-------------------|--------------------|-------------------------|
| | | Leak | Rupture (Hoop) | Rupture (Shear) | Catastrophic Rupture |
| 50 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.010 | 0.980 | 0.000 | 0.020 | 0.000 |
| 70 | 0.030 | 0.960 | 0.000 | 0.040 | 0.000 |
| 80 | 0.075 | 0.946 | 0.000 | 0.054 | 0.000 |
| 90 | 0.130 | 0.938 | 0.000 | 0.062 | 0.000 |
| 100 | 0.190 | 0.930 | 0.000 | 0.070 | 0.000 |
| 110 | 0.300 | 0.920 | 0.000 | 0.080 | 0.000 |
| 120 | 0.400 | 0.910 | 0.000 | 0.090 | 0.000 |
| 130 | 0.515 | 0.880 | 0.000 | 0.120 | 0.000 |
| 140 | 0.630 | 0.840 | 0.000 | 0.160 | 0.000 |
| 150 | 0.740 | 0.790 | 0.000 | 0.210 | 0.000 |
| 160 | 0.800 | 0.750 | 0.000 | 0.250 | 0.000 |
| 170 | 0.867 | 0.680 | 0.000 | 0.320 | 0.000 |
| 180 | 0.920 | 0.630 | 0.000 | 0.370 | 0.000 |
| 190 | 0.960 | 0.590 | 0.000 | 0.410 | 0.000 |
| 200 | 0.977 | 0.550 | 0.000 | 0.450 | 0.000 |
| 225 | 1.000 | 0.500 | 0.000 | 0.500 | 0.000 |

Table 1-3
Expert C

| Pressure (psig) | Cumulative Failure Probability | Conditional Probabilities for Failure Mode | | | |
|--------------------|--------------------------------------|--|-------------------|--------------------|-------------------------|
| | | Leak | Rupture (Hoop) | Rupture (Shear) | Catastrophic Rupture |
| 50 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 70 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 80 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 90 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 100 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 110 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 120 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 130 | 0.260 | 0.970 | 0.030 | 0.000 | 0.000 |
| 140 | 1.000 | 0.060 | 0.300 | 0.000 | 0.640 |
| 150 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 160 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 170 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 180 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 190 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 200 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 225 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |

Table 1-4
Aggregate

| Pressure (psig) | Cumul. Fail. Prob. | Prob. Density | Conditional Probabilities for Failure Mode | | | |
|--------------------|--------------------------|------------------|--|-------------------|--------------------|-------------------------|
| | | | Leak | Rupture (Hoop) | Rupture (Shear) | Catastrophic Rupture |
| 50 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.003 | 0.003 | 0.980 | 0.000 | 0.020 | 0.000 |
| 70 | 0.010 | 0.007 | 0.960 | 0.000 | 0.040 | 0.000 |
| 80 | 0.025 | 0.015 | 0.946 | 0.000 | 0.054 | 0.000 |
| 90 | 0.043 | 0.018 | 0.938 | 0.000 | 0.062 | 0.000 |
| 100 | 0.067 | 0.024 | 0.940 | 0.000 | 0.060 | 0.000 |
| 110 | 0.107 | 0.040 | 0.927 | 0.000 | 0.073 | 0.000 |
| 120 | 0.207 | 0.100 | 0.750 | 0.187 | 0.030 | 0.033 |
| 130 | 0.398 | 0.191 | 0.775 | 0.146 | 0.024 | 0.055 |
| 140 | 0.843 | 0.445 | 0.156 | 0.289 | 0.010 | 0.545 |
| 150 | 0.913 | 0.070 | 0.414 | 0.000 | 0.110 | 0.476 |
| 160 | 0.933 | 0.020 | 0.750 | 0.000 | 0.250 | 0.000 |
| 170 | 0.956 | 0.023 | 0.680 | 0.000 | 0.320 | 0.000 |
| 180 | 0.973 | 0.017 | 0.630 | 0.000 | 0.370 | 0.000 |
| 190 | 0.986 | 0.013 | 0.590 | 0.000 | 0.410 | 0.000 |
| 200 | 0.992 | 0.006 | 0.550 | 0.000 | 0.450 | 0.000 |
| 225 | 1.000 | 0.008 | 0.500 | 0.000 | 0.500 | 0.000 |

Table 1-5
 Zion Static Failure Pressure
 Joint Distribution for Containment Failure Pressure and Mode

Joint Probability for Failure Pressure and Mode

| <u>Pressure (psig)</u> | <u>Leak</u> | <u>Rupture (Hoop)</u> | <u>Rupture (Shear)</u> | <u>Catastrophic Rupture</u> | <u>Marginal</u> |
|----------------------------|-------------|---------------------------|----------------------------|---------------------------------|-----------------|
| 50 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.003 | 0.000 | 0.000 | 0.000 | 0.003 |
| 70 | 0.007 | 0.000 | 0.000 | 0.000 | 0.007 |
| 80 | 0.014 | 0.000 | 0.001 | 0.000 | 0.015 |
| 90 | 0.017 | 0.000 | 0.001 | 0.000 | 0.018 |
| 100 | 0.023 | 0.000 | 0.001 | 0.000 | 0.024 |
| 110 | 0.037 | 0.000 | 0.003 | 0.000 | 0.040 |
| 120 | 0.075 | 0.019 | 0.003 | 0.003 | 0.100 |
| 130 | 0.148 | 0.028 | 0.004 | 0.011 | 0.191 |
| 140 | 0.069 | 0.129 | 0.004 | 0.243 | 0.445 |
| 150 | 0.029 | 0.000 | 0.008 | 0.033 | 0.070 |
| 160 | 0.015 | 0.000 | 0.005 | 0.000 | 0.020 |
| 170 | 0.016 | 0.000 | 0.007 | 0.000 | 0.023 |
| 180 | 0.011 | 0.000 | 0.006 | 0.000 | 0.017 |
| 190 | 0.008 | 0.000 | 0.005 | 0.000 | 0.013 |
| 200 | 0.003 | 0.000 | 0.003 | 0.000 | 0.006 |
| 225 | 0.004 | 0.000 | 0.004 | 0.000 | 0.008 |
| Marginal | 0.479 | 0.176 | 0.055 | 0.290 | 1.000 |

Method of Aggregation

The desired form for the results of each expert was a table of cumulative failure probabilities for increments of 10 psig as shown in Table 1-1. When an expert provided cumulative probabilities for a range of pressures, the average of the cumulative probabilities for two adjacent ranges was assigned to the pressure which divided the ranges. For example, if an expert assigned a cumulative probability of 0.10 to failure in the pressure range from 60 psia to 70 psia, and a cumulative probability of 0.20 to failure in the pressure range from 70 psia to 80 psia, then a cumulative failure probability of 0.15 would be assigned to 70 psia. Interpolation was used to fill in other values. A similar technique was used for the conditional probabilities for the four failure modes. Where an expert had not considered a failure mode the probability associated with each pressure level was taken as zero.

To determine the aggregated cumulative failure probability at pressure i , $p(\text{avg},i)$, the average was used:

$$p(\text{avg},i) = (p(1,i) + p(2,i) + p(3,i)) / 3$$

where $p(j,i)$ is the cumulative probability for failure at pressure i provided by the j th expert. The aggregate conditional probability for failure mode m at pressure i , $c(\text{avg},i,m)$, was calculated by:

$$c(\text{avg},i,m) = ([p(1,i)-p(1,i-1)] * c(1,i,m) + [p(2,i)-p(2,i-1)] * c(2,i,m) + [p(3,i)-p(3,i-1)] * c(3,i,m)) / 3 / [p(\text{avg},i) - p(\text{avg},i-1)]$$

where $c(j,i,m)$ is the conditional probability of expert j for failure mode m at pressure i . At the lowest pressure, as for all other pressures, the values sum to one--since they are conditional probabilities they must add to one, even if the event on which they are conditional has zero probability. This method weights the conditional probability for each expert by the probability density at the pressure i . The probability density is the first derivative of the cumulative probability. The backward difference approximation is used for the derivative. The sum of the weighted conditional probabilities is normalized by the difference of the aggregated cumulative probability.

For the purposes of the Zion accident progression analysis, a joint distribution of failure mode and pressure is of greater utility in the sampling process than the probability of a given failure mode conditional on failure pressure. Table 1-5, which gives the probability (density) of failure and the joint probability for the four failure modes, was calculated from Table 1-4 using:

$$p(m,i) = p(i) p(m|i)$$

where $p(m,i)$ is the joint distribution of failure mode m at pressure i , $p(i)$ is the probability density at pressure i and $p(m|i)$ is the conditional probability of failure mode m given pressure i .

Individual Elicitations for Issue 1

Expert A's Elicitation

Containment Failure at Zion

Description of Expert A's Rationale/Methodology

Expert A based his conclusions on an analysis of the mid-section of the cylindrical portion of the containment. His study of the drawings and the results of other analyses led him to conclude that this was the weakest portion of the containment. His primary references were the Sargent & Lundy (S&L) analysis^{A-1} and the 1/6-scale model test at Sandia.^{A-2} As with the other experts considering this issue, Expert A concluded that the three cases, described in Section 1, were indistinguishable; the pressure rises were slow enough that all the loadings were static, and the temperatures were well below those at which degradation of structural properties occurs. As the S&L analysis considered other failure locations, such as the dome and the cylinder base/mat junction area, and concluded that the weakest part was the midsection of the cylinder, Expert A focused on that failure mode and considered the hoop stresses there in some detail. His estimate was that this captured about 90% of the failure probability. Expert A used the 1/6-scale model test results to conclude that, at 2% strain in locations away from penetrations, the strain in the liner close to penetrations was likely to cause a tear.

The occurrence of either a leak or a rupture precludes the later occurrence of catastrophic rupture. Once a liner tear has developed, Expert A would expect it to expand in size as pressure increased. This would make catastrophic rupture very unlikely once a liner tear or leak had developed, but the increase in size could change the tear from a leak to a rupture. Leaks are more likely than rupture at lower failure pressures, and rupture is more likely at the higher pressures.

Expert A concluded that the Zion containment was absolutely safe at 90 psig, and that failure was possible but unlikely at 110 psig. He arrived at the 110 psig figure by calculating that general yielding of the rebar occurred at 120 psig and subtracting 10 psig for aging, unknown construction defects, etc., to set this value for the lower bound for failure. As 1% hoop strain occurs at 132 psig and 2% hoop strain at 140 psig, Expert A expected failure to occur in this pressure range with a high probability. The strain in the rebar and the post-tensioned tendons is about the same. When the tendons fail, the rebar, already highly stressed, will also fail. At 4% strain, catastrophic rupture is very likely, but a leak should have developed at lower pressures in most cases. The following table gives Expert A's view of the response of the containment to increasing pressures.

| <u>Pressure (psig)</u> | <u>Response of the Containment</u> |
|----------------------------|---|
| 64 | Loss of hoop prestress |
| 70 | Loss of vertical prestress |
| 85 | Concrete strength exceeded in hoop direction |
| 114 | Liner yields |
| 120 | Hoop rebar yields, and concrete strength exceeded in the vertical direction |
| 132 | Strain in hoop tendons = 1% |
| 134 | Vertical rebar yields, hoop strain in liner = 1% |
| 140 | Hoop strain in liner = 2% |
| 149 | Ultimate strain (5%) in hoop tendons |

Results of Expert A's Elicitation

Expert A provided the following table for the failure probability and mode of failure. It gives the probability (density) of failure and the joint probability for three of the failure modes.

| <u>Pressure (psig)</u> | <u>Failure Probability Density</u> | <u>Joint Probability</u> | | |
|----------------------------|--|--------------------------|---------------------------|---------------------------------|
| | | <u>Leak</u> | <u>Rupture (Hoop)</u> | <u>Catastrophic Rupture</u> |
| 90 | 0.00 | 0.00 | 0.00 | 0.00 |
| 110-115 | 0.03 | 0.03 | 0.00 | 0.00 |
| 115-120 | 0.10 | 0.08 | 0.02 | 0.00 |
| 120-130 | 0.17 | 0.09 | 0.06 | 0.02 |
| 130-135 | 0.23 | 0.10 | 0.10 | 0.05 |
| 135-140 | 0.25 | 0.05 | 0.13 | 0.07 |
| 140-145 | 0.19 | 0.01 | 0.03 | 0.15 |
| 145-150 | 0.01 | 0.00 | 0.00 | 0.01 |

No column is shown for shear rupture since Expert A did not believe this failure mode was credible.

The marginal probabilities of failure are 36% leak, 34% rupture, and 30% catastrophic rupture. This table was converted into a table of cumulative failure probabilities with conditional probabilities for the failure mode.

| Pressure (psig) | Failure Probability Cumulative | Conditional Probability | | |
|--------------------|-----------------------------------|-------------------------|-------------------|-------------------------|
| | | Leak | Rupture (Hoop) | Catastrophic Rupture |
| 90 | 0.00 | 0.00 | 0.00 | 0.00 |
| 110-115 | 0.03 | 1.00 | 0.00 | 0.00 |
| 115-120 | 0.13 | 0.80 | 0.20 | 0.00 |
| 120-130 | 0.30 | 0.53 | 0.35 | 0.12 |
| 130-135 | 0.55 | 0.40 | 0.40 | 0.20 |
| 135-140 | 0.80 | 0.20 | 0.52 | 0.28 |
| 140-145 | 0.99 | 0.05 | 0.16 | 0.79 |
| 145-150 | 1.00 | 0.00 | 0.00 | 1.00 |

This distribution, based on ranges of pressures, was converted into cumulative failure probabilities for 10 psig increments (see Table 1-1), as described above.

REFERENCES

- A-1. Sargent & Lundy, "Containment Structural Capability of Light Water Nuclear Power Plants," IDCOR Technical Report 10.1, Technology for Energy Corporation, Knoxville, TN, July 1983.
- A-2. D. S. Horschel, Sandia National Laboratories, Letter to J. F. Costello, U.S. Nuclear Regulatory Commission, August 2, 1987.

Expert B's Elicitation

Containment Failure at Zion

Description of B's Rationale/Methodology

Expert B considered two failure locations. The first was at mid-height in the cylindrical portion of the containment. He judged that failure at this location would always result in a leak. The other failure location was a shear failure at the point where the cylinder joins the basemat. Failure at this location could result in either a leak or a rupture. Catastrophic rupture was deemed not credible.

Results of Expert B's Elicitation

Expert B gave the following table of probability density versus pressure range for the hoop stress failure of the cylinder. The cumulative probability was derived from the probability density, adjusted upward slightly to account for the fact that the densities only summed to 0.95.

| <u>Pressure (psig)</u> | <u>Probability Density</u> | <u>Cumulative Probability</u> |
|----------------------------|--------------------------------|-----------------------------------|
| 75-100 | 0.05 | 0.05 |
| 100-125 | 0.15 | 0.20 |
| 125-150 | 0.40 | 0.60 |
| 150-175 | 0.20 | 0.80 |
| 175-200 | 0.10 | 0.90 |
| 200-225 | 0.05 | 0.95 |
| 225-250 | 0.05 | 1.00 |

This failure mode depends only on the tendon yield and the ultimate hoop strength. At the ultimate strength of the average tendon, the pressure differential is 136 psig. Expert B thought that his midpoint failure pressure should be around this value. As all tendons were tested, he took 90% of 136 psig as the pressure representative of the 20% to 25% range of failure probability. Failure at these relatively low pressures could occur because of construction defects, material defects, or deterioration of the structures as it ages. For the 75% to 80% failure probability range, he added 30% to the 136 psig value to get 177 psig. He then drew a smooth curve through these points and estimated the values in the table above.

Converting the table of pressure ranges to specific pressures gives:

| <u>Pressure (psig)</u> | <u>Cumulative Probability of Cylinder Failure (Leak)</u> |
|----------------------------|--|
| 75 | 0.00 |
| 100 | 0.13 |
| 125 | 0.42 |
| 150 | 0.73 |
| 175 | 0.90 |
| 200 | 0.98 |
| 225 | 1.00 |

For the shear failure at the cylinder-basemat junction, both leak and rupture are possible but catastrophic rupture is not credible. Expert 3 gave the following table of probability density versus pressure range for this failure location, including conditional leak-rupture probabilities. The cumulative probability distribution in the following table is derived from the probability density distribution.

| <u>Pressure (psig)</u> | <u>Probability Density</u> | <u>Cumulative Probability</u> | <u>Conditional Probability</u> | |
|----------------------------|--------------------------------|-----------------------------------|--------------------------------|----------------------------|
| | | | <u>Leak</u> | <u>Rupture (Shear)</u> |
| 50-75 | 0.05 | 0.05 | 1.00 | 0.00 |
| 75-100 | 0.10 | 0.15 | 0.90 | 0.10 |
| 100-125 | 0.20 | 0.35 | 0.90 | 0.10 |
| 125-150 | 0.30 | 0.65 | 0.75 | 0.25 |
| 150-175 | 0.20 | 0.85 | 0.40 | 0.60 |
| 175-200 | 0.10 | 0.95 | 0.20 | 0.80 |
| 200-225 | 0.05 | 1.00 | 0.00 | 1.00 |

Failure at the junction of the cylinder and the basemat is possible because of the shear discontinuity at this location. The likelihood of shear failure depends on the extent of cracking in the concrete and the compressive stress developed in the concrete. In the following table, the parameter α represents the extent of concrete cracking: $\alpha = 0.1$ indicates extensive cracking and $\alpha = 1.0$ indicates no cracking. Variations in α , the shear strength, and the tendon yield were considered as follows:

| <u>Quantity</u> | <u>Low</u> | <u>Middle</u> | <u>High</u> |
|---|-----------------------|-----------------------|-----------------------|
| Parameter α | 0.10 | 0.25 | 1.00 |
| Shear Capacity | $2(\rho_c)^{\cdot 5}$ | $3(\rho_c)^{\cdot 5}$ | $5(\rho_c)^{\cdot 5}$ |
| Tendon Yield | $.9 \sigma_{avg}$ | σ_{avg} | $1.3 \sigma_{avg}$ |
| Failure Pressure due to Base Shear (psig) | 80 | 102 | 160 |

The distribution of probability density and failure pressure ranges given above was constructed based on these numbers. Rupture is more likely at the higher pressures since the length of the failure is expected to be longer if it occurs at high pressure.

| Pressure (psig) | Cumulative Shear Failure Probability | Conditional Probability | |
|--------------------|--|-------------------------|--------------------|
| | | Leak | Rupture (Shear) |
| 50 | 0.00 | 1.00 | 0.00 |
| 75 | 0.10 | 0.95 | 0.05 |
| 100 | 0.25 | 0.90 | 0.10 |
| 125 | 0.50 | 0.825 | 0.175 |
| 150 | 0.75 | 0.575 | 0.425 |
| 175 | 0.90 | 0.30 | 0.70 |
| 200 | 0.975 | 0.10 | 0.90 |
| 225 | 1.00 | 0.00 | 0.00 |

Finally, the cylindrical hoop failure table is combined with the shear failure table to get one table that includes the effects of both failure modes.

The total failure probability for a given pressure is the average of the cylinder and shear failure probabilities. The conditional probabilities for mode of failure (hole size) are averages weighted by the probabilities. The equation used is similar to the one presented in the Discussion section above.

| Pressure (psig) | Cumulative Shear Failure Probability | Conditional Probability | |
|--------------------|--|-------------------------|--------------------|
| | | Leak | Rupture (Shear) |
| 50 | 0.00 | 1.00 | 0.00 |
| 75 | 0.05 | 0.95 | 0.05 |
| 100 | 0.19 | 0.93 | 0.07 |
| 125 | 0.46 | 0.90 | 0.10 |
| 150 | 0.74 | 0.78 | 0.22 |
| 175 | 0.90 | 0.65 | 0.35 |

No column is shown for either hoop rupture or catastrophic rupture since Expert B did not believe these failure modes were credible. Converting the table based on pressure ranges to one for specific pressures by interpolation produces the results shown in Table 1-2.

Expert C's Elicitation

Containment Failure at Zion

Description of Expert C's Rationale/Methodology

Expert C considered all three cases together since he felt that the previous pressures are irrelevant and that the temperatures are expected to be low. His main emphasis was on hoop stress in the cylindrical portion of the containment, but noted that bellows failure would be expected at 139 psig, which would result in a direct release to the environment. Liner tears at penetrations might result in releases into the auxiliary building.

The following table gives Expert C's view of the response of the containment to increasing internal pressures:

| <u>Pressure (psig)</u> | <u>Response of the Containment</u> |
|----------------------------|------------------------------------|
| 47 | Design Pressure |
| 54 | Test Pressure |
| 75 | Concrete Cracking |
| 120 | Yield--Liner not Considered |
| 128 | Failure--Liner not Considered |
| 134 | 1% Strain--Liner Considered |
| 136 | Penetration Failure |
| 138 | Failure--Liner Considered |
| 139 | Bellows Failure |
| 140 | Ultimate Strain (4%) |

Expert C's calculations showed that the liner carries 14 psig. He would subtract 1 psig for temperatures above 600°F and would subtract 3 psig for general uncertainty.

The lowest pressure at which Expert C would expect to see any significant chance of failure is at 128 psig, the pressure at which failure is predicted without taking the strength of the liner into account. Failure is assured by 137 psig. The failure distribution is narrow because yield in the hoop tendons starts at 134 psig and deformation then increases very quickly with increasing pressure. Deformations of 26 in. are expected by 143 psig.

Results of Expert C's Elicitation

Expert C's distribution is contained in the following table:

| <u>Pressure (psig)</u> | <u>Cumulative Failure Probability</u> | <u>Conditional Probability</u> | | |
|----------------------------|---|--------------------------------|---------------------------|---------------------------------|
| | | <u>Leak</u> | <u>Rupture (Hoop)</u> | <u>Catastrophic Rupture</u> |
| 120 | 0.0 | 1.0 | 0.0 | 0.0 |
| 128 | 0.2 | 1.0 | 0.0 | 0.0 |
| 134 | 0.4 | 0.9 | 0.1 | 0.0 |
| 135 | 0.6 | 0.8 | 0.2 | 0.0 |
| 136 | 0.9 | 0.6 | 0.3 | 0.1 |
| 137 | 1.0 | 0.4 | 0.4 | 0.2 |
| 138 | 1.0 | 0.2 | 0.5 | 0.3 |
| 139 | 1.0 | 0.1 | 0.4 | 0.5 |
| 143 | 1.0 | 0.0 | 0.0 | 1.0 |

No column is shown for shear rupture since Expert C did not believe this failure mode was credible. The entire failure probability is contained in the range from 120 psig to 137 psig. The conditional probabilities for failure mode above 137 psig are interpreted to mean that, if a rapid pressure rise results in peak pressures above 137 psig, these failure mode probabilities apply.

If the leak that develops is not sufficiently large to arrest the pressure rise, Expert C felt that the liner tear would increase in size until the opening was large enough to arrest the pressure rise. He was certain that a catastrophic rupture would not occur once a leak had developed; catastrophic rupture occurs, then, only in the very few cases where the pressure exceeds 137 psig without a leak developing. The table above was used to construct Table 1-3.

5.2 Issue 2. Containment Failure at Surry

Experts consulted: Joe Rashid, ANATECH Research Corporation; Richard Toland, United Engineers & Constructors; Adolph Walser, Sargent & Lundy; Joe R. Weatherby, Sandia National Laboratories.

Issue Description

What distribution characterizes the failure pressures for static loading of the Surry containment? What conditional probabilities describe the failure modes for each pressure?

The Surry containment is a cylinder with a hemispherical dome roof. Both the cylinder and the dome are constructed of reinforced concrete. The foundation is a reinforced concrete slab. The containment is lined with welded 0.25-in. plate steel. The containment is maintained below ambient atmospheric pressure, at about 10 psia, during operation. The design pressure is 45 psig. The free volume is about 1,850,000 ft³.

Three pressure rise cases were described in the original definition of the issue:

1. Pressure spike at vessel breach,
2. Late deflagration, and
3. Late, gradual pressure rise.

Typical rise times for cases 1 and 2 would be on the order of a few seconds. Typical rise times for case 3 would be on the order of an hour. While very high atmospheric temperatures might be observed for a fraction of a minute in case 1, the bulk temperature of the steel liner which forms the pressure boundary is not expected to exceed 300 to 350°F.

The original issue definition of a large hole or rupture was an opening larger than 1.0 ft², which resulted in depressurization in less than about 2 h. A small hole or leak was anything smaller than 1.0 ft², which did not result in depressurization in less than about 2 h. A review of this matter showed that large dry containments would depressurize in 2 h for holes sizes on the order of 0.3 to 0.5 ft². Thus a small hole or leak should have been on the order of 0.1 ft², and 1.0 ft² is definitely a large hole or rupture. The panel members were asked to reconsider the distributions they provided in light of this redefinition of the hole size. Some of them adjusted their distributions for this or for some other reason.

The failure mode "Catastrophic Rupture" (CR) was added at the time of elicitation. Catastrophic rupture implies complete failure of a substantial portion of the containment pressure boundary, with possible disruption of the piping systems that penetrate or are attached to the containment wall. No similar gross structural failure is implied by the "Rupture" failure mode.

Summary of Results

The four panel members considering this issue all agreed that the three cases could be considered together since the pressure rise times were slow enough that the effects were all static. It was pointed out to the experts that the development of a leak would not arrest the pressure rise for cases 1 and 2, but they did not choose to provide separate distributions for these two cases. However, some of the experts allowed for the possibility that the development of a leak would not arrest the pressure rise by providing rupture and CR probabilities for pressures greater than the pressure for which they thought the development of a leak was certain.

The experts also agreed that there was no need to differentiate between cases on the basis of temperature. The temperatures stated were all low enough that there would be no appreciable structural effect; i.e., no significant changes in material properties occur at the temperatures in question.

Failure location did not turn out to be important since any failure location except shear at the basemat-cylinder junction would result in a direct path to the outside. The reinforcing and concrete details in this junction area were such that three of the four experts ruled out failure in this location. (The fourth expert did not specify failure location explicitly.)

The distributions of the four experts for the containment failure pressure and mode for Surry, as received, are given in Tables A-1, B-1, C-1, and D-1. Experts A and B gave cumulative failure probabilities and interval conditional probabilities for the mode of failure. Their distributions are shown in Tables A-1 and B-1, respectively. Expert A concluded that the containment would fail between 120 and 150 psig. His median value was 135 psig. At 145 psig, he viewed leak, rupture, and CR as about equally likely. He allowed for pressurization above 150 psig by rapid pressure rise by shifting his conditional failure mode probabilities toward CR above 150 psig.

Expert B concluded that the containment would fail between 70 and 165 psig. His median value was 120 psig. The lower end of his distribution allows for faulty welds and liner tears due to stress concentrations around openings. He thought the leak failure mode was most likely if the containment failed below 125 psig, the rupture mode was most likely for failure between 125 and 155 psig, and CR was most likely above 155 psig. Although he was certain that some failure would occur by 165 psig, he allowed for pressurization above this value by rapid pressure rise by shifting his conditional failure mode probabilities toward certain CR above 165 psig.

Expert C gave joint interval probabilities, or joint probability densities, as shown in second, third, and fourth columns of Table C-1. These values were converted to total cumulative failure probabilities with interval conditional probabilities for failure mode as shown in Table C-2. Expert C was virtually certain that containment failure would occur between 125 and 165 psig, although he allowed a 1% probability that the failure might occur as high as 200 psig.

Table A-1
 Surry Static Failure Pressure as Received from Expert A

| Pressure (nsig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Prob. | | |
|--------------------|-----------------------------------|--------------------------|----------------------------|---------|-----------|
| | | | Leak | Rupture | Cat. Rup. |
| 60 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 75 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 80 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 85 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 90 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 95 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 100 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 105 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 110 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 115 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 120 | 0.010 | 0.010 | 1.000 | 0.000 | 0.000 |
| 125 | 0.167 | 0.157 | 0.833 | 0.167 | 0.000 |
| 130 | 0.333 | 0.166 | 0.667 | 0.333 | 0.000 |
| 135 | 0.500 | 0.167 | 0.500 | 0.500 | 0.000 |
| 140 | 0.670 | 0.170 | 0.400 | 0.433 | 0.167 |
| 145 | 0.830 | 0.160 | 0.300 | 0.367 | 0.333 |
| 150 | 1.000 | 0.170 | 0.200 | 0.300 | 0.500 |
| 155 | 1.000 | 0.000 | 0.120 | 0.255 | 0.625 |
| 160 | 1.000 | 0.000 | 0.070 | 0.180 | 0.750 |
| 165 | 1.000 | 0.000 | 0.040 | 0.085 | 0.875 |
| 170 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 175 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 180 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 185 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 190 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 195 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 200 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |

Table B-1
 Surry Static Failure Pressure as Received from Expert B

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Prob. | | |
|--------------------|-----------------------------------|--------------------------|----------------------------|---------|------------|
| | | | Leak | Rupture | Cat. Rupt. |
| 60 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 70 | 0.001 | 0.001 | 1.000 | 0.000 | 0.000 |
| 75 | 0.010 | 0.009 | 0.950 | 0.050 | 0.000 |
| 80 | 0.020 | 0.010 | 0.900 | 0.100 | 0.000 |
| 85 | 0.030 | 0.010 | 0.850 | 0.150 | 0.000 |
| 90 | 0.050 | 0.020 | 0.800 | 0.200 | 0.000 |
| 95 | 0.110 | 0.060 | 0.767 | 0.233 | 0.000 |
| 100 | 0.180 | 0.070 | 0.733 | 0.267 | 0.000 |
| 105 | 0.250 | 0.070 | 0.700 | 0.300 | 0.000 |
| 110 | 0.330 | 0.080 | 0.667 | 0.333 | 0.000 |
| 115 | 0.410 | 0.080 | 0.633 | 0.367 | 0.000 |
| 120 | 0.500 | 0.090 | 0.600 | 0.400 | 0.000 |
| 125 | 0.620 | 0.120 | 0.433 | 0.533 | 0.034 |
| 130 | 0.740 | 0.120 | 0.267 | 0.667 | 0.066 |
| 135 | 0.850 | 0.110 | 0.100 | 0.500 | 0.100 |
| 140 | 0.900 | 0.050 | 0.083 | 0.750 | 0.167 |
| 145 | 0.950 | 0.050 | 0.067 | 0.700 | 0.233 |
| 150 | 0.990 | 0.040 | 0.050 | 0.650 | 0.300 |
| 155 | 0.994 | 0.004 | 0.033 | 0.500 | 0.467 |
| 160 | 0.997 | 0.003 | 0.017 | 0.350 | 0.633 |
| 165 | 1.000 | 0.003 | 0.000 | 0.200 | 0.800 |
| 170 | 1.000 | 0.000 | 0.000 | 0.100 | 0.900 |
| 175 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 180 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 185 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 190 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 195 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 200 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |

Table C-1
 Surry Static Failure Pressure as Received from Expert C

| Pressure (psig) | Joint Interval Probability | | | Failure Prob. Density | Cumulative Failure Probability |
|--------------------|----------------------------|---------|-----------|--------------------------|-----------------------------------|
| | Leak | Rupture | Cat. Rup. | | |
| 60 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 75 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 80 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 85 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 90 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 95 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 100 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 105 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 110 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 115 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 120 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 125 | 0.010 | 0.005 | 0.000 | 0.015 | 0.015 |
| 130 | 0.020 | 0.010 | 0.000 | 0.030 | 0.045 |
| 135 | 0.040 | 0.015 | 0.000 | 0.055 | 0.100 |
| 140 | 0.180 | 0.120 | 0.000 | 0.300 | 0.400 |
| 145 | 0.110 | 0.130 | 0.030 | 0.270 | 0.670 |
| 150 | 0.060 | 0.090 | 0.040 | 0.190 | 0.860 |
| 155 | 0.020 | 0.030 | 0.040 | 0.090 | 0.950 |
| 160 | 0.000 | 0.005 | 0.015 | 0.020 | 0.970 |
| 165 | 0.000 | 0.005 | 0.015 | 0.020 | 0.990 |
| 170 | 0.000 | 0.000 | 0.002 | 0.002 | 0.992 |
| 175 | 0.000 | 0.000 | 0.002 | 0.002 | 0.994 |
| 180 | 0.000 | 0.000 | 0.002 | 0.002 | 0.996 |
| 185 | 0.000 | 0.000 | 0.001 | 0.001 | 0.997 |
| 190 | 0.000 | 0.000 | 0.001 | 0.001 | 0.998 |
| 195 | 0.000 | 0.000 | 0.001 | 0.001 | 0.999 |
| 200 | 0.000 | 0.000 | 0.001 | 0.001 | 1.000 |
| Total | 0.440 | 0.410 | 0.150 | | |

Table D-1
 Surry Static Failure Pressure as Received from Expert D

| <u>Pressure (psig)</u> | <u>Independent Failure Prob.</u> | | | <u>Cumulative Failure Probability</u> | <u>Failure Prob. Density</u> |
|----------------------------|----------------------------------|----------------|------------------|---|----------------------------------|
| | <u>Leak</u> | <u>Rupture</u> | <u>Cat. Rup.</u> | | |
| 60 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 75 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 80 | 0.020 | 0.000 | 0.000 | 0.020 | 0.020 |
| 85 | 0.050 | 0.000 | 0.000 | 0.050 | 0.030 |
| 90 | 0.075 | 0.000 | 0.000 | 0.075 | 0.025 |
| 95 | 0.125 | 0.000 | 0.000 | 0.125 | 0.050 |
| 100 | 0.200 | 0.000 | 0.000 | 0.200 | 0.075 |
| 105 | 0.300 | 0.000 | 0.000 | 0.300 | 0.100 |
| 110 | 0.500 | 0.000 | 0.000 | 0.500 | 0.200 |
| 115 | 0.850 | 0.000 | 0.000 | 0.850 | 0.350 |
| 120 | 0.950 | 0.000 | 0.000 | 0.950 | 0.100 |
| 125 | 0.980 | 0.000 | 0.000 | 0.980 | 0.030 |
| 130 | 1.000 | 0.000 | 0.000 | 1.000 | 0.020 |
| 135 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 140 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 145 | 1.000 | 0.050 | 0.000 | 1.000 | 0.000 |
| 150 | 1.000 | 0.200 | 0.000 | 1.000 | 0.000 |
| 155 | 1.000 | 0.500 | 0.000 | 1.000 | 0.000 |
| 160 | 1.000 | 0.800 | 0.000 | 1.000 | 0.000 |
| 165 | 1.000 | 0.950 | 0.000 | 1.000 | 0.000 |
| 170 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |
| 175 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |
| 180 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |
| 185 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |
| 190 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |
| 195 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |
| 200 | 1.000 | 1.000 | 0.000 | 1.000 | 0.000 |

Table C-2
 Joint Interval Probabilities and Modifications to
 Total Cumulative Probabilities

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Prob. | | |
|--------------------|-----------------------------------|--------------------------|----------------------------|---------|-----------|
| | | | Leak | Rupture | Cat. Rup. |
| 60 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 65 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 70 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 75 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 80 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 85 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 90 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 95 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 100 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 105 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 110 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 115 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 120 | 0.000 | 0.000 | 0.667 | 0.333 | 0.000 |
| 125 | 0.015 | 0.015 | 0.667 | 0.333 | 0.000 |
| 130 | 0.045 | 0.030 | 0.667 | 0.333 | 0.000 |
| 135 | 0.100 | 0.055 | 0.727 | 0.273 | 0.000 |
| 140 | 0.400 | 0.300 | 0.600 | 0.400 | 0.000 |
| 145 | 0.670 | 0.270 | 0.407 | 0.481 | 0.111 |
| 150 | 0.860 | 0.190 | 0.316 | 0.474 | 0.211 |
| 155 | 0.950 | 0.090 | 0.222 | 0.333 | 0.444 |
| 160 | 0.970 | 0.020 | 0.000 | 0.250 | 0.750 |
| 165 | 0.990 | 0.020 | 0.000 | 0.250 | 0.750 |
| 170 | 0.992 | 0.002 | 0.000 | 0.000 | 1.000 |
| 175 | 0.994 | 0.002 | 0.000 | 0.000 | 1.000 |
| 180 | 0.996 | 0.002 | 0.000 | 0.000 | 1.000 |
| 185 | 0.997 | 0.001 | 0.000 | 0.000 | 1.000 |
| 190 | 0.998 | 0.001 | 0.000 | 0.000 | 1.000 |
| 195 | 0.999 | 0.001 | 0.000 | 0.000 | 1.000 |
| 200 | 1.000 | 0.001 | 0.000 | 0.000 | 1.000 |

At 125 psig, he thought that failure was twice as likely to be rupture as leak. At 165 psig he thought that CR was three times as likely as rupture. The three failure modes are approximately equal in the 150 to 155 psig range.

Expert D gave independent failure probabilities for leak and rupture as shown in Table D-1. These values were converted to total cumulative failure probabilities with interval conditional probabilities for failure mode as shown in Table D-2. Expert D did not believe that catastrophic ruptures were credible at Surry. Expert D also believed that only leaks were credible if the containment failed below 140 psig, and that only ruptures were credible if the containment failed above 140 psig. He also was certain that a leak would develop by 130 psig.

Table 2-1 gives the aggregate distribution. The median failure pressure is about 128 psig. Leak is the most likely failure mode below that value. Rupture is the most likely failure mode if the containment fails around 135 to 150 psig. Above 155 psig, catastrophic rupture is the most likely failure mode. The method of aggregation used to form Table 2-1 is described in the next section. The conditional failure probabilities may sum to 0.999 or 1.001 rather than 1.000 because of roundoff errors. Although one of the four experts believed that CR was not a credible failure mode at Surry, his failure probability density was zero for the higher failure pressures. Thus, the conditional probability of catastrophic rupture goes to 1.0 at the highest pressures.

Figure 2-1 shows the distributions of the four experts and the aggregate distribution for total cumulative failure probability. There is little agreement among the experts. Note that Experts A and C concluded that there is little or no chance of failure by 120 psig, while Expert D concluded that failure is almost certain by 120 psig.

Figure 2-2 shows the distributions of the four experts and the aggregate distribution for the conditional probability of leak. There is general agreement among the experts that if the containment fails at the lower end of the pressure range, leak is the most likely failure mode.

Figure 2-3 shows the distributions of the four experts and the aggregate distribution for the conditional probability of rupture. There is general agreement among three of the experts that if the containment fails near the middle of the pressure range, rupture is the most likely failure mode. Expert D felt that rupture was certain if the containment failed above 140 psig.

Figure 2-4 shows the distributions of the four experts and the aggregate distribution for the conditional probability of catastrophic rupture. There is general agreement among three of the experts that if the containment fails at the upper end of the pressure range, CR is most likely failure mode. Expert D did not believe that CR was a credible failure mode at Surry.

Table D-2
 Joint Interval Probabilities and Modifications to
 Total Cumulative Probabilities

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Prob. | | |
|--------------------|-----------------------------------|--------------------------|----------------------------|---------|-----------|
| | | | Leak | Rupture | Cat. Rup. |
| 60 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 75 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 80 | 0.020 | 0.020 | 1.000 | 0.000 | 0.000 |
| 85 | 0.050 | 0.030 | 1.000 | 0.000 | 0.000 |
| 90 | 0.075 | 0.025 | 1.000 | 0.000 | 0.000 |
| 95 | 0.125 | 0.050 | 1.000 | 0.000 | 0.000 |
| 100 | 0.200 | 0.075 | 1.000 | 0.000 | 0.000 |
| 105 | 0.300 | 0.100 | 1.000 | 0.000 | 0.000 |
| 110 | 0.500 | 0.200 | 1.000 | 0.000 | 0.000 |
| 115 | 0.850 | 0.350 | 1.000 | 0.000 | 0.000 |
| 120 | 0.950 | 0.100 | 1.000 | 0.000 | 0.000 |
| 125 | 0.980 | 0.030 | 1.000 | 0.000 | 0.000 |
| 130 | 1.000 | 0.020 | 1.000 | 0.000 | 0.000 |
| 135 | 1.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 140 | 1.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 145 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 150 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 155 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 160 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 165 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 170 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 175 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 180 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 185 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 190 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 195 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 200 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |

Table 2-1
Aggregate: Surry Static Failure Pressure

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Prob. | | |
|--------------------|-----------------------------------|--------------------------|----------------------------|---------|------------|
| | | | Leak | Rupture | Cat. Rupt. |
| 60 | 0.000 | 0.000 | 1.000 | 0.500 | 0.000 |
| 65 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 |
| 75 | 0.003 | 0.002 | 0.950 | 0.050 | 0.000 |
| 80 | 0.010 | 0.008 | 0.967 | 0.033 | 0.000 |
| 85 | 0.020 | 0.010 | 0.963 | 0.037 | 0.000 |
| 90 | 0.021 | 0.011 | 0.911 | 0.089 | 0.000 |
| 95 | 0.059 | 0.028 | 0.873 | 0.127 | 0.000 |
| 100 | 0.095 | 0.036 | 0.871 | 0.129 | 0.000 |
| 105 | 0.138 | 0.043 | 0.876 | 0.124 | 0.000 |
| 110 | 0.208 | 0.070 | 0.905 | 0.095 | 0.000 |
| 115 | 0.315 | 0.107 | 0.932 | 0.068 | 0.000 |
| 120 | 0.365 | 0.050 | 0.820 | 0.180 | 0.000 |
| 125 | 0.446 | 0.081 | 0.692 | 0.296 | 0.013 |
| 130 | 0.530 | 0.084 | 0.544 | 0.432 | 0.024 |
| 135 | 0.613 | 0.083 | 0.405 | 0.562 | 0.033 |
| 140 | 0.743 | 0.130 | 0.485 | 0.444 | 0.071 |
| 145 | 0.863 | 0.120 | 0.336 | 0.466 | 0.198 |
| 150 | 0.963 | 0.100 | 0.240 | 0.418 | 0.343 |
| 155 | 0.986 | 0.023 | 0.214 | 0.340 | 0.445 |
| 160 | 0.992 | 0.006 | 0.002 | 0.263 | 0.735 |
| 165 | 0.998 | 0.006 | 0.000 | 0.243 | 0.757 |
| 170 | 0.998 | 0.000 | 0.000 | 0.000 | 1.000 |
| 175 | 0.999 | 0.001 | 0.000 | 0.000 | 1.000 |
| 180 | 0.999 | 0.000 | 0.000 | 0.000 | 1.000 |
| 185 | 0.999 | 0.000 | 0.000 | 0.000 | 1.000 |
| 190 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 195 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 200 | 1.000 | 0.000 | 0.000 | 0.000 | 1.000 |




Figure 2-1. Cumulative Failure Probabilities.




Figure 2-2. Conditional Probabilities of Leak.




Figure 2-3. Conditional Probabilities of Catastrophic Rupture.




Figure 2-4. Conditional Probabilities of Rupture.

Method of Aggregation

Experts A and B gave cumulative failure probabilities and interval conditional probabilities for the mode of failure. Their distributions were in the proper form for aggregation. The cumulative failure probabilities are for all modes of containment failure. The distributions they provided were not for 5 psig increments, so interpolation has been used to fill in values.

Expert C gave joint interval probabilities, or joint probability densities, as shown in the second, third, and fourth columns of Table 1C. The failure probability density (FPD) column in Table 1C is the sum of the three joint interval probabilities for each pressure. The cumulative failure probability (CFP) column is formed by adding the FPD for the pressure interval in question to the CFP for the preceding pressure interval. The interval conditional probabilities for failure mode in Table 2C are formed by normalizing the joint interval probabilities in Table 1C.

Expert D gave independent cumulative failure probabilities for leak and rupture as shown in the second, third, and fourth columns of Table 1D. The cumulative failure probability column in Table 1D is formed by the equation:

$$CFP(i) = 1 - [1 - G_{lk}(i)] * [1 - G_{rp}(i)] * [1 - G_{cr}(i)]$$

for each pressure interval i ,

where

$CFP(i)$ is the total cumulative failure probability for interval i ;

G_{lk} = the independent cumulative probability of leak failure for interval i ;

G_{rp} = the independent cumulative probability of rupture failure for interval i ;

and

G_{cr} = the independent cumulative probability of catastrophic rupture failure for interval i .

The interval conditional probabilities for failure mode in Table 2D are formed from the total cumulative failure probability and the independent failure probabilities. The equation for the interval conditional probability for leak, $C_{lk}(i)$, is:

$$C_{lk}(i) = \frac{[(2 - CFP(i) - CFP(i-1)) * (G_{lk}(i) - G_{lk}(i-1))]}{[(2 - G_{lk}(i) - G_{lk}(i-1)) * (CFP(i) - CFP(i-1))]}$$

The equations for the interval conditional probability for rupture and CR are analogous.

The aggregation of the cumulative failure probability is a straightforward averaging process. That is, the aggregate for the cumulative failure probability for each pressure interval is the average of the values in Tables A-1, B-1, C-2, and D-2. Note that the FPD is formed using the backward difference of the CFP because most of the experts referred to a pressure range by its upper bound.

For the interval conditional probabilities, the aggregate is formed by weighting each expert's interval conditional probability by the failure probability density for the interval. The equation used is:

$$C(i,m) = [C_A(i,m) * D_A(i) + C_B(i,m) * D_B(i) + C_C(i,m) * D_C(i) + C_D(i,m) * D_D(i)] / [D_A(i) + D_B(i) + D_C(i) + D_D(i)]$$

where

$C(i,m)$ is the aggregate conditional probability for failure in mode m , given that the failure occurs in pressure interval i ;

$C_j(i,m)$ is Expert j 's conditional probability for failure in mode m , given that the failure occurs in pressure interval i ; and

$D_j(i)$ is Expert j 's probability that the containment will fail in pressure interval i .

This can be shown to be equivalent to averaging the joint probabilities. The proof is as follows:

Let

$D(i)$ be the aggregate probability that the containment will fail in pressure interval i ;

$J_j(i,m)$ be Expert j 's joint probability that the containment will fail in pressure interval i and in failure mode m ; and

$J(i,m)$ be the aggregate joint probability that the containment will fail in pressure interval i and in failure mode m .

Now

$$D(i) = [D_A(i) + D_B(i) + D_C(i) + D_D(i)] / 4$$

and

$$J(i,m) = [J_A(i,m) + J_B(i,m) + J_C(i,m) + J_D(i,m)] / 4.$$

The relationship between the failure probability density, D , the joint failure probability, J , and the conditional failure mode probability, C , is:

$$J(i,m) = D(i) * C(i,m).$$

This holds for each individual as well as for the aggregate. So

$$C(i,m) = J(i,m)/D(i) = \{[J_A(i,m) + J_B(i,m) + J_C(i,m) + J_D(i,m)]/4\} \\ / \{[D_A(i) + D_B(i) + D_C(i) + D_D(i)] / 4\}.$$

Using the relationship between the density, the joint, and the conditional probabilities for each expert this becomes

$$C(i,m) = [C_A(i,m) * D_A(i) + C_B(i,m) * D_B(i) + C_C(i,m) * D_C(i) \\ + C_D(i,m) * D_D(i)] / [D_A(i) + D_B(i) + D_C(i) + D_D(i)]$$

as above.

Method of Determining Containment Failure

This section discusses the manner in which the results of the elicitations on this issue will be used in the event trees which follow the accident progression. For each observation in the sample, a sampling scheme selects a load pressure from a load distribution given by the Containment Loads panel and selects a containment failure pressure from the aggregate curve given in Table 2-1. The sampling scheme also selects a random number between zero and one to be used to determine the mode of failure.

The load pressure and the containment failure pressure are compared by a user function in the event tree. If the load pressure is less than the containment failure pressure, the containment does not fail. If the load pressure is greater than or equal to the containment failure pressure, the containment fails. If the containment fails, the random number is used to determine the failure mode. Consider the following example: the failure pressure is 130 psig, the load pressure is 135 psig, and pressure rise is slow compared to the time it takes a leak to depressurize the containment. Since a leak at 130 psig will arrest the pressure rise, the interval conditional probability entries in Table 2-1 for 130 psig are used to determine the failure mode. The interval conditional probability for leak is 0.544, so if the random number is less than 0.544 the failure mode is leak. The interval conditional probability for rupture is 0.432, so if the random number is between 0.544 and 0.976 (= 0.544 + 0.432) the failure mode is rupture. If the random number exceeds 0.976, the failure mode is CR.

If the pressure rise is fast compared to the time it takes a leak to depressurize the containment, the determination of the failure mode is more complicated. Again consider the example in which the failure pressure is 130 psig and the load pressure is 135 psig. If a leak develops at 130 psig, the pressure will keep on rising, and a rupture or CR may develop between 130 and 135 psig. To determine the appropriate failure probability density, the portion of the distribution below 130 psig is discounted since failure has occurred at 130 psig. Thus the density used to determine if an

additional rupture may occur between 130 and 135 psig is not $FPD(135) = 0.083$, but $FPD(135) / (1 - CFP(130)) = 0.083 / (1 - 0.530) = 0.177$. The conditional probability of additional ruptures forming between 130 and 135 psig is the leak probability at 130 psig times the conditional rupture probability for the 135 psig interval times the appropriate failure density. For the conditional probability, the average of the values for 130 and 135 psig is used: $(0.432 + 0.562) / 2 = 0.497$. Thus, the total conditional probability of rupture, for rapid pressure rise with a failure pressure of 130 psig and a load pressure of 135 psig, is:

$$0.432 + 0.544 * 0.497 * 0.177 = 0.480.$$

In general terms, this is:

$$R_{rp}(i) = R_{rp}(i-1) + R_{lk}(i-1) * 0.5 * (C_{rp}(i) + C_{rp}(i-1)) \\ * FPD(i) / (1 - CFP(i-1))$$

where C_{rp} , FPD , and CFP have been defined above and R_{rp} and R_{lk} are the interval conditional probabilities of rupture and leak for fast pressure rise. This equation, and an analogous one for R_{cr} , the interval conditional probability of catastrophic rupture for fast pressure rise, have been used to generate the values shown in Table 2-2. After R_{rp} and R_{cr} have been found, the remaining leak fraction is found from:

$$R_{lk}(i) = 1 - R_{rp}(i) - R_{cr}(i).$$

For a rapid pressure rise, a failure pressure of 130 psig, and a load pressure of 135 psig, the conditional probabilities of leak, rupture, and CR are 0.494, 0.480, and 0.026, respectively, as shown on the appropriate line in Table 2-2. To determine the mode of containment failure for fast pressure rise, the random number is used as it is for slow pressure rise. In our example with a rapid pressure rise, a failure pressure of 130 psig, and a load pressure of 135 psig, if the random number is less than 0.494 the failure mode is leak. If the random number is between 0.494 and 0.974 ($= 0.494 + 0.480$) the failure mode is rupture. If the random number exceeds 0.974, the failure mode is CR.

Table 2-2 shows the failure mode probabilities for rapid pressure rise for two failure pressures, 75 psig and 130 psig, for all load pressures. Successive applications of the equation given above for R_{rp} and the analogous equation for R_{cr} determine the entries for each row based on the row above and the entries in Table 2-1. Zeros have been entered for the failure mode probabilities in Table 2-2 where the load pressure is below the failure pressure as there is no containment failure in these cases. In a few rows in Table 2-2, the failure mode probabilities add to 0.999 or 1.001 instead of 1.000. This is due to roundoff error.

Two questions may be asked about Table 2-2. First, why do the failure mode probabilities not go to the upper limit values shown in Table 2-1? Second, why is there still a possibility of leak at 175 psig when Table 2-1 shows a zero conditional probability for leak at that pressure?

Table 2-2
 Surry Static Failure Pressure
 Failure Mode Probabilities for Rapid Pressure Rise

| Load Pres. (psig) | <u>Failure Mode Probabilities</u> | | | <u>Failure Mode Probabilities</u> | | |
|----------------------|-----------------------------------|----------------|------------------|-----------------------------------|----------------|------------------|
| | (Failure Prob. = 75 psig) | | | (Failure Prob. = 130 psig) | | |
| | <u>Leak</u> | <u>Rupture</u> | <u>Cat. Rup.</u> | <u>Leak</u> | <u>Rupture</u> | <u>Cat. Rup.</u> |
| 60 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 70 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 75 | 0.950 | 0.050 | 0.000 | 0.000 | 0.000 | 0.000 |
| 80 | 0.950 | 0.050 | 0.000 | 0.000 | 0.000 | 0.000 |
| 85 | 0.949 | 0.051 | 0.000 | 0.000 | 0.000 | 0.000 |
| 90 | 0.949 | 0.051 | 0.000 | 0.000 | 0.000 | 0.000 |
| 95 | 0.946 | 0.054 | 0.000 | 0.000 | 0.000 | 0.000 |
| 100 | 0.941 | 0.059 | 0.000 | 0.000 | 0.000 | 0.000 |
| 105 | 0.936 | 0.064 | 0.000 | 0.000 | 0.000 | 0.000 |
| 110 | 0.927 | 0.073 | 0.000 | 0.000 | 0.000 | 0.000 |
| 115 | 0.917 | 0.083 | 0.000 | 0.000 | 0.000 | 0.000 |
| 120 | 0.909 | 0.091 | 0.000 | 0.000 | 0.000 | 0.000 |
| 125 | 0.881 | 0.119 | 0.001 | 0.000 | 0.000 | 0.000 |
| 130 | 0.830 | 0.167 | 0.003 | 0.544 | 0.432 | 0.024 |
| 135 | 0.753 | 0.240 | 0.007 | 0.494 | 0.480 | 0.026 |
| 140 | 0.613 | 0.367 | 0.020 | 0.402 | 0.563 | 0.035 |
| 145 | 0.444 | 0.497 | 0.059 | 0.291 | 0.649 | 0.060 |
| 150 | 0.214 | 0.640 | 0.146 | 0.140 | 0.742 | 0.117 |
| 155 | 0.110 | 0.691 | 0.199 | 0.072 | 0.776 | 0.152 |
| 160 | 0.070 | 0.704 | 0.226 | 0.046 | 0.785 | 0.169 |
| 165 | 0.021 | 0.717 | 0.262 | 0.014 | 0.793 | 0.193 |
| 170 | 0.017 | 0.717 | 0.266 | 0.011 | 0.793 | 0.196 |
| 175 | 0.013 | 0.717 | 0.270 | 0.008 | 0.793 | 0.199 |
| 180 | 0.009 | 0.717 | 0.274 | 0.006 | 0.793 | 0.201 |
| 185 | 0.006 | 0.717 | 0.276 | 0.004 | 0.793 | 0.203 |
| 190 | 0.004 | 0.717 | 0.279 | 0.003 | 0.793 | 0.204 |
| 195 | 0.002 | 0.717 | 0.281 | 0.001 | 0.793 | 0.206 |
| 200 | 0.000 | 0.717 | 0.283 | 0.000 | 0.793 | 0.207 |

The first question may be phrased: why don't the entries for 180 to 200 psig in Table 2-2 show 0.0 for rupture and 1.00 for CR as in Table 2-1? The answer is that the results shown in Table 2-2 come from a much different type of calculation. For rapid pressure rise, the fraction of leaks that are still leaks at 180 psig, and for which an additional failure is calculated at 180 psig, are all CR as indicated in Table 2-1. Table 2-2 shows the results of working up in pressure from 75 and 130 psig to the load pressures shown in the left column. Ruptures are much more likely than CRs up to 140 psig pressure range. Thus, from 110 to 150 psig, where the FPD is relatively large, a much larger fraction of a leak failure is converted to ruptures than is converted to CRs.

The second question is: why is there a small but nonzero probability of leak for 175 to 200 psig in Table 2-2 when Table 2-1 shows a zero conditional probability for leak for those pressures? The reason for this is that, of the leaks that occurred at 75 or 130 psig and are still leaks at 175 psig, the fraction that has an additional failure at 175 psig is less than 1.00. There is still a small probability of failure above 175 psig, or 180 psig, etc. The nonzero entries for leak above 170 psig merely indicate that the CFP has not gone to 1.000 exactly at 175 psig. As there is some probability density above 170 psig, then there is some chance that the leak will not be converted to rupture or CR at 175 psig, or 180 psig, etc. Thus there are nonzero entries for leak above 170 psig.

Individual Elicitations for Issue 2

Expert A's Elicitation

Containment Failure at Surry

Description of Expert A's Rationale/Methodology

Expert A found the available information for Surry to be less than that available for Zion, and would have preferred more information. Based on the failure modes found to be important in studies of similar containments, e.g., Indian Point,^{A-1} Expert A considered four failure modes:

- Hoop--in the cylinder;
- Hoop--in the dome;
- Shear--at the cylinder-basemat junction;
- Penetrations.

Meridional failure in the dome will be similar to the hoop failure and was not considered explicitly. On the basis of the detailed drawings and some calculations he made, Expert A concluded that the cylinder-basemat junction was a very strong region and ruled out failure at this location. He looked briefly at the equipment hatch, personnel airlock, pipe penetrations, and electrical penetrations. He concluded that they were sufficiently similar to those at Zion that failure at one of those locations was of low enough probability that it could be dismissed from further consideration.

The way the rebar was placed at the top of the dome led Expert A to question the strength of the dome at high stress levels. At low and medium stress levels, with the liner taken into account for both the cylinder and the dome, the dome is stronger than the cylinder.

For the cylinder, the hoop stress can adequately be calculated by hand. Expert A got 119 psig, which agrees with the Stone & Webster analysis.^{A-2} This is the value for general yield of the rebar. This is the lowest pressure at which Expert A would expect to find any chance of failure: at this pressure the cylinder wall has moved out 2 in.

Expert A then calculated that 2% hoop strain corresponded to 150 psig, including the effects of strain hardening of the rebar. At this level of strain, he concluded that liner tear is certain at discontinuities such as around penetrations and stiffener plates. Further, concrete cracking at 2% general strain will have removed much of the liner support. At 2% strain, the cylinder wall has moved out 16 in.

Results of Expert A's Elicitation

Expert A provided the following table, which contains his views on failure probability and mode of failure:

| <u>Pressure</u> <u>(psig)</u> | <u>Cumulative Fail. Probability</u> | <u>Conditional Probability</u> | | |
|----------------------------------|-------------------------------------|--------------------------------|----------------|---------------------|
| | | <u>Leak</u> | <u>Rupture</u> | <u>Cat. Rupture</u> |
| 119 | 0.001 | 1.0 | 0.0 | 0.0 |
| 127 | 0.25 | 0.7 | 0.3 | 0.0 |
| 135 | 0.50 | 0.5 | 0.5 | 0.0 |
| 142 | 0.75 | 0.4 | 0.5 | 0.1 |
| 150 | 1.0 | 0.2 | 0.3 | 0.5 |
| 170 | 1.0 | 0.0 | 0.0 | 1.0 |

Interpolation was used to create Table A-1 (see page 5.2-3), which gives the probabilities for increments of 5 psig. The cumulative failure curve is essentially linear from 120 psig to 150 psig, and Expert A thought that this was a good representation of his conclusions.

If the leak that develops is not sufficiently large to arrest the pressure rise, Expert A thought that the liner tear would increase in size, either in length or width of both, until the opening was large enough to arrest the pressure rise. He was certain that it would not go to a CR once a leak had developed. CR occurs, then, only in the very few cases where the pressure has reached the 145 to 150 psig range without a leak developing.

REFERENCES

- A-1. United Engineers & Constructors, "Indian Point Units 2 and 3, Containment Capability Analysis," prepared in support of the Indian Point Probabilistic Safety Study, Philadelphia, PA, March 1980.
- A-2. W. J. Pananos and C. F. Reeves, "Containment Integrity at Surry Nuclear Power Station," TP84-13, Stone & Webster Engineering Corp., Boston, MA, 1984.

Expert B's Elicitation

Containment Failure at Surry

Description of Expert B's Rationale/Methodology

Expert B based his analysis on the Stone & Webster study of the Surry containment,^{B-1} studies of other plants such as Indian Point 2 and 3,^{B-2} Seabrook,^{B-3} and the 1/6th-scale test at Sandia.^{B-4} Temperatures and pressure rise times are such that all the cases can be considered together. The expected leakage modes are small liner tears, hatch ovalization, and penetration failures. The expected rupture modes are large liner tears, hatch failure, and penetration failures. The expected burst or catastrophic rupture failure mode is complete hoop failure of the rebar.

Expert B's hoop membrane stress analysis showed the following:

| <u>Pressure</u> <u>(psig)</u> | <u>σ_m</u> <u>(ksi)</u> | <u>Condition</u> |
|----------------------------------|--|----------------------------------|
| 120 | 57.0 | Shell general yield, rebar yield |
| 130 | 62.5 | Cadweld minimum |
| 144 | 70.0 | Minimum rebar failure |
| 166 | 82.0 | Average rebar failure |

Results of Expert B's Elicitation

Expert B placed the lower bound of any type of failure at 75 psig. While the bulk of the failure probability falls above 90 psig, some probability has been placed below 90 psig to account for possible construction defects, such as poor cadwelds of the rebar. Other sources of uncertainty are the rebar placement in the apex of the dome, the hoop bars in the dome, and the reinforcing around the equipment hatch. Failure could be expected to result from localized strain in the rebars, which leads to liner tears. As with the other panel members, he expects failures at low pressures to be mostly leaks due to defects, liner tears, and such. In the middle of the failure pressure range ruptures predominate, and CR or burst failures occur only for the upper end of the range.

Expert B provided the following table, which contains his views on failure probability and mode of failure:

| <u>Pressure</u> <u>(psig)</u> | <u>Cumulative Fail. Probability</u> | <u>Conditional Probability</u> | | |
|----------------------------------|-------------------------------------|--------------------------------|----------------|---------------------|
| | | <u>Leak</u> | <u>Rupture</u> | <u>Cat. Rupture</u> |
| 75 | 0.01 | 0.95 | 0.05 | 0.00 |
| 90 | 0.05 | 0.80 | 0.20 | 0.00 |
| 105 | 0.25 | 0.70 | 0.30 | 0.00 |
| 120 | 0.50 | 0.60 | 0.40 | 0.00 |
| 135 | 0.85 | 0.10 | 0.80 | 0.10 |
| 150 | 0.99 | 0.05 | 0.65 | 0.30 |
| 165 | 1.00 | 0.00 | 0.20 | 0.80 |

Expert B allowed for the possibility of leaks as low as 75 psig because he considered the possibility that some of the rebar cadwelds might not have produced the proper strength and because of the reinforcing details around some of the larger openings. Either of these might lead to localized stress concentrations which would result in liner tears at relatively low pressures. Expert B thus placed half his probability of failure below 120 psig where shell and rebar general yield occur. He pointed out that the Surry containment was constructed quite some time ago when construction methods and quality control were not at today's standards. The failures below 120 psig are all leaks or large leaks (ruptures). Expert B does not think that catastrophic rupture is likely unless the containment fails at pressures considerably in excess of 120 psig.

The pressure range from 105 to 135 psig contains 60% of the failure probability. Interpolation was used to generate intermediate values from the table above so that Table B-1 (see page 5.2-4), in 5 psig increments, could be constructed.

REFERENCES

- B-1. W. J. Pananos and C. F. Reeves, "Containment Integrity at Surry Nuclear Power Station," TP84-13, Stone & Webster Engineering Corp., Boston, MA, 1984.
- B-2. United Engineers & Constructors, "Indian Point Units 2 and 3, Containment Capability Analysis," prepared in support of the Indian Point Probabilistic Safety Study, Philadelphia, PA, March 1980.
- B-3. United Engineers & Constructors, "Containment Ultimate Capacity of Seabrook Station Units 1 & 2 for Internal Pressure Loads," Philadelphia, PA, February 1983.
- B-4. D. S. Horschel, Sandia National Laboratories, Letter to J. F. Costello, U.S. Nuclear Regulatory Commission, August 2, 1987.

Expert C's Elicitation

Containment Failure at Surry

Description of Expert C's Rationale/Methodology

Expert C based his conclusions on an analysis of the mid-section of the cylindrical portion of the containment. His study of the drawings and the results of other analyses led him to conclude that this was the weakest portion of the containment. Much of his conclusions about the leak mode and liner tear come from the 1/6th-scale model test at Sandia.^{C-1} As with the others considering this issue, Expert C concluded that the cases were indistinguishable; the pressure rises were slow enough that all the loading was static, and the temperatures were well below those at which degradation of structural properties occurs.

Development of either a leak or a rupture precludes the later occurrence of CR. Once a liner tear has developed, it is difficult to see how it could be kept from expanding with a continued increase in pressure. Further, additional liner tears may develop elsewhere. Distinguishing between leak and rupture is difficult because there is a continuum of sizes, and a leak may develop into a rupture as the tear increases in size. On the whole, CR is quite unlikely. Leaks are more likely than rupture at the lower failure pressures, and vice versa at the higher pressures.

Results of Expert C's Elicitation

Expert C provided a table for the failure probability and mode of failure for six pressure ranges. This table provides the probability (density) of failure and the joint probability for the three failure modes and takes into account Expert C's uncertainty about the actual rebar properties.

| Pressure (psig) | Failure Probability Density | Joint Probability | | |
|--------------------|-----------------------------|-------------------|--------------|---------|
| | | Leak | Cat. Rupture | Rupture |
| 120 to 135 | 0.10 | 0.07 | 0.03 | 0.00 |
| 135 to 140 | 0.30 | 0.18 | 0.12 | 0.00 |
| 140 to 147 | 0.40 | 0.16 | 0.20 | 0.04 |
| 147 to 155 | 0.15 | 0.03 | 0.05 | 0.07 |
| 155 to 164 | 0.04 | 0.00 | 0.01 | 0.03 |
| 164 to 208 | 0.01 | 0.00 | 0.00 | 0.01 |

The marginal probabilities of failure are 44% leak, 41% rupture, and 15% CR. Interpolation was used to expand this table to one with 5 psig increments. The results are shown in Table C-1 (see page 5.2-5).

Expert C was fairly confident that failure could be expected between 135 psig and 155 psig as 85% of his probability lay within that range. Forty percent of the probability lay within the 140 to 147 psig range. Within the range where failure was most likely to occur, leak and rupture were approximately equally likely. The distribution was terminated at 200 psig, since the 99% value for the pressure rise did not exceed 200 psig in any of the cases considered by the Containment Loads Panel.

REFERENCE

- C-1. D. S. Herschel, Sandia National Laboratories, Letter to J. F. Costello, U.S. Nuclear Regulatory Commission, August 2, 1987.

Expert D's Elicitation

Containment Failure at Surry

Description of Expert D's Rationale/Methodology

Expert D's analysis led him to conclude that a leak was certain to develop by 130 psig. At this pressure the rebar has yielded considerably and reached a strain of about 1%. He would expect leaks to develop due to dislocation at discontinuities.^{D-1} There is no possibility of a leak developing at pressures below 75 psig. This value was obtained by hoop membrane stress analysis assuming that the liner is at its yield stress of 35 ksi. If the liner and the hoop reinforcement are both at their respective yield stress, which is 55 ksi for the reinforcement and 35 ksi for the liner, the pressure would be 110 psig. Expert D took 110 psig to be his median value for leaks. He noted that the specified minimum yield strength is 55 ksi for the reinforcement and 35 ksi for the liner.

Expert D took the lower threshold for rupture to be 140 psig, which was determined by a local effects analysis of the discontinuity at the basemat-cylinder junction.^{D-2} He expected that a crack would open at this junction for a substantial portion of the circumference. Although the crack might be very small, it would be long enough to depressurize the containment in less than 2 hours. He concluded that rupture was certain when the main reinforcement reaches its specified minimum ultimate strength. For the Surry containment, Expert D considered catastrophic rupture to be impossible.

Results of Expert D's Elicitation

Expert D provided separate distributions for leak and for rupture. The leak distribution is:

| | | | | | | | | | | | | |
|-------------------|-----|-----|-----|------|------|-----|-----|-----|-----|-----|-----|-----|
| Pressure (psig) | 75 | 80 | 85 | 90 | 95 | 100 | 105 | 110 | 115 | 120 | 125 | 130 |
| Cum. Distrib. Fn. | 0.0 | .02 | .05 | .075 | .125 | .20 | .30 | .50 | .85 | .95 | .98 | 1.0 |

This distribution has 75% of the leakage failure between 100 and 120 psig.

The rupture distribution is:

| | | | | | | | |
|-------------------|-----|-----|-----|-----|-----|-----|-----|
| Pressure (psig) | 140 | 145 | 150 | 155 | 160 | 165 | 170 |
| Cum. Distrib. Fn. | 0.0 | .05 | .20 | .50 | .80 | .95 | 1.0 |

This distribution has 60% of the rupture failures between 150 and 160 psig.

These independent distributions for leak and rupture were used directly in Table D-1 (see page 5.2-6). The distributions for the leak and rupture modes do not overlap. Leakage modes occur below 130 psig and rupture mode occur above 140 psig. The region with no failures between the two modes, from 130 psig to 140 psig, is due to strain hardening. In other words, if failure does not occur during rebar general yield, then strain hardening will put off failure until about 155 psig.

Expert D was confident that a leak would develop by 130 psig and that ruptures would occur only above 140 psig. If the development of a leak did not arrest the pressure rise, then Expert D concluded that the hole size would increase, changing the failure mode from leak to rupture.

REFERENCES

- D-1. Y. R. Rashid et al., "State-of-the-Art Review of Concrete Containment Response to Severe Overpressurization," Transactions of the 9th SMIRT Conference, Lausanne, Switzerland, August 17-21, 1987.
- D-2. R. A. Dameron et al., "Analytical Correlation and Post-Test Analysis of the Sandia 1:6-Scale Reinforced Concrete Containment Test," Fourth Workshop on Containment Integrity, Arlington, VA, June 14-17, 1988.

5.3 Issue 3. Peach Bottom Containment Failure

Experts consulted: David Clauss, Sandia National Laboratories; Kam Mohktarian, Chicago Bridge & Iron NA-COIN, Inc.; Joe Rashid, ANATECH Research Corporation

Issue Description

What are the plausible pressure-temperature induced containment failure modes at Peach Bottom? For the identified containment failure modes and for each pressure-temperature loading case, at what pressure would the Peach Bottom containment fail?

The following sections on Background, Discussion, and Context are reprinted as they were presented to the Structural Response Expert Panel.

Background

Peach Bottom has a GE Mark I pressure suppression containment with a design pressure of 62 psig. The Reactor Safety Study (RSS)³⁻¹ analysis of the Peach Bottom containment predicted failure in the torus with a mean failure pressure of 160 psig. Many later studies of Peach Bottom have referenced the Ames Laboratory study³⁻² which predicted that the Mark I containment at Browns Ferry would fail at the drywell knuckle (junction between the cylindrical and spherical sections) at 117 psig based on a 0.2% strain criterion. Browns Ferry has a thicker, more uniform torus shell than Peach Bottom. The recently completed Chicago Bridge and Iron (CB&I) study³⁻³ addressed global containment shell failure for a Mark I containment essentially identical to that at Peach Bottom Unit 2. CB&I found the first point on the containment to reach 1% membrane strain (failure criterion) was on the upper portion of the torus at 159 psig. CB&I recommended further study of penetrations, personnel lock, equipment hatch, and drywell head closure bolts to address the potential for local failure. IDCOR has postulated creep failure of the drywell shell in scenarios involving core concrete interactions (CCI) that result in drywell temperatures approaching 1200°F.

Four loading cases are:

Case 1: The containment is being gradually pressurized. Drywell shell temperatures are less than 500°F. This may occur either before vessel breach or, given water-cooled debris, after vessel breach. No containment leak has yet developed.

Case 2: At the time of vessel breach, the containment is rapidly pressurized from a pressure P_{bf} to a peak pressure P_{pk} .

P_{bf} is in the 60 to 120 psig range. Drywell shell temperatures are < 500°F during the pressurization. No containment leak exists before vessel breach.

Case 3 The containment is being gradually pressurized at high temperatures (800 to 1200°F) as a result of sustained CCI after vessel breach. No containment leak has yet developed.

Case 4 The containment at low (near atmospheric) pressure as gases from sustained CCI are vented through the suppression pool via a wetwell leak or rupture; however, the temperature of the drywell shell is increasing into the high temperature (800 to 1200°F) regime.

Ten failure modes and locations were identified by the experts.

1. WWLaW--wetwell leak above water line with no bypass;
2. WWLbW--wetwell leak below water line with bypass;
3. WWRaW--wetwell rupture above water line with no bypass;
4. WWRbW--wetwell rupture below water line with bypass;
5. CWWR--catastrophic wetwell rupture;
6. DWL--drywell leak to reactor building;
7. DWR--drywell rupture to reactor building;
8. DWHL--drywell head leak to refueling floor;
9. DWHR--drywell head rupture to refueling floor;
10. CDWR--catastrophic drywell rupture to reactor building.

Discussion

The results will be used in the Accident Progression Event Tree (APET) in the following way.

1. Question: For this time period did containment fail? For each observation in the sample, the sampling program will select a load pressure from the containment load distribution; then it will select a failure pressure from the appropriate containment failure pressure distribution. If the failure pressure is less than the containment load pressure, then failure occurs with 1.0 probability for that observation.
2. Question: What is the containment failure mode and location? For this question, there are two ways to reach the load pressure: (1) a slow pressure rise, and (2) a fast pressure rise. For the slow pressure rise, the sampling program will select a random number between zero and one for each observation. The user function will compare this number to the ordered sum of the conditional failure mode probabilities for the failure pressure selected in the previous question. The failure mode corresponding to the increment

that the random number falls in will be chosen for that observation. For fast pressure rise, only a rupture or catastrophic rupture will preclude further pressure rise. The user function calculates the conditional probability of the various modes over the interval between the selected failure and load pressures. This is done in the user function in the APET for each observation. The resulting conditional probabilities will be compared to a random number as in the slow case and a failure mode selected for that observation.

Accident Progression Event Tree Context

A wide spectrum of failure sizes is conceivable, ranging from very small leaks to large ruptures. Induced leaks that are too small to preclude further pressurization are considered; however, because such small leaks would not appreciably alter the accident progression or preclude larger leaks or rupture, small induced leaks are not very significant to risk. Consequently, the focus of this issue is to identify alternative modes for larger leaks or ruptures, with the terms leak and rupture defined as follows:

A leak is an opening that would arrest a gradual containment pressure buildup but would not result in containment depressurization within 2 h. A gradual pressure buildup means a few psi per hour and excludes pressure spikes arising from rapid reactor coolant system's depressurization, combustion events, steam spikes, and direct containment heating. In the NUREG-1150 analysis for Peach Bottom, openings of size 10 in.² to 1.8 ft² are classified as leaks.

A rupture is an opening that would result in rapid (<2 h) containment depressurization. For Peach Bottom, openings in excess of 1.8 ft² are classified as ruptures.

The review group is specifically requested to consider a catastrophic rupture that would eliminate major portions of the containment structures (e.g., 1:8th-scale steel model) as a potential failure mode.

Based on differences in the decontamination potential for radionuclide releases, the Peach Bottom APET distinguishes four location categories for containment failure:

- Cat. 1 Failure in the torus that does not lead to suppression pool bypass (e.g., an opening in the top of the torus);
- Cat. 2 Failure in the torus that leads to suppression pool bypass (i.e., to draining of the suppression pool);
- Cat. 3 Failure in the drywell resulting in flow to the reactor building (e.g., failure in a downcomer);
- Cat. 4 Failure in the drywell resulting in flow to the refueling bay (e.g., drywell head seal leakage).

The review group may, of course, identify more than one mode of failure corresponding to any of these broad location categories; however, from a source term perspective at least this level of delineation is required.

Pressure-temperature-induced containment failure questions are asked in the Peach Bottom APET for four different time regimes: (1) before uncovering the core, (2) before reactor pressure vessel breach when the containment pressure buildup is fairly steady as steam and hydrogen are released from the reactor vessel to containment, (3) immediately after reactor vessel breach when a rapid containment pressure increase is possible particularly in high-pressure meltdown scenarios, and (4) later, when a steady buildup in containment pressure is possible given either water-cooled debris or CCIs. In the presence of sustained CCIs, the containment temperature will also increase steadily.

Based on severe-accident pressure and temperature loadings calculations performed using codes such as MARCH, MAAP, MELCOR, and CONTAIN, drywell temperatures may be divided into the following two categories for the purpose of assessing containment failure modes:

Med. T Drywell structure temperatures are less than 500°F as would be the case before or immediately after vessel breach.

High T Drywell structural temperatures are in the 800°F to 1200°F range. This case is only possible after vessel failure, with uncooled core debris on the drywell floor.

Summary of Results

Table 3-1 shows the aggregate results for cases 1 and 2. Table 3-2 lists results used in the accident frequency analysis. Tables 3-3 and 3-4 contain the aggregate results for case 3. Table 3-3 applies when the drywell is at 800°F and Table 3-4 applies when the drywell is at 1200°F. The results for case 4 are given in Table 3-5.

The aggregate results of this issue are also used in the accident frequency analysis of NUREG-1150. For certain sequences in which core cooling is still working but where containment heat removal has failed, the containment pressure will continue to rise until failure occurs. In this case, failure is certain, but we need to know if a leak or rupture has occurred and if the fission products escape to the reactor building or to the refueling floor.

The results of the slow pressure rise case (case 1) are used in the accident frequency analysis. The sum over all leaks and all ruptures at the failure pressure selected for locations in the reactor building and the refueling floor gives the conditional probability of leak versus rupture and location. For the point estimate calculation the mean values are used. For the LHS TEMAC runs, the cumulative failure distribution is sampled to select a failure pressure and then the conditional probability for that failure pressure for leak versus rupture is used to quantify the events for that observation.

Method of Aggregation

For each of the cases, the experts assessed failure probabilities over slightly different ranges and their values had to be extrapolated both above and below their assessed range. In the lower direction, a failure probability of zero was assigned since these pressures were below the experts' lowest failure pressure. The conditional probability of the various modes was assigned the same value as those at the experts' lowest assessed pressure. In the upper direction, the experts' curves were extended as described in each case.

For the aggregation of the experts' results in this situation, we need two different pieces of data. First, we need to determine the failure pressure and, second, the conditional probability of each failure mode. Each expert's results were used to calculate a cumulative probability of failure curve. The aggregated cumulative failure probability was calculated by simple averaging:

$$PT(ave,i) = (p(1,i) + p(2,i) + p(3,i)) / 3$$

where $p(j,i)$ = the j th experts' cumulative probability of failure at pressure i and $PT(ave,i)$ = the aggregate cumulative probability of failure at pressure i .

The experts' results were then converted into the form of conditional probabilities of the m th failure mode at a certain pressure i . The aggregated conditional probability of the m th mode at pressure i was calculated by simple averaging:

$$c(ave,i,m) = (c(1,i,m) + c(2,i,m) + c(3,i,m)) / 3$$

where $c(ave,i,m)$ = the aggregate conditional probability of the m th mode at pressure i , and $c(j,i,m)$ = the conditional probability of failure of the m th mode for the j th expert at pressure i , with the following exception: for pressures where the cumulative probability of failure is zero, the conditional failure mode probabilities are set equal to those for the lowest pressure for which the cumulative failure probability is non-zero.

Table 2
 Peach Bottom Front-End Information - Phases 1 and 2

| Pressure (psig) | Cumulative Probability | Conditional Probability of Failure at Pressure J | | | | | |
|--------------------|---------------------------|--|--------|--------|---------|--------|--------|
| | | Leak | LtRF | LtRB | Rupture | RtRF | RtRB |
| 90.0000 | 0.0000 | 0.8889 | 0.5556 | 0.3333 | 0.1111 | 0.0000 | 0.1111 |
| 95.0000 | 0.0050 | 0.8889 | 0.5556 | 0.3333 | 0.1111 | 0.0000 | 0.1111 |
| 100.0000 | 0.0100 | 0.8889 | 0.5556 | 0.3333 | 0.1111 | 0.0000 | 0.1111 |
| 105.0000 | 0.0183 | 0.8889 | 0.5556 | 0.3333 | 0.1111 | 0.0000 | 0.1111 |
| 110.0000 | 0.0242 | 0.8889 | 0.5556 | 0.3333 | 0.1111 | 0.0000 | 0.1111 |
| 115.0000 | 0.0357 | 0.8797 | 0.5523 | 0.3274 | 0.1203 | 0.0039 | 0.1163 |
| 120.0000 | 0.0471 | 0.8706 | 0.5491 | 0.3215 | 0.1294 | 0.0078 | 0.1216 |
| 125.0000 | 0.0751 | 0.8614 | 0.5457 | 0.3157 | 0.1386 | 0.0118 | 0.1268 |
| 130.0000 | 0.1095 | 0.8523 | 0.4964 | 0.3559 | 0.1477 | 0.0157 | 0.1320 |
| 135.0000 | 0.1556 | 0.8431 | 0.3722 | 0.4709 | 0.1569 | 0.0196 | 0.1373 |
| 140.0000 | 0.2220 | 0.8342 | 0.4267 | 0.4075 | 0.1658 | 0.0172 | 0.1486 |
| 145.0000 | 0.3919 | 0.8128 | 0.1595 | 0.6533 | 0.1872 | 0.0149 | 0.1723 |
| 150.0000 | 0.5703 | 0.7875 | 0.0971 | 0.6904 | 0.2125 | 0.0125 | 0.2000 |
| 155.0000 | 0.6628 | 0.6409 | 0.1105 | 0.5304 | 0.3591 | 0.0101 | 0.3490 |
| 160.0000 | 0.7539 | 0.5779 | 0.1816 | 0.3963 | 0.4221 | 0.0077 | 0.4144 |
| 165.0000 | 0.8317 | 0.3236 | 0.1381 | 0.1855 | 0.6764 | 0.0067 | 0.6697 |
| 170.0000 | 0.9247 | 0.3332 | 0.1408 | 0.1924 | 0.6668 | 0.0057 | 0.6611 |
| 175.0000 | 0.9616 | 0.3048 | 0.1319 | 0.1730 | 0.6952 | 0.0116 | 0.6835 |
| 180.0000 | 0.9964 | 0.2292 | 0.0925 | 0.1367 | 0.7708 | 0.0175 | 0.7532 |
| 185.0000 | 0.9976 | 0.4955 | 0.2434 | 0.2521 | 0.5045 | 0.0172 | 0.4873 |
| 190.0000 | 0.9987 | 0.4444 | 0.2077 | 0.2366 | 0.5556 | 0.0170 | 0.5387 |
| 195.0000 | 0.9998 | 0.4614 | 0.2308 | 0.2306 | 0.5386 | 0.0167 | 0.5219 |
| 200.0000 | 0.9999 | 0.5007 | 0.2897 | 0.2110 | 0.4993 | 0.0167 | 0.4827 |
| 205.0000 | 0.9999 | 0.4729 | 0.4063 | 0.0666 | 0.5271 | 0.0167 | 0.5105 |

5.3-7

Table 3-2 (continued)

| Pressure (psig) | Cumulative Probability | Conditional Probability of Failure at Pressure J | | | | | | | |
|--------------------|---------------------------|--|--------|--------|---------|--------|--------|--|--|
| | | Leak | LtRF | LtRB | Rupture | RtRF | RtRB | | |
| 210.0000 | 0.9999 | 0.4881 | 0.4223 | 0.0658 | 0.5119 | 0.0167 | 0.4952 | | |
| 215.0000 | 0.9999 | 0.5056 | 0.4385 | 0.0671 | 0.4944 | 0.0167 | 0.4777 | | |
| 220.0000 | 1.0000 | 0.4645 | 0.3965 | 0.0680 | 0.5355 | 0.0167 | 0.5188 | | |
| 225.0000 | 1.0000 | 0.4277 | 0.3637 | 0.0640 | 0.5723 | 0.0167 | 0.5556 | | |
| 230.0000 | 1.0000 | 0.3937 | 0.3300 | 0.0637 | 0.6063 | 0.0167 | 0.5896 | | |
| 235.0000 | 1.0000 | 0.3643 | 0.2990 | 0.0653 | 0.6357 | 0.0167 | 0.6190 | | |
| 240.0000 | 1.0000 | 0.3592 | 0.2947 | 0.0644 | 0.6408 | 0.0167 | 0.6242 | | |
| 245.0000 | 1.0000 | 0.3419 | 0.2788 | 0.0631 | 0.6581 | 0.0167 | 0.6414 | | |
| 250.0000 | 1.0000 | 0.3329 | 0.2706 | 0.0622 | 0.6671 | 0.0167 | 0.6505 | | |
| 255.0000 | 1.0000 | 0.3195 | 0.2582 | 0.0613 | 0.6805 | 0.0167 | 0.6639 | | |
| 260.0000 | 1.0000 | 0.3104 | 0.2504 | 0.0600 | 0.6896 | 0.0167 | 0.6730 | | |
| 265.0000 | 1.0000 | 0.3734 | 0.3134 | 0.0600 | 0.6266 | 0.0167 | 0.6099 | | |
| 270.0000 | 1.0000 | 0.4067 | 0.3467 | 0.0600 | 0.5933 | 0.0167 | 0.5767 | | |
| 275.0000 | 1.0000 | 0.6067 | 0.5467 | 0.0600 | 0.3933 | 0.0167 | 0.3767 | | |

Table 3-4
Average of Experts: Case 3B

| Pressure (psia) | Cumulative Probability | Conditional Probability of Failure in Mode I at Pressure J | | | | | | | | | | | | |
|--------------------|---------------------------|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | MWLAJ | MWLBW | MWRAJ | MWRBW | CMWBJ | DWL | DWEL | DWR | DWER | CIWBJ | | | |
| 5.0000 | 0.0167 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 10.0000 | 0.1667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 15.0000 | 0.3333 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 20.0000 | 0.3333 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 25.0000 | 0.3333 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 30.0000 | 0.3611 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 35.0000 | 0.3889 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 40.0000 | 0.4167 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3467 | 0.6533 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 45.0000 | 0.4942 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3615 | 0.5686 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 50.0000 | 0.5917 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3763 | 0.4839 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 55.0000 | 0.6805 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3677 | 0.4264 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 60.0000 | 0.7725 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1469 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.9022 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1173 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 70.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1072 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 75.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4367 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 80.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4367 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 85.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4367 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 90.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4367 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4367 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4367 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.4133 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.3633 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.3700 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.2200 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.3133 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 1.0000 | 0.0037 | 0.0004 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.2252 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 1.0000 | 0.0022 | 0.0002 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1734 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 1.0000 | 0.0015 | 0.0002 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1396 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 1.0000 | 0.0365 | 0.0043 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1177 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 1.0000 | 0.0208 | 0.0024 | 0.0000 | 0.0000 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 1.0000 | 0.2047 | 0.0232 | 0.0128 | 0.0025 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 160.0000 | 1.0000 | 0.1399 | 0.0159 | 0.0190 | 0.1585 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 165.0000 | 1.0000 | 0.0750 | 0.0086 | 0.0232 | 0.2244 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 170.0000 | 1.0000 | 0.0301 | 0.0036 | 0.0151 | 0.2846 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 175.0000 | 1.0000 | 0.0301 | 0.0035 | 0.0075 | 0.2921 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 180.0000 | 1.0000 | 0.0301 | 0.0035 | 0.0000 | 0.2997 | 0.0000 | 0.3667 | 0.1033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Table 3-5
Case 4 Results

| Expert | Mode of Failure | | | | |
|---------|-----------------|-------|-------|-------|------|
| | DWL | DWHL | DWR | DWHR | GDWR |
| A | 0.05 | 0.00 | 0.00 | 0.00 | 0.00 |
| B | 0.25 | 0.04 | 0.32 | 0.02 | 0.06 |
| C | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Average | 0.10 | 0.013 | 0.107 | 0.007 | 0.02 |

REFERENCES

- 3-1. U.S. Nuclear Regulatory Commission, "Reactor Safety Study--An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants," U.S. Nuclear Regulatory Commission Report WASH-1400 (NUREG-75/014), Washington, D.C., 1975.
- 3-2. L. Greimann et al., "Reliability Analysis of Steel Containment Strength," NUREG/CR-2442, Ames Laboratory, June 1982.
- 3-3. K. Mohktarian et al., "Mark I Containment Severe Accident Analysis for the Mark I Owners Group," Chicago Bridge & Iron NA-CON, Inc., Chicago, IL, April 1987.

Individual Elicitations for Issue 3

Expert A's Elicitation

Peach Bottom Containment Failure

Description of Expert A's Rationale/Methodology

The Expert gave his assessment in the form of cumulative distribution functions for each failure mode over the pressure range. For cases 1 and 2, Expert A provided the following information.

| <u>Pressure</u> | <u>WwLaW</u> | <u>DWL</u> | <u>DWHL</u> | <u>WwRaW</u> | <u>WwRbW</u> | <u>DWR</u> |
|-----------------|--------------|------------|-------------|--------------|--------------|------------|
| 120 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125 | - | 0 | - | 0 | 0 | 0 |
| 130 | .05 | 0 | - | 0 | 0 | 0 |
| 135 | - | 0 | - | 0 | 0 | 0 |
| 140 | .2 | 0 | .1 | 0 | 0 | 0 |
| 145 | .5 | 0 | - | 0 | 0 | 0 |
| 150 | .9 | 0 | .2 | 0 | 0 | 0 |
| 155 | .99 | 0 | - | .15 | 0 | 0 |
| 160 | 1 | 0 | - | .5 | 0 | 0 |
| 165 | 1 | - | - | .8 | 0 | 0 |
| 170 | 1 | .2 | .5 | - | 0 | 0 |
| 175 | 1 | - | - | - | .05 | 0 |
| 180 | 1 | .5 | - | 1 | .2 | 0 |
| 185 | 1 | .8 | - | 1 | .5 | 0 |
| 190 | 1 | .95 | .8 | 1 | .8 | 0 |
| 195 | 1 | - | - | 1 | .95 | 0 |
| 200 | 1 | 1 | - | 1 | 1 | 0 |
| 202.5 | 1 | 1 | - | 1 | 1 | .05 |
| 205 | 1 | 1 | - | 1 | 1 | .25 |
| 210 | 1 | 1 | .95 | 1 | 1 | .5 |
| 215 | 1 | 1 | - | 1 | 1 | - |
| 220 | 1 | 1 | - | 1 | 1 | .55 |
| 225 | 1 | 1 | - | 1 | 1 | - |
| 230 | 1 | 1 | - | 1 | 1 | .9 |
| 235 | 1 | 1 | - | 1 | 1 | - |
| 240 | 1 | 1 | 1 | 1 | 1 | 1 |

Comments on-Cases 1 & 2

1. Wetwell leak no bypass (WwLaW)-Discontinuity strains at T-stiffeners reach 4% at 150 psig. From a criterion developed for MARK I failure limits, this 4% strain is equivalent to a uniaxial ductility limit of 19%. Because the general strain state in the far field regions of the shell at the 50% probability (pressure = 145 psig) is at or below yield, this mode is predominantly a leakage mode. The 50% probability corresponding to 145 psig is based on the fact that a peak strain of 3.5% is reached at that pressure. This is of the same order of magnitude as strains measured in EPRI containment experiments where small, 1 to 2-in.,

leaks occurred. At the 20% probability (140 psig), the far field strain is still elastic. Therefore, if a crack initiates at a pressure of 140 psig, it will be arrested in the elastic region of the shell or by the adjacent stiffener which is about 3 ft away. An opening larger than 1.8 ft² is unlikely to develop.

2. Unlike location WWLaW, the membrane strain is less dominant for WWLbW. However, it is still a local strain concentration. The material fails at higher surface strain; hence, higher failure pressures. This mode is likely to develop into a rupture mode very quickly and is, therefore, not considered (see WWRbW). The crack would unzip in the hoop direction where no crack arrest mechanism exists.
3. For the DWL (at the downcomers), the highest surface strain is in the drywell, but failure there would lag the wet well. Failure at this location develops due to a bending strain. Because of the constraining effect of the floor, the failure size could not grow to a rupture.
4. For DWHL, a large uncertainty exists due to uncertainties in bolt pre-load, bolt relaxation, and degradation of the gasket material. Up to 40 mil resiliency is estimated to remain in the gasket material depending on age. Since gaskets are replaced periodically and are not allowed to deteriorate, there is no reason to assume that more than a 50% reduction in resiliency can occur.
5. For WWRaW or WWRbW, rupture mode develops only if the WWLaW crack arrests too soon before leakage is large enough. The probability distribution curve is steeper in the early range of pressure for WWRaW due to the fact that failure could evolve very rapidly from a point where the peak strain grows nonuniformly with pressure. For WWRbW, the distribution function is symmetric about the midpoint due to the fact that failure cannot be pinpointed to a point or a small region, but could occur anywhere over a large area where the peak strain would grow uniformly with pressure. This is a flatter curve because: (a) the discontinuity at this location is not as strong as at WWRaW, and (b) the strain at this location is predominantly bending unlike the WWRaW case where the strain is membrane. Failure by bending requires much higher surface strains, hence higher failure pressure.
6. For DWR (in the main body of the drywell near penetration), rupture pressure of the shield wall is 240 psig with yielding of reinforcement beginning at 200 psig. Drywell rupture occurs as a result of the loss of the concrete wall back support. This loss of support occurs in stages. First, the rebar in the shielding wall begins to yield and deform with little additional load up to about 1.5% strain. This stage is followed by significant strain hardening in the rebars and rebar deformation slows down significantly until ultimate tensile strength is realized. When this occurs, the rebar becomes unstable and deforms rapidly with a catastrophic decrease in load carrying capacity. These stages are reflected in the shape of the probability distribution curve. The first S in

this curve (200 to 210 psig) corresponds to the first stage or the flat portion of the rebar stress-strain curve and the second S corresponds to the strain hardening portion of the rebar stress-strain curve.

The cumulative failure probability by pressure i is formed by taking the difference between 1.0 and the product of the success probabilities of each mode and subtract from one:

$$p(j,i) = 1 - (1-p(j,i,m)) \dots (1-p(j,i,m)).$$

For example, at 155 psig, $WLaW = .95$, $DWL = 0$, $DWHL = .2750$, $WLaW = .15$, and $WLaW = DWR = 0$. So $PT(150) = 1 - (1-.95) * (1-0) * (1-.275) * (1-.15) * (1-0) * (1-0) = 1 - .05 * .725 * .85 = .9692$.

In order to calculate the conditional probability of failure at a specific pressure, the following formula is used:

$$c(j,i,m) = [(2-p(j,i)-p(j,i-1)) * (p(j,i,m)-p(j,i-1,m))] / [(2-p(j,i,m)-p(j,i-1,m)) * (p(j,i)-p(j,i-1))].$$

When the probability of a particular mode goes to 1.0, its conditional probability is set to zero for all higher pressures since there was no chance of that failure mode occurring in that pressure interval and then a new total cumulative is calculated with the remaining failure modes. For example: at 155 psig, $c(WLaW, 150) = (2-.9692-.9200) * (.95-.90) / (2-.95-.90) * (.9692-.92) = .7510$.

Linear interpolation between points and extrapolation at the high pressure end (by continuing with the conditionals calculated at the point where the last mode went to 1.0) is used to create Table A-1, which is then converted to Tables A-2 and A-3.

Case 3 was divided into two subcases. For case 3a, the drywell structural temperature is 800°F and for case 3b, the temperature is 1200°F. For case 3a, Expert A gave the following information:

| <u>Pressure</u> | <u>WLaW</u> | <u>DWL</u> | <u>DWHL</u> |
|-----------------|-------------|------------|-------------|
| 60 | 0 | 0 | 0 |
| 65 | 0 | 0 | - |
| 70 | 0 | 0 | - |
| 75 | 0 | 0 | - |
| 80 | 0 | 0 | .1 |
| 85 | 0 | 0 | - |
| 90 | 0 | 0 | .2 |
| 95 | 0 | 0 | - |
| 100 | 0 | 0 | - |
| 105 | 0 | 0 | - |

| <u>Pressure</u> | <u>WWLaW</u> | <u>DWL</u> | <u>DWHL</u> |
|-----------------|--------------|------------|-------------|
| 110 | 0 | 0 | .5 |
| 115 | 0 | 0 | - |
| 120 | 0 | 0 | - |
| 125 | - | - | - |
| 130 | .05 | .2 | .8 |
| 135 | - | - | - |
| 140 | .2 | .5 | - |
| 145 | .5 | .8 | - |
| 150 | .9 | .95 | .95 |
| 155 | .99 | - | - |
| 160 | 1 | 1 | - |
| 165 | 1 | 1 | - |
| 170 | 1 | 1 | - |
| 175 | 1 | 1 | - |
| 180 | 1 | 1 | 1 |

Comments for Case 3a:

1. WWLbW, WWRaW, and WWRbW can not occur since temperature is at saturation in wetwell. Failure will occur first in the drywell due to the high temperatures or same as case 1 or 2 for WWLaW.
2. For DWL (at the downcomers), the difference with case 1 is a reduction of material strength (both yield and ultimate) due to 800°F. A 25% reduction was assumed and the failure pressures were adjusted accordingly.
3. For DWHL, the gasket was assumed to lose all its resiliency at 800°F.

The data manipulation is similar to that in cases 1 & 2. The results are shown in Tables A-4, A-5, and A-6.

For cases 3b and 4, Expert A gave the following tabular information for the probability of drywell leak for four pressures for a range of temperatures:

| <u>Temperature</u> | <u>Pressure</u> <u>(psig)</u> | | | |
|--------------------|----------------------------------|-----------|-----------|-----------|
| | <u>5</u> | <u>10</u> | <u>15</u> | <u>90</u> |
| 800 | 0 | 0 | 0 | 0 |
| 850 | 0 | - | - | .1 |
| 900 | 0 | 0 | .05 | .6 |
| 950 | 0 | - | - | - |
| 1000 | 0 | .05 | .15 | .8 |
| 1050 | 0 | - | - | - |
| 1100 | 0 | .2 | .5 | - |
| 1150 | 0 | .35 | .95 | - |
| 1200 | .05 | .5 | 1 | 1 |

For the 90 psig case, the failures are dominated by the behavior of the material under high temperatures. Above 800°F the material begins to exhibit thermal creep in addition to enhanced plastic flow. The combination of high pressure (90 psig) and thermal softening causes the probability distribution curve to be steep in the initial stages of temperature where accelerated thermal effects occur. For the low pressure regime (<15 psig), the effects of high temperature described above become more dominant in the high temperature range when the pressure is low. This is reflected in a steep rise in the distribution curve in the 1000°F to 1200°F range. In both of these cases, the material properties are assumed to degrade by 90%.

For Case 3, the 1200°F curve was used. For case 4, since the pressure is nominal after other failures, DWL = .05 (i.e., 5 psig at 1200°F) was used.

Tables A-7, A-8, and A-9 contain the results of manipulating Expert A's conclusions for case 3B.

Table A-1
Results for Experiment A: Cases 1 and 2

| Pressure (psia) | Cumulative Probability | Conditional Probability of Failure in Mode i at Pressure j | | | | | | | | | | | | |
|--------------------|---------------------------|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | 100% MELB | MGRAN | WSPHS | CMAR | DWL | EMEL | DWR | EMER | CDWR | | | | |
| 90.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.0434 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 0.0975 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 0.1806 | 0.7550 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.2450 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 0.2800 | 0.7657 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.2343 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 0.5750 | 0.8898 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1102 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 0.8200 | 0.8565 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0435 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 0.9692 | 0.8527 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0519 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 160.0000 | 1.0000 | 0.6862 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0545 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 165.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1128 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 170.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.2122 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 175.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 180.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1433 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 185.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0968 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 190.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1340 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 195.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1331 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 200.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0755 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 205.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1304 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 210.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5526 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 215.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5769 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 220.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.7800 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 225.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.6043 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 230.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3718 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 235.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 240.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 245.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 250.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 255.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 260.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 265.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 270.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 275.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Table A-2
Expert A: Cases 1 and 2 Data Conversion

| Pressure (psig.) | Independent Cumulative Failure Probabilities for Modes | | | | | Cumulative Probability: All Modes | Cumulative Failure Probabilities for Remaining Modes | | |
|---------------------|--|--------|--------|--------|--------|---|--|--------|--------|
| | WMLM | DML | DWEL | WMLM | WMLM | | (1) | (2) | (3) |
| 90.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.0250 | 0.0000 | 0.0250 | 0.0000 | 0.0000 | 0.0494 | 0.0250 | 0.0250 | 0.0250 |
| 130.0000 | 0.0500 | 0.0000 | 0.0500 | 0.0000 | 0.0000 | 0.0975 | 0.0500 | 0.0500 | 0.0500 |
| 135.0000 | 0.1250 | 0.0000 | 0.0750 | 0.0000 | 0.0000 | 0.1906 | 0.0750 | 0.0750 | 0.0750 |
| 140.0000 | 0.2000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.2800 | 0.1000 | 0.1000 | 0.1000 |
| 145.0000 | 0.5000 | 0.0000 | 0.1500 | 0.0000 | 0.0000 | 0.5750 | 0.1500 | 0.1500 | 0.1500 |
| 150.0000 | 0.9000 | 0.0000 | 0.2000 | 0.0000 | 0.0000 | 0.8200 | 0.2000 | 0.2000 | 0.2000 |
| 155.0000 | 0.9800 | 0.0000 | 0.2750 | 0.1500 | 0.0000 | 0.9938 | 0.2750 | 0.2750 | 0.2750 |
| 160.0000 | 1.0000 | 0.0000 | 0.3500 | 0.5000 | 0.0000 | 1.0000 | 0.3500 | 0.3500 | 0.3500 |
| 165.0000 | 1.0000 | 0.1000 | 0.4250 | 0.8000 | 0.0000 | 1.0000 | 0.4250 | 0.4250 | 0.4250 |
| 170.0000 | 1.0000 | 0.2000 | 0.5000 | 0.8667 | 0.0000 | 1.0000 | 0.5000 | 0.5000 | 0.5000 |
| 175.0000 | 1.0000 | 0.3500 | 0.5750 | 0.9333 | 0.0000 | 1.0000 | 0.5750 | 0.5750 | 0.5750 |
| 180.0000 | 1.0000 | 0.5000 | 0.6500 | 1.0000 | 0.0000 | 1.0000 | 0.6500 | 0.6500 | 0.6500 |
| 185.0000 | 1.0000 | 0.8000 | 0.7250 | 1.0000 | 0.0000 | 1.0000 | 0.7250 | 0.7250 | 0.7250 |
| 190.0000 | 1.0000 | 0.9500 | 0.8000 | 1.0000 | 0.0000 | 1.0000 | 0.8000 | 0.8000 | 0.8000 |
| 195.0000 | 1.0000 | 0.9900 | 0.8375 | 1.0000 | 0.0000 | 1.0000 | 0.8375 | 0.8375 | 0.8375 |
| 200.0000 | 1.0000 | 1.0000 | 0.8750 | 1.0000 | 0.0000 | 1.0000 | 0.8750 | 0.8750 | 0.8750 |
| 205.0000 | 1.0000 | 1.0000 | 0.9125 | 1.0000 | 0.2500 | 1.0000 | 0.9125 | 0.9125 | 0.9125 |
| 210.0000 | 1.0000 | 1.0000 | 0.9500 | 1.0000 | 0.5000 | 1.0000 | 0.9500 | 0.9500 | 0.9500 |
| 215.0000 | 1.0000 | 1.0000 | 0.9583 | 1.0000 | 0.5250 | 1.0000 | 0.9583 | 0.9583 | 0.9583 |
| 220.0000 | 1.0000 | 1.0000 | 0.9667 | 1.0000 | 0.5500 | 1.0000 | 0.9667 | 0.9667 | 0.9667 |
| 225.0000 | 1.0000 | 1.0000 | 0.9750 | 1.0000 | 0.7250 | 1.0000 | 0.9750 | 0.9750 | 0.9750 |
| 230.0000 | 1.0000 | 1.0000 | 0.9833 | 1.0000 | 0.9000 | 1.0000 | 0.9833 | 0.9833 | 0.9833 |
| 235.0000 | 1.0000 | 1.0000 | 0.9917 | 1.0000 | 0.9500 | 1.0000 | 0.9917 | 0.9917 | 0.9917 |
| 240.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 245.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 250.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 255.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 260.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 265.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 270.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |
| 275.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 | 1.0000 |

(1) Without mode WMLM.
(2) Without modes WMLM and WMLM.
(3) Without modes WMLM, WMLM, DML, and WMLM.

Table A-3
Expert A's Conditional Probabilities: Cases 1 and 2

| Pressure [psi] | Conditional Failure Probability | | | | | Normalized Conditional Failure Probabilities | | | | |
|-------------------|---------------------------------|--------|--------|--------|--------|--|--------|--------|--------|--------|
| | W/Lah | DWL | DWEL | W/RW | DWR | W/Lah | DWL | DWEL | W/RW | DWR |
| 90.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 95.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 100.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 105.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 110.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 115.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 120.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 125.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 130.0000 | 0.5001 | 0.0000 | 0.5001 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 |
| 135.0000 | 0.7544 | 0.0000 | 0.2451 | 0.0000 | 0.0000 | 0.7550 | 0.0000 | 0.2450 | 0.0000 | 0.0000 |
| 140.0000 | 0.7662 | 0.0000 | 0.2344 | 0.0000 | 0.0000 | 0.7657 | 0.0000 | 0.2343 | 0.0000 | 0.0000 |
| 145.0000 | 0.8957 | 0.0000 | 0.1109 | 0.0000 | 0.0000 | 0.8898 | 0.0000 | 0.1107 | 0.0000 | 0.0000 |
| 150.0000 | 0.8758 | 0.0000 | 0.0444 | 0.0000 | 0.0000 | 0.8565 | 0.0000 | 0.0435 | 0.0000 | 0.0000 |
| 155.0000 | 0.8548 | 0.0000 | 0.0374 | 0.0000 | 0.0000 | 0.8627 | 0.0000 | 0.0319 | 0.0000 | 0.0000 |
| 160.0000 | 0.8862 | 0.0000 | 0.0345 | 0.0000 | 0.0000 | 0.8862 | 0.0000 | 0.0345 | 0.0000 | 0.0000 |
| 165.0000 | 0.0000 | 0.1018 | 0.1184 | 0.8281 | 0.0000 | 0.0000 | 0.0970 | 0.1129 | 0.7901 | 0.0000 |
| 170.0000 | 0.0000 | 0.1838 | 0.2180 | 0.6254 | 0.0000 | 0.0000 | 0.1790 | 0.2122 | 0.6088 | 0.0000 |
| 175.0000 | 0.0000 | 0.2046 | 0.1603 | 0.6385 | 0.0000 | 0.0000 | 0.1905 | 0.1493 | 0.6131 | 0.0000 |
| 180.0000 | 0.0000 | 0.1304 | 0.0988 | 0.6871 | 0.0000 | 0.0000 | 0.1114 | 0.0968 | 0.6871 | 0.0000 |
| 185.0000 | 0.0000 | 0.6381 | 0.1787 | 0.0000 | 0.0000 | 0.0000 | 0.5499 | 0.1540 | 0.0000 | 0.0000 |
| 190.0000 | 0.0000 | 0.6941 | 0.1827 | 0.0000 | 0.0000 | 0.0000 | 0.5057 | 0.1331 | 0.0000 | 0.0000 |
| 195.0000 | 0.0000 | 0.7231 | 0.1122 | 0.0000 | 0.0000 | 0.0000 | 0.4866 | 0.0755 | 0.0000 | 0.0000 |
| 200.0000 | 0.0000 | 0.4348 | 0.1304 | 0.0000 | 0.0000 | 0.0000 | 0.4348 | 0.1304 | 0.0000 | 0.0000 |
| 205.0000 | 0.0000 | 0.0000 | 0.5666 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5526 | 0.0000 | 0.0000 |
| 210.0000 | 0.0000 | 0.0000 | 0.6084 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5753 | 0.0000 | 0.0000 |
| 215.0000 | 0.0000 | 0.0000 | 0.7818 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.7800 | 0.0000 | 0.0000 |
| 220.0000 | 0.0000 | 0.0000 | 0.8068 | 0.0000 | 0.1962 | 0.0000 | 0.0000 | 0.8043 | 0.0000 | 0.1957 |
| 225.0000 | 0.0000 | 0.0000 | 0.3846 | 0.0000 | 0.6499 | 0.0000 | 0.0000 | 0.3718 | 0.0000 | 0.6282 |
| 230.0000 | 0.0000 | 0.0000 | 0.3280 | 0.0000 | 0.7653 | 0.0000 | 0.0000 | 0.3000 | 0.0000 | 0.7000 |
| 235.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 240.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 245.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 250.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 255.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 260.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 265.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 270.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |
| 275.0000 | 0.0000 | 0.0000 | 0.5556 | 0.0000 | 0.5556 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.5000 |

Due to small errors, the conditional probabilities calculated did not sum precisely to 1.0; therefore, normalized by sum.

Table A-5
Expert A: Case 3A Data Conversion

| Pressure (psig) | Independent Cumulative Failure Probabilities for Modes | | | | Cumulative Failure Probabilities All Modes | | | |
|--------------------|--|--------|--------|--------|--|--------|--------|--------|
| | WLaW | DWL | DWHL | WLaW | WLaW | WLaW | WLaW | WLaW |
| 60.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.0000 | 0.0000 | 0.0250 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0250 |
| 70.0000 | 0.0000 | 0.0000 | 0.0500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0500 |
| 75.0000 | 0.0000 | 0.0000 | 0.0750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0750 |
| 80.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1000 |
| 85.0000 | 0.0000 | 0.0000 | 0.1500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1500 |
| 90.0000 | 0.0000 | 0.0000 | 0.2000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.2000 |
| 95.0000 | 0.0000 | 0.0000 | 0.2750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.2750 |
| 100.0000 | 0.0000 | 0.0000 | 0.3500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.3500 |
| 105.0000 | 0.0000 | 0.0000 | 0.4250 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.4250 |
| 110.0000 | 0.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 |
| 115.0000 | 0.0000 | 0.0000 | 0.5750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5750 |
| 120.0000 | 0.0000 | 0.0000 | 0.6500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.6500 |
| 125.0000 | 0.0250 | 0.1000 | 0.7250 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.7587 |
| 130.0000 | 0.0500 | 0.2000 | 0.8000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.8480 |
| 135.0000 | 0.1250 | 0.3500 | 0.8375 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9076 |
| 140.0000 | 0.2000 | 0.5000 | 0.8750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9500 |
| 145.0000 | 0.5000 | 0.8000 | 0.9125 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9913 |
| 150.0000 | 0.9000 | 0.9500 | 0.9500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9998 |
| 155.0000 | 0.9500 | 0.9750 | 0.9583 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9999 |
| 160.0000 | 1.0000 | 1.0000 | 0.9667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 165.0000 | 1.0000 | 1.0000 | 0.9750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 170.0000 | 1.0000 | 1.0000 | 0.9833 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 175.0000 | 1.0000 | 1.0000 | 0.9917 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 180.0000 | 1.0000 | 1.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |

Table A-5
Expert A's Conditional Probabilities: Cases 3A

| Pressure (PSIA) | Conditional Failure Probability | | | | | Normalized Conditional Failure Probabilities | | | | |
|--------------------|---------------------------------|--------|--------|--------|--------|--|--------|--------|--------|--------|
| | WMT-AM | WMT-ML | WMT-RH | WMT-RW | DMR | WMT-AM | WMT-ML | WMT-RH | WMT-RW | DMR |
| 60.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 70.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 75.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 80.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 85.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 90.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.0689 | 0.2863 | 0.0000 | 0.0000 | 0.0000 | 0.0683 | 0.2841 | 0.6475 | 0.0000 | 0.0000 |
| 130.0000 | 0.0572 | 0.2580 | 0.0000 | 0.0000 | 0.0000 | 0.0565 | 0.2561 | 0.6874 | 0.0000 | 0.0000 |
| 135.0000 | 0.1686 | 0.4244 | 0.0000 | 0.0000 | 0.0000 | 0.1657 | 0.4171 | 0.4171 | 0.0000 | 0.0000 |
| 140.0000 | 0.1503 | 0.4379 | 0.0000 | 0.0000 | 0.0000 | 0.1465 | 0.4268 | 0.4268 | 0.0000 | 0.0000 |
| 145.0000 | 0.3287 | 0.6104 | 0.2513 | 0.0000 | 0.0000 | 0.2761 | 0.5128 | 0.2111 | 0.0000 | 0.0000 |
| 150.0000 | 0.7039 | 0.5353 | 0.2868 | 0.0000 | 0.0000 | 0.4331 | 0.3898 | 0.1772 | 0.0000 | 0.0000 |
| 155.0000 | 0.5086 | 0.5088 | 0.1383 | 0.0000 | 0.0000 | 0.4400 | 0.4400 | 0.1200 | 0.0000 | 0.0000 |
| 160.0000 | 0.4444 | 0.4444 | 0.1111 | 0.0000 | 0.0000 | 0.4444 | 0.4444 | 0.1111 | 0.0000 | 0.0000 |
| 165.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 170.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 175.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 180.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |

Due to small errors, the conditional probabilities calculated did not sum precisely to 1.0; therefore, normalized by sum.

Table A-8
Expert A: Case 3B Data Conversion

| Pressure (psig) | Independent Cumulative Failure Probabilities for Modes | | | | | | Cumulative Failure Probabilities: All Modes |
|--------------------|--|--------|--------|--------|--------|--------|---|
| | W/LaW | DWL | DWHL | W/RaW | W/RbW | DWR | |
| 5.0000 | 0.0000 | 0.0500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0500 |
| 10.0000 | 0.0000 | 0.5000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.5000 |
| 15.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 20.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 25.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 30.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 35.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 40.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 45.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 50.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 55.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 60.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 65.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 70.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 75.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 80.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 85.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 90.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 95.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 100.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 105.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 110.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 115.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 120.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 125.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 130.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 135.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 140.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 145.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 150.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 155.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 160.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 165.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 170.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 175.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 180.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |

Table A-9
 Expert A's Conditional Probabilities: Case 3B

| Pressure (psig) | Independent Cumulative Failure Probabilities for Modes | | | | | |
|--------------------|--|--------|--------|--------|--------|--------|
| | WLaW | DWL | DWHL | WRaW | WRbW | DWR |
| 5.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 10.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 15.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 20.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 25.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 30.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 35.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 40.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 45.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 50.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 55.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 60.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 70.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 75.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 80.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 85.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 90.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 160.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 165.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 170.0 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 175.0 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 180.00_0 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Expert B's Elicitation

Peach Bottom Containment Failure

Description of Expert B's Rationale/Methodology

The Expert defined ten failure mode/locations and gave probability curves versus pressure for each mode for each case. The values in each column are joint probabilities of failure in each mode given no failure at lower pressures.

For cases 1 and 2, Expert B gave the following tabular information:

| Modes | Pressure (psig) | | | | | | |
|-------|-----------------|------|------|------|------|------|------|
| | 90 | 110 | 135 | 160 | 170 | 180 | 195 |
| WWLaW | 0.0 | 0.02 | 0.04 | 0.06 | 0.07 | 0.07 | 0.07 |
| WWLbW | 0.0 | 0.0 | 0.02 | 0.03 | 0.05 | 0.05 | 0.05 |
| WWRaW | 0.0 | 0.02 | 0.02 | 0.07 | 0.09 | 0.12 | 0.12 |
| WWRbW | 0.0 | 0.0 | 0.02 | 0.05 | 0.04 | 0.07 | 0.07 |
| CWWR | 0.0 | 0.0 | 0.02 | 0.12 | 0.16 | 0.35 | 0.38 |
| DWL | 0.0 | 0.01 | 0.01 | 0.03 | 0.06 | 0.06 | 0.06 |
| DWHL | 0.0 | 0.01 | 0.02 | 0.05 | 0.08 | 0.12 | 0.14 |
| DWR | 0.0 | 0.0 | 0.01 | 0.01 | 0.01 | 0.04 | 0.04 |
| DWHR | 0.0 | 0.0 | 0.01 | 0.01 | 0.01 | 0.05 | 0.05 |
| CDWR | 0.0 | 0.0 | 0.0 | 0.0 | 0.01 | 0.02 | 0.02 |
| Total | 0.0 | 0.06 | 0.17 | 0.43 | 0.58 | 0.95 | 1.00 |

Comments for cases 1 and 2:

No chance of failure until 90 psig based on engineering judgment. In the pressure range from 150 to 180 psig, the probabilities are based on calculations and reports which are based on all types of pressure vessels. As the pressure increases there is more energy to tear the steel and, thus, there is a greater chance for rupture. With less stored energy, it is possible to arrest a crack and maintain a leak. For Case 2, the pressure rise is slow enough to be considered static and therefore is the same as Case 1. In order to calculate the cumulative failure probability, use the formula:

$$p(\text{fail by } p_i) = p(\text{fail by } p_{i-1}) + p(\text{fail between } p_{i-1} < p < p_i) * p(\text{not failing by } p_{i-1}).$$

The cumulative is then: PT(90)=0, PT(110)=.06, PT(135)=.2198, PT(160)=.5553, PT(170)=.8132, PT(180)=.9907, PT(195)=1.0000.

The conditional probability of failure at pressure i in mode j is the probability at pressure i for mode j divided by the total conditional at pressure i.

Linear interpolation between points and, in order to extend the curves on the upper side, it was assumed that the conditional probabilities remain fixed above 165 psig. The results for cases 1 and 2 are shown in Table B-1.

Case 3

Expert B indicated that this case is more complicated due to the effects of temperature. To treat this case properly, the expert stated that he would need pressure and temperature histories. The expert divided the temperature range into two regions centered on 800 and 1200°F. For both cases, the wetwell temperature is limited to the suppression pool saturation temperature (300 to 350°F). The expert indicated that when the drywell temperature exceeded the wetwell temperature, there was a greater likelihood that failure would occur in the drywell.

For case 3a, Expert B gave the following probabilities:

| Modes | Pressure (psig) | | | | | |
|-------|-----------------|------|------|------|------|------|
| | 75 | 95 | 115 | 135 | 150 | 165 |
| WWLaW | 0.0 | 0.0 | 0.02 | 0.05 | 0.06 | 0.06 |
| WWLbW | 0.0 | 0.0 | 0.01 | 0.02 | 0.03 | 0.03 |
| WWRaW | 0.0 | 0.0 | 0.02 | 0.03 | 0.06 | 0.06 |
| WWRbW | 0.0 | 0.0 | 0.0 | 0.03 | 0.04 | 0.04 |
| CWWR | 0.0 | 0.0 | 0.0 | 0.09 | 0.13 | 0.14 |
| DWL | 0.0 | 0.01 | 0.02 | 0.04 | 0.05 | 0.05 |
| DWHL | 0.0 | 0.02 | 0.05 | 0.09 | 0.16 | 0.18 |
| DWR | 0.0 | 0.0 | 0.0 | 0.01 | 0.05 | 0.05 |
| DWHR | 0.0 | 0.0 | 0.0 | 0.01 | 0.36 | 0.38 |
| CDWR | 0.0 | 0.0 | 0.0 | 0.0 | 0.01 | 0.01 |
| Total | 0.0 | 0.03 | 0.12 | 0.37 | 0.95 | 1.00 |

The cumulative is $PT(75)=0$, $PT(95)=.03$, $PT(115)=.1464$, $PT(135)=.4622$, $PT(150)=.9/31$, $PT(165)=1.0$.

Case 3a assumes 800°F in drywell and 300°F in wetwell. The failure probability is based on a one hour exposure to 800°F. The yield strength at this temperature is approximately 85% of that at ambient temperatures. The general trend is an increase in the probability of failure with an increase in temperature. There could be some cases, however, where higher temperatures do not necessarily mean higher failure probability (e.g., the thermal growth of the drywell shell may help if the shell impinges on the concrete wall; this is a secondary effect). At this temperature, an increase in exposure time to 24 h would not change these probabilities.

Interpolation was used to form Table B-2.

For case 3b, Expert B provided the following conclusions:

| Modes | Pressure (psig) | | | | |
|-------|-----------------|------|------|------|------|
| | 25 | 40 | 50 | 55 | 60 |
| WWLaw | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| WWLbW | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| WWRaW | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| WWRbW | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| CWWR | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| DWL | 0.0 | 0.01 | 0.08 | 0.10 | 0.10 |
| DWHL | 0.0 | 0.24 | 0.28 | 0.30 | 0.31 |
| DWR | 0.0 | 0.0 | 0.03 | 0.05 | 0.05 |
| DWHR | 0.0 | 0.0 | 0.23 | 0.50 | 0.52 |
| CDWR | 0.0 | 0.0 | 0.0 | 0.02 | 0.02 |
| Total | 0.0 | 0.25 | 0.62 | 0.97 | 1.00 |

The cumulative is PT(25)=0, PT(40)=.25, PT(50)=.7150, PT(55)=.9915, PT(60)=1.0.

Case 3b assumes 1200°F in the drywell and 350°F in the wetwell. Failure will occur in the drywell at lower pressures than those that could cause failure in the wetwell. The yield strength at this temperature is approximately 30% of that at ambient temperatures. The likely leakage would be at flange openings and degraded seals and gaskets. Failure probabilities are based on one hour of exposure. With 24 h of exposure, the leak modes (6 and 7) may change to rupture. Given leak modes in 1 h at 60 psig and additional exposure, these will definitely change to rupture. The change will occur at 50 psig. However, a leak will depressurize the containment in 2 h so no additional failure occurs. Case 3b results are shown in Table B-3.

| | | |
|-------|----|----|
| MODE | 50 | 60 |
| DWR | .2 | .2 |
| DWHR | .5 | .5 |
| CDWR | .2 | .3 |
| Total | .9 | 1 |

For case 4, Expert B provided the following probabilities for different temperatures.

| <u>Mode</u> | <u>1 Hour</u> | | | | | | <u>24 Hours</u> | |
|-------------|-------------------------|------------|------------|-------------|-------------|-------------|------------------------|-------------|
| | <u>Temperature (°F)</u> | | | | | | <u>Temperature(°F)</u> | |
| | <u>600</u> | <u>800</u> | <u>900</u> | <u>1000</u> | <u>1100</u> | <u>1200</u> | <u>1000</u> | <u>1200</u> |
| DWL | 0.0 | 0.1 | 0.18 | 0.2 | 0.22 | 0.25 | 0.24 | 0.3 |
| DWHL | 0.0 | 0.0 | 0.0 | 0.0 | 0.03 | 0.04 | 0.0 | 0.15 |
| DWR | 0.0 | 0.05 | 0.08 | 0.13 | 0.25 | 0.32 | 0.17 | 0.3 |
| DWHR | 0.0 | 0.0 | 0.0 | 0.0 | 0.01 | 0.02 | 0.0 | 0.15 |
| CDWR | 0.0 | 0.0 | 0.0 | 0.01 | 0.02 | 0.06 | 0.01 | 0.10 |
| Total | 0.0 | 0.15 | 0.26 | 0.34 | 0.53 | 0.69 | 0.42 | 1.0 |

Case 4 assumes that containment failure has already occurred so that pressure is low and assesses that probability of additional failure due to high drywell temperatures for exposure times of 1 and 24 h. The composite probabilities at 900 and 1000°F are based on high temperature analyses performed by the expert. At 1200°F, the failure mode will be catastrophic failure caused by thermal buckling. For this analysis, the values at 1200°F for case 4 are used.

Sources of Uncertainty

The expert indicated that the major sources of uncertainty in his assessment were uncertainties in the material properties and the uncertainty in fabrication details. For example, there could be residual stresses around welds or areas of local stress concentration which could affect the strength of the containment. For Case 3, the expert said that to treat the problem properly, he would need the time histories of pressure and temperature. Not knowing these introduces some additional uncertainty into the results.

Some of the uncertainty for Case 3 could be removed if typical pressure and temperature histories from thermal-hydraulic codes could be supplied for the scenarios of interest.

Table B-1
Results of Expert B: Cases 1 and 2

| Pressure (psia) | Cumulative Probability | Conditional Probability of Failure in Mode I at Pressure J | | | | | | | | | | | | |
|--------------------|---------------------------|--|--------------------|--------------------|--------------------|--------------------|--------------------|--------|--------|--------|--------|--------|--------|--------|
| | | WML ₁ W | WML ₂ W | WRL ₁ W | WRL ₂ W | WRL ₃ W | WRL ₄ W | DMR | EMER | CMR | DMR | | | |
| 95.0000 | 0.0000 | 0.3333 | 0.0000 | 0.3333 | 0.0000 | 0.0000 | 0.1667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0150 | 0.3333 | 0.0000 | 0.3333 | 0.0000 | 0.3333 | 0.1667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0300 | 0.3333 | 0.0000 | 0.3333 | 0.0000 | 0.3333 | 0.1667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0450 | 0.3333 | 0.0000 | 0.3333 | 0.0000 | 0.3333 | 0.1667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0600 | 0.3333 | 0.0000 | 0.3333 | 0.0000 | 0.3333 | 0.1667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0920 | 0.3137 | 0.0235 | 0.2902 | 0.0235 | 0.2902 | 0.1451 | 0.0235 | 0.0235 | 0.0235 | 0.0118 | 0.0118 | 0.0118 | 0.0000 |
| 120.0000 | 0.1239 | 0.2941 | 0.0470 | 0.2470 | 0.0471 | 0.2470 | 0.1235 | 0.0471 | 0.0471 | 0.0471 | 0.0235 | 0.0235 | 0.0235 | 0.0000 |
| 125.0000 | 0.1559 | 0.2745 | 0.0706 | 0.2039 | 0.0706 | 0.2039 | 0.1020 | 0.0706 | 0.0706 | 0.0706 | 0.0352 | 0.0352 | 0.0352 | 0.0000 |
| 130.0000 | 0.1878 | 0.2549 | 0.0941 | 0.1607 | 0.0942 | 0.1607 | 0.0804 | 0.0942 | 0.0942 | 0.0942 | 0.0470 | 0.0470 | 0.0470 | 0.0000 |
| 135.0000 | 0.2198 | 0.2353 | 0.1176 | 0.1176 | 0.1177 | 0.1176 | 0.0588 | 0.1177 | 0.1177 | 0.1177 | 0.0588 | 0.0588 | 0.0588 | 0.0000 |
| 140.0000 | 0.2869 | 0.2161 | 0.1080 | 0.1266 | 0.1174 | 0.1266 | 0.0610 | 0.1174 | 0.1174 | 0.1174 | 0.0517 | 0.0517 | 0.0517 | 0.0000 |
| 145.0000 | 0.3540 | 0.1970 | 0.0985 | 0.1357 | 0.1171 | 0.1357 | 0.0632 | 0.1171 | 0.1171 | 0.1171 | 0.0446 | 0.0446 | 0.0446 | 0.0000 |
| 150.0000 | 0.4211 | 0.1778 | 0.0889 | 0.1447 | 0.1169 | 0.1447 | 0.0654 | 0.1170 | 0.1170 | 0.1170 | 0.0374 | 0.0374 | 0.0374 | 0.0000 |
| 155.0000 | 0.4882 | 0.1587 | 0.0794 | 0.1538 | 0.1166 | 0.1538 | 0.0676 | 0.1165 | 0.1165 | 0.1165 | 0.0303 | 0.0303 | 0.0303 | 0.0000 |
| 160.0000 | 0.5553 | 0.1395 | 0.0698 | 0.1628 | 0.1163 | 0.1628 | 0.0698 | 0.1163 | 0.1163 | 0.1163 | 0.0232 | 0.0232 | 0.0232 | 0.0000 |
| 165.0000 | 0.6842 | 0.1301 | 0.0782 | 0.1590 | 0.0927 | 0.1590 | 0.0866 | 0.1271 | 0.1271 | 0.1271 | 0.0202 | 0.0202 | 0.0202 | 0.0086 |
| 170.0000 | 0.8132 | 0.1207 | 0.0862 | 0.1552 | 0.0690 | 0.1552 | 0.1034 | 0.1379 | 0.1379 | 0.1379 | 0.0172 | 0.0172 | 0.0172 | 0.0173 |
| 175.0000 | 0.9019 | 0.0972 | 0.0694 | 0.1498 | 0.0714 | 0.1498 | 0.0833 | 0.1321 | 0.1321 | 0.1321 | 0.0297 | 0.0297 | 0.0297 | 0.0192 |
| 180.0000 | 0.9907 | 0.0737 | 0.0526 | 0.1263 | 0.0737 | 0.1263 | 0.0632 | 0.1263 | 0.1263 | 0.1263 | 0.0421 | 0.0421 | 0.0421 | 0.0211 |
| 185.0000 | 0.9938 | 0.0725 | 0.0517 | 0.1242 | 0.0725 | 0.1242 | 0.0621 | 0.1309 | 0.1309 | 0.1309 | 0.0414 | 0.0414 | 0.0414 | 0.0207 |
| 190.0000 | 0.9969 | 0.0712 | 0.0509 | 0.1221 | 0.0712 | 0.1221 | 0.0611 | 0.1354 | 0.1354 | 0.1354 | 0.0407 | 0.0407 | 0.0407 | 0.0204 |
| 195.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 200.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 205.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 210.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 215.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 220.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 225.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 230.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 235.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 240.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 245.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 250.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 255.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 260.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 265.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 270.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |
| 275.0000 | 1.0000 | 0.0700 | 0.0500 | 0.1200 | 0.0700 | 0.1200 | 0.0600 | 0.1400 | 0.1400 | 0.1400 | 0.0400 | 0.0400 | 0.0400 | 0.0200 |

Expert C's Elicitation

Peach Bottom Containment Failure

Description of Expert C's Rationale/Methodology

Expert C limited his investigation to consideration of membrane stress; i.e., bending and thermal stresses were assumed to be self-limiting, which implied that they would not affect capacity. The membrane stresses were based on calculations documented in References C-1 and C-2 with extrapolations to higher pressures based on the equations for membrane stresses of various shells of revolution given in Reference C-3. Although it was recognized that failure initiates due to strain concentrations at design details, the equivalent free-field equivalent membrane strain was used to estimate the failure pressure. Based on the results of testing scale steel containment models^{C-4, C-5} the following approximate criteria were used.

No failure. The point at which membrane yielding of a steel plate section is first calculated to occur when beam and ring stiffeners are ignored.

Low probability of failure. General yield of section based on axisymmetric finite element calculations which include stiffeners and other local supports.

Median estimate. The point at which 1 to 2% equivalent strain arises in some section of the torus.

High probability of failure. The point at which 5% equivalent strain arises in some section of the torus.

Certain failure. The pressure at which membrane stress in the weakest plate section reaches the ultimate stress of the material.

The failure size depends on the growth of the initial crack. It was assumed that a crack is arrested only if it enters a region of plate material that is still elastic as determined from the membrane stresses.

In the wetwell, the maximum membrane stress occurs in the 0.504-in. plate just above the waterline, and consequently this is where failure is most likely to initiate. There is a small chance that a tear could initiate below the waterline. At higher pressure, a greater percentage of the wetwell plates are inelastic and an initial crack is more likely to grow; thus there is a higher probability of rupture.

In the drywell, contact with the shield building, which could impart additional strength to the shell, cannot be explicitly taken into account. To compensate for the effect of the shield building, the probability of drywell shell failure at low strains was decreased compared to the assumptions made for the wetwell. Since the membrane stress is uniform over a number of large areas in the drywell shell, the failure size is

almost sure to correspond to rupture (catastrophic failure was felt to be precluded by interaction with the shield building).

The Expert assessed all four cases together by giving failure curves versus pressure for various temperatures.

Wetwell Failure

| Pressure | Cum. Failure | Failure Pt. Pres. | Conditional Probability At Pressure | | | |
|----------|--------------|-------------------|-------------------------------------|--------|--------|--------|
| | | | WFLaW | WFLbW | WWRaW | WWRbW |
| 125 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 140 | 0.01 | 0.01 | 0.9 | 0.1 | 0.0 | 0.0 |
| 150 | 0.2585 | 0.251 | 0.8088 | 0.0916 | 0.0199 | 0.0797 |
| 165 | 0.6307 | 0.502 | 0.2251 | 0.0259 | 0.0757 | 0.6733 |
| 170 | 0.9084 | 0.752 | 0.0904 | 0.0107 | 0.0452 | 0.8537 |
| 180 | 0.9955 | 0.951 | 0.0904 | 0.0105 | 0.0 | 0.8991 |
| 260 | 1.0 | 0.999 | 0.0 | 0.0 | 0.0 | 1.0 |

Assessed temperature in wetwell will be in 400°F range for all cases; therefore, only one curve.

Drywell Rupture (DWR)

| GDF | 200°F | 400°F | 600°F | 800°F | 1000°F | 1200°F |
|-----|-------|-------|-------|-------|--------|--------|
| 0 | 155 | 150 | 125 | 105 | 90 | 58 |
| .25 | 175 | 170 | 155 | 120 | 100 | 60 |
| .5 | 190 | 190 | 190 | 170 | 110 | 63 |
| .75 | 240 | 240 | 250 | 200 | 120 | 66 |
| 1 | 270 | 280 | 290 | 225 | 130 | 68 |

The 400°F, 800°F, and 1200°F curves were used for cases 1 and 2, 3a and 4a, and 3b and 4b, respectively.

For drywell head failure, the expert gave a FORTRAN program to calculate the failure pressure based on his uncertainty in the underlying parameters: $DT = T(\text{ave flange temp}) - T(\text{ave bolt temp})$, $F_1 = \text{applied mechanical preload}$, $S_p = \text{seal performance parameter}$. All other parameters were considered reasonably well known.

| | | | | | | | |
|--------------------|----|------|-----|-----|-----|------|-----|
| DT(°F) | 10 | 25 | 60 | 75 | 87 | 150 | 200 |
| cdf(<600) | 0 | .025 | .25 | .50 | .75 | .975 | 1.0 |
| DT(°F) | 10 | 60 | 100 | 120 | 150 | 165 | 200 |
| cdf(> = 600) | 0 | .125 | .25 | .50 | .75 | .875 | 1.0 |
| $F_1(\text{kips})$ | 75 | 95 | 100 | 107 | 125 | | |
| cdf | 0 | .25 | .50 | .75 | 1.0 | | |

| | | | | | | | |
|--------------|---|-----|-----|----|-----|------|-----|
| S_p (mils) | 0 | 6 | 12 | 15 | 25 | 35 | 40 |
| cdf | 0 | .01 | .25 | .5 | .75 | .999 | 1.0 |

| | | | | | | |
|--------------|---|-----|----|-----|------|-----|
| S_p (mils) | 0 | 6 | 8 | 10 | 15 | 40 |
| cdf | 0 | .05 | .5 | .95 | .999 | 1.0 |

The FORTRAN program was modified to allow an LHS sample of one hundred for DT , F_1 , and S_p to be used to evaluate the probability of a certain size leak for different drywell temperatures at different pressures. The results were then analyzed to obtain the cumulative failure probability and the conditional probability of leak versus rupture at a temperature for the various pressures. The FORTRAN program is listed below:

```

PROGRAM LEAKAREA
  DIMENSION EF(12), EB(12), EBT(12), EPSF(12), EPSB(12),
    T(12), SIGY(12)
  DIMENSION ALHS(5,100)
  REAL KF, KBE, KBT, L, LA, LAMIN, LAMAX, LAINC, MULT1,
    MULT2, N, T3, NU
C
C THIS PROGRAM CALCULATES THE LEAK AREA OF A PRESSURE UNSEATING
C HATCH AT A GIVEN TEMPERATURE AND PRESSURE FOR AN LHS SAMPLE OF
C THE BOLT PRELOAD, THE SEAL SPRINGBACK, AND THE DELTA T BETWEEN
C THE FLANGE AND THE BOLT
C
C DATA FOR PHYSICAL PARAMETERS
C
C T = THE FLANGE TEMPERATURE
C EF = THE ELASTIC MODULI FOR THE FLANGE MATERIAL
C EB = THE ELASTIC MODULI FOR THE BOLT MATERIAL IF THE PRESSURE
C IS LESS THAN THE BOLT YIELD PRESSURE
C EBT = THE ELASTIC MODULI FOR THE BOLT IF THE PRESSURE IS
C GREATER THAN THE BOLT YIELD PRESSURE
C EPSF = THERMAL STRAINS FOR FLANGE MATERIAL
C EPSB = THERMAL STRAINS FOR BOLT MATERIAL
C SIGY = YIELD STRENGTHS FOR BOLT MATERIAL (IN KSI)
C
  DATA T/ 70., 200., 300., 400., 500., 600., 700., 800.,
    900., 1000., 1100., 1200./
  DATA EF/ 27.9E6, 27.8E6, 27.4E6, 27.0E6, 26.4E6, 25.7E6,
    24.8E6, 23.4E6, 21.8E6, 20.6E6, 18.3E6, 17.0E6/
  DATA EB/ 2*31.5E6, 31.2E6, 30.9E6, 30.4E6, 29.9E6, 29.4E6,
    28.8E6, 28.1E6, 27.0E6, 25.9E6, 24.5E6/
  DATA EBT/ 7*200.E3, 180.E3, 150.E3, 100.E3, 60.E3, 30.E3/
  DATA EPSF/ 0., .00076, .00141, .00214, .00295, .00383,
    .00474, .00567, .00662, .00759, .00860, .00962/
  DATA EPSB/ 0., .00082, .00153, .00224, .00295, .00370,
    .00453, .00540, .00630, .00720, .00820, .00920/
  DATA SIGY/ 105., 102.7, 99., 95.5, 90.1, 83.8, 76.6, 73.6,
    65.5, 58., 50., 40./
  OPEN(UNIT=20, FILE='LHSLEAKAREA.OUT', STATUS='NEW', FORM=
    'FORMATTED')

```

```

C DEFAULT DATA FOR PEACH BOTTOM DRYWELL HEAD FOLLOWS
C
C N = THE NUMBER OF BOLTS
C A = THE TENSILE AREA OF ONE BOLT
C L = THE GRIP LENGTH
C R = THE FLANGE RADIUS
C THICK = THE FLANGE THICKNESS
C NU = POISSON'S RATIO
C
      N = 68
      A = 4.292
      L = 36.
      R = 194.
      THICK = 1.25
      NU = 0.3
C
C READ LHS FILE
C
      OPEN(UNIT = 55, STATUS = 'OLD', FILE = 'LHS.DAT')
      DO I = 1, 100
        READ(55,*) II, JJ, (ALHS(J,I), J= 1, 5)
      END DO
C
C LOOP ON FLANGE TEMPERATURE
C
      10 DO I=2,12
          TF = T(I)
C
C LOOP ON PRESSURE 5 PSIG INCRMENTS
C
      20 DO J = 50, 280, 5
          PRES = J
C
C LOOP ON LHS SAMPLE
C
      30 DO K =1,100
          KF = 6.28*R*THICK*EF(1)/L
          IF(TF.LT.600.0) THEN
            DT= ALHS(1,K)
            F = ALHS(3,K)*1E3
            S = ALHS(4,K)*1E-3
          ELSE
            DT = ALHS(2,K)
            F = ALHS(3,K)*1E3
            S = ALHS(5,K)*1E-3
          END IF
          TB = TF*DT
C
C INTERPOLATE MATERIAL PROPERTIES FOR BOLT AS NECESSARY
C

```

```

40      DO II = 1,12
        IF(TB.LE.T(II)) THEN
          II=II-1
          I2=II
          COEF1 = (T(I2)-TB)/(T(I2)-T(II))
          COEF2 = (TB-T(II))/(T(I2)-T(II))
          EBI = COEF1*EB(I1) + COEF2*EB(I2)
          EBTI = COEF1*EBT(I1) + COEF2*EBT(I2)
          DELTAEPS = EPSF(I) * COEF1 + COEF2*EPS(I2)
          SIGMAY = 1000.*(COEF1*SIGMA(I1) + COEF2*SIGMA(I2))
          KBE = N*A*EBI/L
          KBT = N*A*EBTI/L
          MULT1 = KBE/(3.14*R**2)
          MULT2 = 1 + 2*NU*KBE/KF
          MULT3 = (KBE+KF)/(KBE*KF*MULT2)
          MULT4 = KBT/(3.14*R**2)
          YPRES = (N*SIGMAY*A)/(3.14*R**2)
          END IF
        END DO

C
C CALCULATE LEAK AREA AS A FUNCTION OF PRESS FOR VARIOUS VALUES
C OF DT, F, AND S
C
      IF(PRES.LE.YPRES) THEN
        Z1 = PRES/MULT1
      ELSE
        Z1 = YPRES/MULT1 + (PRES-YPRES)/MULT4
      END IF
      Z2 = MULT3*F
      Z3 = (DELTAEPS*L)/MULT2
      LA = (6.28*R)*(Z1 - Z2 - Z3 - S)

C
C IF THE LEAK AREA IS LESS THAN ZERO THEN SET TO ZERO
C
      IF(LA.LE.0.) LA = 0

C
C WRITE THE VARIABLES TF, PRES, LA
C
      60  WRITE(20,*) TF, PRES, LA
        END DO
      END DO
      END DO
      STOP
      END

```

The result of running this program is a set of tables for each pressure giving, for different temperatures, the cumulative distribution for leak areas. For the case of an unsaturated pool a leak is < 4 in.²; for a saturated pool a leak is less than 255 sq in. From these program output tables, we can construct tables for a particular temperature showing the cumulative probability of failure by pressure *i* and the conditional probability of leak versus rupture. However, the expert said that the

process by which failure occurs is that the area will increase to the point that it just releases the pressure and is, therefore, always a leak. So only the cumulative failure probability was used with all failures assessed as leaks except in the 1200°F case when the failure pressure exceeded the yield strength.

| <u>Pressure</u> | <u>At 400°F</u> | <u>At 800°F</u> | <u>At 1200°F</u> | | |
|-----------------|-------------------|-------------------|-------------------|-------------|----------------|
| | <u>Cum. Fail.</u> | <u>Cum. Fail.</u> | <u>Cum. Fail.</u> | <u>Leak</u> | <u>Rupture</u> |
| 50 | 0.0 | 0.0 | 0.03 | 1.0 | 0.0 |
| 55 | 0.0 | 0.01 | 0.05 | 1.0 | 0.0 |
| 60 | 0.0 | 0.03 | 0.09 | 1.0 | 0.0 |
| 65 | 0.0 | 0.03 | 0.12 | 1.0 | 0.0 |
| 70 | 0.0 | 0.04 | 0.14 | 1.0 | 0.0 |
| 75 | 0.0 | 0.07 | 0.15 | 1.0 | 0.0 |
| 80 | 0.0 | 0.09 | 0.18 | 1.0 | 0.0 |
| 85 | 0.0 | 0.12 | 0.21 | 1.0 | 0.0 |
| 90 | 0.0 | 0.14 | 0.24 | 1.0 | 0.0 |
| 95 | 0.0 | 0.15 | 0.32 | 1.0 | 0.0 |
| 100 | 0.0 | 0.18 | 0.42 | 1.0 | 0.0 |
| 105 | 0.01 | 0.21 | 0.46 | 0.93 | 0.07 |
| 110 | 0.01 | 0.24 | 0.56 | 0.84 | 0.16 |
| 115 | 0.01 | 0.25 | 0.65 | 0.80 | 0.20 |
| 120 | 0.01 | 0.30 | 0.70 | 0.35 | 0.65 |
| 125 | 0.02 | 0.38 | 0.79 | 0.63 | 0.37 |
| 130 | 0.04 | 0.46 | 0.84 | 0.37 | 0.63 |
| 135 | 0.05 | 0.52 | 0.90 | 0.23 | 0.77 |
| 140 | 0.09 | 0.60 | 0.95 | 0.11 | 0.89 |
| 145 | 0.13 | 0.65 | 0.98 | 0.05 | 0.95 |
| 150 | 0.15 | 0.70 | 1.0 | 0.0 | 1.0 |
| 155 | 0.19 | 0.75 | | | |
| 160 | 0.32 | 0.81 | | | |
| 165 | 0.37 | 0.85 | | | |
| 170 | 0.43 | 0.90 | | | |
| 175 | 0.48 | 0.95 | | | |
| 180 | 0.53 | 0.97 | | | |
| 185 | 0.59 | 0.98 | | | |
| 190 | 0.63 | 0.98 | | | |
| 195 | 0.67 | 1.0 | | | |
| 200 | 0.73 | 1.0 | | | |
| 205 | 0.77 | 1.0 | | | |

| <u>Pressure</u> | <u>At 400°F</u> | <u>At 800°F</u> | <u>At 1200°F</u> | | |
|-----------------|-------------------|-------------------|-------------------|-------------|----------------|
| | <u>Cum. Fail.</u> | <u>Cum. Fail.</u> | <u>Cum. Fail.</u> | <u>Leak</u> | <u>Rupture</u> |
| 210 | 0.81 | 1.0 | - | - | - |
| 215 | 0.83 | 1.0 | - | - | - |
| 220 | 0.84 | 1.0 | - | - | - |
| 225 | 0.88 | 1.0 | - | - | - |
| 230 | 0.91 | 1.0 | - | - | - |
| 235 | 0.92 | 1.0 | - | - | - |
| 240 | 0.92 | 1.0 | - | - | - |
| 245 | 0.93 | 1.0 | - | - | - |
| 250 | 0.93 | 1.0 | - | - | - |
| 255 | 0.95 | 1.0 | - | - | - |
| 260 | 0.96 | 1.0 | - | - | - |

The Expert C said that unless the maximum pressure exceeded the yield pressure that the leak area would decrease if the pressure decreased.

In order to calculate the total cumulative failure probability curve and the conditional probabilities, the same method was used as for Expert A. The three curves for wetwell, drywell, and drywell head were combined and conditionals calculated. The wetwell conditional was split in proportion to the splits given by the expert. For Case 4, the expert's results imply that no additional failure will occur since at least 50 psig is needed to get failure and, in this case, the pressure will be near atmospheric.

Tables C-1 through C-9 contain the results of Expert C's elicitation.

Table C-1
Results of Expert C: Cases 1 and 2

| Pressure (PSI.K) | Cumulative Failure Probability | WFLM | WFLW | WFLM | WFLW | MFLM | MFLW | CMR | DML | DML | DMR | DMR | CMR |
|---------------------|--------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | | | | | | | | | | | | |
| 90.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0100 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0125 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0150 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.0175 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.0200 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 0.0432 | 0.1243 | 0.0138 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 0.0564 | 0.2214 | 0.0246 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 0.0991 | 0.0646 | 0.0717 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 0.2468 | 0.6398 | 0.0717 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 0.3697 | 0.7030 | 0.0796 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 0.5312 | 0.3795 | 0.0431 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 160.0000 | 0.7064 | 0.2008 | 0.0228 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 165.0000 | 0.8110 | 0.1478 | 0.0170 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 170.0000 | 0.9508 | 0.0767 | 0.0092 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 175.0000 | 0.9828 | 0.0703 | 0.0082 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 180.0000 | 0.9987 | 0.0808 | 0.0094 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 185.0000 | 0.9990 | 0.0179 | 0.0021 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 190.0000 | 0.9993 | 0.0189 | 0.0022 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 195.0000 | 0.9994 | 0.0227 | 0.0026 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 200.0000 | 0.9996 | 0.0162 | 0.0019 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 205.0000 | 0.9997 | 0.0178 | 0.0021 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 210.0000 | 0.9998 | 0.0155 | 0.0018 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 215.0000 | 0.9998 | 0.0191 | 0.0022 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 220.0000 | 0.9999 | 0.0215 | 0.0025 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 225.0000 | 0.9999 | 0.0107 | 0.0012 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 230.0000 | 1.0000 | 0.0100 | 0.0012 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 235.0000 | 1.0000 | 0.0142 | 0.0016 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 240.0000 | 1.0000 | 0.0120 | 0.0014 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 245.0000 | 1.0000 | 0.0083 | 0.0010 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 250.0000 | 1.0000 | 0.0050 | 0.0007 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 255.0000 | 1.0000 | 0.0034 | 0.0004 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 260.0000 | 1.0000 | 0.0020 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 265.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 270.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 275.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Table C-2
Expert C: Cases 1 and 2 Data Conversion

| Pressure (psia) | Independent Cumulative Failure Probability for Initial Modes | | | Cond. Probability of Wetwell Modes Given Wetwell Failure | | | |
|--------------------|---|--------|--------|---|--------|--------|--------|
| | DWR | DWH | HW | W/LWH | W/LHW | W/RWH | W/RHW |
| 100.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 0.0100 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0000 | 0.0125 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 115.0000 | 0.0000 | 0.0150 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 120.0000 | 0.0000 | 0.0175 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 125.0000 | 0.0000 | 0.0200 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 130.0000 | 0.0000 | 0.0400 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 135.0000 | 0.0000 | 0.0500 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 140.0000 | 0.0000 | 0.0600 | 0.0100 | 0.0000 | 0.1000 | 0.0000 | 0.0000 |
| 145.0000 | 0.0000 | 0.1300 | 0.1343 | 0.6544 | 0.0958 | 0.0100 | 0.0398 |
| 150.0000 | 0.0000 | 0.1500 | 0.2585 | 0.6088 | 0.0818 | 0.0189 | 0.0787 |
| 155.0000 | 0.0625 | 0.1900 | 0.3826 | 0.6142 | 0.0697 | 0.0385 | 0.2776 |
| 160.0000 | 0.1250 | 0.3200 | 0.5086 | 0.4197 | 0.0478 | 0.0771 | 0.4754 |
| 165.0000 | 0.1875 | 0.3700 | 0.6307 | 0.2251 | 0.0259 | 0.0757 | 0.6733 |
| 170.0000 | 0.2500 | 0.4200 | 0.8084 | 0.0004 | 0.0107 | 0.0452 | 0.6537 |
| 175.0000 | 0.3125 | 0.4800 | 0.9520 | 0.0004 | 0.0100 | 0.0226 | 0.8784 |
| 180.0000 | 0.3750 | 0.5300 | 0.9945 | 0.0004 | 0.0105 | 0.0000 | 0.8991 |
| 185.0000 | 0.4375 | 0.5900 | 0.9959 | 0.0047 | 0.0098 | 0.0000 | 0.9054 |
| 190.0000 | 0.5000 | 0.6300 | 0.9961 | 0.0791 | 0.0094 | 0.0000 | 0.9117 |
| 195.0000 | 0.5250 | 0.6700 | 0.9963 | 0.0734 | 0.0085 | 0.0000 | 0.9180 |
| 200.0000 | 0.5500 | 0.7300 | 0.9965 | 0.0778 | 0.0079 | 0.0000 | 0.9243 |
| 205.0000 | 0.5750 | 0.7700 | 0.9969 | 0.0621 | 0.0072 | 0.0000 | 0.9306 |
| 210.0000 | 0.6000 | 0.8100 | 0.9972 | 0.0565 | 0.0066 | 0.0000 | 0.9369 |
| 215.0000 | 0.6250 | 0.8300 | 0.9975 | 0.0508 | 0.0059 | 0.0000 | 0.9432 |
| 220.0000 | 0.6500 | 0.8400 | 0.9978 | 0.0452 | 0.0052 | 0.0000 | 0.9495 |
| 225.0000 | 0.6750 | 0.8800 | 0.9980 | 0.0395 | 0.0046 | 0.0000 | 0.9558 |
| 230.0000 | 0.7000 | 0.9100 | 0.9983 | 0.0339 | 0.0039 | 0.0000 | 0.9622 |
| 235.0000 | 0.7250 | 0.9180 | 0.9986 | 0.0282 | 0.0033 | 0.0000 | 0.9685 |
| 240.0000 | 0.7500 | 0.9280 | 0.9989 | 0.0226 | 0.0026 | 0.0000 | 0.9748 |
| 245.0000 | 0.7917 | 0.9340 | 0.9992 | 0.0169 | 0.0020 | 0.0000 | 0.9811 |
| 250.0000 | 0.8333 | 0.9420 | 0.9994 | 0.0113 | 0.0013 | 0.0000 | 0.9874 |
| 255.0000 | 0.8750 | 0.9500 | 0.9997 | 0.0056 | 0.0007 | 0.0000 | 0.9937 |
| 260.0000 | 0.9167 | 0.9600 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 265.0000 | 0.9583 | 0.9700 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 270.0000 | 0.9792 | 0.9800 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |
| 275.0000 | 1.0000 | 0.9900 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 |

Table C-3
Expert C'S Conditional Probabilities: Cases 1 & 2

| Pressure (PSI) [2] | Conditional Probability of Failure | | | | Normalized Conditional Probability of Failures* | | | | Conditional Probability for Weibull Modes | | | | Failure All Modes | Cumulative Failure DPR, DPRE | |
|-----------------------|---------------------------------------|--------|--------|--------|--|--------|--------|--------|--|--------|--------|--------|----------------------|------------------------------------|--------|
| | DPR | DPRE | MM | DNR | DPR | DPRE | MM | DNR | WBLWH | WBLWF | WBLWH | WBLWF | WBLWH | WBLWF | |
| 100.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0100 | 0.0100 |
| 110.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0125 | 0.0125 |
| 115.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0150 | 0.0150 |
| 120.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0175 | 0.0175 |
| 125.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0200 | 0.0200 |
| 130.0000 | 0.0000 | 0.8618 | 0.1382 | 0.0000 | 0.8618 | 0.1382 | 0.0000 | 0.0000 | 0.1243 | 0.1243 | 0.0000 | 0.0000 | 0.0000 | 0.0432 | 0.0432 |
| 135.0000 | 0.0000 | 0.7540 | 0.2460 | 0.0000 | 0.7540 | 0.2460 | 0.0000 | 0.0000 | 0.2214 | 0.2214 | 0.0000 | 0.0000 | 0.0000 | 0.0564 | 0.0564 |
| 140.0000 | 0.0000 | 0.9282 | 0.0718 | 0.0000 | 0.9282 | 0.0718 | 0.0000 | 0.0000 | 0.0846 | 0.0846 | 0.0000 | 0.0000 | 0.0000 | 0.0991 | 0.0991 |
| 145.0000 | 0.0000 | 0.2516 | 0.7484 | 0.0000 | 0.2512 | 0.7488 | 0.0000 | 0.0000 | 0.6398 | 0.6398 | 0.0000 | 0.0000 | 0.0000 | 0.2468 | 0.2468 |
| 150.0000 | 0.0000 | 0.1309 | 0.8700 | 0.0000 | 0.1309 | 0.8692 | 0.0000 | 0.0000 | 0.7079 | 0.7079 | 0.0000 | 0.0000 | 0.0000 | 0.3687 | 0.3687 |
| 155.0000 | 0.2186 | 0.1641 | 0.6218 | 0.0000 | 0.2184 | 0.1632 | 0.6184 | 0.0000 | 0.3798 | 0.3798 | 0.0000 | 0.0000 | 0.0000 | 0.5312 | 0.5312 |
| 160.0000 | 0.1500 | 0.3795 | 0.4856 | 0.1478 | 0.3739 | 0.4784 | 0.1478 | 0.0000 | 0.2008 | 0.2008 | 0.0000 | 0.0000 | 0.0000 | 0.7064 | 0.7064 |
| 165.0000 | 0.1710 | 0.1762 | 0.6841 | 0.1691 | 0.1742 | 0.6787 | 0.1691 | 0.0000 | 0.1478 | 0.1478 | 0.0000 | 0.0000 | 0.0000 | 0.8110 | 0.8110 |
| 170.0000 | 0.0609 | 0.0761 | 0.9174 | 0.0576 | 0.0722 | 0.8700 | 0.0576 | 0.0000 | 0.0787 | 0.0787 | 0.0000 | 0.0000 | 0.0000 | 0.9508 | 0.9508 |
| 175.0000 | 0.1113 | 0.1174 | 0.7896 | 0.1082 | 0.1142 | 0.7776 | 0.1082 | 0.0000 | 0.0703 | 0.0703 | 0.0000 | 0.0000 | 0.0000 | 0.9828 | 0.9828 |
| 180.0000 | 0.0556 | 0.0589 | 0.9569 | 0.0514 | 0.0545 | 0.8941 | 0.0514 | 0.0000 | 0.0806 | 0.0806 | 0.0000 | 0.0000 | 0.0000 | 0.9987 | 0.9987 |
| 185.0000 | 0.3461 | 0.4484 | 0.2122 | 0.3433 | 0.4454 | 0.2107 | 0.3433 | 0.0000 | 0.0179 | 0.0179 | 0.0000 | 0.0000 | 0.0000 | 0.7063 | 0.7063 |
| 190.0000 | 0.4093 | 0.3568 | 0.2389 | 0.4066 | 0.3547 | 0.2385 | 0.4066 | 0.0000 | 0.0189 | 0.0189 | 0.0000 | 0.0000 | 0.0000 | 0.7694 | 0.7694 |
| 195.0000 | 0.2149 | 0.4788 | 0.3104 | 0.2140 | 0.4769 | 0.3081 | 0.2140 | 0.0000 | 0.0227 | 0.0227 | 0.0000 | 0.0000 | 0.0000 | 0.8150 | 0.8150 |
| 200.0000 | 0.1630 | 0.6030 | 0.2412 | 0.1618 | 0.5987 | 0.2395 | 0.1618 | 0.0000 | 0.0162 | 0.0162 | 0.0000 | 0.0000 | 0.0000 | 0.8433 | 0.8433 |
| 205.0000 | 0.1891 | 0.5295 | 0.2878 | 0.1879 | 0.5261 | 0.2859 | 0.1879 | 0.0000 | 0.0155 | 0.0155 | 0.0000 | 0.0000 | 0.0000 | 0.8785 | 0.8785 |
| 210.0000 | 0.1784 | 0.5544 | 0.2772 | 0.1750 | 0.5509 | 0.2730 | 0.1750 | 0.0000 | 0.0178 | 0.0178 | 0.0000 | 0.0000 | 0.0000 | 0.9023 | 0.9023 |
| 215.0000 | 0.2310 | 0.3978 | 0.3769 | 0.2287 | 0.3956 | 0.3767 | 0.2287 | 0.0000 | 0.0181 | 0.0181 | 0.0000 | 0.0000 | 0.0000 | 0.9240 | 0.9240 |
| 220.0000 | 0.2602 | 0.2462 | 0.4780 | 0.2790 | 0.2432 | 0.4756 | 0.2790 | 0.0000 | 0.0215 | 0.0215 | 0.0000 | 0.0000 | 0.0000 | 0.9383 | 0.9383 |
| 225.0000 | 0.1526 | 0.5886 | 0.2747 | 0.1592 | 0.5734 | 0.2704 | 0.1592 | 0.0000 | 0.0107 | 0.0107 | 0.0000 | 0.0000 | 0.0000 | 0.9440 | 0.9440 |
| 230.0000 | 0.1568 | 0.5598 | 0.3015 | 0.1540 | 0.5489 | 0.2951 | 0.1540 | 0.0000 | 0.0106 | 0.0106 | 0.0000 | 0.0000 | 0.0000 | 0.9510 | 0.9510 |
| 235.0000 | 0.2426 | 0.2595 | 0.5072 | 0.2403 | 0.2571 | 0.5025 | 0.2403 | 0.0000 | 0.0142 | 0.0142 | 0.0000 | 0.0000 | 0.0000 | 0.9730 | 0.9730 |
| 240.0000 | 0.2295 | 0.2471 | 0.5355 | 0.2267 | 0.2442 | 0.5291 | 0.2267 | 0.0000 | 0.0120 | 0.0120 | 0.0000 | 0.0000 | 0.0000 | 0.9775 | 0.9775 |
| 245.0000 | 0.3261 | 0.2010 | 0.5026 | 0.3127 | 0.1984 | 0.4809 | 0.3127 | 0.0000 | 0.0083 | 0.0083 | 0.0000 | 0.0000 | 0.0000 | 0.9815 | 0.9815 |
| 250.0000 | 0.3068 | 0.1784 | 0.5531 | 0.2955 | 0.1718 | 0.5327 | 0.2955 | 0.0000 | 0.0060 | 0.0060 | 0.0000 | 0.0000 | 0.0000 | 0.9853 | 0.9853 |
| 255.0000 | 0.2795 | 0.1448 | 0.6517 | 0.2602 | 0.1346 | 0.6087 | 0.2602 | 0.0000 | 0.0034 | 0.0034 | 0.0000 | 0.0000 | 0.0000 | 0.9903 | 0.9903 |
| 260.0000 | 0.2002 | 0.1111 | 0.6867 | 0.2002 | 0.1111 | 0.6867 | 0.2002 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9957 | 0.9957 |
| 265.0000 | 0.7323 | 0.3145 | 0.0000 | 0.6997 | 0.3003 | 0.0000 | 0.6997 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 1.0000 |
| 270.0000 | 0.6000 | 0.4000 | 0.0000 | 0.6000 | 0.4000 | 0.0000 | 0.6000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 1.0000 |
| 275.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 1.0000 |

*Due to small errors, the conditional probabilities calculated did not sum precisely to 1.0; therefore, normalized by sum.

Table C-4
Results of Expert C: Case 3A and 2

| Erosion (psf) | Cumulative Failure Probability | Conditional Probability of Failure in Mode i at Pressure j | | | | | | | | | | | | |
|------------------|--------------------------------------|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | WASH | WASH | WASH | WASH | WASH | WASH | WASH | WASH | WASH | WASH | | | |
| 50.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 55.0000 | 0.0100 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 60.0000 | 0.0200 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.0310 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 70.0000 | 0.0400 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 75.0000 | 0.0700 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 80.0000 | 0.0900 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 85.0000 | 0.1200 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 90.0000 | 0.1400 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.1500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.1800 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.2100 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.3033 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.3750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.4750 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.5505 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 0.6220 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 0.6760 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 0.7426 | 0.0394 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 0.8106 | 0.3733 | 0.0418 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 0.8665 | 0.5800 | 0.0405 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 0.9112 | 0.7556 | 0.0313 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 | 0.0173 |
| 160.0000 | 0.9484 | 0.1734 | 0.0198 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 | 0.0236 |
| 165.0000 | 0.9709 | 0.1137 | 0.0131 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 | 0.0382 |
| 170.0000 | 0.9954 | 0.0659 | 0.0078 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 | 0.0329 |
| 175.0000 | 0.9989 | 0.0409 | 0.0046 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 | 0.0102 |
| 180.0000 | 0.9999 | 0.0665 | 0.0077 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 | 0.0050 |
| 185.0000 | 1.0000 | 0.0105 | 0.0022 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 190.0000 | 1.0000 | 0.0190 | 0.0012 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 195.0000 | 1.0000 | 0.0027 | 0.0003 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 200.0000 | 1.0000 | 0.0222 | 0.0027 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 205.0000 | 1.0000 | 0.0175 | 0.0020 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 210.0000 | 1.0000 | 0.0141 | 0.0016 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 215.0000 | 1.0000 | 0.0106 | 0.0012 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 220.0000 | 1.0000 | 0.0068 | 0.0008 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 225.0000 | 1.0000 | 0.0026 | 0.0003 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Table C-3
Expert C: Case 3A Data Conversion

| Pressure (psia) | Independent Cumulative Failure Probability for Initial Modes | | | | Cond. Probability of Netwell Modes Given Netwell Failure | | | | Cumulative Failure: All Modes | |
|--------------------|---|--------|--------|--------|---|--------|--------|--------|----------------------------------|--------|
| | EMR | DMR | WR | WLR | WMLW | WMLB | WMLM | WMLH | | |
| 50.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 55.0000 | 0.0000 | 0.0100 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0100 |
| 60.0000 | 0.0000 | 0.0299 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0299 |
| 65.0000 | 0.0000 | 0.0710 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0710 |
| 70.0000 | 0.0000 | 0.0400 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0400 |
| 75.0000 | 0.0000 | 0.0700 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0700 |
| 80.0000 | 0.0000 | 0.0900 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.0900 |
| 85.0000 | 0.0000 | 0.1200 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.1200 |
| 90.0000 | 0.0000 | 0.1400 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.1400 |
| 95.0000 | 0.0000 | 0.1500 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.1500 |
| 100.0000 | 0.0000 | 0.1800 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.1800 |
| 105.0000 | 0.0000 | 0.2100 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.2100 |
| 110.0000 | 0.0433 | 0.2400 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.3033 |
| 115.0000 | 0.1667 | 0.2500 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.3750 |
| 120.0000 | 0.2300 | 0.3000 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.4750 |
| 125.0000 | 0.2750 | 0.3800 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.5200 |
| 130.0000 | 0.3000 | 0.4600 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.6200 |
| 135.0000 | 0.3250 | 0.5200 | 0.0000 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.6760 |
| 140.0000 | 0.3500 | 0.6000 | 0.0100 | 0.0000 | 0.0000 | 0.1000 | 0.0000 | 0.0000 | 0.0000 | 0.7426 |
| 145.0000 | 0.3750 | 0.6500 | 0.1343 | 0.0000 | 0.8544 | 0.0958 | 0.0100 | 0.0398 | 0.0106 | 0.8665 |
| 150.0000 | 0.4000 | 0.7000 | 0.2585 | 0.0000 | 0.8088 | 0.0916 | 0.0192 | 0.0797 | 0.0865 | 0.9112 |
| 155.0000 | 0.4250 | 0.7500 | 0.3826 | 0.0000 | 0.6142 | 0.0687 | 0.0385 | 0.2776 | 0.0884 | 0.9484 |
| 160.0000 | 0.4500 | 0.8100 | 0.5066 | 0.0000 | 0.4197 | 0.0478 | 0.0571 | 0.4754 | 0.0909 | 0.9709 |
| 165.0000 | 0.4750 | 0.8500 | 0.6307 | 0.0000 | 0.2251 | 0.0259 | 0.0757 | 0.6733 | 0.0924 | 0.9854 |
| 170.0000 | 0.5000 | 0.9000 | 0.8084 | 0.0000 | 0.0904 | 0.0167 | 0.0452 | 0.8337 | 0.0929 | 0.9954 |
| 175.0000 | 0.5417 | 0.9500 | 0.9520 | 0.0000 | 0.0904 | 0.0106 | 0.0226 | 0.8754 | 0.0929 | 0.9989 |
| 180.0000 | 0.5833 | 0.9700 | 0.9955 | 0.0000 | 0.0904 | 0.0105 | 0.0000 | 0.8991 | 0.0929 | 0.9999 |
| 185.0000 | 0.6250 | 0.9700 | 0.9958 | 0.0000 | 0.0947 | 0.0098 | 0.0000 | 0.9034 | 0.0929 | 1.0000 |
| 190.0000 | 0.6667 | 0.9810 | 0.9961 | 0.0000 | 0.0781 | 0.0032 | 0.0000 | 0.9117 | 0.0929 | 1.0000 |
| 195.0000 | 0.7083 | 1.0000 | 0.9963 | 0.0000 | 0.0734 | 0.0065 | 0.0000 | 0.9160 | 0.0929 | 1.0000 |
| 200.0000 | 0.7500 | 1.0000 | 0.9966 | 0.0000 | 0.0678 | 0.0079 | 0.0000 | 0.9243 | 0.0929 | 1.0000 |
| 205.0000 | 0.8000 | 1.0000 | 0.9969 | 0.0000 | 0.0521 | 0.0072 | 0.0000 | 0.9306 | 0.0929 | 1.0000 |
| 210.0000 | 0.8500 | 1.0000 | 0.9972 | 0.0000 | 0.0365 | 0.0066 | 0.0000 | 0.9369 | 0.0929 | 1.0000 |
| 215.0000 | 0.9000 | 1.0000 | 0.9975 | 0.0000 | 0.0508 | 0.0059 | 0.0000 | 0.9432 | 0.0929 | 1.0000 |
| 220.0000 | 0.9500 | 1.0000 | 0.9978 | 0.0000 | 0.0452 | 0.0052 | 0.0000 | 0.9485 | 0.0929 | 1.0000 |
| 225.0000 | 1.0000 | 1.0000 | 0.9980 | 0.0000 | 0.0395 | 0.0046 | 0.0000 | 0.9559 | 0.0929 | 1.0000 |

Table C-6
Expert C's Conditional Probabilities: Case 3A

| Pressure (psik) | Cum Fail Modes & Wt | Conditional Probability of Failure | | | | Normalized Conditional Probability of Failures* | | | | Conditional Probability for Metwell Modes | | | | | | |
|--------------------|---------------------------|---------------------------------------|--------|--------|--------|--|--------|--------|--------|--|--------|--------|--------|--------|--------|--------|
| | | DWR | DWBL | SW | DWR | DWBL | SW | DWR | DWBL | SW | DWR | DWBL | SW | DWR | DWBL | SW |
| 50.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 55.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 60.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 70.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 75.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 80.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 85.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 90.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 0.0833 | 0.6925 | 0.3083 | 0.0000 | 0.0000 | 0.6925 | 0.3083 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 0.1667 | 0.7821 | 0.2179 | 0.0000 | 0.0000 | 0.7821 | 0.2179 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 0.2500 | 0.8533 | 0.1467 | 0.0000 | 0.0000 | 0.8533 | 0.1467 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 0.2750 | 0.2188 | 0.7812 | 0.0000 | 0.0000 | 0.2188 | 0.7812 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 0.3000 | 0.2030 | 0.7970 | 0.0000 | 0.0000 | 0.2030 | 0.7970 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 0.3250 | 0.2364 | 0.7636 | 0.0000 | 0.0000 | 0.2364 | 0.7636 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 0.3500 | 0.2878 | 0.7122 | 0.0000 | 0.0000 | 0.2878 | 0.7122 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 0.4589 | 0.4288 | 0.5712 | 0.0000 | 0.0000 | 0.4288 | 0.5712 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 0.5551 | 0.1178 | 0.4422 | 0.0000 | 0.0000 | 0.1178 | 0.4422 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 0.6450 | 0.1057 | 0.4543 | 0.0000 | 0.0000 | 0.1057 | 0.4543 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 160.0000 | 0.7286 | 0.0838 | 0.5162 | 0.0000 | 0.0000 | 0.0838 | 0.5162 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 165.0000 | 0.8061 | 0.0834 | 0.4226 | 0.0000 | 0.0000 | 0.0834 | 0.4226 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 170.0000 | 0.8542 | 0.0335 | 0.2748 | 0.0000 | 0.0000 | 0.0335 | 0.2748 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 175.0000 | 0.9780 | 0.0710 | 0.5444 | 0.0000 | 0.0000 | 0.0710 | 0.5444 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 180.0000 | 0.9981 | 0.0527 | 0.2768 | 0.0000 | 0.0000 | 0.0527 | 0.2768 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 185.0000 | 0.9984 | 0.2045 | 0.6857 | 0.0000 | 0.0000 | 0.2045 | 0.6857 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 190.0000 | 0.9987 | 0.4129 | 0.3510 | 0.0000 | 0.0000 | 0.4129 | 0.3510 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 195.0000 | 0.9988 | 0.0667 | 0.8963 | 0.0000 | 0.0000 | 0.0667 | 0.8963 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 200.0000 | 0.9992 | 0.6598 | 0.0000 | 0.0000 | 0.0000 | 0.6598 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 205.0000 | 0.9994 | 0.7222 | 0.0000 | 0.0000 | 0.0000 | 0.7222 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 210.0000 | 0.9996 | 0.7553 | 0.0000 | 0.0000 | 0.0000 | 0.7553 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 215.0000 | 0.9997 | 0.8000 | 0.0000 | 0.0000 | 0.0000 | 0.8000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 220.0000 | 0.9999 | 0.8667 | 0.0000 | 0.0000 | 0.0000 | 0.8667 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 225.0000 | 1.0000 | 0.9333 | 0.0000 | 0.0000 | 0.0000 | 0.9333 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

* Due to small errors, the conditional probabilities calculated did not sum precisely to 1.0; therefore, normalized by sum.

Table C-7
Results of Expert C: Case 3B and Z

| Pressure (psia) | Cumulative Failure Probability | Conditional Probability of Failure in Mode I at Pressure J | | | | | | | | | | | | |
|--------------------|--------------------------------------|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | | WMLM | WMLW | WMLH | WMLB | WMLC | WMLD | WMLE | WMLF | WMLG | WMLH | | | |
| 5.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 10.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 15.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 20.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 25.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 30.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 35.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 40.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 45.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 50.0000 | 0.0300 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 55.0000 | 0.0500 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 60.0000 | 0.3175 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 65.0000 | 0.7067 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 70.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 75.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 80.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 85.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 90.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 95.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 100.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 105.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 110.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 115.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 120.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 125.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 130.0000 | 1.0000 | 0.0110 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 135.0000 | 1.0000 | 0.0065 | 0.0007 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 140.0000 | 1.0000 | 0.0045 | 0.0005 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 145.0000 | 1.0000 | 0.1154 | 0.0129 | 0.0071 | 0.0014 | 0.0054 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 150.0000 | 1.0000 | 0.0625 | 0.0071 | 0.0071 | 0.0015 | 0.0062 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 155.0000 | 1.0000 | 0.6142 | 0.0597 | 0.0597 | 0.0385 | 0.2776 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 160.0000 | 1.0000 | 0.4197 | 0.0478 | 0.0478 | 0.0571 | 0.4754 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 165.0000 | 1.0000 | 0.2251 | 0.0259 | 0.0259 | 0.0757 | 0.6733 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 170.0000 | 1.0000 | 0.0804 | 0.0107 | 0.0107 | 0.0452 | 0.8537 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 175.0000 | 1.0000 | 0.0804 | 0.0106 | 0.0106 | 0.0226 | 0.8764 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |
| 180.0000 | 1.0000 | 0.0804 | 0.0105 | 0.0105 | 0.0000 | 0.8991 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 |

Table C-8
Expert C: Case 3B Data Conversion

| Pressure (psia) | Independent Cumulative Failure Probability for Initial Modes | | | Conditional Probability of Netwell Modes Given Netwell Failure | | | Conditional Probability of Failure | | | Cum. Fail. All Modes | Cum. Fail. DMSLR and MW Only |
|--------------------|---|--------|--------|---|--------|----------|---------------------------------------|--------|--------|-------------------------|------------------------------------|
| | DMS | DMSLR | MW | MW_MW | MW_DMS | MW_DMSLR | DMS | DMSLR | MW | | |
| 5.0000 | 0.0000 | 0.2600 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 10.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 15.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 20.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 25.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 30.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 35.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 40.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 45.0000 | 0.0000 | 0.0000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 |
| 50.0000 | 0.0000 | 0.0300 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0300 |
| 55.0000 | 0.0000 | 0.0500 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0500 |
| 60.0000 | 0.2500 | 0.0900 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 0.8714 | 0.1312 | 0.0000 | 0.3175 |
| 65.0000 | 0.6667 | 0.1200 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 0.964 | 0.0420 | 0.0000 | 0.7067 |
| 70.0000 | 1.0000 | 0.1400 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 0.9885 | 0.0115 | 0.0000 | 0.1400 |
| 75.0000 | 1.0000 | 0.1500 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.1500 |
| 80.0000 | 1.0000 | 0.1800 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.1800 |
| 85.0000 | 1.0000 | 0.2100 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.2100 |
| 90.0000 | 1.0000 | 0.2400 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.2400 |
| 95.0000 | 1.0000 | 0.3200 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.3200 |
| 100.0000 | 1.0000 | 0.4200 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.4200 |
| 105.0000 | 1.0000 | 0.4600 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.4600 |
| 110.0000 | 1.0000 | 0.5600 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.5600 |
| 115.0000 | 1.0000 | 0.6500 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.6500 |
| 120.0000 | 1.0000 | 0.7000 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.7000 |
| 125.0000 | 1.0000 | 0.7800 | 0.0000 | 0.9000 | 0.1000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.7800 |
| 130.0000 | 1.0000 | 0.8400 | 0.0033 | 0.9000 | 0.1000 | 0.0033 | 0.0000 | 0.9890 | 0.0122 | 0.0000 | 0.8405 |
| 135.0000 | 1.0000 | 0.9000 | 0.0067 | 0.9000 | 0.1000 | 0.0067 | 0.0000 | 0.9932 | 0.0072 | 0.0000 | 0.9007 |
| 140.0000 | 1.0000 | 0.9500 | 0.0100 | 0.9000 | 0.1000 | 0.0100 | 0.0000 | 0.9955 | 0.0050 | 0.0000 | 0.9505 |
| 145.0000 | 1.0000 | 0.9800 | 0.1343 | 0.8544 | 0.0958 | 0.0100 | 0.0398 | 0.9999 | 0.0001 | 0.0000 | 0.9827 |
| 150.0000 | 1.0000 | 1.0000 | 0.2585 | 0.8086 | 0.0716 | 0.0199 | 0.0797 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |
| 155.0000 | 1.0000 | 1.0000 | 0.3817 | 0.6142 | 0.0697 | 0.0385 | 0.2776 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |
| 160.0000 | 1.0000 | 1.0000 | 0.5033 | 0.4197 | 0.0478 | 0.0571 | 0.4734 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |
| 165.0000 | 1.0000 | 1.0000 | 0.6307 | 0.2251 | 0.0259 | 0.0757 | 0.6733 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |
| 170.0000 | 1.0000 | 1.0000 | 0.8084 | 0.0934 | 0.0197 | 0.0452 | 0.8537 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |
| 175.0000 | 1.0000 | 1.0000 | 0.9520 | 0.0394 | 0.0105 | 0.0226 | 0.8754 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |
| 180.0000 | 1.0000 | 1.0000 | 0.9955 | 0.0094 | 0.0105 | 0.0226 | 0.8991 | 0.9999 | 0.0001 | 0.0000 | 1.0000 |

Table C-2
Expert C's Conditional Probabilities: Case 2B

| Pressure (PSIA) | Normalized Conditional Probability of Failures ^a | | | | Conditional Probability for Network Nodes | | | | Conditional Split for DMEL/R | | | |
|--------------------|--|--------|--------|--------|--|--------|--------|--------|------------------------------|--------|--------|--------|
| | DWR | DMEL | MD | WHL-AM | WHL-1A | WHL-2A | WHL-2B | WHL-2C | L | R | DMEL | DMER |
| 5.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 10.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 15.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 20.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 25.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 30.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 35.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 40.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 45.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 50.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 55.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 60.0000 | 0.8692 | 0.1308 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.1308 | 0.0000 |
| 65.0000 | 0.9562 | 0.0438 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0438 | 0.0000 |
| 70.0000 | 0.9885 | 0.0115 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0115 | 0.0000 |
| 75.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 80.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 85.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 90.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 95.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 100.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 105.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 110.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 115.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 120.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 125.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 1.0000 | 0.0000 |
| 130.0000 | 0.0000 | 0.9876 | 0.0122 | 0.0110 | 0.0012 | 0.0000 | 0.0000 | 0.0000 | 0.3700 | 0.6300 | 0.3655 | 0.6223 |
| 135.0000 | 0.0000 | 0.9928 | 0.0072 | 0.0065 | 0.0007 | 0.0000 | 0.0000 | 0.0000 | 0.2300 | 0.7700 | 0.2283 | 0.7645 |
| 140.0000 | 0.0000 | 0.9950 | 0.0050 | 0.0045 | 0.0005 | 0.0000 | 0.0000 | 0.0000 | 0.1100 | 0.8900 | 0.1094 | 0.8855 |
| 145.0000 | 0.0000 | 0.8649 | 0.1351 | 0.1154 | 0.0129 | 0.0014 | 0.0054 | 0.0054 | 0.0500 | 0.9500 | 0.0432 | 0.8216 |
| 150.0000 | 0.0000 | 0.9227 | 0.0773 | 0.0625 | 0.0071 | 0.0015 | 0.0062 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.9227 |
| 155.0000 | 0.0000 | 0.0000 | 1.0000 | 0.6142 | 0.0697 | 0.0385 | 0.2776 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 160.0000 | 0.0000 | 0.0000 | 1.0000 | 0.4197 | 0.0478 | 0.0571 | 0.4754 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 165.0000 | 0.0000 | 0.0000 | 1.0000 | 0.2251 | 0.0259 | 0.0757 | 0.6723 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 170.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0904 | 0.0107 | 0.0452 | 0.8537 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 175.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0994 | 0.0106 | 0.0226 | 0.8764 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |
| 180.0000 | 0.0000 | 0.0000 | 1.0000 | 0.0204 | 0.0105 | 0.0000 | 0.8991 | 0.0000 | 0.0000 | 1.0000 | 0.0000 | 0.0000 |

^aDue to small errors, the conditional probabilities calculated did not sum precisely to 1.0; therefore, normalized by sum.

REFERENCES

- C-1. K. Mohktarian et al., "Mark I Containment Severe Accident Analysis," Chicago Bridge & Iron NA-CON, Chicago, IL, April 1987.
- C-2. K. Mohktarian, "An Investigation of High Temperature Accident Conditions for Mark I Containment Vessels," Chicago Bridge & Iron NA-CON, Chicago, IL, January 1986.
- C-3. A. C. Ugural, Stresses in Plates and Shells, McGraw Hill, New York, 1981.
- C-4. D. S. Horschel, "The Design, Fabrication, Testing, and Analyses of Four 1:32-Scale Steel Containment Models," NUREG/CR-3902, SAND84-2153, Sandia National Laboratories, 1988.
- C-5. L. N. Koenig, "The Test of a Large Steel Containment Model," NUREG/CR-4216, SAND85-0790, Sandia National Laboratories, December 1986.

5.4. Issue 4. Effect of Wetwell Rupture on ECCS Survivability and Reactor Building Integrity at Peach Bottom

Experts consulted: David B. Clauss, Sandia National Laboratories; Ken Mohktarian, Chicago Bridge & Iron; Subir Sen, Bechtel Corporation.

Issue Description

This issue addresses two questions: (1) What is the probability of a containment rupture with enough kinetic energy to sever emergency core cooling system (ECCS) piping? and (2) What is the probability of significant reactor building bypass given a rupture in the wetwell at Peach Bottom?

This issue is very closely related to the P-T induced containment failure issue (Issue 3). The initial conditions for this issue are containment failure in the torus and a wetwell rupture (WWR) or a catastrophic rupture (CWWR) failure mode (see Issue 3). Whether containment failure breaks the ECCS lines is important in sequences in which the containment fails before the onset of core damage. Whether wetwell rupture leads to reactor building bypass is important in sequences in which core damage occurs before containment failure because a potential source of decontamination (the reactor building) could be eliminated.

There are three types of questions in the accident progression tree (APET) that are relevant to this issue:

Question Type 1: Is the suppression pool drained before core damage? The answers to this question characterize the state of the wetwell. There are three states: drainage: (a) suppression pool drained completely, representing a catastrophic wetwell failure; (b) suppression pool depleted so that the water level is below the drywell vents, representing a failure below the water level in the torus and; (c) no suppression pool drainage, the failure is above the water line and is not catastrophic.

Question Type 2: After the suppression pool drainage question, the status of the condensate system piping, the status of the control rod drive piping, and the status of the high pressure service water piping are asked. The piping in each of the systems is either intact or it is not. (Success or failure of these systems also depends on issues other than the one being considered.) The review group was asked to provide the probabilities of survivability of the lines for these three systems given a wetwell failure by rupture.

Question Type 3: What is the level of reactor building breach/bypass without a hydrogen burn? Four levels of bypass are considered: (a) no bypass--the standby gas treatment system can handle all releases to the reactor building,

Question Type 3

Continued

(b) small level of bypass--most of the release passes through the reactor building, (c) large level of bypass--decontamination of the release is equivalent to decontamination of releases that have gone to the refueling bay, and (d) complete bypass of the reactor building. The review group was asked to provide the relative probabilities of the different levels of bypass given a wetwell failure.

Summary of Results

All three experts agreed that failure of the control rod drive (CRD) or condensate piping is negligible. They also agreed that only the unreinforced portions of the wetwell could fail catastrophically and that only catastrophic rupture could fail the piping high pressure service water (HPSW)--residual heat removal (RHR). There is additional structural reinforcement in the eight sections that contain the downcomers. Expert A said that the probability of the HPSW-RHR piping in the torus room failing was a simple ratio of the number of sections of the torus facing the piping to the total. This gives $4/8 = 0.50$ for the probability of HPSW line pipe failure, since four of the eight unreinforced segments face the HPSW pipe. Expert B said that the piping failed only if fragments were generated and gave a 0.8 probability of fragments. This gives $(4/8)*.8 = 0.40$ for the probability of pipe failure. Expert C, gave a 0.12 conditional probability of pipe failure. Averaging these failure probabilities gives $(.50 + .40 + .12)/3 = 0.34$ for the aggregated conditional probability of pipe failure given a CWWR.

The following tables give the probability of each reactor building bypass level as given by each expert for the WWR case.

Table 4-1
Probability of Reactor Building Bypass for WWR--Expert A

| Bypass Level | Pressure(psig) | | | | | | | | |
|-----------------|----------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | 0 | .25 | 3 | 5 | 6 | 10 | 15 | 20 | 50 |
| a | 1.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| b | 0.0 | 1.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| c | 0.0 | 0.0 | 0.0 | 1.0 | 1.0 | 1.0 | 0.5 | 0.0 | 0.0 |
| d | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.5 | 1.0 | 1.0 |

Values were linearly interpolated for the 6 psig case and linearly extrapolated for the 50 psig case. Level "a" goes to zero from 1.0 at .25.

Table 4-2
Probability of Reactor Building Bypass for WWR--Expert B

| Bypass Level | Pressure (psig) | | | | | | | | |
|-----------------|-----------------|-----|-----|-----|-----|------|-------|------|-----|
| | 0 | .25 | 3 | 5 | 6 | 10 | 15 | 20 | 50 |
| a | 1.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| b | 0.0 | 1.0 | 1.0 | 1.0 | 1.0 | 0.75 | 0.575 | 0.40 | 0.0 |
| c | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| d | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.25 | 0.425 | 0.60 | 1.0 |

Values were linearly interpolated for the 3, 5, and 15 psig cases.

Table 4-3
Failure Probabilities for Seven Cases for WWR--Expert C

| Bypass Level | Cases | | | | | | |
|-----------------|-------|------|------|------|------|------|------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 |
| a | 0.70 | 0.20 | 0.80 | 0.30 | 0.70 | 0.20 | 0.08 |
| b | 0.05 | 0.10 | 0.05 | 0.10 | 0.05 | 0.10 | 0.06 |
| c | 0.25 | 0.40 | 0.15 | 0.40 | 0.25 | 0.40 | 0.36 |
| d | 0.00 | 0.30 | 0.00 | 0.20 | 0.00 | 0.30 | 0.80 |
| a+b | 0.75 | 0.30 | 0.85 | 0.40 | 0.75 | 0.30 | 0.14 |

Since level "a" includes the blowout panels for this expert.

The cases for Table 3 were defined as follows:

1. For P-T cases 1 and 2 (see Issue 3) at 170 psig, the conditional probability of reactor building leak levels for WWRaW or WWRbW.
2. For P-T cases 1 and 2 at 170 psig, the conditional probability of reactor building leak levels for CWWR.
3. For P-T cases 3a at 150 psig and 800°F, the conditional probability of reactor building leak levels for WWRaW or WWRbW.
4. For P-T cases 3a at 150 psig and 800°F, the conditional probability of reactor building leak levels for CWWR.
5. For P-T cases 3b at 1200°F, the conditional probability of reactor building leak levels for WWRaW or WWRbW.
6. For P-T cases 3b at 1200°F, the conditional probability of reactor building leak levels for CWWR.

7. For P-T case 4 at 150 psig and 800°F, the conditional probability of reactor building leak levels for CWWR (others are level a).

Some judgment was required to convert Expert C's results into the same form as those of Experts A and B. There is no bypass up to .25 psig when the blowout panels on the refueling floor open. Then at 2 psig, floor slabs etc. start to go. At 3 psig structural failure may begin. From MELCOR runs for Pesch Bottom, the pressure from WWR is in the range of 3 psig so we take the results from cases 1, 3, and 5 to be at 3 psig. The CWWR is in the 10 psig range so we take the results of cases 2, 4, and 6 to be at 10 psig. Interpolate linearly between points and extend on upper side by letting Level "b" go to zero at 15 psig, Level "c" increase until 15 psig then go to zero at 50 psig, and Level "d" increase to 1.0 at 50 psig. Table 4-3 is then converted to Table 4-4 for Expert C.

Table 4-4
Probability of Reactor Building Bypass for WWR--Expert C

| Bypass Level | Pressure (psig) | | | | | | | | | |
|-----------------|-----------------|-----|-----|------|-------|-------|------|-------|-------|-----|
| | 0 | .25 | 2 | 3 | 5 | 6 | 10 | 15 | 20 | 50 |
| a | 1.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| b | 0.0 | 1.0 | 1.0 | 0.75 | 0.62 | 0.56 | 0.30 | 0.0 | 0.0 | 0.0 |
| c | 0.0 | 0.0 | 0.0 | 0.25 | 0.293 | 0.314 | 0.40 | 0.525 | 0.450 | 0.0 |
| d | 0.0 | 0.0 | 0.0 | 0.0 | 0.086 | 0.129 | 0.30 | 0.475 | 0.550 | 1.0 |

Table 4-5 provides the aggregate results formed by averaging the probabilities of the three experts.

Table 4-5
Probability of Reactor Building Bypass for WWR--Aggregate

| Bypass Level | Pressure (kPa) | | | | | | | | | |
|-----------------|----------------|------|------|-------|-------|-------|-------|-------|-------|-------|
| | 0 | 1.72 | 13.8 | 20.7 | 34.5 | 41.4 | 68.9 | 103.4 | 137.8 | 344.6 |
| a | 1.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| b | 0.0 | 1.0 | 1.0 | 0.917 | 0.54 | 0.519 | 0.35 | 0.192 | 0.133 | 0.0 |
| c | 0.0 | 0.0 | 0.0 | 0.083 | 0.431 | 0.438 | 0.467 | 0.341 | 0.150 | 0.0 |
| d | 0.0 | 0.0 | 0.0 | 0.0 | 0.029 | 0.043 | 0.183 | 0.467 | 0.717 | 1.0 |

Individual Elicitations for Issue 4

Expert A's Elicitation

Effect of Wetwell Rupture on ECCS Survivability and Reactor Building Integrity at Peach Bottom

Description of Expert A's Rationale/Methodology

Rationale for Position on ECCS Survivability

Expert A felt that the probability of a catastrophic rupture was extremely small. He felt that a catastrophic rupture would definitely produce fragments and that a noncatastrophic rupture would produce a pressure pulse. He felt that the likelihood of a fragment fully penetrating the reactor building wall was less than 1% so it is not included in the Expert's assessment.

1. The Expert felt that the most likely direction of the fragments is radially outward from the containment centerline. The ceiling of the torus room is therefore an unlikely target.
2. The 2-ft-thick reinforced concrete ceilings are an effective barrier to missiles (fragments). Even if directed upwards, the fragments would not fully penetrate the torus room ceiling.
3. The CRD and condensate piping, which are located above the torus room, will never be in jeopardy from the fragments produced in a catastrophic wetwell rupture.
4. The HPSW lines are located along one side of the torus room and are not protected by the concrete wall. The Expert stated that there are eight segments of the wetwell in which the wetwell is equally likely to fail. The chance that the wetwell will fail in the area of the HPSW lines is therefore about 4/8 (0.50).

Method for Assessing Probability of Reactor Building Bypass

Expert A provided the probabilities of reactor building bypass conditional on pressure pulses in the reactor building. He left the calculation of the pressure pulses given wetwell rupture for the NUREG-1150 staff. The probabilities of the reactor building bypass levels discussed in the Issue Description are given in Table A-1 for several equivalent static pressures.

Table A-1
Descriptions of Equivalent Static Pressures

| Equivalent Static Pressure (psig) | Reactor Building Bypass Level | Comments |
|--------------------------------------|----------------------------------|--|
| $P_{rb}^* < 0.25$ | Level a | Reactor building blowout panels open at 0.25 psig |
| $P_{rb} < 3.0$ | Level a and Level b | Same comment |
| $P_{rb} < 5.0$ | Level b and Level b' | Concrete plugs and hatches in corner room open |
| $P_{rb} < 10.0$ | Level b' | Some leakage to environment; some to reactor building blowout panels |
| $P_{rb} < 20.0$ | Level b' and Level d | Some chance of reactor building structural failure |
| $P_{rb} > 20.0$ | Level d | Virtually certain of structural failure |

* P_{rb} : equivalent static pressure (psig) in the reactor building.

Level b': a new level defined by the Expert. Concrete plugs in the torus room lift, leakage into the corner room, and hatches open there to the environment (about 150 ft²) and to the reactor building (about 200 ft²). For our analysis, this is equivalent to level c, a large bypass of the reactor building.

Results of Expert A's Elicitation

Probability of Injection Line Failure Due to Wetwell Rupture

1. The probability of failure of the CRD lines or the condensate lines given rupture in the wetwell is essentially zero (see preceding section).
2. The probability of failure of the HPS waterline, given a catastrophic rupture in the wetwell, is about 0.50. This represents 4/8 (see preceding section).

Probability of Reactor Building Bypass Due to Wetwell Rupture

The probabilities of Levels a, b, b', and d are shown as a function of pressure in Table A-2.

Table A-2
Probability of Reactor Building Bypass--Expert A

| | Pressure (psig) | | | | | | |
|------------|-----------------|-----|-----|-----|-----|-----|-----|
| | 0 | .25 | 3 | 5 | 10 | 15 | 20 |
| Level a | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Level b | 0.0 | 1.0 | 1.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Level b'=c | 0.0 | 0.0 | 0.0 | 1.0 | 1.0 | 0.5 | 0.0 |
| Level d | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.5 | 1.0 |

Expert A said to use linear interpolation for the transition from Level "b" to "b'" (between 3 and 5 psig) and for Level "b'" to "d" (between 10 and 20 psig). At .25 psig, Level a switches to Level "b" as the blowout panels open.

To read the table:

1. Below 0.25 psig--Level "a" occurs.
2. Between 0.25 and 3 psig--Level "b" occurs.
3. Between 3 and 5 psig--a linear transfer from Level "b" to Level "b'" occurs.
4. Between 5 and 10 psig--Level "b'" occurs.
5. Between 10 and 20 psig--a linear transfer from Level "b'" to Level "d" occurs.
6. Above 20 psig--Level "d" occurs.

For example, at 15 psig there is a 50% probability that the reactor building bypass level is Level "b'" and a 50% probability that the reactor building bypass level is Level "d".

Sources of Uncertainty

Fragments could impact the concrete torus room ceiling and could decrease the pressure capacity of the ceiling. The impact on side walls is inconsequential because they are below grade. The likelihood of fragments directed vertically is small; this was not accounted for in the Expert's elicitation.

Correlations with Other Variables

No correlations were specified by the expert for this issue.

Suggestions for Reducing Uncertainty

Additional information on the reactor building structure would help in reducing the uncertainty in the building response. No explicit calculations of reactor building structural capacity were made; capacity was estimated based on design pressure and assessed safety margin.

Expert B's Elicitation

Effect of Wetwell Rupture on ECCS Survivability and Reactor Building Integrity at Peach Bottom

Description of Expert B's Rationale/Methodology

In analyzing this issue, Expert B reasoned as follows:

1. The expected pressure at which the torus may rupture was 130 to 150 psig or above.
2. Two time regimes were important-before core damage and vessel breach. The Expert said that the response of the torus will be the same in these two cases since the temperature will be roughly the same.
3. The piping that is of interest is:
 - (i) HPSW to RHR discharge lines, covers one half of torus room.
 - (ii) Condensate piping in steam tunnel.
 - (iii) CRD lines, penetrate DW at 78°, 112°, 248°, and 292°.
4. Existing hatches in the torus room roof slab vent either into the reactor building or directly to the outside.
5. Peach Bottom containment P-T failure analysis (see Peach Bottom P-T issue writeup) shows that the torus shell is thinner in the upper segment and that it will be near or at yield in the circumferential direction when rupture is expected to occur. A crack is therefore more likely to propagate.
6. Any of the eight non-
gments may rupture.
7. With the crack propagating from the stiffener location, along the circumference, the thinner upper torus segment can fragment into several pieces (worst case).
8. From physical considerations, weld detail etc., four to six fragments are expected. The weight of each fragment will be about 3000 to 4000 lbs.
9. Estimated velocity of impact will be about 150 ft/s.
10. The kinetic energy of the missiles is smaller than the tornado generated automobile missile.
11. The available concrete thickness (23 to 33 in.) will be adequate to withstand the missile at elev 135'-0".

12. The presence of steel beams on the bottom surface of the slab will deform the missile, thus dissipating energy.
13. Missiles are therefore not expected to be able to reach the CRD and condensate pipe locations.
14. HPWS/RHR line runs through the torus room and will be impacted if the break occurs in four of the eight non-vent segments.
15. The above calculations are based on decoupling pressure effects.
16. Because the torus area vents to the 135'-0" floor of the reactor building (about 500 ft²), the reactor building will pressurize as the torus depressurizes. However, the increase in reactor building pressure is not very well known.
17. Because of the vent to the outside (about 300 ft²), part of the flow will bypass the reactor building.

Results of Expert B's Elicitation

Expert B decomposed the problem in the following way.

Rupture locations are the non-vent segments of the torus, of which there are eight. Failure of any of the segments is equally likely. Independent of location, the likelihood of fragments is four times that of no fragments. The probability of fragments is .8, the probability of no fragments is .2. Even with fragments, all failures are ruled out except for impact and failure of the HPSW/RHR lines. The probability of impact is non-zero only for four of the non-vent segments near the piping. Given impact, the probability of failure is 1.0. If there are no fragments, then failure of the piping is negligible and the reactor building failure is dependent on peak pressure and venting considerations.

Because of the lack of structural information on the reactor building, all of the experts based their failure pressure distribution on their general knowledge of similar structures. The Expert said that the building was designed to normally 3 psig and should be able to withstand up to 6 psig. The probability of failure was therefore:

| <u>Pressure (psig)</u> | <u>Probability of Failure</u> |
|----------------------------|-------------------------------|
| 0 | 0 |
| 6 | 0 |
| 10 | .25 |
| 20 | >.5 |
| 50 | 1.0 |

The implication of Expert B's elicitation was that this would be a gross failure of the reactor building and, that, this failure would result in

what we would classify as a Level "d" bypass. The Expert did not consider the blowout panels. Since no significant leak is possible below .25 psig when the blowout panels rupture, we can construct the following table for leakage level vs pressure:

| | <u>Pressure</u> | | | | | |
|---------|-----------------|------------|-----------|------------|------------|------------|
| | <u>0</u> | <u>.25</u> | <u>.6</u> | <u>1.0</u> | <u>2.0</u> | <u>5.0</u> |
| Level a | 1.0 | 1.0 | 0 | 0 | 0 | 0 |
| Level b | 0 | 1.0 | 1.0 | .75 | .40 | 0 |
| Level c | 0 | 0 | 0 | 0 | 0 | 0 |
| Level d | 0 | 0 | 0 | .25 | .60 | 1.0 |

Where we have used .6 to represent the Expert's assessment of >.5 and used our general knowledge of the reactor building to fill in the lower portion of the curve (i.e., < .25 psig).

Sources of Uncertainty

The Expert identified the following areas of uncertainty:

1. Will the torus rupture be a large leakage or fragmentation of the torus shell?
2. What will be the weight and velocity of the fragments?
3. What will be the pressure in the torus after the blowdown?
4. What will be the pressure in the reactor building?

Correlation with Other Variables

The Expert did not specify any correlation with other variables.

Suggested Methods of Reducing Uncertainty

The Expert said that if more information could be obtained on the structural strength of the reactor building, then the failure pressure could be specified more precisely.

Expert C's Elicitation

Effect of Wetwell Rupture on ECCS Survivability and Reactor Building Integrity at Peach Bottom

Determination of Expert C's Rationale/Methodology

The Expert tied his elicitation on this issue to his elicitation on the P-T induced containment failure. He used the same cases as before and the same failure modes and probabilities. For the catastrophic wetwell rupture case, he then branched out to the cases for this issue.

Results of Expert C's Elicitation

For P-T Cases 1, 2, and 3 at 170 psig and $< 500^{\circ}\text{F}$, the conditional probability of failing due to CWR:

1. The reactor building only = .18
2. The HPSW pipe only = .04
3. Both reactor building and HPSW pipe = .08
4. Failing neither = .70

For P-T Cases 1, 2, and 3 at 150 psig and $< 500^{\circ}\text{F}$, the conditional probability of failing due to CWR:

1. The reactor building only = .39
2. The HPSW pipe only = .03
3. Both reactor building and HPSW pipe = .09
4. Failing neither = .55

For P-T Case 3 at 150 psig and 800°F , the conditional probability of failing due to CWR:

1. The reactor building only = .08
2. The HPSW pipe only = .06
3. Both reactor building and HPSW pipe = .06
4. Failing neither = .80

For P-T Cases 1 and 2 at 170 psig, the conditional probability of reactor building leak levels for WWRaW or WWRbW is:

1. Level a = .70
2. Level b = .05
3. Level c = .25
4. Level d = .00

For P-T Cases 1 and 2 at 170 psig, the conditional probability of reactor building leak levels for CWR is:

1. Level a = .20
2. Level b = .10
3. Level c = .40
4. Level d = .30

For P-T Cases 3a at 150 psig and 600°F, the conditional probability of reactor building leak levels for WWRaW or WWRbW is:

1. Level a = .80
2. Level b = .05
3. Level c = .15
4. Level d = .00

For P-T Cases 3a at 150 psig and 800°F, the conditional probability of reactor building leak levels for CWR is:

1. Level a = .30
2. Level b = .10
3. Level c = .40
4. Level d = .20

For P-T Cases 3b at 1200°F, the conditional probability of reactor building leak levels for WWRaW or WWRbW is:

1. Level a = .70
2. Level b = .05
3. Level c = .25
4. Level d = 0.0

For P-T Case 3b at 1200°F, the conditional probability of reactor building leak levels for CWR is:

1. Level a = .20
2. Level b = .10
3. Level c = .40
4. Level d = .30

For P-T Case 4 at 150 psig and 800°F, the conditional probability of reactor building leak levels for CWR (others are Level "a") is:

1. Level a = .08
2. Level b = .06
3. Level c = .06
4. Level d = 0.80

Because of the blowout panels to the outside on the refueling floor and to the turbine building, there will always be some bypass for WWR. Therefore, the Expert's Level "a" is really Level "b" for the purposes of our modeling of this issue and the two results for "a" and "b" will be added together in the aggregation.

Sources of Uncertainty

Expert C suggested that more information on the structural strength of the reactor building would enable him to reduce the uncertainty on the reactor building failure pressure for the different scenarios.

Correlations with Other Variables

No correlations were specified by the expert for this issue.

Suggested Methods for Reducing Uncertainty

Obtain more information on the reactor building structure.

5.5 Issue 5: Containment Failure at Sequoyah Due to Static Pressure

Experts consulted: David Clauss, Sandia National Laboratories; Kam Mohktarian, Chicago Bridge & Iron; Don Wesley, IMPELL.

Issue Description

The issue is: what distribution characterizes the failure pressures for static loading of the Sequoyah Containment? what conditional probabilities describe the failure modes for each pressure?

The Sequoyah ice condenser containment is in the shape of a cylinder with a hemispherical dome. There is an outer building constructed of reinforced concrete, but this issue concerns only with the pressure boundary. The pressure boundary is located within the concrete shed structure and is a free-standing steel shell with external stiffeners. The foundation is a reinforced concrete slab, and the steel shell is embedded in this slab. The design pressure is 10.8 psig. The free volume is about 1,200,000 ft³. The containment consists of three compartments: the lower compartment which contains the RCS, steam generators, etc.; the ice condenser itself; and the upper compartment, which contains the polar crane and little else.

Three pressure rise cases were described in the original definition of the issue:

1. Rapid pressure increase at vessel breach;
2. Late deflagration; and
3. Late, gradual pressure rise.

Typical rise times for cases 1 and 2 would be on the order of a few seconds. While very high atmospheric temperatures might be observed for a fraction of a minute in case 1, the bulk temperature of the steel liner which forms the pressure boundary is not expected to exceed 300 to 350°F for any of the cases. Containment failure due to detonations is considered in another issue.

It is necessary to distinguish between failure locations that would bypass the ice condenser and those which would not. Failure of the dome, or of the equipment hatch, creates a path from the upper compartment to the environment, which does not bypass the ice condenser. Failure in the ice condenser itself is assumed to create a bypass, but 60° of the containment wall is not occupied by the ice condenser, and failure in this segment would not bypass the ice condenser. Failure at the cylinder-base mat junction is below the bottom of the ice condenser, and opens a path from the lower compartment to the outside, bypassing the ice condenser completely. The concrete building surrounding the steel shell is not considered to be a significant barrier as its pressure capability is less than that of the steel shell.

The original issue definition of a large hole or rupture was an opening larger than 1.0 ft², which resulted in depressurization in less than about 2 h. A small hole or leak was anything smaller than 1.0 ft², which did not result in depressurization in less than about 2 h. A review of this matter showed that large dry containments would depressurize in 2 h for holes sizes on the order of 0.3 to 0.5 ft². Thus a small hole or leak should have been on the order of 0.1 ft², and 1.0 ft² is definitely a large hole or rupture.

The failure mode "Catastrophic Rupture" (CR) was added at the time of elicitation. The containment failure implied by this failure mode is complete failure of a substantial portion of the containment pressure boundary, with possible disruption of the piping systems that penetrate or are attached to the containment wall. Catastrophic rupture is judged to always result in bypass of the ice condenser. No gross structural failure is implied by the "Rupture" failure mode.

Summary of Results

The three panel members considering this issue all agreed that the three cases could be treated together since the pressure rise times were slow enough that structural response could be considered static. However, they stressed that the pressure rise time and the ultimate load in the absence of failure must be considered in determining the failure mode since the development of a leak will not arrest the pressure rise for events with fast rise times such as deflagrations and direct containment heating. Two of the three concluded that high temperature conditions (500 to 600°F) warranted separate consideration. One expert identified a separate failure mode for the higher temperature range. However, there was confusion in the initial issue statement as to the exact meaning of the temperatures given there. The temperatures in the 500 to 600°F range are transitory air temperatures in the upper compartment, not bulk temperatures of the structural steel shell. The surface temperatures of the shell may reach these temperatures briefly, but the average temperature in the membrane never exceeds 300 to 350°F. Thus the high temperature results were not needed, and were not utilized.

The distributions of the three experts, in the form received, are given in Table 5-1 for Expert A, Table 5-2 for Expert B, and Table 5-3 for Expert C. These tables were transformed into a common form for aggregating. These are Tables 5-4, 5-5, and 5-6. The data manipulations required are discussed in the next section. Note that the conditional probabilities for failure mode are interval probabilities, that is, they apply only for failure in the interval between the pressure indicated and the pressure on the previous line.

Expert A concluded that the containment would fail by either catastrophic rupture of the cylindrical shell or buckling of the equipment hatch. He provided independent cumulative failure probabilities for each location as shown in Table 5-1. Failure of the shell would always be a catastrophic

rupture, which bypasses the ice condenser. Buckling of the equipment hatch would always be a leak. Because of the location of the hatch, this leak does not bypass the ice condenser. Expert A thought that the median pressure for failure of the shell was 80 psig, whereas hatch buckling would only reach a cumulative probability of 10% at 120 psig. Thus, Expert A's conclusions were heavily weighted toward catastrophic rupture.

Table 5-1
Sequoyah Static. Failure Probabilities for Expert A

| Pressure (psig) | Cylinder Shell | | Hatch Buckling | |
|--------------------|-----------------------------|--|-----------------------------|---------------------------|
| | Cumulative Failure Prob. | Conditional Prob. Catastrophic Rup. | Cumulative Failure Prob. | Conditional Prob. Leak |
| 20 | 0.000 | 1.000 | 0.000 | 1.000 |
| 25 | 0.000 | 1.000 | 0.000 | 1.000 |
| 30 | 0.000 | 1.000 | 0.000 | 1.000 |
| 35 | 0.000 | 1.000 | 0.000 | 1.000 |
| 40 | 0.000 | 1.000 | 0.000 | 1.000 |
| 45 | 0.000 | 1.000 | 0.000 | 1.000 |
| 50 | 0.001 | 1.000 | 0.000 | 1.000 |
| 55 | 0.010 | 1.000 | 0.000 | 1.000 |
| 60 | 0.035 | 1.000 | 0.000 | 1.000 |
| 65 | 0.100 | 1.000 | 0.000 | 1.000 |
| 70 | 0.210 | 1.000 | 0.000 | 1.000 |
| 75 | 0.340 | 1.000 | 0.000 | 1.000 |
| 80 | 0.500 | 1.000 | 0.001 | 1.000 |
| 85 | 0.630 | 1.000 | 0.010 | 1.000 |
| 90 | 0.760 | 1.000 | 0.020 | 1.000 |
| 95 | 0.840 | 1.000 | 0.033 | 1.000 |
| 100 | 0.920 | 1.000 | 0.047 | 1.000 |
| 105 | 0.960 | 1.000 | 0.060 | 1.000 |
| 110 | 0.980 | 1.000 | 0.073 | 1.000 |
| 115 | 0.990 | 1.000 | 0.087 | 1.000 |
| 120 | 1.000 | 1.000 | 0.100 | 1.000 |

Expert B thought that the containment could fail by rupture of the cylindrical shell, ovalization of the hatch flange, or failure of the anchorage system (see Table 5-2). He provided independent distributions for each location. For each location, he provided conditional probabilities for failure mode. For rupture of the shell, his median failure pressure was 60 psig. For shell failure, he was certain that the mode would be rupture below 50 psig and catastrophic failure above 55 psig. It was assumed that the shell ruptures would be randomly distributed in azimuth. As the ice

Table 5-2
Sequoyah Static Failure Probabilities for Expert B

| Pressure (psia) | Cylinder Shell | | | Match Ovalization | | | Anchorage Failure | | |
|--------------------|----------------------------|---------------------------|-----------------------------|----------------------------|------------------------|---------------------------|----------------------------|------------------------|---------------------------|
| | Cumul. Failure Prob. | Cond. Prob. Rupture | Cond. Prob. Cat. Rup. | Cumul. Failure Prob. | Cond. Prob. Leak | Cond. Prob. Rupture | Cumul. Failure Prob. | Cond. Prob. Leak | Cond. Prob. Rupture |
| 20 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 25 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 30 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 35 | 0.005 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 40 | 0.008 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 45 | 0.008 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 50 | 0.010 | 0.800 | 0.200 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 55 | 0.100 | 0.300 | 0.700 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 60 | 0.500 | 0.000 | 1.000 | 0.000 | 1.000 | 0.000 | 0.000 | 1.000 | 0.000 |
| 65 | 0.620 | 0.000 | 1.000 | 0.010 | 1.000 | 0.000 | 0.100 | 1.000 | 0.000 |
| 70 | 0.750 | 0.000 | 1.000 | 0.090 | 0.800 | 0.200 | 0.250 | 1.000 | 0.000 |
| 75 | 0.900 | 0.000 | 1.000 | 0.099 | 0.200 | 0.800 | 0.500 | 0.700 | 0.300 |
| 80 | 0.990 | 0.000 | 1.000 | 0.099 | 0.000 | 1.000 | 0.600 | 0.000 | 0.700 |
| 85 | 0.992 | 0.000 | 1.000 | 0.999 | 0.000 | 1.000 | 0.850 | 0.000 | 1.000 |
| 90 | 0.994 | 0.000 | 1.000 | 0.999 | 0.000 | 1.000 | 0.900 | 0.000 | 1.000 |
| 95 | 0.995 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 | 0.930 | 0.000 | 1.000 |
| 100 | 0.996 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 | 0.950 | 0.000 | 1.000 |
| 105 | 0.997 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 | 0.990 | 0.000 | 1.000 |
| 110 | 0.998 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 | 0.995 | 0.000 | 1.000 |
| 115 | 0.999 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 | 0.999 | 0.000 | 1.000 |
| 120 | 1.000 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 | 1.000 | 0.000 | 1.000 |

condenser occupies 300° of the outer wall of the containment, five sixths of the shell ruptures will occur in the ice condenser and will therefore bypass it, while one sixth of the shell ruptures will not bypass the ice condenser. Expert B was certain that ovalization of the hatch flange would cause containment failure between 65 and 70 psig. As the size of the opening depends directly upon the expansion of the shell, which in turn causes the ovalization of the flange, he was certain it would be a leak below 70 psig and a rupture above 75 psig. For anchorage failure, Expert B's median failure pressure was 75 psig. He was certain that the mode would be leak below 75 psig and catastrophic failure above 80 psig. All anchorage failures will bypass the ice condenser.

Expert C provided joint cumulative failure probabilities for the five failure modes directly, as shown in Table 5-3. His median failure pressure is about 54 psig. At the lower failure pressures all failure modes are possible, but at the higher failure pressures the predominant failure mode is CR.

Table 5-3
Sequoyah Static. Failure Probabilities for Expert C

| Pressure (psig) | Joint Cumulative Probabilities | | | | | |
|--------------------|--------------------------------|----------------|----------------------|-------------------|-------------------------|--------------|
| | Leak No Bypass | Leak Bypass | Rupture No Bypass | Rupture Bypass | Catastrophic Rupture | All Modes |
| 20 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 30 | 0.015 | 0.025 | 0.005 | 0.010 | 0.000 | 0.055 |
| 35 | 0.030 | 0.050 | 0.010 | 0.020 | 0.000 | 0.110 |
| 40 | 0.035 | 0.055 | 0.020 | 0.060 | 0.005 | 0.175 |
| 45 | 0.040 | 0.060 | 0.030 | 0.100 | 0.010 | 0.240 |
| 50 | 0.040 | 0.065 | 0.100 | 0.130 | 0.025 | 0.360 |
| 55 | 0.040 | 0.070 | 0.170 | 0.160 | 0.040 | 0.480 |
| 60 | 0.040 | 0.070 | 0.190 | 0.180 | 0.170 | 0.650 |
| 65 | 0.040 | 0.070 | 0.210 | 0.200 | 0.300 | 0.820 |
| 70 | 0.040 | 0.070 | 0.215 | 0.205 | 0.380 | 0.910 |
| 75 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 80 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 85 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 90 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 95 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 100 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 105 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 110 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 115 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |
| 120 | 0.040 | 0.070 | 0.220 | 0.210 | 0.460 | 1.000 |

Table 5-4
 Conversion of Expert A's Elicitation Values from Table 5-1

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Probabilities | | | | |
|--------------------|--------------------------------------|-----------------------------|------------------------------------|----------------|----------------------|-------------------|-------------------------|
| | | | Leak No Bypass | Leak Bypass | Rupture No Bypass | Rupture Bypass | Catastrophic Rupture |
| 20 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 30 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 35 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 40 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 45 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 50 | 0.001 | 0.001 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 55 | 0.010 | 0.009 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 60 | 0.035 | 0.025 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 65 | 0.100 | 0.065 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 70 | 0.210 | 0.110 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 75 | 0.340 | 0.130 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 80 | 0.501 | 0.160 | 0.004 | 0.000 | 0.000 | 0.000 | 0.996 |
| 85 | 0.634 | 0.133 | 0.029 | 0.000 | 0.000 | 0.000 | 0.971 |
| 90 | 0.765 | 0.131 | 0.029 | 0.000 | 0.000 | 0.000 | 0.977 |
| 95 | 0.845 | 0.080 | 0.032 | 0.000 | 0.000 | 0.000 | 0.968 |
| 100 | 0.924 | 0.078 | 0.021 | 0.000 | 0.000 | 0.000 | 0.979 |
| 105 | 0.962 | 0.039 | 0.020 | 0.000 | 0.000 | 0.000 | 0.980 |
| 110 | 0.981 | 0.019 | 0.021 | 0.000 | 0.000 | 0.000 | 0.979 |
| 115 | 0.991 | 0.009 | 0.022 | 0.000 | 0.000 | 0.000 | 0.978 |
| 120 | 1.000 | 0.009 | 0.022 | 0.000 | 0.000 | 0.000 | 0.978 |

Table 5-5
 Conversion of Expert B's Elicitation Values from Table 5-2

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Probabilities | | | | |
|--------------------|--------------------------------------|-----------------------------|------------------------------------|----------------|----------------------|-------------------|-------------------------|
| | | | Leak No Bypass | Leak Bypass | Rupture No Bypass | Rupture Bypass | Catastrophic Rupture |
| 20 | 0.000 | 0.000 | 0.000 | 0.000 | 0.167 | 0.833 | 0.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.000 | 0.167 | 0.833 | 0.000 |
| 30 | 0.000 | 0.000 | 0.000 | 0.000 | 0.167 | 0.833 | 0.000 |
| 35 | 0.005 | 0.005 | 0.000 | 0.000 | 0.167 | 0.833 | 0.000 |
| 40 | 0.006 | 0.001 | 0.000 | 0.000 | 0.167 | 0.833 | 0.000 |
| 45 | 0.008 | 0.002 | 0.000 | 0.000 | 0.167 | 0.833 | 0.000 |
| 50 | 0.010 | 0.002 | 0.000 | 0.000 | 0.133 | 0.667 | 0.200 |
| 55 | 0.100 | 0.090 | 0.000 | 0.000 | 0.050 | 0.250 | 0.700 |
| 60 | 0.500 | 0.400 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 65 | 0.661 | 0.161 | 0.043 | 0.435 | 0.000 | 0.000 | 0.522 |
| 70 | 0.898 | 0.337 | 0.822 | 0.119 | 0.156 | 0.000 | 0.103 |
| 75 | 1.000 | 0.002 | 0.004 | 0.428 | 0.018 | 0.183 | 0.387 |
| 80 | 1.000 | 0.000 | 0.000 | 0.231 | 0.000 | 0.578 | 0.231 |
| 85 | 1.000 | 0.000 | 0.000 | 0.000 | 0.002 | 0.960 | 0.038 |
| 90 | 1.000 | 0.000 | 0.000 | 0.000 | 0.002 | 0.960 | 0.038 |
| 95 | 1.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 100 | 1.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 105 | 1.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 110 | 1.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 115 | 1.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |
| 120 | 1.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 1.000 |

Table 5-6
Conversion of Expert C's Elicitation Values from Table 5-3

| Pressure (psia) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Probabilities | | | | |
|--------------------|--------------------------------------|-----------------------------|------------------------------------|----------------|----------------------|-------------------|-------------------------|
| | | | Leak No Bypass | Leak Bypass | Rupture No Bypass | Rupture Bypass | Catastrophic Rupture |
| 20 | 0.000 | 0.000 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 25 | 0.000 | 0.000 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 30 | 0.055 | 0.055 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 35 | 0.110 | 0.055 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 40 | 0.175 | 0.065 | 0.077 | 0.077 | 0.154 | 0.615 | 0.077 |
| 45 | 0.240 | 0.065 | 0.077 | 0.077 | 0.154 | 0.615 | 0.077 |
| 50 | 0.380 | 0.120 | 0.000 | 0.042 | 0.583 | 0.250 | 0.120 |
| 55 | 0.480 | 0.120 | 0.000 | 0.042 | 0.583 | 0.250 | 0.120 |
| 60 | 0.650 | 0.170 | 0.000 | 0.000 | 0.118 | 0.118 | 0.765 |
| 65 | 0.820 | 0.170 | 0.000 | 0.000 | 0.118 | 0.118 | 0.765 |
| 70 | 0.910 | 0.090 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 75 | 1.000 | 0.090 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 80 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 85 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 90 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 95 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 100 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 105 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 110 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 115 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |
| 120 | 1.000 | 0.000 | 0.000 | 0.000 | 0.056 | 0.056 | 0.889 |

Table 5-7 gives the aggregate distribution. The three individual distributions were aggregated as explained in the next section. The median of the average distribution is about 64 psig. The 5 and 95% failure pressures are about 39 and 95 psig, respectively. At the very lowest failure pressures, leak is the dominant failure mode. Above the median failure pressure, catastrophic rupture is the dominant failure mode.

Figure 5-1 shows the cumulative failure probability for static failure pressure at Sequoyah for the three experts who considered this issue and the aggregate. Figures 5-2 through 5-6 are plots of the conditional probabilities for the five failure modes. These plots do not have a smooth monotonic appearance since each expert thought that each failure mode was most likely to occur in a different pressure range.

Table 5-7
Aggregate Static Failure Probabilities for Sequoyah

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Probabilities | | | | |
|--------------------|--------------------------------------|-----------------------------|------------------------------------|----------------|----------------------|-------------------|-------------------------|
| | | | Leak No Bypass | Leak Bypass | Rupture No Bypass | Rupture Bypass | Catastrophic Rupture |
| 20 | 0.000 | 0.000 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 25 | 0.000 | 0.000 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 30 | 0.018 | 0.018 | 0.273 | 0.455 | 0.091 | 0.182 | 0.000 |
| 35 | 0.038 | 0.020 | 0.250 | 0.417 | 0.097 | 0.236 | 0.000 |
| 40 | 0.060 | 0.022 | 0.076 | 0.076 | 0.154 | 0.619 | 0.076 |
| 45 | 0.083 | 0.022 | 0.075 | 0.075 | 0.154 | 0.822 | 0.075 |
| 50 | 0.124 | 0.041 | 0.000 | 0.041 | 0.571 | 0.255 | 0.133 |
| 55 | 0.187 | 0.073 | 0.000 | 0.023 | 0.340 | 0.240 | 0.367 |
| 60 | 0.395 | 0.198 | 0.000 | 0.000 | 0.034 | 0.034 | 0.933 |
| 65 | 0.527 | 0.132 | 0.018 | 0.177 | 0.050 | 0.050 | 0.704 |
| 70 | 0.706 | 0.179 | 0.390 | 0.075 | 0.107 | 0.009 | 0.418 |
| 75 | 0.780 | 0.074 | 0.000 | 0.004 | 0.023 | 0.024 | 0.950 |
| 80 | 0.833 | 0.054 | 0.004 | 0.600 | 0.000 | 0.000 | 0.898 |
| 85 | 0.878 | 0.044 | 0.029 | 0.000 | 0.000 | 0.000 | 0.971 |
| 90 | 0.922 | 0.044 | 0.023 | 0.000 | 0.000 | 0.000 | 0.977 |
| 95 | 0.948 | 0.027 | 0.032 | 0.000 | 0.000 | 0.000 | 0.968 |
| 100 | 0.975 | 0.026 | 0.021 | 0.000 | 0.000 | 0.000 | 0.979 |
| 105 | 0.987 | 0.013 | 0.020 | 0.000 | 0.000 | 0.000 | 0.980 |
| 110 | 0.994 | 0.006 | 0.021 | 0.000 | 0.000 | 0.000 | 0.979 |
| 115 | 0.997 | 0.003 | 0.022 | 0.000 | 0.000 | 0.000 | 0.978 |
| 120 | 1.000 | 0.003 | 0.022 | 0.000 | 0.000 | 0.000 | 0.978 |




Figure 5-1. Cumulative Failure Probability.




Figure 5-2. Conditional Probability for Failure Mode: Leak, No Bypass.




Figure 5-3. Conditional Probability for Failure Mode: Leak, Bypass.




Figure 5-4. Conditional Probability for Failure Mode: Rupture, No Bypass.




Figure 5-5. Conditional Probability for Failure Mode: Rupture with Bypass.




Figure 5-6. Conditional Probability for Failure Mode: Catastrophic Rupture.

Method of Aggregation

Some manipulation was required to get each expert's elicitation values into the form of Tables 5-1, 5-2, and 5-3, so they could be combined to obtain Table 5-7. The distributions the experts provided were not for 5 psig increments (the actual values provided are given below), so interpolation has been used to determine probabilities for the 5 psig increments.

Converting the results of Expert A from Table 5-1 to Table 5-4 was straightforward since he had only shell and hatch failures, and the shell failures are always catastrophic failure and the hatch failures are always leak-no bypass. The Cumulative Failure Probability column in Table 5-4 is formed by the equation:

$$CFP(i) = 1 - (1 - G_{sh}(i)) * (1 - G_{ha}(i))$$

for each pressure interval i , where:

$CFP(i)$ is the total cumulative failure probability for interval i ;

$G_{sh}(i)$ is the independent cumulative probability for failure of the cylindrical shell for interval i ;

and

$G_{ha}(i)$ is the independent cumulative probability for failure of the hatch by buckling for interval i .

Above 75 psig, the standard formula for converting independent distributions to interval conditional probabilities was used. It is:

$$C_{ln}(i) = [(2 - CFP(i) - CFP(i-1)) * (G_{ha}(i) - G_{ha}(i-1))] / [(2 - G_{ha}(i) - G_{ha}(i-1)) * (CFP(i) - CFP(i-1))]$$

for each pressure interval i , where $CFP(i)$, $G_{sh}(i)$, and $G_{ha}(i)$ have been defined above, and

$C_{ln}(i)$ is - the interval conditional probability for leak - no bypass for interval i .

The equation for the interval conditional probability for CR, $C_{cr}(i)$, is analogous. The standard formulas did not give meaningful results for 120 psig, so the interval conditional probabilities for the previous interval were used.

Converting the results of Expert B from Table 5-2 to Table 5-5 was much more complicated since Expert B provided independent distributions for each location, and, for each location, conditional probabilities for failure mode. The Cumulative Failure Probability columns in Tables 5-2 and 5-5 are easily formed from:

$$CFP(i) = 1 - (1 - G_{sh}(i)) * (1 - G_{ha}(i)) * (1 - G_{an}(i))$$

for each pressure interval i , where where $CFP(i)$, $G_{sh}(i)$, and $G_{ha}(i)$ have been defined above, and

$G_{an}(i)$ is the independent cumulative probability for failure of the anchorage for interval i .

The interval conditional probabilities were more difficult to obtain. First the interval probability densities shown in Table 5-8 were obtained by backward differencing. Next the conditional probabilities in Table 5-2 were used to obtain the joint probability densities (joint on pressure interval, location, and mode) shown in Table 5-9. For rupture-no bypass failure of the shell, the shell failure probability density from Table 5-8 is multiplied by one sixth of the conditional probability for rupture for the shell (the third column) in Table 5-2 since only one sixth of the ruptures will not bypass the ice condenser. The other columns in Table 5-9 are found analogously.

The interval conditional probabilities shown in Table 5-5 are formed by considering similar failure modes together without regard to location and normalizing by the total density for that interval. There is only one catastrophic failure column (shell) in Table 5-9, so the entry in Table 5-5, for a given pressure interval, is just the entry in Table 5-9 divided by the sum of all the entries in that row in Table 5-9. There are two columns for rupture-bypass (shell and anchorage) in Table 5-9, so the entry in Table 5-5 is the sum of both of rupture-bypass entries in Table 5-9 divided by the sum of all the entries in that row in Table 5-9. Table 5-5 has the results of Expert B in the proper form for averaging with the results of Experts A and C.

Expert C gave joint cumulative probabilities for pressure and failure modes as shown in Table 5-3. The All Modes column, which is the sum of the five columns to the left of it, is therefore the cumulative failure probability shown in Table 5-6. The Failure Probability Density column in Table 5-2 is the backward difference of the cumulative failure probability. The Interval Conditional Probabilities in Table 5-6 are formed by considering the joint probability densities. That is, the backward differences of the entries in Table 5-3 are divided by the total Failure Probability Density, the second column in Table 5-6, to get the Interval Conditional Probabilities in Table 5-6.

Table 5-8
Interval Probabilty Densities

| Pressure (psig) | Total Cumulative Failure Probability | Failure Probability Density | | |
|--------------------|---|--------------------------------|-------|-----------|
| | | Shell | Hatch | Anchorage |
| 20 | 0.000 | 0.000 | 0.000 | 0.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.000 |
| 30 | 0.000 | 0.000 | 0.000 | 0.000 |
| 35 | 0.005 | 0.005 | 0.000 | 0.000 |
| 40 | 0.006 | 0.001 | 0.000 | 0.000 |
| 45 | 0.008 | 0.002 | 0.000 | 0.000 |
| 50 | 0.010 | 0.002 | 0.000 | 0.000 |
| 55 | 0.100 | 0.090 | 0.000 | 0.000 |
| 60 | 0.500 | 0.400 | 0.000 | 0.000 |
| 65 | 0.661 | 0.120 | 0.010 | 0.100 |
| 70 | 0.998 | 0.130 | 0.980 | 0.150 |
| 75 | 1.000 | 0.150 | 0.009 | 0.250 |
| 80 | 1.000 | 0.090 | 0.000 | 0.300 |
| 85 | 1.000 | 0.002 | 0.000 | 0.050 |
| 90 | 1.000 | 0.002 | 0.000 | 0.050 |
| 95 | 1.000 | 0.001 | 0.000 | 0.030 |
| 100 | 1.000 | 0.001 | 0.000 | 0.030 |
| 105 | 1.000 | 0.001 | 0.000 | 0.030 |
| 110 | 1.000 | 0.001 | 0.000 | 0.005 |
| 115 | 1.000 | 0.001 | 0.000 | 0.004 |
| 120 | 1.000 | 0.001 | 0.000 | 0.001 |

Table 5-9
Expert B's Joint Probability Densities

| Pressure (psig) | Shell Joint Failure Probability Density | | | Hatch Joint Fail. Prob. Dens. | | Anchor. Joint Fail. Prob. Dens. | |
|--------------------|--|-------------------|-------------------|----------------------------------|----------------------|------------------------------------|-------------------|
| | Rupture No Bypass | Rupture Bypass | Catas. Rupture | Leak No Bypass | Rupture No Bypass | Leak Bypass | Rupture Bypass |
| 20 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 30 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 35 | 0.001 | 0.004 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 40 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 45 | 0.000 | 0.002 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 50 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 55 | 0.005 | 0.023 | 0.063 | 0.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.000 | 0.000 | 0.400 | 0.000 | 0.000 | 0.000 | 0.000 |
| 65 | 0.000 | 0.000 | 0.120 | 0.010 | 0.000 | 0.100 | 0.000 |
| 70 | 0.000 | 0.000 | 0.130 | 0.784 | 0.196 | 0.150 | 0.000 |
| 75 | 0.000 | 0.000 | 0.150 | 0.002 | 0.007 | 0.175 | 0.075 |
| 80 | 0.000 | 0.000 | 0.090 | 0.000 | 0.000 | 0.090 | 0.210 |
| 85 | 0.000 | 0.000 | 0.002 | 0.000 | 0.000 | 0.000 | 0.050 |
| 90 | 0.000 | 0.000 | 0.002 | 0.000 | 0.000 | 0.000 | 0.050 |
| 95 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.030 |
| 100 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.030 |
| 105 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.030 |
| 110 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.005 |
| 115 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.004 |
| 120 | 0.000 | 0.000 | 0.001 | 0.000 | 0.000 | 0.000 | 0.001 |

The aggregation of the cumulative failure probability is a straightforward averaging process. That is, the aggregate values of the cumulative failure probability for each pressure interval in Tables 5-4, 5-5, and 5-6 are summed and divided by three. For the interval conditional probabilities, the aggregate is formed by weighting each expert's interval conditional probability by the failure probability density for the interval. The equation used is:

$$C(i,m) = \frac{[C_A(i,m) * D_A(i) + C_B(i,m) * D_B(i) + C_C(i,m) * D_C(i)]}{[D_A(i) + D_B(i) + D_C(i)]}$$

where:

C(i,m) is the aggregate conditional probability for failure in mode m, given that the failure occurs in pressure interval i;

$C_j(i,m)$ is Expert j 's conditional probability for failure in mode m , given that the failure occurs in pressure interval i ; and

$D_j(i)$ is Expert j 's probability that the containment will fail in pressure interval i .

This can be shown to be equivalent to averaging the joint probabilities. The proof is as follows: let

$D(i)$ be the aggregate probability that the containment will fail in pressure interval i ;

$J_j(i,m)$ be Expert j 's joint probability that the containment will fail in pressure interval i and in failure mode m ; and

$J(i,m)$ be the aggregate joint probability that the containment will fail in pressure interval i and in failure mode m ; and now

$$D(i) = [D_A(i) + D_B(i) + D_C(i)] / 3$$

and

$$J(i,m) = [J_A(i,m) + J_B(i,m) + J_C(i,m)] / 3.$$

The relationship between the failure probability density, D , the joint failure probability, J , and the conditional failure mode probability is:

$$J(i,m) = D(i) * C(i,m).$$

So

$$C(i,m) = J(i,m) / D(i) = ([J_A(i,m) + J_B(i,m) + J_C(i,m)] / 3) / ([D_A(i) + D_B(i) + D_C(i)] / 3).$$

Using the relationship between the density, the joint, and the conditional probabilities for each expert this becomes

$$C(i,m) = [C_A(i,m) * D_A(i) + C_B(i,m) * D_B(i) + C_C(i,m) * D_C(i)] / [D_A(i) + D_B(i) + D_C(i)]$$

as above.

Method of Determining Containment Failure

This section discusses the manner in which the results of the elicitations on this issue will be used in the event trees that follow the accident progression. For each observation in the sample, a sampling scheme selects a load pressure from a load distribution given by the Containment Loads Panel, and it selects a containment failure pressure from the aggregate curve given in Table 5-7. It also selects a random number between zero and one to be used to determine the mode of failure.

The load pressure and the containment failure pressure are compared by a user function in the event tree. If the load pressure is less than the containment failure pressure, the containment does not fail. If the load pressure is greater than or equal to the containment failure pressure, the containment fails. If the containment fails, the random number is used to determine the failure mode. Consider the following example: the failure pressure is 65 psig, the load pressure is 70 psig, and pressure rise is slow compared to the time it takes a leak to depressurize the containment. Because the occurrence of a leak will arrest the pressure rise, the interval conditional probability entries in Table 5-7 for 65 psig are used to determine the failure mode. The interval conditional probability for leak-no bypass is 0.018, so if the random number is less than 0.018, the failure mode is leak-no bypass. The interval conditional probability for leak-bypass is 0.177, so if the random number is between 0.018 and 0.195 (= 0.018 + 0.177) the failure mode is leak-bypass. The other failure modes are determined analogously. The following table gives the results for a failure pressure of 65 psig:

| <u>Range for Random Number</u> | <u>Failure Mode</u> |
|--------------------------------|----------------------|
| 0.000 - 0.018 | Leak-no bypass |
| 0.018 - 0.195 | Leak-bypass |
| 0.195 - 0.245 | Rupture-no bypass |
| 0.245 - 0.295 | Rupture-bypass |
| 0.295 - 1.000 | Catastrophic Rupture |

In Table 5-7, for 65 psig, the conditional probability for catastrophic failure is 0.704, not 0.705 as implied here. This difference is due to roundoff error.

If the pressure rise is fast compared to the time it takes a leak to depressurize the containment, the determination of the failure mode is more complicated. Again consider the example in which the failure pressure is 65 psig and the load pressure is 70 psig.

If a leak develops at 65 psig, the pressure will keep on rising, and a rupture or catastrophic failure may develop between 65 and 70 psig. To determine the appropriate failure probability density for determining the probabilities of ruptures and catastrophic failures between 65 and 70 psig, the portion of the distribution below 65 psig is discounted since failure has occurred at 65 psig. Thus, the density used to determine if an additional rupture may occur between 65 and 70 psig is not $FPD(70) = 0.179$, but $FPD(70)/(1 - CFP(65)) = 0.179/0.473 = 0.378$. The conditional probability of additional ruptures forming between 65 and 70 psig is the leak probability at 65 psig (0.018 + 0.177 = 0.195) times the appropriate failure density times the conditional rupture probability for the 70 psig interval. For the conditional probability of rupture-no bypass, the average of the values for 65 and 70 psig ($0.5*(0.50 + 0.107) = 0.0785$) is used. Thus, the conditional probability of rupture-no bypass for a fast pressure rise, failure pressure equal 65 psig, load pressure equal 70 psig is:

$$0.056 = 0.050 + 0.195 * 0.378 * 0.0785.$$

In general terms, this is:

$$R_{rn}(i) = R_{rn}(i-1) + (R_{ln}(i-1) + R_{lb}(i-1)) * 0.5 * \\ (C_{rn}(i) + C_{rn}(i-1)) * FPD(i) / (1 - CFP(i-1))$$

where:

$R_{rn}(i)$ is the interval conditional probability of rupture-no bypass for rapid pressure rise for pressure interval i ;

$R_{ln}(i)$ is the interval conditional probability of leak-no bypass for rapid pressure rise for pressure interval i ;

$R_{lb}(i)$ is the interval conditional probability of leak-bypass for rapid pressure rise for pressure interval i ;

$CFP(i)$ is the cumulative failure probability for all failure modes for pressure interval i ;

$FPD(i)$ is the failure probability density for all failure modes for pressure interval i ;

and

$C_{rn}(i)$ is the conditional failure probability for rupture-no bypass for pressure interval i .

Analogous equations are used to find the interval conditional probabilities of rupture-bypass (R_{rb}) and catastrophic rupture (R_{cr}) for fast pressure rise. The total remaining leak fraction (R_{lk}) is then found from:

$$R_{lk}(i) = 1 - R_{rn}(i) - R_{rb}(i) - R_{cr}(i).$$

The total leak fraction is split among leak-no bypass and leak-bypass by the same ratio as the original conditional probabilities for that interval.

Table 5-10 shows the failure mode probabilities for rapid pressure rise for a failure pressure of 65 psig. The entry for rupture-no bypass for a load pressure of 70 psig is 0.056 as calculated above.

Successive applications of the equations discussed above determine the entries for each row based on the row above and the entries in Table 5-7. Zeros have been entered for the failure mode probabilities in Table 5-7 where the load pressure is below the failure pressure. In a few rows of Table 5-7, the failure mode probabilities add to 0.999 or 1.001 instead of 1.000. This is due to roundoff error in the program used to generate Table 5-10.

After studying Table 5-10 some readers have inquired why the failure mode probabilities don't go to the upper limit values shown in Table 5-7. That is, why don't the entries for 100 to 120 psig in Table 5-10 closely

resemble the entries for 100 to 120 psig in Table 5-7? The answer is that the results shown in Table 5-10 come from a much different type of calculation. For rapid pressure rise, of the fraction of leaks that are still leaks at 110 psig, and for which an additional failure is calculated at 110 psig, 97.9% go to catastrophic rupture as indicated in Table 5-7. Table 5-10 shows the results of working up the pressure from 65 psig to the load pressures shown in the left column. Ruptures are non-zero for 70 and 75 psig, so the rupture probability for 120 psig in Table 5-10 cannot be zero as it is in Table 5-7.

Table 5-10
Failure Mode Probabilities for Rapid Pressure Rise
Failure Pressure = 65 psig

| Pressure (psig) | Cumulative Failure Probability | Failure Prob. Density | Interval Conditional Probabilities | | | | |
|--------------------|--------------------------------------|-----------------------------|------------------------------------|----------------|----------------------|-------------------|-------------------------|
| | | | Leak No Bypass | Leak Bypass | Rupture No Bypass | Rupture Bypass | Catastrophic Rupture |
| 20 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 30 | 0.018 | 0.018 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 35 | 0.036 | 0.020 | 0.000 | 0.500 | 0.000 | 0.000 | 0.000 |
| 40 | 0.060 | 0.022 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 45 | 0.083 | 0.022 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 50 | 0.124 | 0.041 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 55 | 0.197 | 0.073 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 60 | 0.395 | 0.196 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 65 | 0.527 | 0.132 | 0.018 | 0.177 | 0.050 | 0.050 | 0.704 |
| 70 | 0.706 | 0.178 | 0.122 | 0.023 | 0.056 | 0.053 | 0.746 |
| 75 | 0.780 | 0.074 | 0.001 | 0.116 | 0.058 | 0.053 | 0.771 |
| 80 | 0.833 | 0.054 | 0.087 | 0.002 | 0.059 | 0.054 | 0.799 |
| 85 | 0.878 | 0.044 | 0.066 | 0.000 | 0.059 | 0.054 | 0.822 |
| 90 | 0.912 | 0.044 | 0.043 | 0.000 | 0.059 | 0.054 | 0.845 |
| 95 | 0.948 | 0.027 | 0.029 | 0.000 | 0.059 | 0.054 | 0.859 |
| 100 | 0.975 | 0.026 | 0.014 | 0.000 | 0.050 | 0.054 | 0.873 |
| 105 | 0.997 | 0.013 | 0.007 | 0.000 | 0.059 | 0.054 | 0.880 |
| 110 | 0.994 | 0.006 | 0.004 | 0.000 | 0.059 | 0.054 | 0.884 |
| 115 | 0.997 | 0.003 | 0.002 | 0.000 | 0.059 | 0.054 | 0.886 |
| 120 | 1.000 | 0.003 | 0.000 | 0.000 | 0.058 | 0.054 | 0.887 |

Individual Elicitations f : Issue 5

Expert A's Elicitation

Containment Failure at Sequoyah Due to Static Pressure

Description of Expert A's Rationale/Methodology

Expert A considered seven failure modes or locations.

1. Membrane Failure of the Cylinder
2. Membrane Failure of the Dome
3. Buckling of the Equipment Hatch
4. Personnel Airlock
5. Pipe Penetrations
6. Electrical Penetrations
7. Anchor Bolts.

Expert A ruled out failure of the dome: since it is hemispherical and has about the same thickness as the cylinder, it will be stronger than the cylinder. Based on previous work and knowledge, he concluded that the personnel airlock would not fail before the cylinder. Only local yielding could be expected up to pressures well above the cylinder failure pressures, and the flexible seals can accommodate what yielding may occur. Since the IDCOR study showed that pipe penetrations had high safety margins, he did not consider them further. The electrical penetrations were also ruled out as a Westinghouse study showed they were good to 100 psig or more at about 340°F. Thus, the lower bound for electrical penetration failure is above the upper bound for membrane failure of the cylinder.

Details of the equipment penetration reinforcement were not available for review. Based on experience with other free-standing steel containments, Expert A expected the penetration reinforcement to be somewhat over-reinforced compared to the shell-stiffener system away from major penetrations. Also, the plate thickness is 5/8 in. to 11/16 in. in the area of the equipment hatch. This is expected to result in a stiff area around the penetration with strains significantly less than those in the 1/2-in. plate near the spring line. Consequently, leakage from the equipment penetration-hatch interface due to ovalization or other distortion is not expected to be a controlling mode of failure.

Expert A considered cylinder membrane failure, equipment hatch buckling, and anchor bolt failure in some detail.

Based on the drawing of the anchor bolts available to Expert A before the elicitation meeting, he felt the anchor bolts were likely to yield at pressures comparable with those for which cylinder failure was estimated. This would result in leakage beneath the steel containment wall, assuming fracture of the weld between the containment wall and the floor liner. At the meeting he obtained a better detail drawing of the anchor chair area, which showed that both bolt and chair were embedded in reinforced concrete. Based on this new information, Expert A decided that anchor bolt failure was negligible compared to membrane failure.

Membrane Failure of the Cylinder. Using Sandia's finite element analysis results and other similar analyses, Expert A concluded that the highest stresses and strains in the cylindrical portion of the containment will occur in the half-inch plate just below the spring line. Using actual material properties and smearing out the stiffeners, Expert A calculated a pr/t stress that was close to those obtained by the finite element analyses and concluded that the onset of general yield occurred at 58 psig. Due to biaxial strain effects and gauge effects, Expert A considered it possible that failure might not occur until 10 or even 12% strain was reached. However, he considered it much more likely that failure would occur between 1 and 5% strain.

Buckling of the Equipment Hatch. The middle of the pressure range for this failure mode is about 200 psig. This is based on Expert A's knowledge of spherical cap tests and analyses. The range is quite wide, as the buckling failure mode is associated with large variability. This is shown by the experimental data.^{A-1,A-2,A-3}

Results of Expert A's Elicitation

Membrane Failure of the Cylinder. Expert A took the onset of general yield at 58 psig to be the lower bound (2% probability) for his failure curve. Assuming that failure was most likely around 3% strain, he got 80 psig as his median failure pressure. Assuming a lognormal distribution gave the following table for membrane failure of the cylinder:

| | | | | | | | | | |
|-------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Pressure (psig) | 58 | 62 | 65 | 72 | 80 | 89 | 98 | 104 | 110 |
| Cum. Distrib. Fn. | .02 | .05 | .10 | .25 | .50 | .75 | .90 | .95 | .98 |

The 2% failure at the general yield pressure allows for inaccuracies in the modeling, variations in material properties, localized strain concentrations, and unknown construction defects. Membrane failure in the cylinder is almost certain to be CR since the entire zone, including the stiffeners, is above general yield. That is, the stiffeners will be in the plastic region when the shell fails, so the crack will propagate right through the stiffeners. This was observed in Sandia's scale model tests.

Buckling of the Equipment Hatch. Based on the test results, Expert A placed his 2% failure value at 90 psig. He took a lognormal distribution based on 2% failure at 90 psig and 50% failure at 200 psig and got the following table:

| | | | | | | | |
|-------------------|-----|-----|-----|-----|-----|-----|-----|
| Pressure (psig) | 89 | 104 | 120 | 153 | 200 | 260 | 330 |
| Cum. Distrib. Fn. | .02 | .05 | .10 | .25 | .50 | .75 | .90 |

The upper values are, of course, not relevant here since the cylindrical shell is expected to fail well below 150 psig. Equipment hatch failure by buckling is expected to result in leakage since the tests showed that failure was due to either cracking a weld or distortion at the edge of the

hatch, both of which results in leaks in the tests. There is also a non-negligible probability that buckling can occur without causing a leak. The leak resulting from hatch failure does not bypass the ice condenser since the hatch connects the upper compartment to the outside.

All Failure Modes. The cumulative distributions of the pressures for membrane failure of the cylinder and for equipment hatch buckling can be combined to give the following table:

| <u>Pressure</u> <u>(psig)</u> | <u>Cumulative Probability of Failure</u> | | |
|----------------------------------|--|--------------|-------------|
| | <u>Cylinder</u> | <u>Hatch</u> | <u>Both</u> |
| 58 | .02 | | 0.02 |
| 62 | .05 | | 0.05 |
| 65 | .10 | | 0.10 |
| 72 | .25 | | 0.25 |
| 80 | .50 | | 0.50 |
| 89 | .75 | .02 | 0.76 |
| 98 | .90 | | |
| 104 | .95 | .05 | 0.95 |
| 110 | .98 | | |
| 120 | | .10 | 1.00 |

Probabilities for hatch failure at 98 and 110 psig were not given. Interpolation was used to create a table of total cumulative failure probability and cumulative conditional probability of failure mode for 5 psig increments. By use of the probability density, this was then converted into a table of interval conditional probability for mode as shown in Table A-1.

Expert A was fairly confident that failure could be expected between 65 and 95 psig since about 75% of his probability lay within that range. Within the range where failure was most likely to occur, CR was almost certain since membrane failure of the cylinder was by far the most likely failure mode. There are no rupture failures in Expert A's opinion.

REFERENCES

- A-1. Y. C. Fung and E. E. Sechler, "Instability of Thin Elastic Shells," Proceedings of the First Symposium on Naval Structural Mechanics, pp. 115-168, 1960.
- A-2. Handbook of Structural Stability, NACA Tech. Notes, p. 3783, 1957-1958.
- A-3. S. P. Timoshenko, Theory of Elastic Stability, New York, New York: McGraw-Hill Book Company, Inc., 1936.

Expert B's Elicitation

Containment Failure at Sequoyah Due to Static Pressure

Description of Expert B's Rationale/Methodology

Several failure locations were briefly considered and then dropped from further consideration. Failure of the personnel airlock was ruled out on the basis of tests and analysis.^{B-1} Failures of electrical penetrations were ruled out for the same reasons.^{B-2, B-3} No information was available to allow a reasonable evaluation of the penetrations equipped with bellows. (Most if not all of the mechanical penetrations at Sequoyah are equipped with bellows.) In the absence of test results or enough information to perform a credible analysis, Expert B did not consider these expansion joints further. Thus, Expert B considered in detail three failure locations and two temperatures for one of them. He felt temperature was important only for the membrane failure of the cylindrical portion of the shell.

Failure of the cylindrical shell always results in catastrophic rupture if the failure pressure is above the 60 psig range and always results in rupture if the failure pressure is below the 50 psig range. Below 50 psig, the membrane stresses in the entire shell are still elastic which provides some assurance that crack growth can be arrested. Above 60 psig, large areas of the shell have inelastic (plastic) stresses; there would not be sufficient strength in these areas to arrest crack growth, and crack propagation leads to catastrophic rupture.

Initial failure of the equipment hatch always results in a leak. However, the leak area will increase rapidly if the pressure continues to rise. If the pressure increases a \bar{P} psig above the value which caused the initial leak, the hole area will increase into the rupture region. Failure of the anchorage system could result in either a leak or a rupture, but he judged that even if a leak occurred the size of the tear would eventually increase so that a rupture would result.

Failure of the cylindrical shell will always result in bypass of the ice condenser if it is a catastrophic rupture. If cylinder failure is a rupture, then one sixth of them can be expected not to bypass the ice condenser since there is 60° of the containment wall which is not occupied by the ice condenser. Equipment hatch failure does not bypass the ice condenser due to the location of the hatch.

Anchorage failure would always result in bypass of the ice condenser if the failure always occurred at the cylinder-shell junction, since it is below the bottom of the ice condenser. However, anchorage failure may result in no failure, or only a negligible failure, at this location. Instead the anchorage failure may precipitate failure elsewhere in the shell. Anchorage failure will allow the shell to move up considerably, and this vertical movement may well result in failure of the cylindrical shell at some penetration or stiffener plate where there is resistance to this upward motion. Thus it is impossible to say where the failure might occur.

This being the case, the anchorage failures have been divided evenly between bypass and no bypass of the ice condenser.

Results of Expert B's Elicitation

Membrane Failure of the Cylinder. For failure of the cylindrical shell, Expert B concluded that failure was most likely in the 1/2-in. plate just below the spring line. For failure at this location, about elevation 771 ft, he gave the following results of his calculations:

| <u>Cumulative Probability</u> | <u>Pressure(psig)</u> | | <u>Response of the Containment</u> |
|-------------------------------|-----------------------|--------------|------------------------------------|
| | <u>500°F</u> | <u>300°F</u> | |
| 0.00 | 32 | 35 | General yield ignoring stiffeners |
| 0.05 | 43 | 53 | General yield including stiffeners |
| 0.50 | 58 | 60 | 2% equivalent membrane strain |
| 0.80 | 72 | 72 | 5% equivalent membrane strain |
| 0.99 | 80 | 80 | 10% equivalent membrane strain |
| 1.00 | 95 | 96 | Ultimate strain of material |

Expert B checked his calculations with those of the Ames Laboratory^{B-4} for the Sequoyah containment. When adjusted for material properties and temperature, the comparison was good. The table above contains two values for pressure; one assuming the containment is around 300°F or lower and the other assuming the containment is around 500°F. The higher temperature values have not been used because the bulk metal temperature never reaches 500°F as explained above (see page 5.5-2). Membrane failure of the cylinder is essentially certain by 80 psig for either temperature.

Hatch Ovalization. Expert B felt that hatch failure would occur due to ovalization. Analytical predictions of hatch ovalization failure have matched the test results very well,^{B-5} so there is little uncertainty in this failure mode. This failure mode occurs because the cylindrical sleeve, which is welded to the containment shell, is distorted into an oval shape as the shell moves outward with increasing internal pressure. The hatch itself keeps its circular shape. By 2.5 to 3% strain, the sleeve is so ovalized that the sleeve flange is completely inside the hatch flange at the top and bottom and the sleeve flange is completely outside the hatch flange at the sides. Thus, this type of failure is completely independent

of the gasket condition, and it will continue to grow in area as the hoop strain increases. He was certain that this ovalization would result in development of a leak when the free-field hoop strain in the cylindrical shell at the elevation (741 ft) of the center line of the equipment hatch reached about 2.7%. Expert B gave the following table of cumulative probability of leak as a function of strain:

| <u>Strain (%)</u> | <u>Cumulative Failure Probability</u> | <u>Pressure (psig)</u> |
|-------------------|---------------------------------------|------------------------|
| 2.4 | 0.01 | 66.7 |
| 2.5 | 0.05 | |
| 2.6 | 0.25 | |
| 2.7 | 0.50 | |
| 2.8 | 0.75 | |
| 3.0 | 0.90 | |
| 3.2 | 0.99 | 70.2 |

At 300°F, at elevation 741 ft, the free field hoop strain is 2% at 65 psig and 5% at 78 psig. The pressures for the other strain values above may be obtained by linear interpolation. Thus, Expert B expects a leak due to the hatch ovalization to occur around 68 psig and is certain it will have developed by 70 psig. The leak will be large enough to be denoted a rupture by the time 75 or 80 psig is reached. Catastrophic rupture will not result from this failure mode.

Anchorage Failure. Failure of the anchorage system affects containment integrity indirectly. As the bolts begin to yield, the knuckle could become distressed, leading to a leak. As significant yielding of the bolts occurs, significant vertical motion of the containment shell becomes increasingly probable. This motion is resisted by the penetrations, which could lead to a rupture. The analysis of this failure mode is subject to great uncertainty because it is indirect, i.e., it is based on the response of a component, which is not part of the pressure boundary.

For failure of the anchorage system, Expert B gave the following results of his calculations and a study by the Ames Laboratory:^{B-1}

| <u>Cumulative Probability</u> | <u>Pressure (psig)</u> | <u>Response</u> |
|-------------------------------|------------------------|-----------------------------------|
| 0.00 | 60 | None |
| 0.10 | 65 | Onset of yielding in the bolts |
| 0.80 | 80 | Bolts fail (nominal) |
| 0.95 | 100 | |
| 1.00 | 135 | Anchor rings pull out of concrete |

Leaks resulting from anchorage failure occur at the knuckle and therefore always bypass the ice condenser. The rupture failure could take place at or around any penetration. In the absence of any further information, half the ruptures are assumed to bypass the ice condenser and half are assumed not to bypass it. Failures at the lower pressures result in leaks and failures at the higher pressures result in ruptures. The dividing line between leak and rupture is around the 70 to 75 psig range.

All Three Failure Modes. A table listing the failure probability as a function of pressure for 5 psig increments for all three failure locations can now be constructed:

| Press. (psig) | <u>Cylinder Shell</u> | | | <u>Hatch Failure</u> | | | <u>Anchorage Failure</u> | | |
|------------------|-----------------------|------------|----------|----------------------|------------|-------------|--------------------------|------------|-------------|
| | Cum. Prob. | Cond. Rupt | Prob. CR | Cum. Prob. | Cond. Leak | Prob. Rupt. | Cum. Prob. | Cond. Leak | Prob. Rupt. |
| 30 | 0.00 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 35 | 0.005 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 40 | 0.006 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 45 | 0.008 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 50 | 0.01 | 0.8 | 0.2 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 55 | 0.10 | 0.3 | 0.7 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 60 | 0.50 | 0.0 | 1.0 | 0.0 | 1.0 | 0.0 | 0.0 | 1.0 | 0.0 |
| 65 | 0.62 | 0.0 | 1.0 | 0.01 | 1.0 | 0.0 | 0.10 | 1.0 | 0.0 |
| 70 | 0.75 | 0.0 | 1.0 | 0.99 | 0.8 | 0.2 | 0.25 | 0.7 | 0.3 |
| 75 | 0.90 | 0.0 | 1.0 | 1.0 | 0.2 | 0.8 | 0.50 | 0.3 | 0.7 |
| 80 | 0.99 | 0.0 | 1.0 | 1.0 | 0.0 | 1.0 | 0.80 | 0.0 | 1.0 |

The hatch failures never result in bypass of the ice condenser. Leakage failures of the anchorage always result in bypass of the ice condenser and rupture failures of the anchorage are equally split between bypass and no bypass. The cylinder failures which result in rupture are split 5 to 1 in favor of bypass based on geometrical considerations. (Of the upper wall of the cylindrical shell, 300° is within the ice condenser and 60° is not. Failure within the ice condenser is assumed to result in bypass. Failure is considered equally likely for all segments.)

By assuming that the failures at the three locations are independent, a single table giving the total cumulative failure probability for all locations as a function of pressure can be formed. The method used was briefly explained in the Aggregation section above. The result is Table 5-8. Table 5-8 and its derivation were reviewed by Expert B.

Rupture or catastrophic rupture is possible above the pressure where hatch ovalization leakage is certain because the pressure rise may be too rapid to be arrested by this failure mode. The definition of a leak is that the containment does not depressurize to about atmospheric pressure in less than 2 h. For pressure rises resulting from deflagrations or deflagrations accompanied by direct heating, rise times on the order of a few seconds are expected. For loads due to these events, a leak will not arrest the pressure rise; pressure rise will be arrested only by development of a rupture or a catastrophic rupture.

Expert B felt strongly that the type of containment loading should be taken into account when using his evaluation of containment performance. His primary concern was the treatment of leaks, and the possibility of leaks increasing in area to become ruptures, for the scenarios with a fast pressure rise.

The conclusions of Expert B are shown in Table 5-2 through 5-5. His median failure value is 60 psig. All failures at this pressure are catastrophic ruptures since failure of the cylindrical shell is the only location at which Expert B feels failure is possible at this pressure. Failures below 50 psig are certain to be ruptures since Expert B did not believe leaks were a credible failure mode for failure of the cylindrical shell. Above the 60 psig median pressure, leaks, ruptures, and catastrophic ruptures are possible. Although this seems counter-intuitive at first, it is a direct result of Expert B's conclusion that the lowest pressures at which hatch ovalization and anchorage failure could occur are higher than the pressures at which shell failure is possible.

REFERENCES

- B-1. L. Greimann et al., "Final Report -- Containment Analysis Techniques -- A State-of-the-Art Summary: Final Report," NUREG/CR-3653, SAND83-7463, Prepared by Ames Laboratory for Sandia National Laboratories, March 1984.
- B-2. D. B. Clauss, "Comparison of Analytical Predictions and Experimental Results for the 1:8-Scale Steel Containment Model Pressurized to Failure," NUREG/CR-4209, SAND85-0679, Sandia National Laboratories, July 1985.
- B-3. L. Greimann et al., "An Evaluation of the Effects of Design Details on the Capacity of LWR Steel Containment Buildings," NUREG/CR-4870, SAND87-7066, Sandia National Laboratories, May 1987.
- B-4. D. B. Clauss, "An Evaluation of the Leakage Potential of a Personnel Airlock subject to Severe Accident Loads," Trans. of the 9th Int. Conf. on Structural Mechanics in Reactor Technology, Vol. J, pp. 147-152, August 17-21, 1987.
- B-5. J. D. Keck and F. V. Thome, "Electrical Penetrations Assemblies Severe Accident Testing," SAND86-0703C, Sandia National Laboratories, 1986.

Expert C's Elicitation

Containment Failure at Sequoyah Due to Static Pressure

Description of Expert C's Rationale/Methodology

Expert C considered all three cases to be equivalent, but did provide a separate curve for the high temperature case. He considered five failure modes separately:

- Mode 1: Leak resulting in No Bypass of the Ice Condenser
- Mode 2: Leak resulting in Bypass of the Ice Condenser
- Mode 3: Rupture resulting in No Bypass of the Ice Condenser
- Mode 4: Rupture resulting in Bypass of the Ice Condenser
- Mode 5: Catastrophic Rupture.

Expert C felt that failure is most likely to occur in one of two locations. In the upper compartment, failure was most likely to occur in the 1/2-in.-thick steel of the cylindrical shell just below the spring line. In the lower compartment, a crack in the weld at the point of embedment is the likely failure point. This location is felt by Expert C to be slightly more likely than the spring line location. By 75 psig, general membrane strains are such that failure will probably have occurred based on average material properties. Use of actual material properties may increase this pressure by a few psig.

Expert C arrived at the above conclusions by establishing the relative potential for failure at various locations. As indicated by IDCOR Technical Report 10.1 (Reference C-1) and test data, mechanical and electrical penetrations are not likely to fail before general structural failure. The critical buckling pressure for the hatch cover was calculated, and it was determined that the hatch cover is not likely to buckle at pressures which will cause general yielding in the upper part of the cylindrical shell. Since the cover is pressure-seated, no leakage due to opening of the flanges is expected. Design calculations and test results indicate that the personnel airlock is significantly over-designed for internal pressure and the probability of structural failure of the airlock is very remote. Again, the inner door of the airlock is pressure-seated and not likely to leak. The vessel anchorage is also over-designed and not likely to be the point of first failure. The controlling failure mechanism in the anchorage system would be the yielding of the anchor bolts. Anchor bolts are expected to start yielding at pressures which are somewhat higher than those which cause general yielding of the upper part of the cylindrical shell.

Expert C relied on published results (References C-1 through C-5) as well as his own calculations. In addition, he considered such practical factors as fabrication imperfections, material imperfections, residual stresses, etc. in determining how to distribute the failure probabilities among the various modes and locations. The location and type of hypothesized failures determined the breakdown between bypass of the ice condenser and no bypass of the ice condenser.

Results of Expert C's Elicitation

For 200 to 300°F, Expert C provided the following table giving the failure probabilities by mode and the total:

Probability of Containment Failure (200 to 300°F)

| <u>Pressure (psig)</u> | <u>Mode 1</u> | <u>Mode 2</u> | <u>Mode 3</u> | <u>Mode 4</u> | <u>Mode 5</u> | <u>All Modes</u> |
|----------------------------|---------------|---------------|---------------|---------------|---------------|------------------|
| 25 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 35 | 0.03 | 0.05 | 0.01 | 0.02 | 0.00 | 0.11 |
| 45 | 0.04 | 0.06 | 0.03 | 0.10 | 0.01 | 0.24 |
| 55 | 0.04 | 0.07 | 0.17 | 0.16 | 0.04 | 0.48 |
| 65 | 0.04 | 0.07 | 0.21 | 0.20 | 0.30 | 0.82 |
| 75 | 0.04 | 0.07 | 0.22 | 0.21 | 0.46 | 1.00 |

This table gives exclusive joint cumulative probabilities for the five modes. Interpolation was used to obtain the results for 5 psig intervals shown in Table C-1. The joint probabilities were converted to total conditional probabilities by assuming that the total conditional probability was proportional to the exclusive conditional probability. These probabilities were then converted to interval conditional probabilities as shown in Table 5-6 by use of the probability densities.

For temperatures around 600°F in containment, Expert C calculated that the yield strength of the steel would be considerably lower than the yield strength at room temperature. However, due to warm strain hardening, the ultimate strength of material is not much affected at these temperatures. Considering these temperature effects on material properties, he provided a different table for the condition that the pressures will be concurrent with a shell temperature of 600°F. This table contains a sixth mode, thermal buckling, since Expert C concluded that this failure mode was possible at 600°F when the internal pressure was at or only slightly above ambient atmospheric pressure.

Probability of Containment Failure (600°)

| <u>Pressure (psig)</u> | <u>Mode 1</u> | <u>Mode 2</u> | <u>Mode 3</u> | <u>Mode 4</u> | <u>Mode 5</u> | <u>Mode 6</u> | <u>All Modes</u> |
|----------------------------|---------------|---------------|---------------|---------------|---------------|---------------|------------------|
| 0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.25 | 0.25 |
| 25 | 0.01 | 0.01 | 0.00 | 0.00 | 0.00 | 0.24 | 0.26 |
| 35 | 0.05 | 0.06 | 0.03 | 0.05 | 0.00 | 0.16 | 0.35 |
| 45 | 0.05 | 0.07 | 0.17 | 0.17 | 0.04 | 0.13 | 0.63 |
| 55 | 0.05 | 0.07 | 0.20 | 0.20 | 0.28 | 0.12 | 0.92 |
| 65 | 0.05 | 0.07 | 0.21 | 0.21 | 0.36 | 0.10 | 1.00 |

The cumulative probability for the thermal buckling mode decreases as pressure increases since the internal pressure will tend to counteract the thermal stresses.

The conclusions of Expert C are shown in Tables 5-3 and 5-6. The median of his failure distribution is around 56 psig. At this pressure, rupture is the most likely failure mode. Expert C was virtually certain that the containment would have failed by 75 psig.

REFERENCES

- C-1. Sargent and Lundy, "Containment Structural Capability of Light Water Nuclear Power Plants," IDCOR, Technical Report 10.1, Technology for Energy Corporation, Knoxville, TN, July 1983.
- C-2. "Sequoyah Nuclear Power Plant, Final Safety Analysis Report," Sections 3.8.1 and 3.8.2, Tennessee Valley Authority, Knoxville, TN, 1974.
- C-3. U.S. Nuclear Regulatory Commission, "Safety Evaluation Report Related to the Operation of Sequoyah Nuclear Plant Units 1 and 2," NUREG-0011, Supplement 6, pp. 22-15 and 22-16, Washington, D.C., 1962.
- C-4. W. Sebrell, "The Potential for Containment Leak Paths through Electrical Penetration Assemblies under Severe Accident Conditions," NUREG/CR-3234, SAND83-0538, Sandia National Laboratories, 1983.
- C-5. D. B. Clauss, "Comparison of Analytical Predictions and Experimental Results for the 1:8-Scale Steel Containment Model Pressurized to Failure," NUREG/CR-4209, SAND85-0679, Sandia National Laboratories, 1985.

5.6 Issue 6: Sequoyah Containment Failure Due to Detonation

Experts consulted: Charles Miller, City College of New York; Walter A. von Rieseemann, Sandia National Laboratories; Don Wesley, IMPELL.

Issue Description

What distributions characterize the uncertainty in containment failure due to detonations in the ice condenser, and what is the likely failure site? What distributions characterize the uncertainty in ice condenser bypass due to mechanical displacement of the ice following a hydrogen detonation? The variables elicited are the probability of containment failure and the location of the failure as a function of applied impulse, and the probability of ice condenser bypass as a function of applied impulse.

Summary of Results

Expert A considered the following failure modes for the Sequoyah response to detonation: (1) anchor bolt failure that results in a leak or rupture near the base of the containment, (2) membrane failure in the containment cylinder area, and (3) buckling failure of the cylinder due to detonation at the top of the containment. In addition, the expert considered the probability of loss of ice condenser function due to detonation in the ice condenser.

The expert concluded that buckling would not be reached before blowout of the cylinder and provided distributions for the anchor bolt failure mechanism, membrane failure of the containment cylinder above the ice condenser, membrane failure of the containment cylinder in the lower part of containment, and loss of the ice condenser function.

Expert B analyzed the containment as an axisymmetric ring. For the wall of containment above the ice condenser, a single panel was analyzed for membrane and bending stress. Bending stress was found to be a minor contributor to failure and the plate was found to be fairly strong in bending action (well above the range for hoop failure). For detonation within the ice condenser or upper plenum, only panel response needed to be considered and the expert considered the membrane response of the plate.

The expert concluded that a path would be opened through the ice condenser under any detonation conditions.

Expert C applied a simplified analysis method which, in essence, equates the kinetic energy of the structure to the strain energy. He noted that tests conducted on steel containments showed that failure generally occurred when the global strain reached approximately 2%. Although the steel has a higher capacity in uniaxial tension, the existence of biaxial stress and the presence of strain risers reduce the effective capacity to about 2%. Other tests have shown that strain rate effects (dynamic loading) can increase the strength of steels by a factor of 1.3. Other variables that can affect the failure strain are the yield stress of the

steel, strain rate, strain to failure, effect of temperature on mechanical properties, and the loading function. Based on these factors, Expert C multiplied his best estimate (2% strain) failure impulse estimates by factors of 0.41 and 1.97 to get approximate lower and upper bounds.

Expert C's calculations for the upper plenum and for the ice condenser differed mainly in the need to take the effect of the insulating wall panels into account for the detonations in the ice condenser. The impulse needed to fail the steel shell was estimated as described above. It was estimated that the honeycomb insulating panel would require a constant pressure three times the design pressure to crush. The crane wall consists of at least 3 ft of reinforced concrete. Expert C calculated that the failure impulse for the crane wall would be greater than that for the containment shell.

All of the panel members provided information in the same form, that is, tables of cumulative failure probability as a function of applied impulse. The cumulative failure probability corresponding to some impulse, I , is the probability that the structure will fail at or below the indicated impulse. All three experts gave distributions for failure impulse in both the upper plenum and the ice condenser. In addition, Expert A provided a distribution for failure of containment via anchor bolt failure caused by a detonation in the dome, and Expert B provided a distribution for failure in the containment wall above the plenum. However, subsequent to elicitation of the structural response experts, the containment loading panel determined that a detonation in the containment dome was not credible; therefore, distributions based on detonations in the dome have not been reduced. Possible failure of the containment dome due to deflagrations in the dome is considered under Structural Issue 6--Containment Failure at Sequoyah Due to Static Pressure.

The individual experts' distributions are shown in Tables 6-1 through 6-3. None of the experts provided impulse values for the endpoints of their distributions; these were derived by extrapolation and checked with the experts. Table 6-4 and Figure 6-1 show the aggregate distributions for failure of the upper plenum. Table 6-5 and Figure 6-2 show the aggregate distributions for failure of the ice condenser.

Table 6.1
Distributions for Expert A

Failure of Upper Plenum:

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 3.70 | 0.00 (Extrapolated) |
| 4.48 | 0.02 |
| 5.65 | 0.05 |
| 6.90 | 0.10 |
| 9.45 | 0.25 |
| 13.45 | 0.50 |
| 16.07 | 0.75 |
| 18.62 | 0.90 |
| 20.69 | 0.95 |
| 22.76 | 1.00 (Extrapolated) |

Failure of Ice Condenser:

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 6.50 | 0.00 (Extrapolated) |
| 7.93 | 0.02 |
| 10.07 | 0.05 |
| 12.27 | 0.10 |
| 17.24 | 0.25 |
| 24.82 | 0.50 |
| 30.34 | 0.75 |
| 36.54 | 0.90 |
| 40.68 | 0.95 |
| 44.82 | 1.00 (Extrapolated) |

Table 6-2
Distributions for Expert B

Failure of Upper Plenum:

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 0.46 | 0.00 (Extrapolated) |
| 2.07 | 0.05 |
| 6.90 | 0.20 |
| 12.41 | 0.50 |
| 44.82 | 0.95 |
| 48.42 | 1.00 (Extrapolated) |

Failure of Ice Condenser:

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 5.18 | 0.00 (Extrapolated) |
| 6.90 | 0.01 |
| 13.79 | 0.05 |
| 20.68 | 0.11 |
| 27.58 | 0.25 |
| 34.48 | 0.50 |
| 41.37 | 0.72 |
| 48.26 | 0.89 |
| 55.16 | 0.95 |
| 62.06 | 0.99 |
| 63.78 | 1.00 (Extrapolated) |

Table 6-3
Distributions for Expert C

Failure of Upper Plenum:

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 0.69 | 0.00 |
| 1.38 | 0.01 |
| 3.45 | 0.50 |
| 6.90 | 0.90 |
| 10.34 | 1.00 |

Failure of Ice Condenser:

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 0.69 | 0.00 |
| 1.38 | 0.01 |
| 4.83 | 0.50 |
| 9.66 | 0.90 |
| 13.79 | 1.00 |

Table 6-4
Aggregate Distribution for Failure of Upper Plenum

| Impulse (kPa-s) | Cumulative Failure Probability |
|--------------------|--------------------------------|
| 4.600E-01 | 0.000E+00 |
| 6.900E-01 | 2.381E-03 |
| 1.380E+00 | 1.286E-02 |
| 2.070E+00 | 7.444E-02 |
| 3.450E+00 | 1.976E-01 |
| 3.700E+00 | 2.099E-01 |
| 4.480E+00 | 2.548E-01 |
| 5.550E+00 | 3.221E-01 |
| 6.900E+00 | 4.000E-01 |
| 9.450E+00 | 5.210E-01 |
| 1.034E+01 | 5.643E-01 |
| 1.241E+01 | 6.450E-01 |
| 1.345E+01 | 6.715E-01 |
| 1.607E+01 | 7.699E-01 |
| 1.862E+01 | 8.287E-01 |
| 2.069E+01 | 8.550E-01 |
| 2.276E+01 | 8.812E-01 |
| 4.482E+01 | 9.833E-01 |
| 4.842E+01 | 1.000E+00 |




Figure 6-1. Failure of the Upper Plenum Due to Detonation.

Table 6-5
 Aggregated Distribution for Failure of Ice Condenser

| <u>Impulse (kPa-s)</u> | <u>Cumulative Failure Probability</u> |
|----------------------------|---------------------------------------|
| 6.900E-01 | 0.000E+00 |
| 1.380E+00 | 3.333E-03 |
| 4.830E+00 | 1.667E-01 |
| 5.180E+00 | 1.763E-01 |
| 6.500E+00 | 2.153E-01 |
| 6.900E+00 | 2.290E-01 |
| 7.930E+00 | 2.642E-01 |
| 9.660E+00 | 3.234E-01 |
| 1.007E+01 | 3.294E-01 |
| 1.227E+01 | 3.681E-01 |
| 1.379E+01 | 3.986E-01 |
| 1.724E+01 | 4.433E-01 |
| 2.068E+01 | 4.912E-01 |
| 2.482E+01 | 5.64E-01 |
| 2.758E+01 | 6.250E-01 |
| 3.034E+01 | 7.000E-01 |
| 3.448E+01 | 7.834E-01 |
| 3.654E+01 | 8.219E-01 |
| 4.068E+01 | 8.827E-01 |
| 4.137E+01 | 8.928E-01 |
| 4.482E+01 | 9.350E-01 |
| 4.826E+01 | 9.633E-01 |
| 5.516E+01 | 9.833E-01 |
| 6.206E+01 | 9.967E-01 |
| 6.378E+01 | 1.000E+00 |




Figure 6-2. Failure of Ice Condenser Due to Detonation.

Individual Elicitations for Issue 6

Expert A's Elicitation

Sequoyah Containment Failure Due to Detonation

Determination of Expert A's Rationale/Methodology

Expert A considered the same failure modes which he considered for static failure plus panel failure of the ice condenser and buckling of the cylinder at its base. In particular, these modes are:

Anchor bolt failure. This mode results in a leak or rupture near the base of the containment that produces ice condenser bypass. Static failure occurs at about 135 psig and is controlled by brittle failure of the concrete surrounding the anchor bolt chairs. This failure mode provided a fairly tortuous leak path for fission products. The Expert had difficulty estimating what the dynamic load factor would be. He did not have an accurate estimate of the containment axial (vertical) frequency. An estimate of the frequency was developed which turned out to be in the same range as the expected pulse (0.01 to 0.003 s). Dynamic load factors can vary widely. Load factors of 1.25 to 1.5 can result from sharp pressure spikes dropping off linearly (an essentially triangular pulse shape) or faster. A square pressure pulse could produce a load factor of 2.0. On the other hand load factors of 0.4 could occur when the pressure pulse doesn't excite any of the natural periods of the structure.

Once brittle failure of the concrete occurs, elastic deformations can occur in the bolts of about 0.3 in. There is also some probability of fracture of the 3/8-in. fillet weld of the liner to the shell (estimated to be in the range of 0.5), even for low strains in the bolts. Plastic failure of the bolts could occur above the concrete failure pressure (about 135 psig). This failure could occur without fracturing the bolts. The liner could then fracture. At that point it would only require about 2 psig to lift the shell. At higher pressures, a ductility of the range 10 to 15 is expected, based on 13% strain in 8-in. gauge length. One can derive (from Biggs) the peak pressure that the bolts could withstand from:

$$\text{peak pressure} = R/0.1 \text{ to } R/0.35,$$

where R is the bolt resistance. The bolt strength was increased about 1.48 to 1.58 above the static strength predicted by the equation above, based on Kinney & Graham. This results in Table A-1.

Membrane failure in the containment cylinder area. The Expert considered both the impulse-and-strain-energy-effects approach and the vibration (DAF) approach. Both approaches yielded the same order of magnitude predictions for radial (breathing mode) detonations in the 1/2-in. containment wall above the ice condenser and the 5/8-in. ice condenser wall. He used the same strain criteria for failure as in the static case but increased the

material strength (at the median of the distribution) to account for the rapid strain rate effects. For the mid-height region of the cylinder with the 5/8-in. ice condenser wall the Expert used the same failure requirements as for failure in 1/2-in. material. His failure probability curve for lower containment failure is similar in shape to that for upper containment failure. However, it is offset by a factor of almost two in pressure. Failure in the lower containment results in ice condenser bypass. His method resulted in predictions of failure shown in Table A-2 for failure in the upper cylinder (1/2-in. wall). In the case of failure in the containment cylinder Expert A was uncomfortable with having to estimate his lower bound because there tend to be lower bounds on some parameters such as material strength, etc., that the tail of a lognormal distribution does not appropriately characterize. Also, the level of analysis on which the failure distribution was based probably does not justify very low failure frequency estimates. Lognormal distributions were used for making his probability estimates for a variety of reasons. Since material properties tend to be lognormal, he assumed the pulse duration was lognormally distributed, etc.

Predictions for failure in the mid-height to lower part of the containment are shown in Table A-3. Failure in the mid-height to lower part of the containment results in ice condenser bypass. Membrane failures will always result in leaks.

The spherical dome of the containment has a somewhat lower DAF than other parts of the containment, so containment failures will be controlled by failure in the cylindrical sections.

Buckling failure of the cylinder due to detonation at the top of the containment. The Expert made an estimate of the lateral frequency and found that the DAF would be < 1 for wide frequency variations. The Expert also checked the buckling strength using NASA SP-8007, neglecting pressure strengthening. He assumed an impulse on a half cylinder for several assumed lengths over which the pressure acts. He concluded that buckling would not be reached before blowout of the cylinder.

Expert A did not investigate dynamic buckling of the equipment hatch or electrical penetrations.

In addition to the three containment failure modes mentioned above, Expert A considered the probability of loss of ice condenser function due to detonation in the ice condenser. Loss of ice condenser function was defined as sufficient disarray of the ice baskets and the insulation panels to form a flow channel through the ice condenser for the steam. The Expert called this failure ice condenser panel blowout. He based his results for the estimated capacity of the Sequoyah ice condenser on the Sequoyah final safety analysis report (FSAR) information: a 9 psig design pressure or $1.5 \times \text{DAF} \times 1.4 = 18.9$ psig (for 1.4 M.S.) From an elastic 1.5 DAF, he estimated that $t/T = 0.5$ to 2 and $\mu = 10-20$ for failure

where:

- t = duration of the pulse
- T = natural period of the (elastic) system
- μ = ductility.

Table A-4 shows the estimated failure probabilities.

Results of Expert A's Elicitation

The Expert expressed his failure probabilities in terms of the reflected pressure. The reflected pressure is typically 2.3 x incident pressure. He translated reflected pressure into impulse for pulse durations of 3 to 10 ms. If the Containment Loads Expert Panel predicts pulse durations longer than 20 ms, his pulse durations should be lengthened.

The Expert's lower probability bounds were created by assuming the most benign conditions that he could imagine. He then calculated a median from his estimate of the most likely conditions, assumed a lognormal distribution between the 2% probability and the median, and projected to higher pressures.

The Expert provided probability distributions for three independent failure modes with three independent locations. They are shown in Tables A-1 to A-3. The probability of loss of ice condenser function due to detonation is given in Table A-4.

Table A-1
Anchor Bolt Failure (Ice Condenser Bypass)

| Cumulative Probability | Leak | | Rupture | |
|------------------------|---------------------------|------------------|---------------------------|------------------|
| | Reflected Pressure (psig) | Impulse (psig-s) | Reflected Pressure (psig) | Impulse (psig-s) |
| 0.02 | 125.0 | 1.25 | 185.0 | 1.0 |
| 0.05 | 138.0 | 1.26 | 250.0 | 2.0 |
| 0.10 | 150.0 | 1.27 | 315.0 | 2.0 |
| 0.25 | 170.0 | 1.28 | 470.0 | 3.0 |
| 0.50 | 200.0 | 1.3 | 750.0 | 4.0 |
| 0.75 | 260.0 | 1.32 | 1180.0 | 5.0 |
| 0.90 | 330.0 | 1.33 | 1790.0 | 6.0 |
| 0.95 | 380.0 | 1.34 | 2300.0 | 6.0 |
| 0.98 | 450.0 | 1.35 | | |

Table A-2
 Membrane Failure of the Containment Cylinder
 Containment Wall Above Ice Condenser
 (No Ice Condenser Bypass)

| <u>Cumulative Failure Probability (Leak)</u> | <u>Reflected Pressure (psig)</u> | <u>Impulse (psig-s)</u> | <u>Impulse (kPa-s)</u> |
|--|----------------------------------|-------------------------|------------------------|
| 0.00 | - | - | 3.70 |
| 0.02 | 65.0 | 0.65 | 4.48 |
| 0.05 | 88.0 | 0.82 | 5.65 |
| 0.10 | 115.0 | 1.00 | 6.90 |
| 0.25 | 180.0 | 1.37 | 9.45 |
| 0.5 | 300.0 | 1.95 | 13.45 |
| 0.75 | 490.0 | 2.33 | 16.07 |
| 0.90 | 780.0 | 2.70 | 18.62 |
| 0.95 | 1000.0 | 3.00 | 20.69 |
| 1.00 | - | - | 22.76 |

Table A-3
 Membrane Failure of the Containment Cylinder
 Lower Part of Containment
 (Ice Condenser Bypass)

| <u>Cumulative Failure Probability (Leak)</u> | <u>Reflected Pressure (psig)</u> | <u>Impulse (psig-s)</u> | <u>Impulse (kPa-s)</u> |
|--|----------------------------------|-------------------------|------------------------|
| 0.0 | - | - | 6.50 |
| 0.02 | 115 | 1.15 | 7.93 |
| 0.05 | 160 | 1.46 | 10.07 |
| 0.10 | 210 | 1.78 | 12.27 |
| 0.25 | 330 | 2.50 | 17.24 |
| 0.50 | 560 | 3.60 | 24.82 |
| 0.75 | 940 | 4.4 | 30.34 |
| 0.90 | 1500 | 5.3 | 36.54 |
| 0.95 | 1950 | 5.9 | 40.68 |
| 1.00 | - | - | 44.82 |

Table A-4
Ice Condenser Panel Blowout
(Loss of Ice Condenser Function)

| Cumulative Failure Probability (leak) | Reflected Pressure (psig) | Impulse (psig-s) |
|--|------------------------------|---------------------|
| 0.02 | 22.0 | 0.22 |
| 0.05 | 26.0 | 0.24 |
| 0.10 | 30.0 | 0.26 |
| 0.25 | 38.0 | 0.29 |
| 0.50 | 50.0 | 0.33 |
| 0.75 | 65.0 | 0.34 |
| 0.90 | 83.0 | 0.35 |
| 0.95 | 97.0 | 0.36 |

In Tables A-1 and A-3 the Expert's predictions have been extrapolated to 0 and 1.0 probability using a linear extrapolation from probability 0.02 and 0.95, respectively.

After subsequent discussions with the experts on the Containment Loads Panel it was determined that it would be impossible that a detonation could occur that would load the containment anchor bolts. A detonation in the dome of the containment would be required. Thus the anchor bolt failure mode was not included in the calculation of containment failure probability. Also, at the suggestion of the Containment Loads Panel, AECTR calculations were made to determine the efficiency of the ice condenser when the ice baskets were moved aside to form a flow channel. They indicated that even with considerable disarray of the ice condenser baskets, the ice condenser could maintain its function. Thus the Expert's prediction of ice condenser failure (which assumed that function was lost if the ice baskets were moved enough to form a gas flow channel) was not used in the plant analysis.

Sources of Uncertainty

The sources of uncertainties in Expert A's calculation of membrane failure in the lower part of the containment include: (a) material properties (static properties and strain rate effects), (b) the location of the detonation (he usually assumed that the detonation occurred in the worst place), (c) the duration of the impulse, (d) the natural frequency of the modes that are being excited, and (e) the ductility or strain at which failure occurs.

Suggested Methods for Reducing Uncertainty

Expert A's estimates of the ice condensate panel's blowout probabilities would be improved if he had more information about the panels than can be found in the Final Safety Analysis Report. He would like to have structural drawings to see how the corrugated panels are welded together, etc. The estimates of failure pressure are only order-of-magnitude estimates. He couldn't calculate the dynamic amplification, so he used what was in the FSARs and assumed fairly high ductilities for the steel plate.

Correlations with Other Variables

Possible correlations with other variables being elicited were not discussed.

Expert B's Elicitation

Sequoyah Containment Failure Due to Detonation

Determination of Expert B's Rationale/Methodology

Expert B analyzed the containment as an axisymmetric ring, and first considered the internal pressure to just cause yielding, which was calculated as 54 psig. He considered resistances in the range of 40 to 75 psig, pulse amplification factors of 0.5 to 5, and pulse durations of 0.001 and 0.015 s. The range of impulses calculated for the containment wall above the plenum was 0.120 to 3.04 psi-s (0.83 to 2.10 kPa-s). Failure was considered possible if there were a strain of 2%.

For the wall of containment above the ice condenser, a single panel was analyzed for membrane and bending stress. Bending stress was found to be unlikely to cause failure, and the plate was relatively strong in membrane action; impulses of interest from 1 to 30 psi-s, well above the range for hoop failure.

For the contents of the ice condenser, he concluded that the Sequoyah FSAR's value of 1 psi with a factor of safety of three implied 3 psi for yield of the structure. If a factor of ten for inelastic response is assumed, the structure could handle at most a dynamic pressure of 30 psi. He therefore concluded that, for almost any detonation, a path would be opened through the ice condenser; about 12 baskets could be displaced with no difficulty.

For detonation within the ice condenser or upper plenum, only panel response needs to be considered (axisymmetric loading is not possible). He considered the membrane response of the plate, with amplification.

This Expert considered the effects of a detonation within the upper plenum, allowing the upper end of the plenum to move outwards by a factor of five. For detonation in the upper plenum, the pulse amplification factor for the containment wall was reduced by a factor of five for the upper end, in the middle region by a factor of four, and at the lower end by a factor of three. The reasons for reducing the pulse amplification factors are that reflections are less likely to occur.

Results of Expert B's Elicitation

Containment wall above plenum

| <u>Side-On Impulse (psi-s)</u> | <u>Side-On Impulse (kPa-s)</u> | <u>Probability of Failure</u> |
|------------------------------------|------------------------------------|-------------------------------|
| 0.1 | 0.69 | 0.00 |
| 0.25 | 1.72 | 0.20 |
| 0.50 | 3.44 | 0.55 |
| 0.75 | 5.17 | 0.70 |
| 1.00 | 6.90 | 0.83 |
| 1.25 | 8.62 | 0.93 |
| 1.50 | 10.34 | 0.99 |
| 1.75 | 12.07 | 1.00 |

Containment wall in upper plenum

| <u>Side-On Impulse (psi-s)</u> | <u>Side-On Impulse (kPa-s)</u> | <u>Probability of Failure</u> |
|------------------------------------|------------------------------------|-------------------------------|
| 0.30 | 2.07 | 0.05 |
| 1.00 | 6.90 | 0.20 |
| 1.80 | 12.41 | 0.50 |
| 6.0 | 44.82 | 0.95 |

Containment wall in ice condenser

| <u>Side-On Impulse (psi-s)</u> | <u>Side-On Impulse (kPa-s)</u> | <u>Probability of Failure</u> |
|------------------------------------|------------------------------------|-------------------------------|
| 1.0 | 6.90 | 0.01 |
| 2.0 | 13.79 | 0.05 |
| 3.0 | 20.68 | 0.11 |
| 4.0 | 27.58 | 0.25 |
| 5.0 | 34.48 | 0.50 |
| 6.0 | 41.37 | 0.72 |
| 7.0 | 48.26 | 0.89 |
| 8.0 | 55.16 | 0.95 |
| 9.0 | 62.06 | 0.99 |

Sources of Uncertainty

The loading is not at all well known. Neither the location of initiation, nor the pulse shape, duration, and reflections are known at all. As a result, the uncertainty band has to be very broad to cover all possible loadings. Other sources of uncertainty are the resistance and the strain at failure. There is great uncertainty about the structural details of the ice baskets. However, the range of impulses from any reasonable detonation is probably well above the strength of the baskets.

Expert C's Elucidation

Sequoyah Containment Failure Due to Detonation

Determination of Expert C's Rationale/Methodology

Expert C noted that the final safety analysis report (FSAR) indicates that the walls of the ice condenser are composed of corrugated steel insulating wall panels designed to withstand 19 psig. The design concern was the case where the pressures would be higher outside the ice condenser than inside the ice condenser. As the FSAR states that the panels are "...attached to the containment shell by studs welded to the shell," it appeared reasonable that these insulating panels would also withstand 19 psig when the pressure is higher inside the ice condenser than outside it.

These insulating panels do not extend into the upper plenum. Thus the calculation is different for a detonation in the ice condenser proper than for a detonation in the upper plenum. The impulse from a detonation in the ice condenser would have to crush the insulating panel attached to the containment shell as well as fail the shell itself. The impulse from a detonation in the upper plenum would only have to fail the shell itself. While the walls of the upper plenum are obviously insulated, there is no indication that this insulation has any significant strength in itself.

Expert C assumed that the detonation could occur at any point in the ice condenser or the upper plenum. He further assumed that only a single detonation would occur and that the strength of the plenum itself is negligible. A detonation in the ice condenser could cause failure of the containment shell, the crane wall, or the ends of the ice condenser. (The ice condenser occupies 300° of the space between the crane wall and the steel containment shell. The "ends" of the ice condenser are the walls that run from the crane wall to the containment shell at each end of the 300° occupied by the ice condenser.)

Due to the uncertainty in the definition of the loading (spatial and temporal), a simplified method developed for weapons work was utilized. In essence, this method equates the kinetic energy of the structure to the strain energy. The results of this approximate method compared well with earlier calculations that utilized a different method.

Detonation in the Upper Plenum. Examination of the Sequoyah FSAR convinced Expert C that the upper plenum has essentially no strength and that he need consider only the containment shell. At the elevation of the upper plenum the shell is 0.5 in. thick. The minimum yield strength for the steel is 32 ksi; the upper bound is 47 ksi. On the basis of the tests conducted on steel containments, a global strain of 2% was considered to be failure. While the material has a higher capacity in uniaxial tension, due to biaxial stress conditions, and, more importantly, to strain risers, the 2% value has been found to be reasonable. There is no effect on the material properties due to temperature. Other tests have shown that strain rate effects (dynamic loading) can increase the strength of steels by a factor of 1.3.

The impulse required to cause failure is calculated by equating the kinetic energy to the strain energy. Limitations of this technique are discussed in Expert C's detailed notes. The calculated midpoint failure impulse for detonation in the upper plenum is 0.50 psi-s. The factors that could modify this result are the yield stress of the steel, strain rate, strain to failure, effect of temperature on mechanical properties, and the loading pattern. The total effect is that the "best estimate" results are multiplied by factors of 0.41 and 1.97 to get approximate lower and upper bounds.

At the time of the detonation in the upper plenum, the doors from the ice condenser would be open. No attempt was made to calculate the effect of an impulse on the ice baskets.

Detonation in the Ice Condenser. All sides of the ice condenser are made of insulating wall panels made from corrugated sheet steel. The panels are designed for a pressure of 19 psig. They are attached to the crane wall and the containment shell. Three analyses were performed: (1) failure of the wall panel and the containment shell; (2) failure of the wall panel and the crane wall; and (3) failure of only the wall panel. The third analysis applies to the failure of the ends of the ice condenser.

It appeared to Expert C that the insulating wall panel would crush like a honeycomb material, that is, the pressure required to cause crushing will be constant. He estimated that three times design pressure would be required to crush the wall panels.

For failure of the wall panel and the containment shell, Expert C calculated a midpoint failure impulse of 0.70 psi-s. The factors that could modify the results were taken to be the same as for the detonation in the upper plenum. The containment shell is 0.625 in. thick at the elevation of the ice condenser.

For failure of the wall panel and the crane wall, the situation is complicated by the fact that there is no description of the reinforcing steel in the crane wall in the Sequoyah FSAR. It is stated that the wall is designed for an internal pressure of 12 psig and for local jet forces of 100 to 300 kips. The minimum thickness of the wall is 3.0 ft. Based on this information, Expert C calculated the failure impulse for the crane wall would be greater than that for the containment shell.

For failure of only the wall panel, i.e., the failure of the ends of the ice condenser, Expert C calculated a midpoint failure impulse of 0.35 psi-s. Failure of the ends of the ice condenser would result in bypass of the ice condenser, but not containment failure. How much function of the ice condenser would be lost by failure of an end of the ice condenser would depend upon the exact failure location and size.

Effect of a Detonation on the Ice Baskets. The ice baskets are cylinders approximately 12 in. in diameter and 12 ft in length. Four baskets are joined to form a column 48 ft long. The sheet steel forming the wall of the baskets are perforated: the open area is 64%. There is a lateral

support for the baskets every 6 ft. This consists of a lattice frame. The frame is supported by columns at the four corners of the frame. The two interior columns at the crane wall are attached to the wall while the two outside columns next to the shell are free standing.

A detonation in the ice condenser away from the lattice frames could cause a considerable radial displacement of the ice baskets. There is approximately 2 in. between baskets, and a cumulative displacement of 16 in. could occur. The impulse required to deform the baskets is difficult to determine due to the many variables, including the strength of the ice basket when filled with ice. It was estimated that an impulse as low as 0.02 psi-s would cause a large deformation. The uncertainties involved in this estimate are great; there is no way outside of involved experiments or calculations to refine this estimate.

References and details of his calculations are contained in Expert C's detailed notes, which are not reproduced here.

Results of Expert C's Elicitation

Expert C provided 1, 50, and 90% probability values for the impulse needed to fail the containment due to a detonation in the upper plenum and for the impulse needed to fail the containment due to a detonation in the ice condenser. These values are listed in the table below. The 0 and 100% values are extrapolations which account for other uncertainties and unknown effects. These extrapolations were made by the project staff and approved by Expert C.

For the impulse needed to fail the containment due to a detonation in the upper plenum, the midpoint value was obtained by using the estimate that a 2% global strain is equivalent to failure. The 1 and 90% impulses were obtained by applying the modification factors described above. For the impulse needed to fail the containment due to a detonation in the ice condenser, the midpoint value was obtained as described above based on a 2% global strain and the need to crush the insulating wall panels. The 1 and 90% impulses were again obtained by applying the given modification factors to the strain energy.

Best Estimate of the Impulse Needed to Fail Containment

| Cumulative Probability | <u>Detonation in the Upper Plenum</u> | | <u>Detonation in the Ice Condenser</u> | |
|---------------------------|---------------------------------------|----------------|--|----------------|
| | <u>(psi-s)</u> | <u>(kPa-s)</u> | <u>psi-s)</u> | <u>(kPa-s)</u> |
| 0% | 0.10 | 0.69 | 0.10 | 0.69 |
| 1% | 0.20 | 1.38 | 0.20 | 1.38 |
| 50% | 0.50 | 3.45 | 0.70 | 4.83 |
| 90% | 1.0 | 6.90 | 1.4 | 9.66 |
| 100% | 1.5 | 10.34 | 2.0 | 13.79 |

Sources of Uncertainty

The three major sources of uncertainty in any structural dynamics problem are: (1) the spatial and temporal description of the loading function; (2) the design of the structural components; and (3) the method(s) of analysis. For this issue, the usual method of analysis was modified so that a failure level was calculated instead of a response for a given load. However, this does not completely eliminate the uncertainty with respect to the load. As discussed in the section on calculations in the notes, the response (failure level) obviously depends on the full description of the load (spatial, direction, magnitude, pulse shape, etc.). The effect on the response has been estimated in the text.

Regarding uncertainty in the design of the structural components, a complete set of design drawings for the containment shell was available. Material properties for the steel shell were also available, including mill tests. However, only the details and drawings in the FSAR were available for the design of the ice condenser components (wall panels, ice baskets, and lattice frame). In particular, the details of the design of the wall panels are sketchy. No "as-built" drawings were available.

Because of the lack of detailed design drawings and due to the nature of the investigation, no detailed analyses were conducted. For example, a finite element analysis of the wall panels was not attempted. Rather, as described in the Expert's notes, a simplified method of analysis was used. This method has been used successfully in other applications, such as weapons design. Expert C concluded that the use of this simplified method was not a major contributor to the overall uncertainty.

5.7 Issue 7: Containment Failure Due to Wetwell Detonations at Grand Gulf

Experts consulted: Charles Miller, City College of New York; Subir Sen, Bechtel Corp ; Donald Wesley, IMPELL.

Issue Description

Two separate questions were asked. The first was: "What is the distribution that characterizes the uncertainty in the dynamic load in the wetwell required to produce failure of the containment for the Grand Gulf atomic power plant?" The second was: "What is the distribution that characterizes the uncertainty in the dynamic load in the wetwell required to produce failure of the structure between the wetwell and the drywell, above the suppression pool?"

The independent variables were initial leakage level in the drywell, impulse generated by the detonation and existing static pressure at the time of detonation. Three cases were initially defined.

Case 1: No existing leakage in the drywell and the wetwell is at ambient pressure at the time of detonation.

Case 2: The wetwell was preconditioned by a sustained static pressure before the detonation.

Case 3: There is an existing leak in the drywell at Levels 2 or 3, respectively. Thus, the drywell has been preconditioned by damage due to pressure pulses before the detonation.

During discussion, the three experts agreed that the range of impulses for which the existence of pre-existing leakage at Levels 2 or 3 made any difference in the containment response was so small that pre-existing leakage could be ignored. Thus, Case 3 is indistinguishable from Case 1 and no separate results were obtained for Case 3.

The variable elicited is the probability of a failure at a given level. Levels of failure are separately defined for the containment leakage and for suppression pool bypass.

For the containment or wetwell failure, three levels of failure were defined at first:

Level 1 is development of a leak which does not significantly exceed the technical specifications. (Leakage less than 0.5% per day.)

Level 2 is a leak having an area of approximately 0.1 ft².

Level 3 is a leak sufficient to depressurize the containment (area greater than 1 ft²).

It was later determined that leakage near the design basis level was not of interest and Level 1 was eliminated.

For suppression pool bypass or drywell failure, four levels were defined:

Level 1 is development of a leak with an area of approximately 0.017 ft².

Level 2 is a leak with an area of approximately 0.1 ft².

Level 3 is a leak with an area of approximately 1.0 ft².

Level 4 is the drywell completely failed; the failure creates an escape path with an area of approximately 10 ft² or more.

Subsequent to the elicitation, the accident progression event tree was altered to combine Levels 3 and 4, and Level 1 was eliminated.

All three experts indicated that failure probabilities for case 2 could be obtained from the distributions for case 1 by application of the interaction factor. Thus there were no separate results given for case 2. Furthermore, case 2 was not used in the accident progression analysis. The only time the static pressure would be large enough to significantly affect the failure distribution would be during blackout accidents when the suppression pool has reached saturation temperature. In this situation, the wetwell will probably be inert due to the high steam concentration. Therefore, as case 3 was combined with case 1 and case 2 was not used, only the results for case 1 were aggregated.

Summary of Results

Tables 7-1 through 7-3 contain the containment failure distribution for the three experts. The aggregate distribution is given in Table 7-4. Tables 7-5 and 7-6 give the distributions of Experts A and B for wetwell failure or suppression pool by pass. Expert C concluded that his distribution for drywell failure (Table 7-3) applied to wetwell failures as well. The aggregate wetwell failure distributions are given in Table 7-7.

Expert A provided cumulative failure probabilities as functions of applied impulse, and conditional probabilities of failure at Levels 1, 2, and 3. The cumulative failure probability was corrected for elimination of Level 1, and the conditional probabilities for Levels 2 and 3 were renormalized. After elimination of Level 1, Expert A's cumulative distribution did not go to a high probability level. The distribution was linearly extrapolated to unit probability. For drywell failure, Expert A provided separate distributions for detonations originating in the wetwell annulus and the dome. Either ignition location is equally likely, so the two distributions were numerically averaged. Table 7-1 shows Expert A's corrected distribution for containment failure in the standard format. Table 7-5 shows Expert A's corrected distribution for drywell failure.

Expert B also provided total and conditional distributions for each level. A distribution was given for drywell failure only, with the proviso that impulse levels should be reduced by 40% for the containment wall. Expert B's conditional probabilities for Levels 3 and 4 were summed to give total probabilities for a combined Level 3 and 4. Tables 7-2 and 7-6 give the failure distributions for Expert B.

Expert C provided separate distributions for failure at Levels 2 and 3. He stated that he was unable to distinguish between the drywell and containment, and that the same distribution should apply to each. Expert C's independent distributions for each failure level were converted to a total cumulative failure probability, and conditional probabilities for each level. Table 7-3 gives Expert C's converted results for containment and drywell failure. Note that Expert C did not assume that Level 2 was more likely at low levels and Level 3 was more likely at high levels, as did the other experts. He apparently believes that Level 2 is approximately twice as likely as Level 3 at all impulse levels. The jumps in the curves are a result of the numerical conversion to conditional probabilities, and do not indicate an intention by the expert to vary the conditional probabilities.

Method of Aggregation

To make the aggregation simpler, all distributions were converted to impulse at intervals of 2.5 kPa-s. Linear interpolation was used to find dependent variables between the impulse points given by the experts, and points outside of the range given by the experts were found by linear extrapolation.

The total cumulative failure probabilities and conditional probabilities for each level were aggregated by averaging probabilities for each impulse level. The results are shown in Tables 7-4 and 7-7 and Figures 7-1 and 7-2. Figure 7-1 shows the aggregate cumulative failure probability and the aggregate conditional failure level probabilities for containment (wetwell) failure. Figure 7-2 shows analogous information for drywell failure. The conditional probabilities for each level fluctuate because of the numerical conversion procedure used on Expert C's data. The quality of the aggregated conditional probabilities can be improved if the mean value for all impulse levels is used for Expert C. The results of this smoothing procedure are shown in Figures 3 and 4.

The results from the three experts are qualitatively similar. Usually Expert B assessed a lower strength than the other experts, and Expert C assessed a higher strength, although there are exceptions for some cases and some fractiles. Expert A was generally intermediate between Experts B and C. The aggregate total cumulative failure curves are smooth and well behaved. The aggregate distributions appear to be roughly log-normal in shape.

Table 7-1
Containment Failure: Distributions for Expert A

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 2.5 | 0.073 | 1.000 | 0.000 |
| 5.0 | 0.272 | 0.937 | 0.063 |
| 7.5 | 0.533 | 0.856 | 0.144 |
| 10.0 | 0.606 | 0.715 | 0.285 |
| 12.5 | 0.679 | 0.573 | 0.427 |
| 15.0 | 0.751 | 0.430 | 0.570 |
| 17.5 | 0.824 | 0.294 | 0.706 |
| 20.0 | 0.896 | 0.16 | 0.833 |
| 22.5 | 0.969 | 0.048 | 0.952 |
| 25.0 | 1.000 | 0.000 | 1.000 |

Table 7-2
Containment Failure
Distributions for Expert B

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 2.5 | 0.005 | 1.000 | 0.000 |
| 5.0 | 0.118 | 1.000 | 0.000 |
| 7.5 | 0.285 | 1.000 | 0.000 |
| 10.0 | 0.474 | 1.000 | 0.000 |
| 12.5 | 0.626 | 0.747 | 0.253 |
| 15.0 | 0.766 | 0.459 | 0.541 |
| 17.5 | 0.841 | 0.000 | 1.000 |
| 20.0 | 0.907 | 0.000 | 1.000 |
| 22.5 | 0.941 | 0.000 | 1.000 |
| 25.0 | 0.961 | 0.000 | 1.000 |
| 27.5 | 0.974 | 0.000 | 1.000 |
| 30.0 | 0.988 | 0.000 | 1.000 |
| 32.5 | 1.000 | 0.000 | 1.000 |

Table 7-3
Containment or Drywell Failure
Distributions for Expert C

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 2.5 | 0.000 | 1.000 | 0.000 |
| 5.0 | 0.000 | 1.000 | 0.000 |
| 7.5 | 0.000 | 1.000 | 0.000 |
| 10.0 | 0.000 | 1.000 | 0.000 |
| 12.5 | 0.030 | 0.813 | 0.187 |
| 15.0 | 0.059 | 0.626 | 0.374 |
| 17.5 | 0.106 | 0.696 | 0.305 |
| 20.0 | 0.154 | 0.765 | 0.235 |
| 22.5 | 0.217 | 0.721 | 0.279 |
| 25.0 | 0.279 | 0.677 | 0.323 |
| 27.5 | 0.339 | 0.674 | 0.326 |
| 30.0 | 0.398 | 0.671 | 0.329 |
| 32.5 | 0.453 | 0.678 | 0.322 |
| 35.0 | 0.507 | 0.686 | 0.314 |
| 37.5 | 0.557 | 0.695 | 0.306 |
| 40.0 | 0.606 | 0.703 | 0.297 |
| 42.5 | 0.656 | 0.607 | 0.393 |
| 45.0 | 0.706 | 0.511 | 0.489 |
| 47.5 | 0.747 | 0.498 | 0.502 |
| 50.0 | 0.788 | 0.486 | 0.514 |
| 52.5 | 0.818 | 0.517 | 0.483 |
| 55.0 | 0.849 | 0.548 | 0.452 |
| 57.5 | 0.872 | 0.594 | 0.407 |
| 60.0 | 0.895 | 0.639 | 0.361 |
| 62.5 | 0.913 | 0.639 | 0.361 |
| 65.0 | 0.930 | 0.638 | 0.362 |
| 67.5 | 0.940 | 0.548 | 0.452 |
| 70.0 | 0.950 | 0.457 | 0.543 |
| 72.5 | 0.958 | 0.453 | 0.547 |
| 75.0 | 0.966 | 0.449 | 0.551 |
| 77.5 | 0.972 | 0.460 | 0.540 |
| 80.0 | 0.978 | 0.470 | 0.530 |
| 82.5 | 0.983 | 0.536 | 0.463 |
| 85.0 | 0.987 | 0.603 | 0.397 |
| 87.5 | 0.991 | 0.637 | 0.364 |
| 90.0 | 0.994 | 0.670 | 0.330 |

Table 7-3 (continued)

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 92.5 | 0.995 | 0.560 | 0.440 |
| 95.0 | 0.996 | 0.450 | 0.550 |
| 97.5 | 0.997 | 0.477 | 0.524 |
| 100.0 | 0.998 | 0.503 | 0.497 |
| 102.5 | 0.999 | 0.535 | 0.465 |

Table 7-4
Containment Failure
Aggregate Distributions

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 2.5 | 0.026 | 1.000 | 0.000 |
| 5.0 | 0.130 | 0.979 | 0.021 |
| 7.5 | 0.273 | 0.932 | 0.068 |
| 10.0 | 0.360 | 0.846 | 0.154 |
| 12.5 | 0.445 | 0.611 | 0.389 |
| 15.0 | 0.525 | 0.348 | 0.652 |
| 17.5 | 0.590 | 0.170 | 0.830 |
| 20.0 | 0.653 | 0.118 | 0.882 |
| 22.5 | 0.709 | 0.076 | 0.924 |
| 25.0 | 0.747 | 0.054 | 0.946 |
| 27.5 | 0.771 | 0.045 | 0.955 |
| 30.0 | 0.795 | 0.038 | 0.962 |
| 32.5 | 0.818 | 0.034 | 0.966 |
| 35.0 | 0.836 | 0.031 | 0.969 |
| 37.5 | 0.852 | 0.028 | 0.972 |
| 40.0 | 0.869 | 0.026 | 0.974 |
| 42.5 | 0.885 | 0.020 | 0.980 |
| 45.0 | 0.902 | 0.016 | 0.984 |
| 47.5 | 0.916 | 0.014 | 0.986 |
| 50.0 | 0.929 | 0.013 | 0.987 |
| 52.5 | 0.940 | 0.013 | 0.987 |
| 55.0 | 0.950 | 0.013 | 0.987 |
| 57.5 | 0.957 | 0.013 | 0.987 |
| 60.0 | 0.965 | 0.013 | 0.987 |

Table 7-4 (continued)

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 62.5 | 0.971 | 0.013 | 0.987 |
| 65.0 | 0.977 | 0.012 | 0.988 |
| 67.5 | 0.980 | 0.010 | 0.990 |
| 70.0 | 0.983 | 0.008 | 0.992 |
| 72.5 | 0.986 | 0.007 | 0.993 |
| 75.0 | 0.989 | 0.007 | 0.993 |
| 77.5 | 0.991 | 0.007 | 0.993 |
| 80.0 | 0.993 | 0.007 | 0.993 |
| 82.5 | 0.994 | 0.007 | 0.993 |
| 85.0 | 0.996 | 0.008 | 0.992 |
| 87.5 | 0.997 | 0.008 | 0.992 |
| 90.0 | 0.998 | 0.008 | 0.992 |
| 92.5 | 0.998 | 0.007 | 0.993 |
| 95.0 | 0.999 | 0.005 | 0.995 |
| 97.5 | 0.999 | 0.005 | 0.995 |
| 100.0 | 0.999 | 0.006 | 0.994 |
| 102.5 | 1.000 | 0.006 | 0.994 |

Table 7-5
Drywell Failure
Distributions for Expert A

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 5.0 | 0.036 | 0.979 | 0.021 |
| 7.5 | 0.076 | 0.951 | 0.049 |
| 10.0 | 0.129 | 0.907 | 0.093 |
| 12.5 | 0.180 | 0.877 | 0.123 |
| 15.0 | 0.245 | 0.849 | 0.151 |
| 17.5 | 0.324 | 0.821 | 0.179 |
| 20.0 | 0.404 | 0.793 | 0.207 |
| 22.5 | 0.446 | 0.778 | 0.222 |
| 25.0 | 0.474 | 0.767 | 0.233 |
| 27.5 | 0.502 | 0.757 | 0.243 |
| 30.0 | 0.530 | 0.747 | 0.253 |
| 32.5 | 0.558 | 0.737 | 0.263 |

Table 7-5 (continued)

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 35.0 | 0.583 | 0.725 | 0.275 |
| 37.5 | 0.595 | 0.707 | 0.293 |
| 40.0 | 0.607 | 0.688 | 0.312 |
| 42.5 | 0.620 | 0.670 | 0.330 |
| 45.0 | 0.632 | 0.651 | 0.349 |
| 47.5 | 0.645 | 0.633 | 0.367 |
| 50.0 | 0.657 | 0.615 | 0.385 |
| 52.5 | 0.669 | 0.596 | 0.404 |
| 55.0 | 0.682 | 0.578 | 0.422 |
| 57.5 | 0.694 | 0.559 | 0.441 |
| 60.0 | 0.707 | 0.541 | 0.459 |
| 62.5 | 0.719 | 0.523 | 0.477 |
| 65.0 | 0.731 | 0.504 | 0.496 |
| 67.5 | 0.744 | 0.486 | 0.514 |
| 70.0 | 0.756 | 0.466 | 0.534 |
| 72.5 | 0.769 | 0.446 | 0.554 |
| 75.0 | 0.781 | 0.425 | 0.575 |
| 77.5 | 0.793 | 0.404 | 0.596 |
| 80.0 | 0.806 | 0.383 | 0.617 |
| 82.5 | 0.818 | 0.363 | 0.637 |
| 85.0 | 0.831 | 0.342 | 0.658 |
| 87.5 | 0.843 | 0.321 | 0.679 |
| 90.0 | 0.856 | 0.301 | 0.699 |
| 92.5 | 0.868 | 0.280 | 0.720 |
| 95.0 | 0.880 | 0.259 | 0.741 |
| 97.5 | 0.893 | 0.238 | 0.762 |
| 100.0 | 0.905 | 0.218 | 0.782 |
| 102.5 | 0.918 | 0.197 | 0.803 |
| 105.0 | 0.930 | 0.176 | 0.824 |
| 107.5 | 0.942 | 0.156 | 0.844 |
| 110.0 | 0.947 | 0.142 | 0.858 |
| 112.5 | 0.952 | 0.129 | 0.871 |
| 115.0 | 0.957 | 0.115 | 0.885 |
| 117.5 | 0.962 | 0.101 | 0.899 |
| 120.0 | 0.968 | 0.087 | 0.913 |
| 122.5 | 0.973 | 0.073 | 0.927 |
| 125.0 | 0.978 | 0.059 | 0.941 |

Table 7-6
 Drywell Failure
 Distribution for Expert B

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 2.5 | 0.000 | 1.000 | 0.000 |
| 5.0 | 0.024 | 1.000 | 0.000 |
| 7.5 | 0.089 | 1.000 | 0.000 |
| 10.0 | 0.183 | 1.000 | 0.000 |
| 12.5 | 0.285 | 1.000 | 0.000 |
| 15.0 | 0.399 | 1.000 | 0.000 |
| 17.5 | 0.509 | 1.000 | 0.000 |
| 20.0 | 0.596 | 0.825 | 0.175 |
| 22.5 | 0.688 | 0.708 | 0.292 |
| 25.0 | 0.766 | 0.459 | 0.541 |
| 27.5 | 0.811 | 0.000 | 1.000 |
| 30.0 | 0.856 | 0.000 | 1.000 |
| 32.5 | 0.901 | 0.000 | 1.000 |
| 35.0 | 0.921 | 0.000 | 1.000 |
| 37.5 | 0.941 | 0.000 | 1.000 |
| 40.0 | 0.955 | 0.000 | 1.000 |
| 42.5 | 0.964 | 0.000 | 1.000 |
| 45.0 | 0.972 | 0.000 | 1.000 |
| 47.5 | 0.980 | 0.000 | 1.000 |
| 50.0 | 0.988 | 0.000 | 1.000 |
| 52.5 | 0.996 | 0.000 | 1.000 |
| 55.0 | 1.000 | 0.000 | 1.000 |

Table 7.7
Drywell Failure
Aggregate Distributions

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 2.5 | 0.000 | 1.000 | 0.000 |
| 5.0 | 0.020 | 0.993 | 0.007 |
| 7.5 | 0.055 | 0.984 | 0.016 |
| 10.0 | 0.104 | 0.969 | 0.031 |
| 12.5 | 0.165 | 0.897 | 0.103 |
| 15.0 | 0.234 | 0.825 | 0.175 |
| 17.5 | 0.313 | 0.839 | 0.161 |
| 20.0 | 0.385 | 0.794 | 0.206 |
| 22.5 | 0.450 | 0.736 | 0.264 |
| 25.0 | 0.506 | 0.634 | 0.366 |
| 27.5 | 0.551 | 0.477 | 0.523 |
| 30.0 | 0.595 | 0.473 | 0.527 |
| 32.5 | 0.637 | 0.472 | 0.528 |
| 35.0 | 0.670 | 0.470 | 0.530 |
| 37.5 | 0.698 | 0.467 | 0.533 |
| 40.0 | 0.723 | 0.464 | 0.536 |
| 42.5 | 0.746 | 0.426 | 0.574 |
| 45.0 | 0.770 | 0.387 | 0.613 |
| 47.5 | 0.790 | 0.377 | 0.623 |
| 50.0 | 0.811 | 0.367 | 0.633 |
| 52.5 | 0.828 | 0.371 | 0.629 |
| 55.0 | 0.844 | 0.375 | 0.625 |
| 57.5 | 0.855 | 0.384 | 0.616 |
| 60.0 | 0.867 | 0.393 | 0.607 |
| 62.5 | 0.877 | 0.387 | 0.613 |
| 65.0 | 0.887 | 0.381 | 0.619 |
| 67.5 | 0.895 | 0.344 | 0.656 |
| 70.0 | 0.902 | 0.308 | 0.692 |
| 72.5 | 0.909 | 0.300 | 0.700 |
| 75.0 | 0.916 | 0.291 | 0.709 |
| 77.5 | 0.922 | 0.288 | 0.712 |
| 80.0 | 0.928 | 0.284 | 0.716 |

Table 7-7 (continued)

| Impulse (kPa-s) | Total Cumulative Failure Probability | Conditional Probabilities | |
|--------------------|---|---------------------------|-----------------|
| | | Level 2 Failure | Level 3 Failure |
| 82.5 | 0.934 | 0.300 | 0.700 |
| 85.0 | 0.939 | 0.315 | 0.685 |
| 87.5 | 0.945 | 0.319 | 0.681 |
| 90.0 | 0.950 | 0.324 | 0.676 |
| 92.5 | 0.954 | 0.280 | 0.720 |
| 95.0 | 0.959 | 0.236 | 0.764 |
| 97.5 | 0.963 | 0.238 | 0.762 |
| 100.0 | 0.968 | 0.240 | 0.760 |
| 102.5 | 0.972 | 0.244 | 0.756 |
| 105.0 | 0.976 | 0.248 | 0.752 |
| 107.5 | 0.980 | 0.280 | 0.720 |
| 110.0 | 0.982 | 0.313 | 0.687 |
| 112.5 | 0.984 | 0.319 | 0.681 |
| 115.0 | 0.986 | 0.325 | 0.675 |
| 117.5 | 0.987 | 0.268 | 0.732 |
| 120.0 | 0.989 | 0.210 | 0.790 |
| 122.5 | 0.991 | 0.210 | 0.790 |
| 125.0 | 0.993 | 0.209 | 0.791 |




Figure 7-1. Aggregate Containment Failure Distributions.




Figure 7-2. Aggregate Drywell Failure Distributions.




Figure 7-3. Aggregate Smoothed Containment Failure Distributions.




Figure 7-4. Aggregate Smoothed Drywell Failure Distributions.

Individual Elicitations for Issue 7

Expert A's Elicitation

Containment Failure Due to Wetwell Detonations at Grand Gulf

Description of Expert A's Rationale/Methodology

Expert A first considered the strength of the containment due to a static pressure. He estimated the wetwell failure pressure to be between 40 and 75 psig, with a median (based on reported yield strength) of 56 psig. For the structure between the drywell and the wetwell--which he considered to be more uncertain--he took low, median, and high values to be 30, 50, and 80 psig, respectively.

He then considered the response of the structure to pulses with durations of 1 to 15 ms, with low, median, and high values of containment strength, and high and low "pulse amplification factors" of 3 and 0.1. The lower value of the pulse amplification factor accounts for the fact that the impulse in the annular region between the wetwell and drywell could not possibly be axisymmetric, and therefore must be less severe than the axisymmetric case. For detonations above the drywell, the minimum pulse amplification factor was 0.5.

Expert A then computed the response of a single degree of freedom system, and calculated the impulse to give five times the yield deflection, corresponding to approximately 2% strain in the liner. Because of strain concentrations, 2% average strain would give much higher local strains, and would be expected to cause failure.

Expert A performed analyses for three cases: failure in containment above the drywell, due to detonation above the drywell (Case 1A); failure of the containment due to a detonation in the wetwell annulus (Case 1B), and failure of the drywell due to a detonation in the wetwell annulus (Case 1C).

The location of a detonation is uncertain. It is assumed that ignition sites are equally likely in the dome above the drywell and in the annulus between the drywell and the containment structure. For failure of the containment, therefore, the overall cumulative distribution function (CDF) is taken to be the average of the CDF for Cases 1a and 1b.

Case 1 was calculated in detail. Case 2 can be derived from Case 1 by multiplying impulse values by the factor $(1 - P_s/P_y)$, where P_s is the static pressure, and P_y is the pressure to cause yield. For Case 3, the Expert believed that any damage to the drywell would be highly localized, and it would be unlikely that the damaged area would coincide with the area to which impulse was applied. Therefore, Case 3 is not distinct from Case 1.

Level 4 was ruled out for the drywell, because the load would be compressive, and the Expert did not believe this level of damage was possible for compressive loading.

Results of Expert A's Elicitation

Expert A provided impulses for five failure probabilities for Cases 1a, 1b, and 1c as shown in Tables A-1, A-2, and A-3. To extend these distributions to 0 and 1.0 probabilities, linear extrapolation was used. However, in no case was the 0th percentile impulse allowed to be less than half the 5th percentile impulse.

Table A-1
Case 1A--Failure of Containment Above Drywell,
Due to Detonation Above Drywell

| Side-On Impulse (psi-s) | Probability of Failure | Conditional Probability For Each Level | | |
|----------------------------|---------------------------|--|---------|---------|
| | | Level 1 | Level 2 | Level 3 |
| 0.04 | 0.05 | 0.95 | 0.05 | 0.00 |
| 0.5 | 0.25 | 0.50 | 0.50 | 0.00 |
| 0.75 | 0.50 | 0.25 | 0.70 | 0.05 |
| 1.00 | 0.75 | 0.10 | 0.80 | 0.10 |
| 2.00 | 0.95 | 0.00 | 0.50 | 0.50 |

Table A-2
Case 1B--Failure of Containment at Annulus,
Due to Detonation in the Annulus

| Side-On Impulse (psi-s) | Probability of Failure | Conditional Probability For Each Level | | |
|----------------------------|---------------------------|--|---------|---------|
| | | Level 1 | Level 2 | Level 3 |
| 0.4 | 0.05 | 0.95 | 0.05 | 0.00 |
| 2.0 | 0.25 | 0.50 | 0.40 | 0.10 |
| 3.0 | 0.50 | 0.10 | 0.60 | 0.30 |
| 5.0 | 0.75 | 0.00 | 0.50 | 0.50 |
| 10.0 | 0.95 | 0.00 | 0.20 | 0.80 |

Table A-3
Case 1C--Failure of Drywell/Wetwell Structure
Due to Detonation in Wetwell Annulus

| Side-On Impulse (psi-s) | Probability of Failure | Conditional Probability For Each Level | | | |
|----------------------------|---------------------------|--|---------|---------|---------|
| | | Level 1 | Level 2 | Level 3 | Level 4 |
| 0.4 | 0.05 | 0.90 | 0.10 | 0.00 | 0.00 |
| 1.0 | 0.25 | 0.60 | 0.40 | 0.00 | 0.00 |
| 1.5 | 0.50 | 0.20 | 0.75 | 0.05 | 0.00 |
| 3.0 | 0.75 | 0.05 | 0.85 | 0.10 | 0.00 |
| 10.0 | 0.95 | 0.00 | 0.75 | 0.25 | 0.00 |

To aggregate this Expert's distributions with those of the other experts', and to average his distributions for Cases 1A and 1B, it is necessary to develop independent CDFs for each failure level. The probability density function (PDF) is calculated from the CDF. The average density over an impulse level "i" is

$$D(i-1/2) = (P(i) - P(i-1)) / (I(i) - I(i-1)),$$

where:

$D(i-1/2)$ is the probability density at the midpoint of the interval $i-1$ to i ;

$P(i)$ is the probability of failure at interval i ;

$P(i-1)$ is the probability of failure at interval $i-1$;

$I(i)$ is the impulse at interval i , and

$I(i-1)$ is the impulse at interval $i-1$.

The probability of failure in level m within the interval is the density across the interval, times the average conditional probability of failure in level m for the interval:

$$D(i-1/2, m) = D(i-1/2) * [\Pr(F(i, m: F)) + \Pr(F(i-1, m: F))] / 2,$$

where:

$D(i-1/2, m)$ is the probability density of failure at the midpoint of the interval $i-1$ to i , in level m ,

$\Pr(F(i, m: F))$ is the conditional probability of failure at level m , interval i , given that failure occurs at the interval.

The CDF for failure in level m (independent of failure at all other levels) is the integral of the density $D(i,m)$ from the lowest to the highest level of impulse. The independent CDFs for each level are then averaged for Cases 1A and 1B. Also, the independent CDFs will be averaged with those of the other experts to give aggregated CDFs for failure at each level. The assumption of independence implies that the total failure probability is:

$$P_T = 1 - (1 - P_1)(1 - P_2)(1 - P_3),$$

where:

P_T is the total failure probability, that is, the probability of failure at any level;

P_1 is the probability of failure at Level 1, independent of all other levels;

P_2 is the probability of failure at Level 2, etc.

As a check on the calculations, the total probability of the independent CDFs for each level must be equal to the total probability given by the expert. Because the independent CDFs have been calculated using numerical differentiation and integration--with the inaccuracies to which these processes are subject--the averaged CDFs will not usually be exactly equal to the computed CDFs. A factor "k" was calculated, which, when multiplied by the density for each failure level, made the computed total CDF equal to the original CDF at each point.

The independent CDFs are given in Tables A-4 through A-6.

Table A-4
Case 1A: Independent CDFs for Each Failure Level

| Side-On Impulse (psi-s) | Independent Failure Probabilities | | | |
|----------------------------|-----------------------------------|---------|---------|-------|
| | Level 1 | Level 2 | Level 3 | Total |
| 0.02 | 0.000 | 0.000 | 0.000 | 0.00 |
| 0.04 | 0.049 | 0.001 | 0.000 | 0.05 |
| 0.5 | 0.202 | 0.060 | 0.000 | 0.25 |
| 0.75 | 0.324 | 0.254 | 0.008 | 0.50 |
| 1.0 | 0.397 | 0.568 | 0.039 | 0.75 |
| 2.0 | 0.422 | 0.893 | 0.190 | 0.95 |
| 2.25 | 0.422 | 1.000 | 0.509 | 1.00 |

Table A-5
Case 1B: Independent CDFs for Each Failure Level

| Side-On Impulse (psi-s) | Independent Failure Probabilities | | | |
|----------------------------|-----------------------------------|---------|---------|-------|
| | Level 1 | Level 2 | Level 3 | Total |
| 0.2 | 0.000 | 0.000 | 0.000 | 0.00 |
| 0.4 | 0.049 | 0.001 | 0.000 | 0.05 |
| 2.0 | 0.203 | 0.049 | 0.011 | 0.25 |
| 3.0 | 0.305 | 0.219 | 0.079 | 0.50 |
| 5.0 | 0.329 | 0.487 | 0.273 | 0.75 |
| 10.0 | 0.329 | 0.729 | 0.724 | 0.95 |
| 11.25 | 0.329 | 0.760 | 1.000 | 1.00 |

Table A-6
Case 1C: Independent CDFs for Each Failure Level

| Side-On Impulse (psi-s) | Independent Failure Probabilities | | | |
|----------------------------|-----------------------------------|---------|---------|-------|
| | Level 1 | Level 2 | Level 3 | Total |
| 0.25 | 0.000 | 0.000 | 0.000 | 0.00 |
| 0.4 | 0.048 | 0.003 | 0.000 | 0.05 |
| 1.0 | 0.206 | 0.055 | 0.000 | 0.25 |
| 1.5 | 0.335 | 0.241 | 0.008 | 0.50 |
| 3.0 | 0.388 | 0.575 | 0.039 | 0.75 |
| 10.0 | 0.398 | 0.906 | 0.119 | 0.95 |
| 11.75 | 0.398 | 1.000 | 0.168 | 1.00 |

The overall probability of containment failure is the average, by levels, of the independent probabilities for Cases 1a and 1b. Figure A-1 shows the averaged failure probabilities for Levels 1 through 3, along with the total cumulative failure probability. The ordinate on each curve is the probability that the impulse required to cause failure of that level (independent of all other levels) is no greater than the value of impulse on the abscissa. The ordinate for the "total" curve is the probability that the impulse required to cause failure at any level is no greater than the value on the abscissa.

Table A-1, for containment failure, is obtained from Tables A-4 and A-5 by eliminating Level 1, interpolating to obtain failure probabilities for 2.5 kPa-s, and combining independent distributions to obtain a total cumulative distribution and conditional probabilities for failure level. Table A-5, for drywell failure, is obtained analogously from Table A-6.

CONTAINMENT FAILURE BY DETONATIONS, GRAND GULF




Figure A-1. Averaged Failure Probabilities for Levels 1 Through 3.

Sources of Uncertainty

A major source of uncertainty is the description of the detonation. If the initiation point, duration, and reflections of the impulse were accurately known, the structural response could be calculated with much less uncertainty. There is also considerable uncertainty with regard to the level of damage expected; however, this uncertainty is also less than the uncertainty in the initial conditions.

Suggested Methods for Removing Uncertainty

Because the major source of uncertainty is the stochastic nature of the initial conditions, it is virtually impossible to make marked reduction in the uncertainty.

Expert B's Elicitation

Containment Failure Due to Wetwell Detonations at Grand Gulf

Description of Expert B's Rationale/Methodology

Expert B considered five basic failure modes: (1) failure of the drywell concrete, (2) failure of the drywell head, (3) failure of the drywell head closure pins, (4) failure of the vacuum breaker pipes, and (5) failure of any other pipe penetrations. He worked from existing containment analysis results, but he had no drywell analysis results or structural drawings. He estimated concrete strength of the drywell by the same safety factors used for the containment.

Expert B concluded that vacuum breaker failure was unlikely because the path that the pressure pulse must follow to the vacuum breakers is quite tortuous. For a detonation in the drywell, the momentum of the pulse would be absorbed in the two 30° elbows embedded in the concrete and one more 90° elbow in the piping. Although he had no detailed description of the valves, they are designed to withstand 35 psi pressure, so, in his opinion, failure from a detonation impulse is not likely. For a detonation in the upper part of the wetwell, approximately 10 ft of 8 in. Schedule 40 pipe and valves are exposed to the pressure pulse in the containment atmosphere. It would be more likely that a detonation would fail the vacuum pipes because of drag forces from the detonation than by a reflected wave. However, this is not a likely possibility. The pipe is expected to hinge near the slab and at a support. Large ductility can be mobilized (in his judgment, 10 to 20) before pipe fracture. Very high pressures can be tolerated, well outside the range of credible pressures.

The Expert concentrated on the drywell-wetwell wall. Leak and rupture appear to be controlled by the concrete. Simple hand calculations of the expected strain in the drywell liner were conducted by the expert to estimate the expected static capacity and to estimate the elastic frequency. The peak dynamic reflected pressures at which leak was expected to occur were translated to impulse by assuming impulse durations of 3 to 10 ms with varying shapes. He did include consideration of secondary impulses in calculating the impulse from peak dynamic pressure. He looked for places where the strain concentrates in the liner. Leakage could occur as well at other places but ductile failure there would lead to rupture. He used conservative assumptions to form a lower bound. Leak was expected from ductilities of about 3 to 8.

Expert B did not differentiate between probability of failure at Level 2 and Level 3, both of which he classified as leakage. Level 2 and Level 3 failures imply no rebar failure and no large hole in the concrete. An example of a Level 2 failure would be a tear in the liner and a crack in the concrete with a fraction of an inch width extending several feet in length. This type of failure would be expected to occur most often as a result of strain concentrations around penetrations etc. An example of a Level 3 failure would also consist of a tear in the liner and a narrow concrete crack, but this time extending over a much greater length. This

type of failure would be expected to occur away from areas of strain concentration and would be expected to occur in the area of high average hoop strains. A crack of this type could be expected to run over half the height of the wall or more.

The Expert gave a separate distribution for rupture. Rupture pressures were estimated by assuming a ductile liner, no controlling strain concentrations and an average strain of 4 to 5%. In order for the concrete to rupture, the rebar would be required to fracture before liner rupture. Rupture pressures were estimated using the same pressure pulse assumptions (i.e., translating a reflected pressure into impulse by assuming a 3 to 10 ms pulse duration) but using higher liner ductilities of from about 5 to 15 to reach the expected reinforcing steel uniaxial strains required to cause failure.

Head failure was dismissed as a failure mode because there was no possibility of a detonable mixture there. If there is a possibility of getting detonable mixtures in the upper head of the drywell, he did make estimates of the pressures required to produce shear pin failure.

Expert B did not look at details such as hatches or electrical penetrations. He expressed concern that some hatches could be one-way hatches and could unseat if overpressures are encountered in the unexpected direction.

Expert B obtained his failure probability distributions for the containment (wetwell) by taking his distributions for the drywell and reducing the failure pressures down by 40%.

Finally, all the estimates were predicated on the assumption that the impulse duration of the detonation would range from 3 to 10 ms. Changing the pulse duration to 20 to 40 ms would require the Expert to take a closer look at the structure vibration modes, since the dynamic amplification is a non-linear effect once yield is exceeded.

Results of Expert B's Elicitation

Case 1

Table B-1 shows Expert B's estimate of the probability of leakage in the drywell due to concrete failure as a function of reflected pressure and impulse. At the lower values of reflected pressure he expects a Level 2 leak, at the higher values of reflected pressure he expects a Level 3 leak to result. The dividing line between Level 2 and Level 3 leaks is about 400 psig.

Table B-1
Drywell Leakage

| Cumulative Failure Probability for Leakage | Reflected Pressure (psig) | Impulse to Dry Well (psig-s) | Impulse (kPa-s) |
|--|---------------------------|------------------------------|-----------------|
| 0.02 | 70 | 0.7 | 4.8 |
| 0.05 | 100 | 0.9 | 6.2 |
| 0.10 | 140 | 1.14 | 7.8 |
| 0.25 | 230 | 1.7 | 11.7 |
| 0.5 | 400 | 2.5 | 17.2 |
| 0.75 | 700 | 3.5 | 24.1 |
| 0.9 | 1200 | 4.7 | 32.4 |
| 0.95 | 1600 | 5.6 | 38.6 |
| 0.98 | 2300 | 6.9 | 47.6 |

Table B-2 depicts his estimate of the probabilities of rupture failure of the drywell. His rupture curve applies to Levels 3 and 4. Above a reflected pressure of 2000 psig a Level 4 leak would be more likely than a Level 3 leak. Below a reflected pressure of 1300 psig a Level 3 leak would be more likely than a Level 4 leak. There is no chance of a Level 4 leak at or below 800 psig.

Table B-2
Drywell Rupture

| Cumulative Failure Probability for Rupture | Reflected Pressure (psig) | Impulse to Dry Well (psig-s) | Impulse to Drywell (kPa-s) |
|--|---------------------------|------------------------------|----------------------------|
| 0.02 | 300 | 3.0 | 20.7 |
| 0.05 | 410 | 3.5 | 24.7 |
| 0.10 | 530 | 3.9 | 26.2 |
| 0.25 | 810 | 4.8 | 33.1 |
| 0.50 | 1300 | 6.0 | 41.4 |
| 0.75 | 2090 | 8.4 | 58.0 |
| 0.90 | 3200 | 11.4 | 78.7 |
| 0.95 | 4100 | 13.7 | 117.3 |
| 0.98 | 5600 | 17.0 | 132.5 |

In order to put these distributions into the required format for aggregation with the other experts' distributions it was necessary to separate the probabilities for the Levels 2, 3 and 4 failures and to extend the distributions to 0 and 1.0 probabilities. The results are shown in Table B-3. The impulse units have been converted to kPa-s in Table B-3.

Table B-3
Conditional probabilities of Drywell Failure

| Cumulative Failure Probability | Impulse to Drywell(kPa-s) | Conditional Probability | | |
|--------------------------------|---------------------------|-------------------------|---------|---------|
| | | Level 2 | Level 3 | Level 4 |
| 0.00 | 3.91 | 1.0 | 0.0 | 0.0 |
| 0.02 | 4.83 | 1.0 | 0.0 | 0.0 |
| 0.05 | 6.21 | 1.0 | 0.0 | 0.0 |
| 0.10 | 7.86 | 1.0 | 0.0 | 0.0 |
| 0.25 | 11.72 | 1.0 | 0.0 | 0.0 |
| 0.50 | 17.24 | 1.0 | 0.0 | 0.0 |
| 0.54 | 18.40 | 1.0 | 0.0 | 0.0 |
| 0.62 | 20.69 | 0.75 | 0.25 | 0.0 |
| 0.75 | 24.13 | 0.67 | 0.33 | 0.0 |
| 0.80 | 26.89 | 0.0 | 1.00 | 0.0 |
| 0.90 | 32.41 | 0.0 | 1.0 | 0.0 |
| 0.95 | 38.61 | 0.0 | 0.85 | 0.15 |
| 0.95 | 41.37 | 0.0 | 0.67 | 0.33 |
| 0.98 | 47.58 | 0.0 | 0.56 | 0.44 |
| 1.00 | 53.60 | 0.0 | 0.45 | 0.55 |
| 1.00 | 57.92 | 0.0 | 0.33 | 0.67 |
| 1.00 | 78.60 | 0.0 | 0.15 | 0.85 |
| 1.00 | 94.46 | 0.0 | 0.05 | 0.95 |
| 1.00 | 117.21 | 0.0 | 0.02 | 0.98 |
| 1.00 | 132.40 | 0.0 | 0.0 | 1.00 |

Conditional probabilities for failure at each level were then converted to joint cumulative probabilities as shown in Table B-4.

Table B-4
Joint Cumulative Probability of Drywell Failure

| Cumulative Failure Probability | Impulse to Drywell(kPa-s) | Joint Cumulative Probability | | |
|--------------------------------|---------------------------|------------------------------|---------|---------|
| | | Level 2 | Level 3 | Level 4 |
| 0.00 | 3.91 | 0.0 | 0.00 | 0.00 |
| 0.02 | 4.83 | 0.02 | 0.00 | 0.00 |
| 0.05 | 6.21 | 0.05 | 0.00 | 0.00 |
| 0.10 | 7.86 | 0.10 | 0.00 | 0.00 |
| 0.25 | 11.72 | 0.25 | 0.00 | 0.00 |
| 0.50 | 17.24 | 0.50 | 0.00 | 0.00 |

Table B-4 (continued)

| Cumulative Failure Probability | Impulse to Drywell(kPa-s) | Joint Cumulative Probability | | |
|-----------------------------------|------------------------------|------------------------------|---------|---------|
| | | Level 2 | Level 3 | Level 4 |
| 0.54 | 18.40 | 0.54 | 0.60 | 0.00 |
| 0.62 | 20.69 | 0.60 | 0.02 | 0.00 |
| 0.75 | 24.13 | 0.69 | 0.06 | 0.00 |
| 0.80 | 26.89 | 0.69 | 0.11 | 0.00 |
| 0.90 | 32.41 | 0.69 | 0.21 | 0.00 |
| 0.95 | 38.61 | 0.69 | 0.26 | 0.01 |
| 0.96 | 41.37 | 0.69 | 0.26 | 0.01 |
| 0.98 | 47.58 | 0.69 | 0.27 | 0.02 |
| 1.00 | 53.60 | 0.69 | 0.28 | 0.03 |
| 1.00 | 57.92 | 0.69 | 0.28 | 0.03 |
| 1.00 | 78.60 | 0.69 | 0.28 | 0.03 |
| 1.00 | 94.46 | 0.69 | 0.28 | 0.03 |
| 1.00 | 117.21 | 0.69 | 0.28 | 0.03 |
| 1.00 | 152.40 | 0.69 | 0.28 | 0.03 |

Linear interpolation is used to derive failure probabilities for the 2.5 kPa-s increments shown in Table 7-6 for the drywell. Levels 3 and 4 are combined and listed as Level 3 in Table 7-6. Table 7-2, for containment failure, is determined from Table 7-6 by multiplying the impulse levels by 0.60 as explained above.

Case 2

Case 2 can be derived from Case 1 by multiplying impulse values by the factor $(1 - P_s/P_y)$, where P_s is the static pressure, and P_y is the pressure to cause yield.

Sources of Uncertainty

The main sources of uncertainty were the Expert's lack of knowledge of the material properties of the concrete and his lack of knowledge of the details of the plant, purely deterministic uncertainties. The assumption of a 3 to 10 ms pulse duration is also of major importance.

Suggested Methods for Reducing Uncertainty

The only additional, immediately available, information that would have helped the expert was detailed structural drawings, so that he could take a closer look at hatches and also verify the expected static pressure capacity. He had assumed the same factor of safety for the drywell as for the containment. Sandia analysts could check for the existence of one-directional hatches. If all the hatches in the drywell seat in both directions, then he thinks the hatches will not be a principal mode of failure.

Expert C's Elicitation

Containment Failure Due to Wetwell Detonations at Grand Gulf

Determination of Expert C's Rationale/Methodology

Case 1

Expert C considered a single detonation in the wetwell with no preconditioning. He assumed the detonation resulted in an axisymmetric impulsive load to structure. He looked at two locations in the containment: the upper containment (dome region) and the annular space in the wetwell. The Expert felt the asymmetrical geometry of the wetwell would have a higher capacity than the dome region. The areas he reviewed were the containment dome, drywell dome, cylindrical shell at the spring line, containment and drywell personnel locks, containment equipment hatch, vacuum breakers, and the piping system. Expert C ruled out the containment dome because the cylindrical shell is weaker than the dome. He expected that the piping system would see a drag load rather than an impulse load. Because the drag load would be less than the impulse load, he ruled out failure of the piping system. The vacuum breakers would fail only if a detonation occurred right next to them and even if they did fail, the impulse would collapse the pipe and close off any leakage. It was the Expert's opinion that the areas of concern were the containment and drywell personnel locks, equipment hatch, and the shell at the spring line. However, it was hard for the Expert to believe that both doors would fail on the personnel lock.

The Expert assumed the leakage level could be related to the ductility ratio. Next, he looked at the range of static capacities and ductility ratios for the various areas of concern. From this information, the Expert assessed the failure probability of the containment and the drywell. He felt the same distribution would apply to both the containment and the drywell because they had similar failure modes.

The Expert defined three levels of leakage: very small leak, small leak, and large leak. The very small leak corresponds to roughly the nominal leakage level. The large leakage level corresponds to a leak that is greater than 1 ft², and this includes both Levels 3 and 4 when applied to the drywell.

Case 2

The failure probabilities for this case can be derived from Case 1 by multiplying impulse values by the interaction factor, $(1 - P_s/P_y)$, where P_s is the static pressure and P_y is the yield pressure.

Results of Expert C's Elicitation

For Case 1, the failure probabilities for a very small leak, a small leak, and a large leak are presented in Tables C-1, C-2, and C-3, respectively. The distributions tabulated in Tables C-1, C-2, and C-3 applied to both the containment structure and the structure between the wetwell and the drywell. Linear interpolation is used to generate failure probabilities for 2.5 kPa-s steps as shown in Table 7-3. Leakage Level 3 was eliminated as not being of interest. The Case 1 distributions may be used with an interaction equation to obtain the distributions for Case 2. Case 3 has been combined with Case 1.

Table C-1
Containment/Drywell Failure Probabilities
Very Small Leakage (Level 1)

| <u>Normal Impulse</u> <u>(psi-s)</u> | <u>Cumulative</u> <u>Probability</u> |
|---|---|
| 1.5 | 0.00 |
| 4.5 | 0.50 |
| 9.0 | 0.95 |

Table C-2
Containment/Drywell Failure Probabilities
Small Leakage (Level 2)

| <u>Normal Impulse</u> <u>(psi-s)</u> | <u>Cumulative</u> <u>Probability</u> |
|---|---|
| 1.5 | 0.00 |
| 3.0 | 0.15 |
| 6.0 | 0.50 |
| 12.0 | 0.95 |

Table C-3
Containment/Drywell Failure Probabilities
Large Leakage (Level 3)

| <u>Normal Impulse</u> <u>(psi-s)</u> | <u>Cumulative</u> <u>Probability</u> |
|---|---|
| 1.5 | 0.00 |
| 3.0 | 0.05 |
| 7.5 | 0.50 |
| 15.0 | 0.95 |

Sources of Uncertainty

The major sources of uncertainty were the location of the detonation, the characteristics of the dynamic load, and the material properties.

5.8. Issue 8. Pedestal Failure at Grand Gulf

Experts consulted: Subir Sen, Bechtel Corp., Richard Toland, United Engineers and Contractors; Walter von Riewemann, Sandia National Laboratories.

Issue Description

What distributions characterize the quantity of concrete erosion that will result in structural failure of the vessel pedestal at Grand Gulf? Structural failure of the vessel pedestal is defined to mean loss of support of the vessel such that gross motion of the vessel results. It was previously assumed that such failure will induce suppression pool bypass leakage from the drywell to the containment (wetwell).

The Structural Response Expert Panel felt that this assumption was wrong. They felt that there was a small likelihood that the failure of the pedestal would result in failure of the drywell structure and subsequent bypass. The probability of drywell failure, given pedestal failure, was elicited informally from this Panel.

Nine cases were outlined. They correspond to the different vertical erosion values, radial erosion values, and effective debris depths shown in Table 8-1.

Table 8-1
Issue Case Structure

| <u>Cases</u> | <u>Debris Depth (ft)</u> | <u>Radial Erosion Range (ft)</u> | <u>Vertical Erosion Depth (ft)</u> |
|--------------|------------------------------|--------------------------------------|--|
| 1 | 4 | 0 to 10 | 1.5 |
| 2 | 4 | 0 to 10 | 3.5 |
| 3 | 4 | 0 to 10 | 5.0 |
| 4 | 7 | 0 to 10 | 1.5 |
| 5 | 7 | 0 to 10 | 3.5 |
| 6 | 7 | 0 to 10 | 5.0 |
| 7 | 10 | 0 to 10 | 1.5 |
| 8 | 10 | 0 to 10 | 3.5 |
| 9 | 10 | 0 to 10 | 5.0 |

Summary of Results

Expert A felt that the pedestal failure depended on the radial erosion depth, not the axial erosion depth. He felt that the strength of the pedestal wall would depend on temperature and that at 900°F the wall would be relatively strong, but at 1600°F, the wall would have lost almost all strength. The expert felt that at high temperatures, the pedestal wall

would crack and he postulated a behavior similar to concrete beams with rebar. He felt that there was a lower probability of pedestal failure for erosion below the drywell floor than for erosion above the drywell floor.

The NUREG-1150 analysts only used the information given in the curve appropriate for a 4-ft debris depth. The Molten Core Containment Interaction (MCCI) group felt that the concrete above that level was not in jeopardy.

A cumulative distribution was created directly from the curve provided in the elicitation notes. The distribution was inverted to give the probability of pedestal failure for different radial erosion depths--this was done for ease in combining this information with that given by the MCCI group.

Expert B assumed that the probability of pedestal failure depends only on radial erosion and the temperature of the rebar. While estimating failure probabilities, the expert felt that the outer vertical cage of rebar was the load element and discounted the concrete. This expert gave all of his results in terms of temperature of the outer rebar group. He stated that failure will occur in the range of 1200 to 1400°F. Because the Molten Core/Containment Interaction Expert Panel unanimously stated that the thermal front precedes the erosion front by only a few centimeters, the NUREG-1150 staff assigned a probability of 0.0 to pedestal failure until the erosion front reached the outer rebar group, at which point a probability of 1.0 was assigned.

Expert C based his analysis on a number of drawings of the pedestal region and observed that the pedestal contained a large amount of rebar. He performed a literature search to determine the effects of temperature on the mechanical properties of both the reinforcing steel and the concrete. He found that in the 1000 to 1500°F range, the reinforcing steel has a dramatic loss of ultimate strength, yield strength and modulus of elasticity. At 1000°, the compressive strength of concrete is 30 to 80% of its strength at room temperature. At 1600°F, the compressive strength is nearly zero. Expert C felt that if the inside steel loses its strength, the likelihood of pedestal failure is high.

He felt that the greater the vertical erosion, the less radial erosion is required to cause pedestal failure. He gave probabilities of pedestal failure dependent on radial erosion depths for three different vertical erosion depth cases (5 ft, 3.5 ft, and 1.5 ft.) The radial and axial erosion profile described by the expert's 5-ft vertical erosion depth case is unrealistic according to the Molten Core Containment Interaction Expert Panel. The probabilities for the 5 ft vertical erosion case were therefore neglected.

Because the probabilities of pedestal failure for the 3.5 and the 1.5 vertical erosion cases did not differ by a substantial amount, the two vertical erosion cases were averaged to simplify the aggregation with the other experts. The probabilities were averaged with the other experts dependent on radial erosion depth only.

Expert C assigned a low probability to drywell failure conditional on pedestal failure. He felt that there was a high probability that the pipes supporting the vessel would fail at one of the several large angle bends between the vessel and the drywell. This would preclude failure at a drywell penetration.

The summary of the expert results and the aggregated distribution is presented in Table 8-2.

Table 8-2
Experts' Results and Aggregated Distribution

| Experts | Probability of Pedestal Failure vs. Radial Erosion Depth | | | | | | | | | | | |
|---------|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|------|
| | 0 ft | 1.0 ft | 2.5 ft | 3.0 ft | 3.3 ft | 3.5 ft | 3.7 ft | 4.0 ft | 4.4 ft | 4.8 ft | 5.5 ft | 7 ft |
| A | 0 | 0 | 0.1 | 0.2 | 0.3 | 0.4 | 0.5 | 0.6 | 0.7 | 0.8 | 0.9 | 1 |
| B | 0 | 0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 1 | 1 |
| C | 0 | 0.272 | 0.926 | 0.992 | 0.993 | 0.994 | 0.995 | 0.996 | 0.997 | 0.999 | 1 | 1 |

Arithmetic Average of Experts' Elicitations

| Probability of Pedestal Failure vs. Radial Erosion Depth | | | | | | | | | | | |
|--|--------|----------|--------|----------|----------|-------|----------|----------|----------|------|--|
| 1 ft | 2.5 ft | 3 ft | 3.3 ft | 3.5 ft | 3.7 ft | 4 ft | 4.4 ft | 4.8 ft | 5.5 ft | 7 ft | |
| 0.090666 | 0.342 | 0.397333 | 0.431 | 0.474666 | 0.498333 | 0.532 | 0.565666 | 0.599666 | 0.986666 | 1 | |

Only two experts provided informal information on the drywell failure following pedestal failure. Expert A estimated that the failure would occur with a probability of 0.25 and Expert C estimated that the failure would occur with a probability of 0.1. These were averaged to get an aggregated probability of 0.175.

Individual Elicitations for Issue 8

Expert A's Elicitation

Pedestal Failure at Grand Gulf

Determination of Expert A's Rationale/Methodology

The dependency of vertical erosion on pedestal failure was dropped by the Expert. The vertical erosion is into the base mat and, therefore, the Expert felt it would not affect the pedestal wall. In addition, the "effective" debris depths of 7 and 10 ft were combined into a debris depth that represents erosion above the drywell floor. The 4-ft debris depth represents erosion below the drywell floor. The Expert felt that the total amount of material eroded was not the primary factor but, rather, the depth and the location of the radial erosion (i.e., above or below the drywell floor). Thus, even though more material is eroded with an "effective" debris depth of 10 ft when compared to 7 ft, it is the radial erosion depth that will determine if the pedestal will fail or not and, therefore, these two locations can be combined to represent an above drywell floor depth.

For the load on the pedestal the Expert included the reactor pressure vessel (RPV) (without debris material) and the shield wall. He felt the load was relatively "light" compared to virgin support strength of the pedestal and, therefore, felt the strength of the pedestal wall would depend on its temperature. The Expert assumed that at 900°F the wall would still have good strength, but at 1600°F the wall would have lost nearly all of its strength. He assumed that the temperature gradient through the pedestal wall was linear and that at the erosion front the temperature was 1600°F while at the outside surface of the pedestal wall the temperature was 200°F. The Expert thought the high temperatures in the pedestal would crack the pedestal wall and, thus, he considered the wall as a bunch of concrete beams with rebar.

For erosion depths above the drywell floor (7 or 10 ft), the load from the RPV and the shield wall was compared against the reduced concrete section. With a 3-ft radial erosion depth the reduced section capacity is approximately equal to the load. With a 4-ft radial erosion depth the section capacity was significantly less than the load. With a 5-ft radial erosion depth, the Expert thought there was a 5% probability that the RPV piping would support the RPV. He felt the highly uncertain area was between radial erosion depths of 3 and 4 ft.

The Expert stated that there was a lower probability of pedestal failure for erosion below the drywell floor than for erosion above the drywell floor. He felt the section of the pedestal below the drywell floor was in a better configuration structurally to survive radial erosion. The large heat sink at this location will also reduce the probability of failure.

Results of Expert A's Elicitation

Expert A's probabilities for pedestal failure as a function of radial erosion depth for erosion above and below the drywell floor are presented in Table A-1.

Table A-1
Probability of Pedestal Failure

| Radial Erosion Depth (ft) | Cumulative Probability | |
|------------------------------|------------------------|---------------------|
| | Above Drywell Floor | Below Drywell Floor |
| 1 | 0.00 | 0.00 |
| 2 | 0.15 | 0.05 |
| 3 | 0.40 | 0.25 |
| 4 | 0.75 | 0.60 |
| 5 | 0.95 | 0.85 |
| 6 | 1.00 | 0.95 |
| 7 | 1.00 | 1.00 |

The Expert stated that pedestal failure does not necessarily cause drywell leakage. The Expert felt that the conditional probability of drywell leakage given pedestal failure was definitely less than 50%. Not having analyzed the situation, the Expert suggested a 0.25 probability of drywell failure conditional on pedestal failure.

Sources of Uncertainty

The major sources of uncertainty in this issue were the temperature profile and history through the pedestal wall and the actual strength of the pedestal wall as a function of temperature.

Correlations with Other Variables

No correlations were discussed between other variables in the event trees and the variables discussed as part of this issue.

Expert B's Elicitation

Pedestal Failure at Grand Gulf

Determination of Expert B's Rationale/Methodology

The Expert grouped all the cases together. The Expert assumed that the probability of pedestal failure depends only on radial erosion and the temperature of the rebar, since the material strength of the pedestal is strongly dependent on temperature at temperatures above 800°F for steel and 300 to 400°F for concrete.

The pedestal is heavily reinforced with rebar. Rebar cages have been imbedded in the concrete close to each vertical face. In estimating failure probabilities the Expert considered the outer vertical cage of rebar as the load element and discounted the concrete. He looked at the yield strength (F_y) vs. temperature (T) and performed his calculations on an equivalent steel cylinder. The size of the equivalent cylinder was calculated as follows. The cage near the outer circumference of the pedestal consists of two rows of #11 rebar. The rebar is spaced every 4 in. There is thus about 9 in.² cross-sectional area of rebar for every foot of pedestal outer circumference. The outer circumference of the pedestal is about 100 ft, giving a total of 900 in.² of reinforcing steel.

The load on the steel is about 1800 k (1 k = 1 kipp = 1000 pounds) for the reactor pressure vessel, 200 k for the residual core (50%), 1500 k for the pedestal and 1.5×10^3 k for the shield wall. The total weight that must be supported is 5000 k.

The reduction in yield strength of #11 rebar as a function of temperature is given in Table B-1.

Table B-1
Reduction in Yield Strength vs. T(°F)

| Temperature | 800° | 1000° | 1200° | 1400° |
|------------------|------|-------|-------|-------|
| Fraction reduced | 0.7 | 0.6 | 0.3 | 0.1 |

(Fraction of room temperature yield strength reduced)

The required strength of the rebar is $5000/900 = 5.6$ ksi (kipps per square inch). At room temperature the yield strength of #11 rebar is 60 ksi. The reduction in yield strength that must take place before the pedestal fails is $5.6/60 = 0.1$. An estimate of the buckling stress of an individual rebar, assuming no effective lateral support by concrete on a 5 ft length, is 8 ksi at 1200°F. Thus the temperature at which failure occurs is estimated to be in the range of 1200 to 1400°F.

Results of Expert B's Elicitation

The probability of pedestal failure is given as a function of average temperature in the rebar in Table B-2.

Table B-2
Probability of Pedestal Failure vs.
Average Temperature in the Outer Rebar Group

| <u>Cumulative Probability</u> | <u>Temperature (°F)</u> |
|-----------------------------------|-------------------------|
| 0.05 | 1200 |
| 0.50 | 1300 |
| 0.95 | 1400 |

The average temperature should be calculated at the elevation that gives the maximum temperature.

If the Expert is mistaken about the type of rebar used (# 1), the project can recalculate his probability distribution by recalculating the 0.5 probability point of the F_y vs T curve. One should just translate the curve described in Table B-2 so that the temperature at which the yield strength reaches 0.1 corresponds to the probability of 0.5 and the temperature at which the yield strength is 0.2 corresponds to 0.05. Given those two points, one should then construct a unimodal and symmetrical curve.

Sources of Uncertainty

The type of steel used for the rebar was not known for sure. The Expert assumed that the steel in the rebar was #11. Other sources of uncertainty are the Expert's knowledge of the dependence of material properties on temperature.

Correlations with Other Variables

Correlations with variables other than rebar temperature were not identified.

Suggested Methods for Reducing Uncertainty

This issue is more sensitive to concrete erosion rate than to structural parameters.

Expert C's Elicitation

Pedestal Failure at Grand Gulf

Description of Expert C's Rationale/Methodology

Expert C based his analysis on a number of drawings of the pedestal region. Figure C-1 is the sketch that accompanied the issue paper. Since it is not to scale, Expert C found it misleading. Figure C-2 (Reference C-1) and Drawing C-1048A (Reference C-2) give a better idea of the size and shape of the pedestal. Drawing C-1067C (Reference C-3) shows the rebar placement in the haunch area at the top of the pedestal, and Drawing C1070A (Reference C-4) show the placement of the door and the four openings at the top of the pedestal for the control rod drives (CRD) lines. There are two sumps in the cavity floor, as shown in Drawing C-1042 (reference C-5).




Figure C-1. Grand Gulf Reactor Pedestal Configuration.




Figure C-2. Drawing C-1048A.

Expert C noted that the pedestal contained a large amount of rebar. In addition, there is a ring girder in Drawing 1067C (Reference C-3) (top elevation = 121 ft 4.5 in.) to which the RPV skirt flange is bolted. This ring girder is anchored to the pedestal by 3/5 in.-diameter bolts, some of which are 11 ft 8 in. long. In fact, the pedestal from approximately elevation 114 ft 0 in. to 119 ft 10 in. consists of a large amount of steel with a "little" concrete in between.

Expert C noted that the heavy reinforcing which extends all the way through the wall in the haunch region at the top of the pedestal in Drawing C-1067C (Reference C-3) does not extend below about elevation 114 ft (Reference C-2). From elevation 114 ft 0 in. down to elevation 100 ft 9 in. there is reinforcing steel only in the faces of the pedestal. From elevation 100 ft 9 in. down to elevation 93 ft 0 in. this steel is joined by the horizontal steel of the floor. This portion of the pedestal is thus heavily reinforced (see Reference C-2). The steel in the pedestal is #11 bars. In the vertical direction (i.e., horizontal steel) there are two bars every 9 in. in each face. There are two vertical bars every 4" in each face, except for one set of bars which are spaced at 8" as shown in Reference C-2.

There are five cutouts in the pedestal wall (see Drawing C-1070A, Reference C-4). The four CRD line openings have their bottoms at elevation 114 ft 0 in. This area is lined with steel and there is a steel frame which spans over the openings. The concrete around these openings appears to be heavily reinforced. The fifth opening is a door 3 ft wide and 7 ft high at azimuth 220°. The bottom of the opening is at 104 ft 1 in. The opening for the door is not steel-lined and the concrete around it does not appear to be reinforced.

There are two sumps in the cavity floor, as shown in Drawing C-1042 (Reference C-5). Their bottom elevation is 91 ft 6 in. and they are lined with 0.25 in. steel plate. In fact, the entire cavity is lined with steel plate.

Material Properties. Since the loading condition involves elevated temperatures, a literature search was conducted to determine the effects of temperature on the mechanical properties of both the reinforcing steel and the concrete.

The ASME code for steels is divided into two classes. For light water reactors, the temperatures are assumed to be less than 900°F. The other class covers breeder reactor applications where higher temperatures are expected for selected components. Actual mechanical strength values for temperature above 800°F are difficult to obtain, but in the 1000 to 1500°F temperature range the reinforcing steel has a dramatic loss of ultimate strength, yield strength, and modulus of elasticity.

(References C-6 and C-7 were consulted. For A-514 and A-517 steel, curves are given for properties at elevated temperatures. At 1000°F, the ultimate and yield strengths are approximately 50% to 70% of their room temperature values. At 1200°F, the ultimate and yield strengths are approximately 30% of their room temperature values. At 1600°F, the ultimate and yield strengths are close to zero. While these steels have a different carbon content than the rebar steel, Expert C expected that the material properties of the rebar would show similar degradation with elevated temperature.)

The structural properties of concrete also decrease with increasing temperature. At 1000°F, the compressive strength of concrete is 30% to 80% of its strength at room temperature. At 1600°F, concrete's compressive strength is nearly zero. See References C-8 through C-12 for details.

Loading Parameters. The question being addressed is the failure of the Grand Gulf reactor pedestal due to erosion of the concrete by the molten core. The following items were given as input:

1. The thermal front is only slightly ahead of the erosion front;
2. Radial erosion up to 10 ft is to be considered;
3. The core debris will not fill the cavity above elevation 100 ft 9 in.;
4. Erosion depths of 1.5 ft, 3.5 ft and 5.0 ft are to be considered.

Expert C assumed that the erosion depth is measured from elevation 94 ft 6 in. He also ignored the equipment drain sump.

Rationale for Evaluation. Expert C concluded that there were too many uncertainties involved to attempt a structural analysis considering the rebar, concrete, and transformed areas. Rather, he examined the behavior of the pedestal considering only how the loads from the RPV are transmitted to the foundation.

The pedestal from elevation 100 ft 9 in. to elevation 114 ft 0 in. carries both the axial compression load and the bending load (the RPV load is eccentric) through the concrete, the vertical steel, and the hoop steel. Expert C assumed that if the inside steel (approximate radius 11 ft) has lost its strength, the likelihood of failure is high. At the same time (temperature) that the steel loses its strength, the concrete also loses its compressive strength. (The inside steel varies in radius from 10 ft 10 in. to 11 ft 3.5 in.)

The basemat (elevation 93 ft 0 in. to 100 ft 9 in.) contains radial steel and ring steel. Since the core debris will not be above 100 ft 9 in., and the thermal and erosion fronts will be close together, this steel will also have to be degraded to affect the load capacity of the pedestal.

The Expert considered loading on the drywell wall following pedestal failure from the main steam lines and the feedwater lines only. The remainder of the lines connecting the Reactor Pressure Vessel (RPV) to the drywell wall were not considered stout enough to put any substantial loads on the drywell wall.

The steam lines (28 in. diameter) leave the RPV at elevation 176 ft 10 in. and go through the drywell wall at elevation 151 ft 0 in. The feedwater lines (24 in. diameter) enter the RPV at elevation 164 ft and go through the drywell wall at 143 ft. There are at least two right angle turns and a considerable length of pipe between the RPV and the drywell wall in both the feedwater and steam lines. A high degree of flexibility is therefore

expected in the piping. The Expert felt that both lines will either bend (distort) enough or fail within the drywell and not cause failure of the drywell wall. (He felt the distortion was more likely than failure.)

The Expert pointed out that two other points must be considered: (1) if the RPV does not fall straight down into the cavity, there could be side loads near elevation 185 ft that could fail the drywell head or the drywell wall; (2) the through guard pipe assembly bellows can fail due to either excessive motion or high internal pressure. The latter was felt to be unlikely since pressure will bleed through the suppression pool. The Expert felt that there would not be excessive deformation.

After pedestal failure, loads placed on the drywell wall by the main steam lines and the feedwater lines may lead to failure of this wall, which would result in suppression pool bypass. The failure could occur near elevation 185 ft from the side loads or as a bellows failure. Expert C concluded that suppression pool bypass by this means was unlikely; he assigned a probability of 0.1 for suppression pool bypass following pedestal failure.

Results of Expert C's Elicitation

The issue paper requested that each expert provide a curve giving the cumulative probability of pedestal failure for 1.5 ft 3.5 ft and 5.0 ft of vertical erosion. Curves illustrating the type of information desired were provided in Figure C-3 of the issue description. Expert C drew the curves reflecting his conclusions on a copy, which is included here as Figure C-3. Because this curve is hard to read, the 0%, 50%, 99%, and 100% points are listed below. The table gives radial erosion distances in feet.

Radial Erosion (ft) that Results in Pedestal Failure, for Vertical Erosion = Z

| Cumulative Probability | Z = 5.0' | Z = 3.5' | Z = 1.5' |
|------------------------|----------|----------|----------|
| 0% | 0.25 | 0.25 | 0.25 |
| 50% | 0.80 | 1.25 | 2.0 |
| 99% | 1.5 | 2.25 | 3.0 |
| 100% | 5.0 | 5.0 | 5.0 |

For an upper bound, Expert C assumed that if the radial erosion was 5 ft 0 in., the failure of the pedestal was assured, regardless of the vertical erosion. With 5 ft of radial erosion, only the outermost 9 in. of concrete and part of the outer layer of rebar is intact. Pedestal failure is certain at this point. For a lower bound, he reasoned that with only 0.25 ft (3 in.) of erosion, the inner layer of rebar is essentially intact and pedestal failure is not credible.

For 1.5-ft vertical erosion, Expert C concluded that there is a 50% probability of failure if the vertical erosion is 2.0 ft. Vertical erosion of 1.5 ft removes the concrete wearing course on top of the foundation mat.




Figure C-3. Probability of Pedestal Failure.

The greater the vertical erosion, the less radial erosion is required to cause pedestal failure. Thus Expert C's midpoint values for 3.5 ft and 5.0 ft vertical erosion are less than for 1.5 ft vertical erosion. For 3.5 ft vertical erosion, he selected a midpoint value of 1.25 ft. For 5 ft of vertical concrete erosion, Expert C concluded that there would be a 50% chance of pedestal failure when the radial erosion was 0.8 ft (9.6 in.). The rebar along the inner surface of the wall lies between 3 in. and 12 in. inside the inner surface of the concrete. When the bulk of the rebar is gone, and 5 ft of the cavity floor is eroded away, Expert C felt the strength remaining would be marginal in resisting the forces tending to move the top of the pedestal inward around the 230° location.

Sources of Uncertainty

The major area of uncertainty is in calculating the strength of the footing (elevation 9 ft 0 in. to elevation 100 ft 9 in. for the pedestal. Any material behind the erosion front has no strength at all and any material behind the thermal front (temperatures above about 1000°F) has greatly reduced strength. If the radial erosion is 5 ft (into the footing), the pedestal will have no support and will fall. Intermediate values were based on engineering judgment; no attempt was made to analyze the complex reinforced concrete footing in detail.

REFERENCES

- C-1. Drawing K-M-1736, Section E-W, looking east, Grand Gulf.
- C-2. Drawing C-1048A, Grand Gulf Unit 1 - Containment Reinforced Concrete Section & Details, Rev. 18, 5-31-79, Bechtel.
- C-3. Drawing C-1067C, Grand Gulf Unit 1 - RPV Pedestal Reinforced Concrete Section & Details, Rev. 13, 12-5-74, Bechtel.
- C-4. Drawing C-1070A, Grand Gulf Unit 1 - Containment Concrete - RPV Pedestal Wall Developed Elevation, Plans, & Details, Rev. 13, 3-14-85, Bechtel.
- C-5. Drawing C-1042, Grand Gulf Unit 1 - Containment Reinforced Concrete - Pedestal Foundation Plan at Elevation 100' 9", Rev. 8, 7-24-81, Bechtel.
- C-6. By ASME, Section III, Division 2, reinforcing steel for reactor usage must conform to either ASTM A-615 or A-706 (paragraph CC-2310). The carbon content is approximately 0.33%.
- C-7. H. J. Hucek, The Structural Alloy Handbook, 3 vols., Battelle Memorial Institute, 1987.
- C-8. G. N. Freskakis, "Behavior of Reinforced Concrete at Elevated Temperatures," Proceedings of Second ASCE Conference on Civil Engineering and Nuclear Power, Vol. 1 Materials and Structural Design, Sept. 15-17, 1980, pp 3-4-1 to 3-4-30.
- C-9. T. Kanazu and Y. Aoyagi, "Mechanical Behaviours of Concrete and Reinforced Concrete at Elevated Temperatures up to 500°C," Paper H5/1, Transactions of the 8th SMIRT, 1985.
- C-10. C. B. Oland, D. J. Naus, and G. C. Robinson, "Testing Program for Determining the Mechanical Properties of Concrete to Temperatures of 621°C," Oakridge National Laboratory, Oak Ridge, TN, 1980. (Paper presents test plan for LMFBR components.)
- C-11. G. E. Troxell, H. E. Davis, and J. W. Kelly, Composition and Properties of Concrete, pp 248-250, McGraw Hill, New York, 1968.
- C-12. P. A. Pfeiffer, J. M. Kennedy, A. H. Marchertas, "Thermal Effects in Concrete Containment Analysis," Proceedings of the Fourth Workshop on Containment Integrity, June 1988, Sandia National Laboratories, Albuquerque, New Mexico.

DISTRIBUTION:

Frank Abbey
U. K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
ENGLAND

Kiyoharu Abe
Department of Reactor Safety
Research
Nuclear Safety Research Center
ToKai Research Establishment
JAERI
Tokai-mura, Naga-gun
Ibaraki-ken,
JAPAN

Ulvi Adalioglu
Nuclear Engineering Division
Cekmece Nuclear Research and
Training Centre
P.K.1, Havaalani
Istanbul
TURKEY

Bharat Agrawal
USNRC-RES/AEB
MS: NL/N-344

Kiyoto Aizawa
Safety Research Group
Reactor Research and Development
Project
PNC
9-13m 1-Chome Akasaka
Minatu-Ku
Tokyo
JAPAN

Oguz Akalin
Ontario Hydro
700 University Avenue
Toronto, Ontario
CANADA M5G 1X6

David Aldrich
Science Applications International
Corporation
1710 Goodridge Drive
McLean, VA 22102

Agustin Alonso
University Politecnica De Madrid
J Gutierrez Abascal, 2
28006 Madrid
SPAIN

Christopher Amos
Science Applications International
Corporation
2109 Air Park Road SE
Albuquerque, NM 87106

Richard C. Anoba
Project Engr., Corp. Nuclear Safety
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

George Apostolakis
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

James W. Ashkar
Boston Edison Company
800 Boylston Street
Boston, MA 02199

Donald H. Ashton
Bechtel Power Corporation
P.O. Box 2166
Houston, TX 77252-2166

J. de Assuncao
Cabinete de Proteccao e Seguranca
Nuclear
Secretario de Estado de Energia
Ministerio da Industria
av. da Republica, 45-6°
1000 Lisbon
PORTUGAL

Mark Averett
Florida Power Corporation
P.O. Box 14042
St. Petersburg, FL 33733

Raymond O. Bagley
Northeast Utilities
P.O. Box 270
Hartford, CT 06141-0270

Juan Bagues
Consejo de Seguridad Nucleare
Sarangela de la Cruz 3
28020 Madrid
SPAIN

George F. Bailey
Washington Public Power Supply
System
P. O. Box 968
Richland, WA 99352

H. Bairiot
Belgonucleaire S A
Rue de Champ de Mars 25
B-1050 Brussels
BELGIUM

Louis Baker
Reactor Analysis and Safety
Division
Building 207
Argonne National Laboratory
9700 South Cass Avenue
Argonne, IL 60439

H-P. Balfanz
TUV-Norddeutschland
Grosse Bahnstrasse 31,
2000 Hamburg 54
FEDERAL REPUBLIC OF GERMANY

Patrick Baranowsky
USNRC-NRR/OEAB
MS: 11E-22

H. Bargmann
Dept. de Mecanique
Inst. de Machines Hydrauliques
et de Mecaniques des Fluides
Ecole Polytechnique de Lausanne
CH-1003 Lausanne
M.E. (ECUBLENS)
CH. 1015 Lausanne
SWITZERLAND

Robert A. Bari
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Richard Barrett
USNRC-NRR/PRAB
MS: 10A-2

Kenneth S. Baskin
S. California Edison Company
P.O. Box 800
Rosemead, CA 91770

J. Basselier
Belgonucleaire S A
Rue du Champ de Mars 25, B-1050
Brussels
BELGIUM

Werner Bastl
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Anton Bayer
BCA/ISH/ZDB
Postfach 1108
D-8042 Neuherberg
FEDERAL REPUBLIC OF GERMANY

Ronald Bayer
Virginia Electric Power Co.
P. O. Box 26666
Richmond, VA 23261

Eric S. Beckjord
Director
USNRC-RES
MS: NL/S-007

Bruce B. Beckley
Public Service Company
P.O. Box 330
Manchester, NH 03105

William Beckner
USNRC-RES/SAIB
MS: NL/S-324

Robert M. Bernero
Director
USNRC-NMSS
MS: 6A-4

Ronald Berryman [2]
Virginia Electric Power Co.
P. O. Box 26666
Richmond, VA 23261

Robert C. Bertucio
NUS Corporation
1301 S. Central Ave, Suite 202
Kent, WA 98032

John H. Bickel
EG&G Idaho, Inc.
P.O. Box 1625
Idaho Falls, ID 83415

Peter Bieniarz
Risk Management Association
2309 Dietz Farm Road, NW
Albuquerque, NM 87107

Adolf Birkhofer
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

James Blackburn
Illinois Dept. of Nuclear Safety
1035 Outer Park Drive
Springfield, IL 62704

Dennis C. Bley
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

Roger M. Blond
Science Applications Int. Corp.
20030 Century Blvd., Suite 201
Germantown, MD 20874

Simon Board
Central Electricity Generating
Board
Technology and Planning Research
Division
Berkeley Nuclear Laboratory
Berkeley Gloucestershire, GL139PB
UNITED KINGDOM

Mario V. Bonace
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06101

Gary J. Boyd
Safety and Reliability Optimization
Services
9724 Kingston Pike, Suite 102
Knoxville, TN 37922

Robert J. Breen
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Charles Brinkman
Combustion Engineering
7910 Woodmont Avenue
Bethesda, MD 20814

K. J. Brinkmann
Netherlands Energy Res. Fdn.
P.O. Box 1
1755ZG Petten NH
NETHERLANDS

Allan R. Brown
Manager, Nuclear Systems and
Safety Department
Ontario Hydro
700 University Ave.
Toronto, Ontario M5G1X6
CANADA

Robert G. Brown
TENERA L.P.
1340 Saratoga-Sunnyvale Rd.
Suite 206
San Jose, CA 95129

Sharon Brown
EI Services
1851 So. Central Place, Suite 201
Kent, WA 98031

Ben Buchbinder
NASA, Code QS
600 Maryland Ave. SW
Washington, DC 20546

R. H. Buchholz
Nutech
6835 Via Del Oro
San Jose, CA 95119

Robert J. Budnitz
Future Resources Associates
734 Alameda
Berkeley, CA 94707

Gary R. Burdick
USNRC-RES/DSR
MS: NL/S-007

Arthur J. Buslik
USNRC-RES/PRAB
MS: NL/S-372

M. Bustraan
Netherlands Energy Res. Fdn.
P.O. Box 1
1755ZG Fctten NH
NETHERLANDS

Nigel E. Buttery
Central Electricity Generating
Board
Booths Hall
Chelford Road, Knutsford
Cheshire, WA168QG
UNITED KINGDOM

Jose I. Calvo Molins
Probabilistic Safety Analysis
Group
Consejo de Seguridad Nuclear
Sor Angela de la Cruz 3, Pl. 6
28020 Madrid
SPAIN

J. F. Campbell
Nuclear Installations Inspectorate
St. Peters House
Balliol Road, Bootle
Merseyside, L20 3LZ
UNITED KINGDOM

Kenneth S. Canady
Duke Power Company
422 S. Church Street
Charlotte, NC 28217

Lennart Carlsson
IAEA A-1400
Wagramerstrasse 5
P.O. Box 100
Vienna, 22
AUSTRIA

Annick Carnino
Electricite de France
32 Rue de Monceau 8EME
Paris, F5008
FRANCE

G. Caropreso
Dept. for Envir. Protect. & Hlth.
ENEA Cre Casaccia
Via Anguillarese, 301
00100 Roma
ITALY

James C. Carter, III
TENERA L.P.
Advantage Place
308 North Peters Road
Suite 280
Knoxville, TN 37922

Eric Cazzoli
Brookhaven National Laboratory
Building 130
Upton, NY 11973

John G. Cesare
SERI
Director Nuclear Licensing
5360 I-55 North
Jackson, MS 39211

S. Chakraborty
Radiation Protection Section
Div. De La Securite Des Inst. Nuc.
5303 Wurenlingen
SWITZERLAND

Sen-I Chang
Institute of Nuclear Energy
Research
P.O. Box 3
Lungtan, 325
TAIWAN

J. R. Chapman
Yankee Atomic Electric Company
1671 Worcester Road
Framingham, MA 01701

Robert F. Christie
Tennessee Valley Authority
400 W. Summit Hill Avenue, W10D190
Knoxville, TN 37902

T. Cianciolo
BWR Assistant Director
ENEA DISP TX612167 ENEUR
Rome
ITALY

Thomas Cochran
Natural Resources Defense Council
1350 New York Ave. NW, Suite 300
Washington, D.C. 20005

Frank Coffman
USNRC-RES/HFB
MS: NL/N-316

Larry Conradi
NUS Corporation
16835 W. Bernardo Drive
Suite 202
San Diego, CA 92127

Peter Cooper
U.K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
UNITED KINGDOM

C. Allin Cornell
110 Coquito Way
Portola Valley, CA 94025

Michael Corradini
University of Wisconsin
1500 Johnson Drive
Madison, WI 53706

E. R. Corran
Nuclear Technology Division
ANSTO Research Establishment
Lucas Heights Research Laboratories
Private Mail Bag 7
Menai, NSW 2234
AUSTRALIA

James Costello
USNRC-RES/SSEB
MS: NL/S-217A

George R. Crane
1570 E. Hobble Creek Dr.
Springville, UT 84663

Mat Crawford
SERI
5360 I-55 North
Jackson, MS 39211

Michael C. Cullingford
Nuclear Safety Division
IAEA
Wagramerstrasse, 5
P.O. Box 100
A-1400 Vienna
AUSTRIA

Garth Cummings
Lawrence Livermore Laboratory
L-91, Box 808
Livermore, CA 94526

Mark A. Cunningham
USNRC-RES/PRAB
MS: NL/S-372

James J. Curry
7135 Salem Park Circle
Mechanicsburg, PA 17055

Peter Cybulskis
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Peter R. Davis
PRD Consulting
1935 Sabin Drive
Idaho Falls, ID 83401

Jose E. DeCarlos
Consejo de Seguridad Nuclear
Sor Angela de la Cruz 3, Pl. 8
28016 Madrid
SPAIN

M. Marc Decreton
Department Technologie
CEN/SCK
Boeretang 200
B-2400 Mol
BELGIUM

Richard S. Denning
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Vernon Denny
Science Applications Int. Corp.
5150 El Camino Real, Suite 3
Los Altos, CA 94303

J. Devooghet
Faculte des Sciences Appliques
Universite Libre de Bruxelles
av. Franklin Roosevelt
B-1050 Bruxelles
BELGIUM

R. A. Diederich
Supervising Engineer
Environmental Branch
Philadelphia Electric Co.
2301 Market St.
Philadelphia, PA 19101

Raymond DiSalvo
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Mary T. Drouin
Science Applications International
Corporation
2109 Air Park Road S.E.
Albuquerque, NM 87106

Andrzej Drozd
Stone and Webster
Engineering Corp.
243 Summer Street
Boston, MA 02107

N. W. Edwards
NUTECH
145 Martinville Lane
San Jose, CA 95119

Ward Edwards
Social Sciences Research Institute
University of Southern California
Los Angeles, CA 90089-1111

Joachim Ehrhardt
Kernforschungszentrum Karlsruhe/INR
Postfach 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

Adel A. El-Bassioni
USNRC-NRR/PRAH
MS: 10A-2

J. Mark Elliott
International Energy Associates,
Ltd., Suite 600
600 New Hampshire Ave., NW
Washington, DC 20037

Farouk Eltawila
USNRC-RES/AEB
MS: NL/N-344

Mike Epstein
Fauske and Associates
P. O. Box 125
16W070 West 83rd Street
Burr Ridge, IL 60521

Malcolm L. Ernst
USNRC-RGN II

F. R. Farmer
The Long Wood, Lyons Lane
Appleton, Warrington
WA4 5ND
UNITED KINGDOM

P. Fehrenback
Atomic Energy of Canada, Ltd.
Chalk River Nuclear Laboratories
Chalk River Ontario, K0J1P0
CANADA

P. Ficara
ENEA Cre Casaccia
Department for Thermal Reactors
Via Anguillarese, 301
00100 ROMA
ITALY

A. Fiege
Kernforschungszentrum
Postfach 3640
D-7500 Karlsruhe
FEDERAL REPUBLIC OF GERMANY

John Flack
USNRC-RES/SAIB
MS: NLS-324

George F. Flanagan
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

Karl N. Fleming
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

Terry Foppe
Rocky Flats Plant
P. O. Box 464, Building T886A
Golden, CO 80402 64

Joseph R. Fragola
Science Applications International
Corporation
274 Madison Avenue
New York, NY 10016

Wiktor Frid
Swedish Nuclear Power Inspectorate
Division of Reactor Technology
P. O. Box 27106
S-102 52 Stockholm
SWEDEN

James Fulford
NUS Corporation
910 Clopper Road
Gaithersburg, MD 20878

Urho Fulkkinen
Technical Research Centre of
Finland
Electrical Engineering Laboratory
Otakaari 7 B
SF-02150 Espoo 15
FINLAND

J. B. Fussell
JBF Associates, Inc.
1630 Downtown West Boulevard
Knoxville, TN 37919

John Garrick
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

John Gaunt
British Embassy
3100 Massachusetts Avenue, NW
Washington, DC 20008

Jim Gieseke
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Frank P. Gillespie
USNRC-NRR/PMAS
MS: 12G-18

Ted Ginsburg
Department of Nuclear Energy
Building 820
Brookhaven National Laboratory
Upton, NY 11973

James C. Glynn
USNRC-RES/PRAB
MS: NL/S-372

P. Govaerts
Departement de la Surete Nucleaire
Association Vincotte
avenue du Roi 157
B-1060 Bruxelles
BELGIUM

George Greene
Building 820M
Brookhaven National Laboratory
Upton, NY 11973

Carrie Grimshaw
Brookhaven National Laboratory
Building 130
Upton, NY 11973

H. J. Van Grol
Energy Technology Division
Energieonderzoek Centrum Nederland
Westerduinweg 3
Postbus 1
NL-1755 Petten ZG
NETHERLANDS

Sergio Guarro
Lawrence Livermore Laboratories
P. O. Box 808
Livermore, CA 94550

Sigfried Hagen
Kernforschungszentrum Karlsruhe
P. O. Box 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

L. Hammar
Statens Kernkraftinspektion
P.O. Box 27106
S-10252 Stockholm
SWEDEN

Stephen Hanauer
Technical Analysis Corp.
6723 Whitrier Avenue
Suite 202
McLean, VA 22101

Brad Hardin
USNRC-RES/TRAB
MS: NL/S-169

R. J. Hardwick, Jr.
Virginia Electric Power Co.
P.O. Box 26666
Richmond, Va 23261

Michael R. Haynes
UKAEA Harwell Laboratory
Oxfordshire
Didcot, Oxon., OX11 0RA
ENGLAND

Michael J. Hazzan
Stone & Webster
3 Executive Campus
Cherry Hill, NJ 08034

A. Hedgran
Royal Institute of Technology
Nuclear Safety Department
Bunellvagen 60
10044 Stockholm
SWEDEN

Sharif Heger
UNM Chemical and Nuclear
Engineering Department
Farris Engineering
Room 209
Albuquerque, NM 87131

Jon C. Helton
Dept. of Mathematics
Arizona State University
Tempe, AZ 85287

Robert E. Henry
Fauske and Associates, Inc.
16W070 West 83rd Street
Burr Ridge, IL 60521

P. M. Herttrich
Federal Ministry for the
Environment, Preservation of
Nature and Reactor Safety
Husarenstrasse 30
Postfach 120629
D-5300 Bonn 1
FEDERAL REPUBLIC OF GERMANY

F. Heuser
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

E. F. Hicken
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

D. J. Higson
Radiological Support Group
Nuclear Safety Bureau
Australian Nuclear Science and
Technology Organisation
P.O. Box 153
Rosebery, NSW 2018
AUSTRALIA

Daniel Hirsch
University of California
A. Stevenson Program on
Nuclear Policy
Santa Cruz, CA 95064

H. Hirschmann
Hauptabteilung Sicherheit und
Umwelt
Swiss Federal Institute for
Reactor Research (EIR)
CH-5303 Wurenlingen
SWITZERLAND

Mike Hitchler
Westinghouse Electric Corp.
Savanna River Site
Aiken, SC 29808

Richard Hobbins
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83415

Steven Hodge
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

Lars Hoegberg
Office of Regulation and Research
Swedish Nuclear Power Inspectorate
P. O. Box 27106
S-102 52 Stockholm
SWEDEN

Lars Hoeghort
IAEA A-1400
Wagranerstrasse 5
P.O. Box 100
Vierua, 22
AUSTRIA

Edward Hofer
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Peter Hoffmann
Kernforschungszentrum Karlsruhe
Institute for Material
Und Festkorperforschung I
Postfach 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

N. J. Holloway
UKAEA Safety and Reliability
Directorate
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA34NE
UNITED KINGDOM

Stephen C. Hora
University of Hawaii at Hilo
Division of Business Administration
and Economics
College of Arts and Sciences
Hilo, HI 96720-4091

J. Peter Hoseman
Swiss Federal Institute for
Reactor Research
CH-5303, Wurenlingen
SWITZERLAND

Thomas C. Houghton
KMC, Inc.
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Dean Houston
USNRC-ACRS
MS: P-315

Der Yu Hsia
Taiwan Atomic Energy Council
67, Lane 144, Keelung Rd.
Sec. 4
Taipei
TAIWAN

Alejandro Huerta-Bahena
National Commission on Nuclear
Safety and Safeguards (CNSNS)
Insurgentes Sur N. 1776
Col. Florida
C. P. 04230 Mexico, D.F.
MEXICO

Kenneth Hughey [2]
SERI
5360 I-55 North
Jackson, MS 39211

Won-Guk Hwang
Kzunghee University
Yongin¹Kun
Kyunggi-Do 170-23
KOREA

Michio Ichikawa
Japan Atomic Energy Research
Institute
Dept. of Fuel Safety Research
Tokai-Mura, Naka-Gun
Ibaraki-Ken, 319-1
JAPAN

Sanford Israel
USNRC-AEOD/ROAB
MS: MNBB-9715

Krishna R. Iyengar
Louisiana Power and Light
200 A Huey P. Long Avenue
Gretna, LA 70053

Jerry E. Jackson
USNRC-RES
MS: NL/S-302

R. E. Jaquith
Combustion Engineering, Inc.
1000 Prospect Hill Road
M/C 9490-2405
Windsor, CT 06095

S. E. Jensen
Exxon Nuclear Company
2101 Horn Rapids Road
Richland, WA 99352

Kjell Johansson
Studsvik Energiteknik AB
S-611 82, Nykoping
SWEDEN

Richard John
SSM, Room 102
927 W. 35th Place
USC, University Park
Los Angeles, CA 90089-0021

D. H. Johnson
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

W. Reed Johnson
Department of Nuclear Engineering
University of Virginia
Reactor Facility
Charlottesville, VA 22901

Jeffery Julius
NUS Corporation
1301 S. Central Ave, Suite 202
Kent, WA 98032

H. R. Jun
Korea Adv. Energy Research Inst.
P.O. Box 7, Daeduk Danju
Chungnam 300-31
KOREA

Peter Kafka
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Geoffrey D. Kaiser
Science Application Int. Corp.
1710 Goodridge Drive
McLean, VA 22102

William Kastenbergl
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

Walter Kato
Brookhaven National Laboratory
Associated Universities, Inc.
Upton, NY 11973

M. S. Kazimi
MIT, 24-219
Cambridge, MA 02139

Ralph L. Keeney
101 Lombard Street
Suite 704W
San Francisco, CA 94111

Henry Kendall
Executive Director
Union of Concerned Scientists
Cambridge, MA

Frank King
Ontario Hydro
700 University Avenue
Bldg. H11 G5
Toronto
CANADA M5G1X6

Oliver D. Kingsley, Jr.
Tennessee Valley Authority
1101 Market Street
GN-38A Lookout Place
Chattanooga, TN 37402

Stephen R. Kinnersly
Winfrith Atomic Energy
Establishment
Reactor Systems Analysis Division
Winfrith, Dorchester
Dorset DT2 8DH
ENGLAND

Ryohel Kiyose
University of Tokyo
Dept. of Nuclear Engineering
7-3-1 Hongo Bunkyo
Tokyo 113
JAPAN

George Klogg
Commonwealth Edison Company
P.O. Box 767, Room 35W
Chicago, IL 60690

Klaus Koberlein
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

E. Kohn
Atomic Energy Canada Ltd.
Candu Operations
Mississauga
Ontario, L5K 1B2
CANADA

Alan M. Kolaczowski
Science Applications International
Corporation
2109 Air Park Road, S.E.
Albuquerque, NM 87106

S. Kondo
Department of Nuclear Engineering
Faculty of Engineering
University of Tokyo
3-1, Hongo 7, Bunkyo-ku
Tokyo
JAPAN

Herbert J. C. Kouts
Brookhaven National Laboratory
Building 179C
Upton, NY 11973

Thomas Kress
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

W. Kroger
Institut für Nukleare
Sicherheitsforschung
Kernforschungsanlage Jülich GmbH
Postfach 1913
D-5170 Jülich 1
FEDERAL REPUBLIC OF GERMANY

Greg Krueger [3]
Philadelphia Electric Co.
2301 Market St.
Philadelphia, PA 19101

Bernhard Kuczera
Kernforschungszentrum Karlsruhe
LWR Safety Project Group (PRS)
P. O. Box 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

Jeffrey L. LaChance
Science Applications International
Corporation
2109 Air Park Road S.E.
Albuquerque, NM 87106

H. Larsen
Riso National Laboratory
Postbox 49
DK-4000 Roskilde
DENMARK

Wang L. Lau
Tennessee Valley Authority
400 West Summit Hill Avenue
Knoxville, TN 37902

Timothy J. Leahy
EI Services
1851 South Central Place, Suite 201
Kent, WA 98031

John C. Lee
University of Michigan
North Campus
Dept. of Nuclear Engineering
Ann Arbor, MI 48109

Tim Lee
USNRC-RES/RPSB
MS: NL/N-353

Mark T. Leonard
Science Applications International
Corporation
2109 Air Park Road, SE
Albuquerque, NM 87106

Leo LeSage
Director, Applied Physics Div.
Argonne National Laboratory
Building 208, 9700 South Cass Ave.
Argonne, IL 60439

Milton Levenson
Bechtel Western Power Company
50 Beale St.
San Francisco, CA 94119

Librarian
NUMARC/USCEA
1776 I Street NW, Suite 400
Washington, DC 80006

Eng Lin
Taiwan Power Company
242, Roosevelt Rd., Sec. 3
Taipei
TAIWAN

N. J. Liparulo
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, PA 15230

Y. H. (Ben) Liu
Department of Mechanical
Engineering
University of Minnesota
Minneapolis, MN 55455

Bo Ljunng
IAEA A-1400
Swedish Nuclear Power Inspectorate
P.O. Box 27106
S-102 52 Stockholm
SWEDEN

J. P. Longworth
Central Electric Generating Board
Berkeley Gloucester
GL13 9PB
UNITED KINGDOM

Walter Lowenstein
Electric Power Research Institute
3412 Hillview Avenue
P. O. Box 10412
Palo Alto, CA 94303

William J. Luckas
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Hans Ludewig
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Robert J. Lutz, Jr.
Westinghouse Electric Corporation
Monroeville Energy Center
EC-E-371, P. O. Box 355
Pittsburgh, PA 15230-0355

Phillip E. MacDonald
EG&G Idaho, Inc., Inc.
P.O. Box 1625
Idaho Falls, ID 83415

Jim Mackenzie
World Resources Institute
1735 New York Ave. NW
Washington, DC 20006

Richard D. Fowler
Idaho Nat. Engineering Laboratory
P.O. Box 1625
Idaho Falls, ID 83415

A. P. Malinauskas
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

Giuseppe Mancini
Commission European Comm.
CEC-JRC Eraton
Ispra Varese
ITALY

Lasse Mattila
Technical Research Centre of
Finland
Lonnrotinkatu 37, P. O. Box 169
SF-00181 Helsinki 18
FINLAND

Roger J. Mattson
SCIENTECH Inc.
11821 Parklawn Dr.
Rockville, MD 20852

Donald McPherson
USNRC-NRR/DONRR
MS: 12G-18

Jim Metcalf
Stone and Webster Engineering
Corporation
245 Summer St.
Boston, MA 02107

Mary Meyer
A-1, MS F600
Los Alamos National Laboratory
Los Alamos, NM 87545

Ralph Meyer
USNRC-RES/AEB
MS: NL/N-344

Charles Miller
8 Hastings Rd.
Momsey, NY 10952

Joseph Miller
Gulf States Utilities
P. O. Box 220
St. Francisville, LA 70775

William Mims
Tennessee Valley Authority
400 West Summit Hill Drive.
W10D199C-K
Knoxville, TN 37902

Jocelyn Mitchell
USNRC-RES/SAIB
MS: NL/S-324

Kam Mohktarian
CBI Na-Con Inc.
800 Jorie Blvd.
Oak Brook, IL 60521

James Moody
P.O. Box 641
Rye, NH 03870

S. Mori
Nuclear Safety Division
OECD Nuclear Energy Agency
38 Blvd. Suchet
75016 Paris
FRANCE

Walter B. Murfin
P.O. Box 550
Mesquite, NM 88048

Joseph A. Murphy
USNRC-RES/DSR
MS: NL/S-007

V. I. Nath
Safety Branch
Safety Engineering Group
Sheridan Park Research Community
Mississauga, Ontario L5K 1B2
CANADA

Susan J. Niemczyk
1545 18th St. NW, #112
Washington, DC 20036

Pradyot K. Niyogi
USDOE-Office of Nuclear Safety
Washington, DC 20545

Paul North
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83415

Edward P. O'Donnell
Ebasco Services, Inc.
2 World Trade Center, 89th Floor
New York, NY 10048

David Okrent
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

Robert L. Olson
Tennessee Valley Authority
400 West Summit Hill Rd.
Knoxville, TN 37902

Simon Ostrach
Case Western Reserve University
418 Gloman Bldg.
Cleveland, OH 44106

D. Paddleford
Westinghouse Electric Corporation
Savanna River Site
Aiken, SC 29808

Robert L. Palla, Jr.
USNRC-NRR/PRAB
MS: 10A-2

Chang K. Park
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Michael C. Parker
Illinois Department of Nuclear
Safety
1035 Outer Park Dr.
Springfield, IL 62704

Gareth Parry
NUS Corporation
910 Clopper Road
Gaithersburg, MD 20878

J. Pelce
Departement de Surete Nucleaire
IPSN
Centre d'Etudes Nucleaires du CEA
B.P. no. 6, Cedex
F-92260 Fontenay-aux-Roses
FRANCE

G. Patrangeli
ENEA Nuclear Energy ALT Disp
Via V. Brancati, 48
00144 Rome
ITALY

Marty Plys
Fauske and Associates
16W070 West 83rd St.
Burr Ridge, IL 60521

Mike Podowski
Department of Nuclear Engineering
and Engineering Physics
RPI
Troy, NY 12180-3590

Robert D. Pollard
Union of Concerned Scientists
1616 P Street, NW, Suite 310
Washington, DC 20036

R. Potter
UK Atomic Energy Authority
Winfrith, Dorchester
Dorset, DT2 8DH
UNITED KINGDOM

William T. Pratt
Brookhaven National Laboratory
Building 130
Upton, NY 11973

M. Preat
Chef du Service Surete Nucleaire et
Assurance Qualite
TRACTEBEL
Bd. du Regent 8
B-100 Brussels
BELGIUM

David Pyatt
USDOF
MS: EH-332
Washington, DC 20545

William Raisin
NUMAEC
1726 M St. NW
Suite 904
Washington, DC 20036

Joe Rashid
ANATECH Research Corp.
3344 N. Torrey Pines Ct.
Suite 1320
La Jolla, CA 90237

Dale M. Rasmuson
USNRC-RES/PRAB
MS: NL/S-372

Ingvard Rasmussen
Riso National Laboratory
Postbox 49
DK-4000, Roskilde
DENMARK

Norman C. Rasmussen
Massachusetts Institute of
Technology
77 Massachusetts Avenue
Cambridge, MA 02139

John W. Reed
Jack R. Benjamin & Associates, Inc.
444 Castro St., Suite 501
Mountain View, CA 94041

David B. Rhodes
Atomic Energy of Canada, Ltd.
Chalk River Nuclear Laboratories
Chalk River, Ontario K0J1P0
CANADA

Dennis Richardson
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, PA 15230

Doug Richeard
Virginia Electric Power Co.
P.O. Box 26666
Richmond, VA 23261

Robert Ritzman
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94304

Richard Robinson
USNRC-RES/PRAB
MS: NL/S-372

Jack E. Rosenthal
USNRC-AEOD/ROAB
MS: MNBB-9715

Denwood F. Ross
USNRC-RES
MS: NL/S-007

Frank Rowsome
9332 Fern Hollow Way
Gaithersburg, MD 20879

Wayne Russell
SERI
5360 I-55 North
Jackson, MS 39211

Jorma V. Sandberg
Finnish Ctr. Rad. Nucl. and Safety
Department of Nuclear Safety
P.O. Box 268
SF-00101 Helsinki
FINLAND

G. Saponaro
ENEA Nuclear Engineering Alt.
Zia V Brancati 48
00144 ROME
ITALY

M. Sarran
United Engineers
P. O. Box 8223
30 S 17th Street
Philadelphia, PA 19101

J. Schroeder
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83415

Marty Sattison
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83415

George D. Sauter
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Jorge Schulz
Bechtel Western Power Corporation
50 Beale Street
San Francisco, CA 94119

B. R. Sehgal
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Subir Sen
Bechtel Power Corp.
15740 Shady Grove Road
Location 1A-7
Gaithersburg, MD 20877

S. Serra
Ente Nazionale per l'Energia
Elettrica (ENEL)
via G. B. Martini 3
Rome
ITALY

Bonnie J. Shapiro
Science Applications International
Corporation
360 Bay Street
Suite 200
Augusta, GA 30901

H. Shapiro
Licensing and Risk Branch
Atomic Energy of Canada Ltd.
Sheridan Park Research Community
Mississauga, Ontario L5K 1B2
CANADA

Dave Sharp
Westinghouse Savannah River Co.
Building 773-41A, P. O. Box 616
Aiken, SC 29802

John Sherman
Tennessee Environmental Council
1719 West End Avenue, Suite 227
Nashville, TN 37203

Brian Sheron
USNRC-RES/DSR
MS: NL/N-007

Rick Sherry
JAYCOR
P. O. Box 85154
San Diego, CA 92138

Steven C. Sholly
MHB Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, CA 95125

Louis M. Shotkin
USNRC-FES/RPSB
MS: NL/N-353

M. Siebertz
Chef de la Section Surete' des
Reacteurs
CEN/SCK
Boeretang, 200
B-2400 Mol
BELGIUM

Melvin Silberberg
USNRC-RES/DE/WNB
MS: NL/S-260

Gary Smith
SERI
5360 I-55 North
Jackson, MS 39211

Gary L. Smith
Westinghouse Electric Corporation
Hanford Site
Box 1970
Richland, WA 99352

Lanny N. Smith
Science Applications International
Corporation
2109 Air Park Road SE
Albuquerque, NM 87106

K. Soda
Japan Atomic Energy Res. Inst.
Tokai-Mura Naka-Gun
Ibaraki-Ken 319-11
JAPAN

David Sommers
Virginia Electric Power Company
P. O. Box 26666
Richmond, VA 23261

Herschel Spector
New York Power Authority
123 Main Street
White Plains, NY 10601

Themis P. Speis
USNRC-RES
MS: NL/S-007

Klaus B. Stadie
OECD-NEA, 38 Bld. Suchet
75016 Paris
FRANCE

John Stetkar
Pickard, Lowe & Garrick, Inc.
2216 University Drive
Newport Beach, CA 92660

Wayne L. Stiede
Commonwealth Edison Company
P.O. Box 767
Chicago, IL 60690

William Stratton
Stratton & Associates
2 Acoma Lane
Los Alamos, NM 87544

Soo-Pong Suk
Korea Advanced Energy Research
Institute
P. O. Box 7
Daejuk Danji, Chungnam 300-31
KOREA

W. P. Sullivan
GE Nuclear Energy
175 Curtner Ave., M/C 789
San Jose, CA 95125

Tony Taig
U.K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
UNITED KINGDOM

John Taylor
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Harry Teague
U.K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
UNITED KINGDOM

Technical Library
Electric Power Research Institute
P.O. Box 10412
Palo Alto, CA 94304

Mark I. Tenme
General Electric inc.
P.O. Box 3508
Sunnyvale, CA 94088

T. G. Theofanous
University of California, S.B.
Department of Chemical and Nuclear
Engineering
Santa Barbara, CA 93106

David Teolis
Westinghouse-Bettis Atomic Power
Laboratory
P. O. Box 79, ZAP 34N
West Mifflin, PA 15122-0079

Ashok C. Thadani
USNRC-NRR/SAD
MS: 7E-4

Garry Thomas
L-499 (Bldg. 490)
Lawrence Livermore National
Laboratory
7000 East Ave.
P.O. Box 808
Livermore, CA 94550

Gordon Thompson
Institute for Research and
Security Studies
27 Ellworth Avenue
Cambridge, MA 02139

Grant Thompson
League of Women Voters
1730 M. Street, NW
Washington, DC 20036

Arthur Tingle
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Rich Toland
United Engineers and Construction
30 S. 17th St., MS 4V7
Philadelphia, PA 19101

Brian J. R. Tolley
DG/XII/D/1
Commission of the European
Communities
Rue de la Loi, 200
B-1049 Brussels
BELGIUM

David R. Torgerson
Atomic Energy of Canada Ltd.
Whiteshell Nuclear
Research Establishment
Pinawa, Manitoba, ROE 1LO
CANADA

Alfred F. Torri
Pickard, Lowe & Garrick, Inc.
191 Calle Magdalena, Suite 290
Encinitas, CA 92024

Klau Trambauer
Gesellschaft Für Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FERERAL REPUBLIC OF GERMANY

Nicholas Tsoufanidis
Nuclear Engineering Dept.
University of Missouri-Rolla
Rolla, MO 65401-0249

Chao-Ch'n Tung
c/o H.B. Bengelsdorf
ERC Environmental Services Co.
P. O. Box 10130
Fairfax, A 22030

Brian D. Turland
UKAEA Culham Laboratory
Abingdon, Oxon OX14 3DB
ENGLAND

Takeo Uga
Japan Institute of Nuclear Safety
Nuclear Power Engineering Test
Center
3-6-2, Toranomon
Minato-ku, Tokyo 108
JAPAN

Stephen D. Urwin
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

A. Valeri
DISP
ENEA
Via Vitaliano Brancati, 48
I-00144 Rome
ITALY

Harold VanderMolen
USNRC-RES/PRAB
MS: NL/S-372

G. Bruce Varnado
ERC International
1717 Louisiana Blvd. NE, Suite 202
Albuquerque, NM 87110

Jussi K. Vaurio
Imatran Voima Oy
Loviisa NPS
SF-07900 Loviisa
FINLAND

William E. Vesely
Science Applications International
Corporation
2929 Kenny Road, Suite 245
Columbus, OH 43221

J. I. Villadoniga Tallon
Div. of Analysis and Assessment
Consejo de Seguridad Nuclear
c/ Sor Angela de la Cruz, 3
28020 Madrid
SPAIN

Willem F. Vinck
Kapelstraat 25
1980
Tervuren
BELGIUM

R. Viröläinen
Office of Systems Integration
Finnish Centre for Radiation and
Nuclear Safety
Department of Nuclear Safety
P.O. Box 268
Kumpulantie 7
SF-00520 Helsinki
FINLAND

Raymond Viskanta
School of Mechanical Engineering
Purdue University
West Lafayette, IN 47907

S. Visweswaran
General Electric Company
175 Curtner Avenue
San Jose, CA 95125

Truong Vo
Pacific Northwest Laboratory
Battelle Blvd.
Richland, WA 99352

Richard Vogel
Electric Power Research Institute
P. O. Box 10412
Palo Alto, CA 94303

G. Volta
Engineering Division
CEC Joint Research Centre
CP No. 1
I-21020 Aspra (Varese)
ITALY

Ian B. Wall
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Adolf Walser
Sargent and Lundy Engineers
55 E. Monroe Street
Chicago, IL 60603

Edward Warman
Stone & Webster Engineering Corp.
P.O. Box 2325
Boston, MA 02107

Norman Weber
Sargent & Lundy Co.
55 E. Monroe Street
Chicago, IL 60603

Lois Webster
American Nuclear Society
355 N. Kensington Avenue
La Grange Park, IL 60525

Wolfgang Werner
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Don Wesley
IMPELL
1651 East 4th Street
Suite 210
Santa Ana, CA 92701

Detlof von Winterfeldt
Institute of Safety and Systems
Management
University of Southern California
Los Angeles, CA 90089-0021

Pat Worthington
USNRC-RES/AEB
MS: NL/N-344

John Wreathall
Science Applications International
Corporation
2929 Kenny Road, Suite 245
Columbus, OH 43221

D. J. Wren
Atomic Energy of Canada Ltd.
Whiteshell Nuclear Research
Establishment
Pinawa, Manitoba, ROE 1LO
CANADA

Roger Wyrick
Inst. for Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

Kun-Joong Yoo
Korea Advanced Energy Research
Institute
P. O. Box 7
Daeduk Danji, Chungnam 300-31
KOREA

Faith Young
Energy People, Inc.
Dixou Springs, TN 37057

Jonathan Young
R. Lynette and Associates
15042 Northeast 40th St.
Suite 206
Redmond, WA 98052

C. Zaffiro
Division of Safety Studies
Directorate for Nuclear Safety and
Health Protection
Ente Nazionale Energie Alternative
Via Vitaliano Brancati, 48
I-00144 Rome
ITALY

Mike Zentner
Westinghouse Hanford Co.
P. O. Box 1970
Richland, WA 99352

X. Zikidis
Greek Atomic Energy Commission
Agia Paraskevi, Attiki
Athens
GREECE

Bernhard Zuczera
Kernforschungszentrum
Postfach 3640
D-7500 Karlsruhe
FEDERAL REPUBLIC OF GERMANY

6460 J. V. Walker
6460A M. Berman
6463 M. P. Sherman
6471 L. D. Bustard
6473 W. A. von Rieseemann
8524 J. A. Wackerly

8523 Document Processing
3141 S. A. Landenberger [5]
3151 G. C. Claycomb
5214 D. F. Clauss
6344 E. D. Gorham
6411 D. D. Carlson
6411 R. J. Breeding
6411 D. M. Kunsman
6400 N. R. Ortiz
6410 D. A. Dahlgren
6412 A. L. Camp
6412 S. L. Daniel
6412 T. M. Hake
6413 L. A. Miller
6412 D. B. Mitchell
6412 A. C. Payne, Jr.
6613 T. T. Sype
6321 T. A. Wheeler
6412 D. W. Whitehead
6413 T. D. Brown
6413 F. T. Harper [2]
6613 R. M. Cranwell
6412 W. R. Ramond [3]
6613 L. Iman
6418 S. L. Thompson
6411 K. J. Maloney
6419 M. P. Bohn
6419 J. A. Lambright
6420 D. A. Powers
6402 K. D. Bergeron
4243 J. J. Gregory
6402 D. C. Williams
6453 J. S. Philbin

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

REPORT NUMBER
(Assigned by NRC. Add Vol. Supp. No. and Addendum Number, if any.)

NUREG/CR-4551
SAND86-1309
Vol. 2, Rev. 1, Part 3

2. TITLE AND SUBTITLE

Evaluation of Severe Accident Risks:
Quantification of Major Input Parameters

Experts' Determination of Structural Response Issues

3. DATE REPORT PUBLISHED

| MONTH | YEAR |
|-------|------|
| March | 1992 |

4. FUND OR GRANT NUMBER

L1272

5. AUTHOR(S)

R. J. Breeding, F. T. Harper, T. D. Brown, J. J. Gregory,
A. C. Payne, E. D. Gorham, W. Murfin,* C. N. Amos**

*Technadyne

**Science Applications International Corporation

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Include Date)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Sandia National Laboratories
Albuquerque, NM 87185-5800

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Division of Safety Issue Resolution
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

In support of the Nuclear Regulatory Commission's (NRC's) assessment of the risk from severe accidents at commercial nuclear power plants in the U.S. reported in NUREG-1150, the Severe Accident Risk Reduction Program (SAARP) has completed a revised calculation of the risk to the general public from severe accidents at five nuclear power plants: Surry, Sequoyah, Zion, Peach Bottom and Grand Gulf.

The emphasis in this risk analysis was not on determining a "so-called" point estimate of risk. Rather, it was to determine the distribution of risk, and to discover the uncertainties that account for the breadth of this distribution. Off-site risk initiation by events, both internal to the power station and external to the power station were assessed.

Much of the important input to the logic models was generated by expert panels. This document presents the distributions and the rationale supporting the distributions for the questions posed to the Structural Response Panel.

12. KEY WORDS DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Probabilistic Risk Assessment, Reactor Safety, Severe Accidents, Structural Response, Nuclear Reactor Containment, Large Dry Containment, Mark I Containment, Mark III Containment, Response to Static Loads, Response to Dynamic Loads, Reactor Building Response, Ice Condenser Containment

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH CLASS RATE
POSTAGE & FEES PAID
USNRC
PERMIT No. G-07

120555139531 1 1AM
US NRC-OADM
DIV FOIA & PUBLICATIONS SVCS
TPS-PDR-NUREG
7-22-81
WASHINGTON DC 20555