

NEW YORK POWER AUTHORITY
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT
 OPERATING DATA REPORT

DOCKET NO.: 50-333
 UNIT NAME: FITZPATRICK
 DATE: APRIL 1992
 COMPLETED BY: RUSS FLAGG
 TELEPHONE: (315)349-6590

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 920301 - 920331
3. Licensed Thermal Power (MW): 2436
4. Nameplate Rating (Gross MWE): 883
5. Design Electrical Rating (Net MWE): 816
6. Maximum Dependable Capacity (Gross MWE) 807
7. Maximum Dependable Capacity (Net MWE) 780

NOTES:

8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons: _____
9. Power level to which restricted, if any (Net MWE): _____
10. Reasons for restrictions, if any: _____

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period:	744.0	2184.0	146210.0
12. Number of Hours Reactor was Critical:	0	0	104831.4
13. Reactor Reserve Shutdown Hours:	0	0	0
14. Hours Generator On-Line:	0	0	101731.2
15. Unit Reserve Shutdown Hours:	0	0	0
16. Gross Thermal Energy Generated (MWH):	0	0	223974910.0
17. Gross Electrical Energy Generated (MWH):	0	0	76322860.0
18. Net Electrical Energy Generated (MWH):	0	0	73269365.0
19. Unit Service Factor:	0	0	69.6
20. Unit Availability Factor:	0	0	69.6
21. Unit Capacity Factor (using MDC Net):	0	0	64.6
22. Unit Capacity Factor (using DER Net):	0	0	61.4
23. Unit Forced Outage Rate:	100.0	100.0	14.4

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):
 Refuel outage commenced January 11, 1992. _____

5. If shutdown at end of report period, estimated date of start-up: May 15, 1992

Units in Test Status (prior to commercial operation):	FORECAST	ACHIEVED
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

9204060147 920331
 PDR ADOCK 05000333
 R PDR

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: MARCH 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: APRIL 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	0
16	0		

SUMMARY: The FitzPatrick Plant remained shutdown for the entire reporting period.

NEW YORK POWER AUTHORITY
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT
 UNIT SHUTDOWNS REPORT

REPORT MONTH: MARCH 1992

DOCKET NO.: 50-333
 UNIT NAME: FITZPATRICK
 DATE: APRIL 1992
 COMPLETED BY: RUSS FLAGG
 TELEPHONE: (315)349-6590

NO.	DATE	TYPE	DURATION	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	SYCSO TDEM	COMPODNEENT	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
2	920301	S	744	C	1	N/A	N/A	N/A	S/D for Refueling Commenced 920110 (Cumulative Hours 1937).

1

F: FORCED
 S: SCHEDULED

2

REASON:
 A. EQUIPMENT FAILURE (EXPLAIN)
 B. MAINTENANCE OR TEST
 C. REFUELING
 D. REGULATORY RESTRICTION
 E. OPERATOR TRAINING AND LICENSE EXAMINATION
 F. ADMINISTRATIVE
 G. OPERATIONAL ERROR (EXPLAIN)
 H. OTHER (EXPLAIN)

3

METHOD:

1. MANUAL
 2. MANUAL SCRAM
 3. AUTOMATIC SCRAM
 4. CONTINUED
 5. REDUCED LOAD
 9. OTHER

4

EXHIBIT G - INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEETS FOR LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: MARCH 1992

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: APRIL 1992
COMPLETED BY: RUSS FLAGG
TELEPHONE: (315)349-6590

The FitzPatrick Plant remained shutdown for this entire reporting period.

The major work items during this reporting period were:

- Reduction of plant combustible loading
- Fire Protection System corrective maintenance
- Core Spray System piping replacement
- Residual Heat Removal System maintenance
- Emergency Diesel Generator maintenance