CILITY	NAME (1	)	-		-				_	_					DOCKE	OCKET NUMBER (2)							PAGE (3)		
	D. C. COOK UNIT 2															10	0	0	13	11	16	1	OF	01	
TLE (4)	PROT	ECI	IV	E F	UNCI	TION CHA	NNEL I	OT '	ΓR	IPP	ED														
EVENT DATE (6) LER NUMBER (6)									REPORT DATE (7)					OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR		YEA	A	SEQUENTIAL	REVISA	MON MON	ТН	DAY		YEAR		FACILITY NAMES			0	DOCKET NUMBER							
										T							(	0	5	10	10	10			
0 7	1 0	8	4	1	-	0 1 9	- 010		8		9	0 1					_	-	5	10	10	0			
	BATING		3	THIS	REPORT	T IS BUSMITTE	D PURSUAN	T TO T	16 A	EQUI	REM	ENTS OF 1	CPR 8: /C	heck one or mon	of the	'ailawin	(11)		_						
MODE (8)			20.402(b)				20	20.406(e)					60.73(a;(2)(iv)			-	73,71(6)								
LEVEL (10)	0,0,0		26.406(a)(1)(i) 26.406(a)(1)(ii)										80.73(a)(2)(vi) 80.73(a)(2)(vii)	() (viii)				OTHER (Specify in Abstract below and in Text, NRC Form							
				20.406(a)(1)(iii) 20.406(a)(1)(iv) 20.406(a)(1)(v)				80	80.73(a)(2)(li) 80.73(a)(2)(lii) 80.73(a)(2)(liii)				90,73(a)(2)(viii)(A) 90,73(a)(2)(viii)(B) 90,73(a)(2)(x)				366A/								
					29,406	e)(1)(a)				_	_	*****	1 20 (12)	90.73(8)(Z)(X)				_	_		-		_		
LICENSEE CONTACT FOR THIS LER (12)													T	TELEPHONE NUMBER											
K. R. BAKER OPERATIONS SUPERINTENDENT															REA CO	-							01		
						COMPLETE	ONE LINE	OR EAC	HC	OMPO	NEN	T FAILURE	DESCRIBE	D IN THIS REPO	ORT (13)										
CAUSS	SYSTEM	сомя				MANUFAC- TURER	REPORTAR TO NPRO					CAUSE	SYSTEM	COMPONENT	MANUFAC					NPROS					
-	-	-		-	_		-					200	-		-		-	+	-						

LICENSEE EVENT REPORT (LER)

ON 7/10/84 THE UNIT WAS IN MODE 3 (HOT STANDBY) WITH TAVE ABOVE P-12 (541 F) PREPARING FOR A STARTUP FOLLOWING A REFUELING OUTAGE. AT 0240 HOURS ONE OF THE FOUR OPERATING REACTOR COOLANT PUMPS WAS REMOVED FROM SERVICE DUE TO INDICATION OF PUMP PROBLEMS.

SUPPLIMENTAL REPORT EXPECT AD (14)

TECHNICAL SPECIFICATION 3.3.2.1, TABLE 3.3-3, ITEM 4d: REQUIRES THAT WHEN TAVE IS ABOVE P-12 (541 F) THE TAVG CHANNEL ASSOCIATED WITH THE PROTECTION FUNCTIONS DERIVED FROM THE OUT OF SERVICE REACTOR COOLANT LOOP BE PLACED IN THE TRIPPED CONDITION WITHIN ONE HOUR. THIS ACTION WAS NOT TAKEN.

THE CONDITION EXISTED UNTIL 0633 AT WHICH TIME TAVE DECREASED BELOW 541 F. THIS SITUATION WAS NOT RECOGNIZED AT THE TIME OF THE OCCURRENCE.

THE ANNUNCIATOR RESPONSE PROCEDURE FOR THE RTD BYPASS RETURN FLOW LOW REQUIRES THE LOOP BISTABLES TO BE TRIPPED WITHIN ONE HOUR. HOWEVER, THE PROCEDURE WAS NOT REFERRED TO SINCE THIS IS AN EXPECTED ALARM WHENEVER A REACTOR COOLANT PUMP IS REMOVED FROM SERVICE.

THE PLANTS SHUTDOWN, HEATUP, AND REACTOR COOLANT PUMP OPERATION PROCEDURES ARE BEING REVISED TO ENSURE THAT TAVG IS REDUCED TO BELOW P-12 (541 F) WITHIN ONE HOUR WHENEVER THERE IS LESS THAN FOUR RCP'S RUNNING. ADDITIONALLY, TRAINING WILL BE DONE ON THIS SITUATION DURING THE LICENSED OPERATOR REQUALIFICATION PROGRAM.

8408160127 840809 PDR ADDCK 05000316 S PDR

YES (If yes, complete EXPECTED SUBMISSION DATE)

ABSTRACT /Limit to 1400 speces i.e., approximately fifteen single-space typewritten lines (18)

JE27

U.S. NUCLEAR REGULATORY COMMISSIO APPROVED DISS NO. 3150-0104

MONTH

EXPECTED SUBMISSION DATE (15) DAY

YEAR

EXPIRES: 8/11/86

NRC Form 366 (9-83) DONALD C. COOK NUCLEAR PLANT P.O. Box 458, Bridgman, Michigan 49106 (616) 465-5901

August 9, 1984

United States Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Operating License DPR-74 Docket No. 50-316

Document Control Manager:

In accordance with the criteria established by 10CFR50.73 entitled Licensee Event Reporting System, the following report/s are being submitted:

RO 84-019-0

Sincerely,

W.G. Smith, Jr. Plant Manager

/cbm

Attachment

cc: John E. Dolan
J.G. Keppler, RO:III
M.P. Alexich
R.F. Kroeger
H. Brugger
E.R. Swanson, RO:III
R.C. Callen, MPSC
G. Charnoff, Esq.
J.M. Hennigan
R.O. Bruggee, EPRI
INPO
PNSRC
J.F. Stietzel
E.L. Townley

Dottie Sherman, ANI Library