

Ralph E. Beedie  
Executive Vice President  
Nuclear Generation

March 31, 1992  
JPN-92-016

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
Withdrawal of Amendment Application (JPTS-84-012)

Reference: NYPA letter, J.C. Brons to the NRC, dated January 16, 1990,  
(JPN-90-008), "Proposed Change to the Technical Specifications  
Regarding Containment Leak Rate Testing Requirements (JPTS-84-  
012)."

Dear Sir:

The New York Power Authority withdraws the Technical Specification amendment application contained in the referenced letter. The proposed changes would have revised the surveillance requirements associated with primary containment leak rate testing at the James A. FitzPatrick Nuclear Power Plant.

Since the Technical Specification amendment application was filed, new circumstances have developed which affect two of the changes proposed in it. First, the NRC issued Generic Letter 91-04, which provides new guidance for exceeding the 24-month maximum surveillance interval for Type B and C leak rate testing. It requires that several evaluations be performed to consider the effects of a 24-month  $\pm 25\%$  Type B and C surveillance test interval. These evaluations will be performed to support the 24-month operating cycle amendment application, expected to be submitted in early 1993.

Second, the Authority determined that the two low pressure coolant injection (LPCI) independent power supply charger/inverters were not designed to withstand the 30-day post accident dose associated with the existing containment leak rate test acceptance criterion. A modification is being installed which will resolve this issue. However, additional evaluations must be performed to ensure that the proposed containment leak rate acceptance criterion would not adversely affect other equipment. Following these evaluations, the Authority may revise and resubmit this Technical Specification amendment request.


000007

9204060268 920331  
PDR ADDCK 05000333  
P PDR

AD17 1/0

If you have any questions, please contact Mr. J. A. Gray, Jr.

Very truly yours,



Ralph E. Beedle  
Executive Vice President  
Nuclear Generation

cc: Regional Administrator  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 136  
Lycoming, NY 13093

Mr. Brian C. McCabe  
Project Directorate I-1  
Division of Reactor Projects - I/II  
U.S. Nuclear Regulatory Commission  
Mail Stop 14 B2  
Washington, DC 20555