

S-36
50-348/364-CIVP
2/19/92

Staff Exh. 36

PAGE 1 OF 1
DOCKETED
USNRC

TABLE OF CONTENTS

'92 MAR 13 P12:11

ENVIRONMENTAL QUALIFICATION PACKAGE NO. 29G

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

MANUFACTURER: Raychem

EQUIPMENT: Chico Equipment entrance seal

005470

MODEL NO.: Raychem NCB with Chico-A seal

QUALIFICATION LEVEL: NUREG - 0588 Cat II

1. SCEW NO.: 29G REV.: 2

2. EQREC NO.: 29G REV.: 3 TOTAL NO. OF SHEETS: 18
NO. OF ATTACHMENTS TO EQREC.: 5

*3. QUALIFICATION DOCUMENTS:

1. Wyle report 58442-2 (04-03-81) "Environmental Qualification Test Report of Raychem Nuclear Cable Breakout and End Sealing Kits" {U400932 & U406385}
2. Qualification Testing of Raychem Environmental Seals for Alabama Power Company, Joseph M. Farley Nuclear Plant, dated 12-31-81 {U400976/U406423}
3. SWRI Project No. 03-4974-001 Test Procedure and SWRI letters dated 02-01-79 and 07-13-79 {U400948 & U406401}
4. Raychem Report EDR-5040 (10-15-81) "Analysis of Heat Aging Data on -52 Molding Material to determine Pre-aging Conditions for Nuclear Qualification Testing" {U400936 & U406389}

*4. MISCELLANEOUS DOCUMENTS:

1. Bechtel letter AP-12696 to APCO dated 03-11-87, 2 sheets

* PROVIDE TITLE, REVISION, DATE, U-NO., LETTER NO., AND NO. OF SHEETS AS APPLICABLE.

NUCLEAR REGULATORY COMMISSION

Docket No. 50-348/364-Civ Official Exh. No. 36
In the matter of Alabama Power Company

Staff ✓ IDENTIFIED 12:18 p.m. 2/19/92
Applicant _____ RECEIVED 12:23 p.m. 2/19/92
Intervenor _____ REJECTED _____
Cont'g Off'r _____ DATE 2/19/92
Contractor _____ Witness _____
Other _____
Reporter L Estep