

S-38 50-348/364-CIVP 2/19/92

88.03/23 15:14 P02 *

Staff Exh. 38

JOSEPH H. FALLET III, JR., UNIT
MANAGERDOCKETED
USNRCENVIRONMENTAL QUALIFICATION REPORT EVALUATION # 296

Equipment Description Raychem/CHICO Equipment Entrance Seal (See Note 4)
 Manufacturer Raychem and Crouse-Hinds
 Qualifier (Test Lab) Raychem/Bechtel/Sr, RI
 Reviewed by Robert A. Frink Title Senior Engineer Date 9/8/87

Attachment 13 through 15.

 Model/Serial No. Raychem NCE with CHICO-A
 Note 2 ④ 58442-5 (C103-4974-001)
 Report No. ELINT-SW-87-5 EDR-5040

Page 1 of 7

HUREG 0388 Requirements	Report Evaluation		Test Report Section or Page	Comments
	Yes	No		
1.0 ESTABLISHMENT OF THE QUALIFICATION PARAMETERS FOR DRA			(A) Sec 3.4 (B) App B Test Log	(A) Max Temp 390°F Max Press 66 psig (80.7%) See Attachment 1 (B) Max Temp 310°F Max Press 60 psig (74.7%) See Note 3 & Attachment 1
1.1 Temperature and Pressure Conditions Inside Containment - LOCA				
a. Does time dependent test profile envelop plant specific temperature and pressure profiles in PRART?	✓			
1.2 Temperature and Pressure Conditions Inside Containment - NSLR			(A) Sec 3.4 (B) App B Test Log	See Note 3 and Attachment 1
a. Does time dependent test profile envelop plant specific temperature and pressure profile in PRART?	✓			
b. If LOCA conditions used, were NSLR conditions enveloped?	✓		(A) Sec 3.4 (B) App B	See Note 4
1.3 Effects of Chemical Spray			(A) Sec 3.4	The CHICO Sealing Compound is covered by the NCB, keeper sleeve & conductor assembly and is not exposed to SNCB. It was tested for chemical resistance consisting of Boron hydrazine, & sodium phosphate, pH 10.5. See A-506150.
a. Was the concentration of chemicals used equal to or more severe than those in the containment spray system?	✓			
1.4 Radiation Conditions Inside and Outside Containment			(A) Sec 3.5 APP A (C) p.1	(A) 2.0×10^8 roentgen gamma (B) 1.02×10^5 rods gamma Note 5.
a. Is radiation qualification based on equipment qualified life plus most severe DRA and post DRA for which equipment must remain functional?	✓			
b. Has beta radiation been addressed?	✓		--	See A-506150, Rev. 1
c. Have components outside the containment been exposed to pump recirculation been addressed?	✓		(A) Sec 3.4 (B) App E	The inside containment conditions; Envelope the outside conditions.
1.5 Environmental Conditions for Outside Containment			(A) Sec 3.4 (B) APP E (C) MSVR	The inside containment conditions envelope the outside conditions. <u>Attachment 5</u> addendum, CHICO Not required for
a. Does time dependent test profile envelop temperature and pressure profiles analyzed in the PRART for NSLR areas?	✓			
2.0 QUALIFICATION METHODS			(A) Sec 1.0	Testing performed in Ref (A) and supplemented by Refs (E), (G) and (L)
2.1 Selection of Methods			(B) (C) (D)	
a. Do qualification methods conform to IEEE 323-1971?	✓			
b. If analysis was performed in lieu of testing, was justification provided?	✓		(D) All	Testing was performed. See Note 1 and Attachment 4 for Analysis
c. If analysis was performed in lieu of testing, was partial type test data provided to support analytical assumptions and conclusions?	✓		(E) All	Testing was performed. See Note 1 & Attachment 4 for Analysis

920219
9204060309
05000348
ADOCK
PDR
G

NUCLEAR REGULATORY COMMISSION

Docket No. D-348-144 Civil Official Dkt. No. 38
in the matter of Altamira Power Company

Staff ✓ IDENTIFIED 12:19 p.m. 3/11/92
Applicant ✓ RECEIVED 12:23 p.m. 3/11/92
Intervenor _____ REJECTED _____
Cont'dg Off'r _____ DATE 3/19/92
Contractor _____ Witness _____
Other _____
Reporter S. Etp

2
5
4

ATCH-EM I.C.T.B. BUREAU OF NUCLEAR REQUIREMENTS	Report Evaluation	Test Report Section or Part	COR REC # 24G Remarks
	Acceptable YES NO	① Sec 3.0 ② App B	
6. If testing was performed, did the test demonstrate the operability of the equipment for the time required in the environmental conditions resulting from the accident?	✓	① Sec 3.0 ② App B	Voltage and leakage test were done
7. For equipment that used not function to mitigate any accident, was it demonstrated that the equipment could not fail in a manner detrimental to plant safety?	N/A		Equipment Required to mitigate accident
8.2 Qualification by Test		① Sec 3.0 ② App A Sec II	
a. Were failure criteria established before the test?	✓	① Sec 3.0 ② App B	See Section 1.2b, Note 3 & Attachment 1
b. Did test profile envelop a composite LOCA/ HLOCA profile inside containment?	✓	① Sec 3.0 ② App B	Chico A sealing compound is inside the NCB assembly.
c. If equipment could become submerged due to flooding, has the ability or necessity for submerged operation been demonstrated?	✓	① Sec 3.0 ② App B	
d. Was simulated accident temperature defined by thermocouples on or near the equipment?	✓	① Sec 3.0 ② App B	
e. Were performance characteristics demonstrated before, during and after the test?	✓	① Sec 3.0 ② App B	Measurement for the NCB supplemented by Ref ④ Test
f. Was acoustic spray of the proper concentration employed at the proper time and duration during the test?	✓	① Sec 3.0 ② App B	See Section 1.3
g. Was Cobalt-60 employed for the gamma irradiation of the equipment?	✓	① Sec 3.0 ② App B	
3.3 Test Sequence		① Sec 3.0 ② All	065480
a. Was the adequacy of the test sequence selected justified?	✓	① Sec 3.0 ② All	
b. Did the test simulate as closely as possible the postulated environment?	✓	① Sec 3.0 ② App B	
c. Did the test procedures conform to the guidelines of Section 5 of IEEE 323-1971?	✓	① Sec 3.0 ② All	
3.0 MARGINS		① Sec 3.0 ② All	See Attachment 2
a. Were quantified margins applied to design parameters to ensure enveloping of accident conditions?	✓	① Sec 3.0 ② All	
b. Was equipment demonstrated to remain functional in the accident environment for at least one hour to excess of the time assumed in the accident environment?	✓	① Sec 3.0 ② All	The DBE ended at 30 day additional tests were done while submerged.
4.0 AGING			Equipment is not a valve or motor.
a. Does qualification program conform to requirements of ANSI 382-1972 for valve operators and IEEE 334-1971 for motors? Are aging effects considered?	N/A		
b. For equipment other than valve operators or motors, has equipment been assessed for materials which are susceptible to aging effects?	✓	① Sec 3.0 ② All	Note 7
c. Has an acceptable accelerated thermal aging method been incorporated in the qualification program to establish qualified life?	✓	① Sec 3.0 ② All	Note 7

RAYCHEM NCB BWRIG 0388 Requirements	Report Evaluation ACCEPTABLE TO TOL TO	Test Report Section BY PAGE	EERBC 7022.64 Requirements	
			1	2
d. Has mechanical (vibril) aging (if applicable) been incorporated in the qualification program?	N/A		1	Non-cycling device
B.0 QUALIFICATION DOCUMENTATION			① All	Notes 1, 3, 5, 7
a. Does the qualification documentation verify that the equipment is qualified for its application and meets its specified performance requirements?	✓		② All ③ All ④ All ⑤ All	"
b. Is qualification data used to demonstrate equipment qualification operating in an undatable zone?	✓		① All ② All ③ All	Some data is raw test data which can be used to demonstrate acceptance
c. Does qualification documentation meet the guideline of IEEE 323-1971?	✓		① All	"
d. If a certificate of conformance is submitted, is it accompanied by test data and information concerning the test program?	N/A			Certificate of Conformity is not submitted

Maintenance Requirements None Specified

Revision 3

Reviewed By: G.M. Crawford Date 3-23-88

Title Engineering Specialist

Organization: Bechtel

Approved by: V.P. Sudar Date 3/23/88

Title: E&G Group Supervisor

Organization: BEPC

Accepted by: Robert Stewart

Organization: APCo

Date 3/23/88

Evaluation Summary The Raychem/CHICO Equipment Entrance seal is considered qualified for use inside and outside containment at Farley Nuclear Plants for Units 1 and 2 for a qualified life of 40 years plus DBE.

005481

Revision

Reviewed by: Sushant Kapur Date 11/24/87

Title Engineer

Organization: Bechtel

Approved By: V.P. Sudar Date 11/24/87

Title: E&G Group Supervisor

Organization: BEPC

Accepted by:

Date 11-24-87

Organization:

APCo-akc

Revision 1

Reviewed By: Robert O. Frink Date 7/9/87

Title SR. ENGINEER

Organization: Bechtel

Approved By: V.P. Sudar Date 9/11/87

Title: E&G Group Supervisor

Organization: BEPC

Accepted by:

Date 1/18/87

Organization:

JM Sard APCo

Notes:

- Qualification of the Raychem/Crouse Hinds (CHICO) environmental seal is based on similarity to the NCBK (Fig. 1) by use of the NCB insulated boot breakout with the WCSF insulated sleeve. This NCB moulder boot is qualified with the WCSF insulating sleeve per Wyle Lab Test Report 5844. The Raychem/Chico environmental entrance seal is similar to the tested WCSF/NCE in that the WCSF sleeve is now surrounded by a 1/4 inch metal coupling. In addition, the NCB is attached to a 1 inch conduit nipple which is filled with CHICO sealing compound to provide structural support for harsh environment. Since the NCB had been qualified previously Ref. (B) tested the CHICO environmental seal configuration (Fig. 2) for postulated Farley LOCA profile.


NCBK

Fig. 1: NCBK Configuration

Qualified By Ref. (A) Wyle
Test Report 5844 2-2

005482




Fig. 2: CHICO Seal Configuration
Qualified By Similarity to NCBK Configuration and Ref. (B)

2
2. References:

- ④ Wyle Laboratories test Report No. 5B442-2. Environmental Qualification Test Report of Raychem Nuclear Cable Breakout and End Sealing Kits. Dated April 3, 1981
- ⑤ Qualification Testing of Raychem Environmental Seals for Alabama Power Co., Joseph M. Farley Nuclear Plant Appendix A. Test Procedure Limit Switch Cable Seal Test
Appendix B APCo QC Test Log
Dated 12/30/81
- ⑥ Southwest Research Institute, Bechtel P.O. 9645,
SwRI PROJECT No. 03-4974-001 Dated February 1, 1979.
- ⑦ Raychem Report NO. EDR-5040. Analysis of Heat Aging Data on -52 Moulding Material to Determine Pre-aging conditions for Nuclear Qualification Testing, Dated 10/15/81

005483

Notes:

3. The CHICO seal configuration (Note 1, Fig. 2) that was tested consists of a 1" nipple (conduit), a 1 $\frac{1}{4}$ " pipe coupling, a Raychem NCB, a Raychem WCOF sleeve and the CHICO A4 (Ref. ② Sec. V, App. A Sec. III, IV & App. B). Testing per Ref. ② did not test to the extremes of the DBE (Specified 316°F, tested 310°F). However, the metal pipe will withstand the DBE extremes; the NCBK was tested to the DBE conditions (Ref. ④) and the CHICO is a cement mixture of calcium aluminate and gypsum content (Attachment 2) inside the conduit (Note 1). In addition, the CHICO-A4 withstood the pressure test, via the NCEK, with .12 psig margin (Attachment 1 p. 2).
4. Testing was only for 24 hours but after 24 hours the pressure is approximately 0 psig. Therefore testing is adequate and the A1SLB is enveloped.
5. A conduit assembly with CHICO-A05 sealing compound (Ref. ②) was irradiated to a value of 1.02×10^8 rads. The only difference between CHICO-A05 that was irradiated and CHICO A4 is the packing size (see Attachment 3, p. 2).

005484

6. Deleted

7. The CHICO configuration for testing was not thermally or radiation aged prior to D&E testing. However, the CHICO inorganic cement mixture (Attachment 1) of calcium aluminate and gypsum cement will not be as susceptible to aging as the organic compounds which were tested in Ref A. Therefore the aging test in References A and D may be utilized for the entire assembly. Thus the testing provided by Ref A and supplemented by References B, C and D provide acceptable justification for aging.

005485


160-E SERIES E-ENCABLING SYSTEM 2 CYCLES X 90 DIVISIONS
PRINTED IN U.S.A. BY GUGGENHEIM

46 6460

The specified curve is based on FSAR Curve, Figure 6.2-40

卷之三

CONTAINMENT TEMPERATURE ENVELOPE
LOC A INSIDE




K-E SEMI-LOGARITHMIC 7 CYCLES X 80 DIVISIONS
HEUFFEL & ERNST CO. MADE IN U.S.A.

46 5460

EQREC #296
COMPOSITE LOCA/MSLB
CONTAINMENT PRESSURE ENVELOPE

The specified curve is
based on FSAR curves,
Figures 6.2-36 and 6.2-39



EQUIPMENT : Raychem/CHICO Equipment
Entrance Seal

ERRECMOREV. 1

ATTACHMENT 2

MARGINS

	FACILITY REQUIREMENT	QUALIFICATION	TOTAL MARGIN
TEMPERATURE	316°F	(A) 390°F (B) 310°F See EUREL Note 3	74°F (23%)
PRESSURE	62.7 psia + 48.0 psig FOR APPROX. 60 SEC. (COMPOSITE PROFILE FOR LOCA & MSLB)	(1) 100 psig (2) 60 psig	(1) 18 psig (37.5%) Note 1 (2) 12 psig (25%)
RADIATION	5×10^7 RADs (TID)	(1) 20×10^7 RADs (2) 10.2×10^7 RADs	(1) 15×10^7 RADs (300%) (2) 5.2×10^7 RADs (104%)
VOLTAGE	600 V	100% V rms	(1) 400 V (66.7%)
FREQUENCY	N/A		Frequency variation will not affect function
OPERATING TIME + 1 HOUR	720 hrs + 1 hrs	(1) 120 hrs + submergence test	

Note 1: The pressure margin exceeded the required 10 psi margin, but the test chamber maintained saturated conditions throughout the test.

SUMMARY: Margins are acceptable

005488

Kaychem/Cimco Equipment Entrance Seal

EQKEC = 29G Attachment D

Page 1 of 2



**CROUSE-HINDS
ELECTRICAL
CONSTRUCTION
MATERIALS**

February 10, 1987



Mr. K. C. Gandhi
Bechtel Eastern Power Corp.
15740 Shady Grove Road
Gaithersburg, MD 20877-1454

Ref: Joseph M. Farley Nuclear Plant Unit 1 and 2
Bechtel Job 7597-042
CHICO-A4 Sealing Compound (ES86-769)
V-4302

Dear Mr. Gandhi,

In response to your request for information regarding the CHICO-A4 compound, we can verify:

- CHICO sealing compound is an expansive cement mixture consisting of calcium aluminate and gypsum cement.
 - The same non-organic ingredients in the CHICO formulation have been used for over 15 years.
 - There has been no change in the mixture that affects the intended application as a sealing compound in explosion-proof sealing fittings.
 - The mechanical properties of currently manufactured CHICO Cement are comparable to the previously supplied compound.

Sincerely,

S. A. Jeffrey
S. A. Jeffrey
Manager, Sales & Services
Eastern Region

SAJ/uk

TICKLER		DUE DATE	
	NOTE	MONTH	DAY
1	PROL. BLD.	JULY	20
2	ALSO 24.14		
3	MAIL		
4	OPTIONAL SIZ		
5	MEDICATIONS		
6	PHOTOGENE		
7	PLANS		
8	MEET		
9	PROJ. ACT		
10	WORK REQUEST		
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			

ELECTRICAL CONSTRUCTION MATERIALS

Division of Cooper Industries, Inc.

Post Office Box 4890, Syracuse, New York 13221, (315) 477-7000, Telex 885462, Facsimile (315) 477-7000

Raychem / CHICO EQUIPMENT ENTRANCE SEAL

Page 2 of 2

Crouse-Hinds

Chico A
Chico A-P
Chico X

For
Conduit
Seals

Application:

- Chico X is ceramic fiber used to make a dam in the space between the integral bushing of the seal fitting hub and the conduit end and around the electrical conductors prior to pouring Chico compound. This prevents compound from leaking into connected conduit.
- Chico A is a water soluble powder that after mixing with water, can be poured to effect a seal that hardens and is suitable for use in hazardous areas.
- Chico A-P Intrapak® is an easy pour, two compartment plastic mixing pouch containing Chico sealing compound and the precise amount of water for mixing. No mixing or measuring implements are required. A hard squeeze of the water compartment releases the water into the Chico compound compartment. Mixing is completed by kneading the transparent pouch for one minute. The mixture is then poured directly into the sealing fitting—no funnel is required. The package label indicates the number and size of sealing fittings that can be made with each pouch.
- UL listings of Crouse-Hinds seal fittings are contingent upon their use with Chico A and X, the materials with which they are tested.

Features:

- Chico compound is unusually dense
- Expands slightly on hardening, bonding to inner walls of sealing fitting
- Chico A hardens in 60-70 minutes
- Chico A-P hardens in 25-30 minutes

Options:

Description
Extra fast setting
Chico compound—
Chico FB (25 to 30
minutes) Information
on request



Chico A
Sealing Compound

Net Weight	Vol. Cu. In. [†]	Cat. #
8 oz.	13	Chico A2
1 lb.	23	Chico A3
1 lb. 3	26	Chico A4
2 lb.	46	Chico A23
2 lb. 4	48	Chico A24
5 lb.	115	Chico A05
10 lb.	230	Chico A5

**Chico A-P[▲]****Intrapak[®]**

**Sealing Compound
and Water in Plastic
Mixing Pouch**

Cu. In. Pouch [‡]	No. of Pouches per Carton	Cartons Cat. #
8	8	Chico A18-PX*
11	6	Chico A38-PX*

**Chico X[▲]****Fiber**

Net Weight	Cat. #
1 oz.	Chico X3
2 oz.	Chico X4
4 oz.	Chico X5
8 oz.	Chico X6
1 lb.	Chico X7

Chart for Approximate
Amount of Fiber Per Hub

Hub Size	Oz. Required	Hub Size	Oz. Required
1/2	1/32	2 1/2	1 1/2
3/4	1/16	3	2
1	1/8	3 1/2	3
1 1/4	1/4	4	4 1/2
1 1/2	1/2	5	7
2	1	6	10

005490

*Denotes revision

*A sixth pouch, containing an appropriate quantity of Chico X fiber, is included in these cartons.

†Number of cubic inches this amount will fill when set. See internal volume requirements for EYE, EZS, EYD and EZD sealing ratings (SF-2 to SF-3).

*Includes 1 oz. Chico X fiber

†Includes 2 oz. Chico X fiber

RAYCHEM/CHICO ENVIRONMENTAL SEAL FOR
NAMCO LIMIT SWITCHES

005491

The Raychem breakout kit for cables is environmentally qualified including thermal aging, irradiation, and LOCA testing (Reference Wyle Test Report No. 58442-2, dated 4/3/81). The Farley configuration uses a breakout at the end of a pipe nipple. Since the breakout had been qualified previously, Farley conducted a test on the Raychem/CHICO environmental seal configuration shown in Figure 1 for pressure and temperature conditions postulated during a LOCA (Reference Qualification Testing of Raychem Environmental Seals for Alabama Power Co., Joseph M. Farley Nuclear Plant, dated 12/30/81). The test did not include exposing the test specimen for chemical spray. The following paragraphs address the effect of chemical spray.

The environmental seals used with NAMCO EA-180 limit switches are composed of a Raychem WCSF breakout boot that has been shrunk onto a 1" pipe nipple attached to the limit switch (See Figure 1). The individual conductors connected to the switch pass through the breakout boot which forms a seal to the conductor insulation/jacket. To provide mechanical rigidity to the breakout boot, the nipple and the breakout boot are filled with Crouse-Hinds sealing compound (CHICO A) and allowed to cure. In addition to providing mechanical rigidity to the breakout boot crotch, the CHICO A provides an additional pressure tight barrier (seal) inside the pipe nipple which is environmentally qualified. CHICO A was qualified by test conducted by Southwest Research Institute (SWRI Project No. 03-4974-001) for use as drywell penetrations for Grand Gulf Nuclear Station. In addition, on the recommendation of Raychem, a keeper sleeve was installed over the breakout boot and the nipple to add rigidity to the boot, and to keep the boot in place during elevated accident temperatures when the adhesive softens.

In the final assembly, an appleton compression adapter is clamped over the keeper sleeve to provide support for the flexible conduit, and it also mechanically clamps the keeper sleeve to the pipe nipple.

The zinc coating on the galvanized steel nipple may interact with the chemical spray during LOCA and form a grey powder over the nipple. However, the chemical spray does not react with the Raychem S1119 adhesive (Reference Wyle Test Report No. 58442-2, Section 3.4, Page 9 and Section 3.4.2). In addition the duration of spray at Farley is only 87 minutes and the individual conductors will be effectively shielded from the spray.

Should there be a failure of the adhesive between the pipe nipple and the breakout boot, for whatever reason, the seal assembly would remain intact because of the keeper sleeve and the clamping action of the compression adapter. If it is postulated that the breakout boot, the keeper sleeve and the compression adapter clamp all fail, the internals of the NAMCO limit switch will still be protected by the approximately 3 inch long CHICO A seal.

ATTACHMENT NO. 4
EQREC # 29G, Page 2 of
Raychem/CHICO Eqm
Entrance Seal




FIGURE 1

3

MAIN STEAM VALVE ROOM ADDENDUM

QUALIFICATION TESTING OF RAYCHEM ENVIRONMENTAL

SEALS FOR ALABAMA POWER COMPANY

JOSEPH M. FARLEY NUCLEAR PLANT

This addendum supports the switch seal configuration used in the main steam valve room. This configuration is identical to that used inside the containment, except that Chico A was not used as a mechanical support for the Raychem breakout.

The use of the Chico sealing compound is not required for use in the main steam valve room because of the low pressure peak (5.8 psig) and the short duration of the transient (1.5 sec as can be seen from attachment 1, pages 1 and 2 of this addendum, the MSLB in the MSR accident profiles are enveloped with considerable margin.

005493

The test specimen consisted of a Raychem breakout boot, a keeper sleeve and a nonmission-lifetime. The endi-

Attachment No 5 to EQPEC #2
Page 2 of 4

3

sealed using solder-filled compression lugs with Raychem heat shrink sleeving sealing the lug barrel to the conductor insulation. Chico 1 was not used on this specimen.

The actual test transient was started when the chamber temperature reached 310°F and the pressure quickly raised to 50 psig. After 7 minutes, the pressure was reduced to 45 psig. After 14 minutes into the test, the seal ruptured.


Because the environmental parameters were exceeded for a time duration several orders of magnitude beyond the required time, the Raychem breakout seal configuration without Chico 1 is qualified for this application.

005494

This specified curve is ...
Calculation No. 525-25-7597
Rev. 0 (Computer Run No. T10576)

00 00 03/23 15:14 P07 *

MSLB INSIDE MAIN STEAM ROOM
TEMPERATURE ENVELOPE



Attachment 1b 5 to EAPC #2
Page 3 of 4

88.03/23 15:14 P08 *

Attachment No 5 to EQREQ #2
Page 4

The specified curve is from
Calculation No. 525-25-7597
Rev. 0 (Computer Run No. T10576)

46 6460

MSLB INSIDE MAIN STEAM ROOM
PRESSURE ENVELOPE

