

7-23-84

Dockets: 50-445
50-446

Texas Utilities Electric Company
ATTN: M. D. Spence, President, TUGCO
Skyway Tower
400 North Olive Street
Lock Box 81
Dallas, Texas 75201

Gentlemen:

Thank you for your letter of May 29, 1984, in response to our letter dated April 30, 1984. We have reviewed your reply and find it to be inadequate, in that, your response does not include a completion date for the final report and does not address action to prevent recurrence.

In addition for our review, we request that you provide us with your detailed sampling plan and the procedure(s) which describes your inspection techniques for assessing the extent of unauthorized weld repairs.

We request that you provide your response within 20 days.

The response directed by this letter is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Should you have any questions regarding this matter, please contact Mr. D. M. Hunnicutt.

Sincerely,

Original Signed By:
Richard L. Bangart

Richard L. Bangart, Director
Division of Radiation Safety and
Safeguards

cc:
Texas Utilities Electric Company
ATTN: B. R. Clements, Vice
President, Nuclear
Skyway Tower
400 North Olive Street
Lock Box 81
Dallas, Texas 75201

Texas Utilities Electric Company
ATTN: H. C. Schmidt, Manager
Nuclear Services
Skyway Tower
400 North Olive Street
Lock Box 81
Dallas, Texas 75201

TF LGI 7/18/84	TLTH DMH 7/18/84	DRS&S RUB 7/18/84	DRS&P RBB 7/19/84	NRR TIP 7/23/84
----------------------	------------------------	-------------------------	-------------------------	-----------------------

IE 31
||

bcc's w/ltr dtd 5/29/84

bcc to DMB (IE31)

bcc distrib. by RIV:

Resident Inspector-Ops

RPB2

D. Hunnicutt, Task Force

RIV File

TEXAS STATE DEPT. OF HEALTH

J. Collins, RA

Resident Inspector-Cons

S. Treby, ELD

R. Denise, DRS&P

R. Bangart, Task Force

T. Ippolito, NRR

L. Gilbert

T. Westerman

TRT

J. Douglas