


NUREG/IA-0056  
GD/PE-N/729



# International Agreement Report

---

## Assessment of Subcooled Boiling Model Used in RELAP5/MOD2 (Cycle 36.05, Version E03) Against Experimental Data

Prepared by  
C. R. Brain

Central Electricity Generating Board  
Generation Development and Construction Division  
Barnett Way  
Barnwood, Gloucester GL4 7R5  
United Kingdom

Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

March 1992

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Thermal-Hydraulic Code Assessment  
and Application Program (ICAP)

Published by  
U.S. Nuclear Regulatory Commission

9204060353 920331  
PDR NUREG  
IA-0056 R PDR

## NOTICE

This report was prepared under an international cooperative agreement for the exchange of technical information. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Available from

Superintendent of Documents  
U.S. Government Printing Office  
P.O. Box 37082  
Washington, D.C. 20013-7082

and

National Technical Information Service  
Springfield, VA 22161



NUREG/IA-0056  
GD/PE-N/729

## International Agreement Report

---

# Assessment of Subcooled Boiling Model Used in RELAP5/MOD2 (Cycle 36.05, Version E03) Against Experimental Data

Prepared by  
C. R. Brain

Central Electricity Generating Board  
Generation Development and Construction Division  
Barnett Way  
Barnwood, Gloucester GL4 7R5  
United Kingdom

Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

March 1992

Prepared as part of  
The Agreement on Research Participation and Technical Exchange  
under the International Thermal-Hydraulic Code Assessment  
and Application Program (ICAP)

Published by  
U.S. Nuclear Regulatory Commission

## NOTICE


This report is based on work performed under the sponsorship of the United Kingdom Atomic Energy Authority. The information in this report has been provided to the USNRC under the terms of the International Code Assessment and Application Program (ICAP) between the United States and the United Kingdom (Administrative Agreement - WH 36047 between the United States Nuclear Regulatory Commission and the United Kingdom Atomic Energy Authority Relating to Collaboration in the Field of Modelling of Loss of Coolant Accidents, February 1985). The United Kingdom has consented to the publication of this report as a USNRC document in order to allow the widest possible circulation among the reactor safety community. Neither the United States Government nor the United Kingdom or any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, or any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

CENTRAL ELECTRICITY GENERATING BOARD  
GENERATION DEVELOPMENT AND CONSTRUCTION DIVISION  
PLANT ENGINEERING DEPARTMENT  
NUCLEAR PLANT BRANCH

Assessment of the subcooled boiling model used in RELAP5/Mod2 (cycle 36 05, version E03) against experimental data.

**Author :** C R Brain - Safety Technology Section.

**Approved by :**



Head of Safety Technolog. Section.

**Summary :**

In order to test the ability of RELAP5/Mod2 to describe subcooled nucleate boiling under conditions similar to those anticipated during intact circuit fault scenarios in pressurised water reactors the code has been assessed against results of high pressure sub-cooled boiling experiments reported in the literature. For cases with low inlet subcooling, agreement between the calculations and the test data is very good, but with increased inlet subcooling the code tends to over estimate the void fraction. It is concluded that RELAP5/Mod2 can be applied with reasonable confidence to the prediction of subcooled boiling void fraction for conditions expected during PWR intact circuit faults.

**Date :** February 1989

## CONTENTS

	<u>Page No</u>
1. INTRODUCTION .....	1
2. THE EXPERIMENTS .....	1
2.1 THE CHRISTENSEN EXPERIMENT .....	1
2.2 THE EGEN, DINGEE AND CHASTAIN EXPERIMENT .....	2
3. THE RELAP5/Mod2 MODELS .....	2
3.1 MODEL OF THE CHRISTENSEN EXPERIMENT .....	2
3.2 MODEL OF THE EGEN, DINGEE AND CHASTAIN EXPERIMENT .....	2
4. RESULTS AND DISCUSSION .....	2
5. THE HEAT TRANSFER CORRELATIONS USED IN RELAP5/Mod2 .....	4
6. CONCLUSIONS .....	6
7. NOMENCLATURE .....	6
8. REFERENCES .....	6
FIGURES 1 TO 14	
APPENDIX 1 RELAP5/Mod2 INPUT FOR THE CHRISTENSEN EXPERIMENT	
APPENDIX 2 RELAP5/Mod2 INPUT FOR THE EGEN EXPERIMENT	

## 1 INTRODUCTION

In some intact circuit faults in PWRs, sub-cooled voiding within the reactor core may significantly influence the primary coolant volume and hence the peak system over-pressure. RELAP5/Mod2 calculations of an ATWT test in the LOBI test facility, reported in reference 1, show a significant over-prediction of system peak pressure. The authors of reference 1 attribute the error, in part, to an over-estimation of vapour generation in the core for conditions of subcooled nucleate boiling. In view of this reported discrepancy, it was considered that further investigation in this area would be worthwhile. Therefore two simple sub-cooled boiling experiments have been modelled with the thermal hydraulics code RELAP5/Mod2 (cycle 36 05, version EO3) which is described in references 5 and 6. The results of these comparisons are described in the present report.

The first of the two experiments modelled (reference 2) involved sub-cooled nucleate boiling of water in a vertical tube at pressures of up to 6.9 MPa (1000 psi). This experiment was chosen since it had already been used in the assessment of two previous versions of RELAP5 (reference 4). The second experiment (reference 3) involved sub-cooled boiling water in a vertical tube at a pressure of 13.8 MPa (2000 psi), which is closer to the conditions of interest in reactor fault analysis.

## 2 THE EXPERIMENTS

In both the experiments the test section consisted of a vertical tube which was electrically heated by passage of an alternating electrical current through the tube walls. The inlet flow to the test section consisted of subcooled water at a known constant temperature, pressure and flow-rate.

The void fraction along the test section was measured with a gamma densitometer. Further details of the individual experiments are as follows.

### 2.1 THE CHRISTENSEN EXPERIMENT (reference 2)

The test section in this experiment consisted of a 127 cm long stainless steel tube of rectangular cross-section (dimensions 1.11 cm x 4.44 cm). Seven different runs were simulated with RELAP5/Mod2, the test conditions for these runs are given in Table 1 below.

Table 1 - Christensen tests selected for analysis.

Run No	Pressure (MPa)	Power (kW)	Flow rate (kg/m <sup>2</sup> s)	Temperature (Kelvin)	Inlet Subcooling (Kelvin)
9	2.76	30	640.9	499.5	2.9
10	2.76	30	646.9	493.7	8.7
11	4.14	50	940.0	511.1	14.4
12	4.14	50	927.8	518.3	7.2
13	4.14	50	920.9	522.2	1.3
15	5.51	70	907.2	530.8	12.5
16	6.89	70	807.7	545.9	42.1

Tables giving the measured variation of void fraction along the tube are presented in reference 2. Void is produced very close to the inlet of this heated length, and the void fraction increases along the tube reaching a maximum value of between 315 and 65 depending on the run conditions.

## 2.2 THE EGEN, DINGEE AND CHASTAIN EXPERIMENT (reference 3)

The test section used in this experiment consisted of a 68.5 cm long type 304 stainless steel tube also of rectangular cross-section, (dimensions 2.5 cm by 0.26 cm). Five of the twenty different experimental runs carried out in the experiment were selected for modelling with RELAP5/Mod2. The test conditions for these runs are given in table 2 below

Table 2 - Egen tests selected for analysis

Run No	Pressure (MPa)	Power (kW)	Flow rate ( $kg/m^2s$ )	Temperature (Kelvin)	Inlet Subcooling (Kelvin)
7	13.79	24	922.2	577.3	31.4
13	13.79	24	922.3	605.0	3.6
15	13.79	48	1166.4	534.0	74.7
16	13.79	60	1153.0	534.0	74.7
19	13.79	24	1123.0	602.0	6.7

The experimental results were expressed as void fraction and steam quality at various locations along the test section.

## 3 THE RELAP5/Mod2 MODELS

### 3.1 MODEL OF THE CHRISTENSEN EXPERIMENT

This experiment was modelled using the noding arrangement shown in figure 13. The test section was modelled as a tube divided into 20 equal volumes, with an attached heat structure consisting of a cylindrical shell having the same internal surface area as the rectangular tube in the experiment. The outside surface of the heat structure was defined as an adiabatic boundary so that all the heat energy flows into the fluid. The initial conditions for each of the runs as tabulated in section 2.1 were set up by specifying the characteristics of the bottom time dependent junction and volume. This model was chosen so as to be very similar to the model used to represent the same experiment in reference 4. The input data is given in full in appendix 1.

### 3.2 MODEL OF THE EGEN, DINGEE AND CHASTAIN EXPERIMENT

The noding arrangement used in this case is shown in figure 14. This input model is generally the same as used for the Christensen experiment except that 27 volumes were used to represent the test section in more detail. The input data is given in appendix 2.

## 4 RESULTS AND DISCUSSION

The void fraction calculated by RELAP5/Mod2 in each hydrodynamic volume within the test section was plotted against height, for each of the experimental cases. Results are given in figures 1-1'. Comparison is made with experimental data giving the measured void fraction at selected points along the tube.

It is observed that in each of the RELAP5/Mod2 calculations the predicted voidage in the volume at the top of the test section is artificially high. This is due to averaging procedures used in modelling the junction between the test section outlet and the outlet time dependent volume. The anomaly could be removed by adding extra volumes at the test section outlet, but it was deemed unnecessary to undertake this modification since the anomaly is localised and in any case there is no experimental void fraction data available very close to the tube outlet.



For cases of low inlet subcooling, (all the Christensen runs and Egen runs 13 and 19) the agreement between experiment and theory is generally very good, with RELAP5/Mod2 adequately predicting both the slope and magnitude of the experimental data. Where discrepancies arise between the two sets of data, the cause is probably experimental measurement errors. In several of the cases, the experimental void fraction is seen to decrease with increasing elevation, and this cannot be a real effect. It is therefore taken as an indication of the experimental uncertainty.

RELAP5 calculations of Christensen's experimental run15 were carried out as one of the developmental assessment problems for RELAP5/Mod2 (reference 4). Reference 4 compares predictions of RELAP5/Mod1, and an unspecified version of RELAP5/Mod2 with the experimental data for this run. These comparisons along with the present calculations performed with RELAP5/Mod2 (cycle 3605, version E03) are included in figure 6. It is seen from the figure that the version of RELAP5/Mod2 used in the present work gives the best agreement with experiment. It is noticeable that RELAP5/Mod1 greatly underestimates voidage close to the tube inlet. This is because RELAP5/Mod1 did not have a thermal disequilibrium modelling capability, and therefore was unable to model vapour generation under subcooled conditions.

However for cases of high inlet subcooling, (Egen runs 7, 15 and 16) RELAP5/Mod2 is not able to predict the experimental results with such precision. The code tends to calculate the production of void very close to the test section inlet, which is not observed in the experimental results. As a result it predicts a much greater voidage along the whole channel.

It is the total voidage throughout the channel and not the void distribution that has the dominant effect on primary pressure, therefore any inaccuracies in the RELAP5 prediction of total void could give rise to the phenomena observed in reference 1. In view of this, the total void throughout the channel for each of the runs has been calculated, and compared with estimated upper and lower bounds for the test results in table 3.

Table 3 - Channel average void fraction.

Run Number	Measured (Lower)	Measured (Upper)	Calculated
Christensen run9	0.29	0.37	0.42
Christensen run10	0.20	0.28	0.27
Christensen run11	0.08	0.16	0.17
Christensen run12	0.21	0.29	0.31
Christensen run13	0.34	0.42	0.39
Christensen run15	0.26	0.30	0.28
Christensen run16	0.23	0.27	0.27
Egen run7	0.14	0.20	0.23
Egen run13	0.45	0.51	0.49
Egen run15	0.06	0.12	0.17
Egen run16	0.18	0.24	0.30
Egen run19	0.33	0.39	0.40

Inspection of the table reveals that RELAP5 systematically over predicts the system mean void fraction in these tests. However in five of the twelve cases the calculation falls within the experimental uncertainty band, and in three other cases the calculation falls just ( $< 0.02$ ) outside it. In the worst case (Egen run 16) the calculated void fraction falls 0.06 outside the experimental band.

## 5. THE HEAT TRANSFER CORRELATIONS USED IN RELAP5/Mod2

As noted previously, reference 1 attributed errors in a RELAP5/Mod2 calculation of a LOBI ATWT test, to inadequate modelling of subcooled vapour generation in the core region. In particular the authors of reference 1 noted that the Unal correlation for interfacial heat transfer in subcooled boiling had been incorrectly coded in RELAP5/Mod2.

To investigate the above assertion, a brief investigation was carried out into the interfacial heat transfer models used by RELAP5/Mod2 in vertical flows for 'wet wall' conditions of present interest. The interfacial heat transfer coefficient is flow regime dependent.

In the bubbly flow regime a modified form of the Unal correlation is used to calculate liquid/interface heat transfer as noted in reference 1, while other correlations are applied in the slug and annular mist regimes. The flow regime boundaries in vertical up flow are defined by the following equations:-

$$0 \leq \alpha_g \leq \alpha_{AB} \quad \text{BUBBLY FLOW}$$

$$\alpha_{AB} \leq \alpha_g \leq \alpha_{AC} \quad \text{SLUG FLOW}$$

$$\alpha_{AC} \leq \alpha_g \leq \alpha_{AD} \quad \text{ANNULAR MIST}$$

The following equation is used for  $\alpha_{AB}$

$$\alpha_{AB} = \max[0.25 \min(1, (0.04D')^8), 10^{-3}] \quad \text{Where } D' = D \left[ g \frac{(\rho_l - \rho_g)}{\sigma} \right]^{0.5}$$

For pressures of 10 MPa and values of hydraulic diameter below 0.017 m  $\alpha_{AB} < 0.013$ .

Hence for the conditions analysed in the present report, and for PWR reactor core or steam generator components where subcooled boiling may occur, bubbly flow will not normally be calculated. Consequently the Unal correlation will not normally be applied in subcooled boiling conditions of interest in PWR transient calculations. The errors in the calculation reported in reference 1 could not therefore have been due to incorrect coding of this model (in fact the authors of reference 1 no longer hold this view, but have shown that the calculation was poor because of inadequate convergence, ref 8). Generally the flow regime of interest will be the slug flow regime, according to reference 5 the liquid/interface heat transfer coefficient in vertical slug flow is -

$$H_{if} = H_{if,TB} + H_{if,bub} \quad (1)$$

$$\text{Where } H_{if,TB} = 118942 Re_l^{0.5} Pr_l^{0.5} \frac{K_l}{D} a'_{gl,TB} \alpha_{TB} \quad (2)$$

$$\text{And } H_{if,bub} = \left[ \max \left\{ \begin{array}{l} \frac{K_l}{\sigma_b} \frac{12}{\pi} \Delta T_{sat} \frac{\rho_l (C_p)_l F_g}{\rho_g h_{fg}} \\ \frac{K_l}{\sigma_b} (2.0 + 0.74 Re_b^{0.5}) \end{array} \right\} + 0.4 |V_f| \rho_l (C_p)_l F_1 a'_{gl} F_2 F_3 \right] \quad (3)$$

Equations defining the terms composing equations (1), (2) and (3) are as follows -

$$Pr_f = \frac{(C_p)_f \mu_f}{K_f} \quad (4)$$

$$Re_f = \mu_f D \min(|V_f - V_g|, 0.8) / \mu_f \quad (5)$$

$$\alpha_{TB} = \text{Taylor bubble void fraction} = \frac{(\alpha_g - \alpha_{gs})}{(1 - \alpha_{gs})} \quad (6)$$

$$a'_{gr,TB} = \text{volumetric interfacial area} = \frac{4.5}{D} \quad (7)$$

$$\alpha_{bub} = \alpha_{AB} F_g \quad (8)$$

$$V_{fp} = (V_g - V_f) F_g^2 \quad (9)$$

$$\alpha_{gr,bub} = (a_{gr})_{bub} (1 - \alpha_{TB}) F_g \quad (10)$$

$$F_g = \exp \left[ -8 \frac{(\alpha_g - \alpha_{AS})}{(\alpha_{AC} - \alpha_{AB})} \right] \quad (11)$$

$$F_1 = \min[0.001, \alpha_{bub}] / \alpha_{bub} \quad (12)$$

$$F_2 = \min[0.25, \alpha_{bub}] / \alpha_{bub} \quad (13)$$

$$F_3 = \begin{cases} 1 & \Delta T_{sf} \leq -1 \\ \max[0.0, F_4(1 + \Delta T_{sf}) - \Delta T_{sf}] & -1 < \Delta T_{sf} < 0 \\ \max[0.0, F_4] & \Delta T_{sf} \geq 0 \end{cases} \quad (14)$$

$$Re_b = \frac{We \sigma (1 - \alpha_{bub})}{\mu_f (V_{fp}^2)^{1/2}} \quad \text{Where } We \sigma = \max(We \sigma, 10^{-10}) \quad (15)$$

$$F_4 = \min[10^{-5}, \alpha_g(1 - Q)](10^5) \quad (16)$$

$$We = \rho_f d_b V_{fp}^2 / \sigma \quad (17)$$

$$a_{gr} = \text{interfacial area per unit volume} = 3.6 \alpha_{bub} / d_b \quad (18)$$

The RELAP5/Mod2, (cycle 36.05, version E03), code listing has been examined in order to verify that the code does indeed contain the above equations.

## 6. CONCLUSIONS

To test the ability of RELAP5/Mod2 to describe subcooled vapour generation under conditions similar to those expected in some PWR intact circuit faults, calculations have been performed of two sets of subcooled boiling experiments from the literature.

For the cases of low inlet subcooling, agreement between calculations and experiment is very good, with void fraction normally being predicted to within the apparent uncertainty on the measured data.

Agreement between calculations and experiment in the high subcooling cases is not as close, with RELAP5/Mod2 over predicting the void produced, particularly near the test section inlet. However the error in the channel average void fraction is not large.

The study indicates that RELAP5/Mod2 (cycle 36.05 version E03) can be used with reasonable confidence to calculate the subcooled void fraction under conditions encountered in PWR pressurised fault sequences.

## 7. NOMENCLATURE

<u>SYMBOL</u>	<u>MEANING</u>
$\rho_g$	gas density ( $kg/m^3$ )
$\rho_l$	liquid density ( $kg/m^3$ )
$g$	acceleration due to gravity ( $m/s^2$ )
$(C_p)_l$	specific heat capacity of liquid ( $J/kgK$ )
$h_{fg}$	latent heat of vaporisation ( $J/kg$ )
$\Delta T_{sf}$	$T_s - T_f$ (K)
$d_b$	average bubble diameter (m)
$D$	hydraulic diameter (m)
$Q$	noncondensable quality
$K_l$	thermal conductivity of liquid ( $W/mK$ )
$\mu_l$	liquid viscosity ( $kg/ms$ )
$V_l$	liquid velocity (m/s)
$V_g$	gas velocity (m/s)
$\sigma$	surface tension ( $N/m$ )
$\alpha_g$	void fraction
$\alpha_{gs}$	average void fraction in the liquid film and slug region
$\alpha_{bub}$	bubble void fraction
$H_{if}$	heat transfer coefficient
$\alpha_{AB}$	$\alpha_g$ for bubbly-slug transition
$\alpha_{AC}$	$\alpha_g$ for slug-annular mist transition
$\alpha_{AD}$	$\alpha_g$ for annular mist - dispersed transition

## 8. REFERENCES

1. JRC ISBRA RESULTS FROM ASSESSMENT OF RELAP5/Mod2 ON THE BASIS OF LOBI TEST DATA, H. STAEDTKE, W. KOLAR 1987.
2. H. CHRISTENSEN, POWER-TO-VOID TRANSFER FUNCTION, ANL-6385, 1961.
3. BMI-1163 VAPOR FORMATION AND BEHAVIOR IN BOILING HEAT TRANSFER, RICHARD A. EGEN, DAVID A. DINGEE, AND JOEL W. CHASTAIN, 1973.


4. RELAP5/Mod2 CODE MANUAL, VOLUME 3: DEVELOPMENTAL ASSESSMENT PROBLEMS  
PWR/LCVSG/A(84)49, EGG-SAAM-6377 DRAFT, J.C. LIN ET AL. SEPTEMBER 1984.

5. RELAP5/Mod2 MODELS AND CORRELATIONS, NUREG/CR-5194, EGG-2531, AUGUST 1988.

6. RELAP5/Mod2 CODE MANUAL, VOLUME 1: CODE STRUCTURE, SYSTEM MODELS, AND  
SOLUTION METHODS, NUREG/CR-4312, EGG-2396, V.H. RANSOM ET AL. AUGUST 1985.

7. MAXIMUM BUBBLE DIAMETER, MAXIMUM BUBBLE-GROWTH TIME AND  
BUBBLE-GROWTH RATE DURING THE SUBCOOLED NUCLEATE FLOW BOILING OF WATER  
UP TO  $17.7 \text{ MN/m}^2$ , H.C. UNAL, 1975.

8. Private communication, I.L. Hirst and H. Staedtke, September 1988.



1-0001

COMPARISON OF RELAPS/MOD2 (36.05, ED03) WITH CHRISTENSEN RUNS

COMPARISON OF RELAPS/MOD2 (36 05 E03) WITH CHRISTENSEN RUN10




FIG. 2. 1988-1990 DATA

43010

COMPARISON OF RELAPS/MOD2 (36 05 E03) WITH CHRISTENSEN RUN10

FIGURE 2

### COMPARISON OF RELAPS WITH EXPERIMENT RUNTIME




FIGURE 3. RELAPS WITH EXPERIMENT RUNTIME

COMPARISON OF RELAPS/MOD2 (36.05, E03) WITH CHRISTENSEN RUNTIME



### COMPARISON OF RELAPS WITH EXPERIMENT RUN12




FIGURE 4. COMPARISON OF RELAPS WITH EXPERIMENT RUN12

COMPARISON OF RELAPS WITH EXPERIMENT E0013





FIGURE 5. 1984 BATTERY OF DATA


PAGE 7

COMPARISON OF RELAPS/MO02 (36.05. E03) WITH CHRISTENSEN RUN13



COMPARISON OF RELAPS VERSIONS WITH CHRISTENSEN RUNS


COMPARISON OF RELAPS WITH EXPERIMENT RUN16



POSITION IN HISTORY OF RELAP

TABLE

COMPARISON OF RELAPS/MOD2 (36.05, E03) WITH CHRISSENSEN RUN16



COMPARISON OF RELAPS-TM02 (36.85, 1.03) WITH EGEN RUBY






FIGURE 9

COMPARISON OF RELAPS-THER2 (36.05 E03) WITH EGEN RUM3



COMPARISON OF RELAPS-TIID2 (36.05, E03) WITH EGEN RUN15



800016

COMPARISON OF PREDICTED AND EXPERIMENTAL VOID FRACTIONS








FIGURE 12

COMPARISON OF RELAP5-1002 (36, 05, 003) WITH EXPERIMENT

NODAL DIAGRAM FOR CHRISTENSEN EXPERIMENT



NODAL DIAGRAM FOR EGEN EXPERIMENT



APPENDIX 1 REI AP5/Mod2 INPUT FOR THE CHRISTENSEN EXPERIMENT

= CARLOS CHRISTENSEN SUB-COOLED BOILING EXPERIMENT

0000100 NEW TRANSNT

0000102 SI SI

0000105 2 0 5 0

\* REF VOL ELEV FLUID NAME

0000120 100010000 0.0 WATER PRIMARY

\* ETIME MINTS RTS FLAG MN MJR RSTART

0000201 10 0 1.0-7 0.1 0003 2 50 100

0000202 100 0 1.0-7 0.1 0003 20 500 1000

-----  
0000301 VOIDG 100010000

0000302 VOIDG 100020000

0000303 VOIDG 100030000

0000304 VOIDG 100040000

0000305 VOIDG 100050000

0000306 VOIDG 100060000

0000307 VOIDG 100070000

0000308 VOIDG 100080000

0000309 VOIDG 100090000

0000310 VOIDG 100100000

0000311 VOIDG 100110000

0000312 VOIDG 100120000

0000313 VOIDG 100130000

0000314 VOIDG 100140000

0000315 VOIDG 100150000

0000316 VOIDG 100160000

0000317 VOIDG 100170000

0000318 VOIDG 100180000

0000319 VOIDG 100190000

0000320 VOIDG 100200000

-----  
0000000 TUBE PIPE

0000001 20 \* NVOLS

0000101 4.9284E-4 20 \* VAREA + NV

0000201 4.9284E-4 19 \* JAREA + NJ

0000301 6.35E-2 20 \* VLENGTH + NV

1000401 0 20 \* VVOL + NV

1000601 +90. 20 \* INC-ANGLE + NV

1000801 4.E-5 0.01776 20 \* ROUGHNESS + HYD DIA(4A/P) + NV

1001001 00 20 \* FRICTION EQUILIB + NV

1001101 00000 19

1001201 103 2.7579E+6 499.5 0.0 0.0 0.0 20 \* PRESSURE + TEMP

1001301 0.77 0.77 0. 19 \* LIQUID VEL + VAPOUR VEL

-----  
1050000 BOTTOM TMDPVOL

1050101 1.0E+6 1.0 1.0E+6

1050102 0. 0. 0. 0. 10

1050200 103

1050201 0.0 2.7579E+6 499.5208

-----  
1060000 BOTTOM TMDPJUN

1060101 105000000 100000000 4.9284E-4

1060201 0 0.77 0.77 0.

APPENDIX 1 cont.

```

1080000 TOP TMDPVOL
1080101 1.0E+6 1.0 1.0E+6 * VAREA + VLENGTH + VVOL
1080102 0.0 0.0 0.0 10
1080200 103
SUBU201 0.0 2.7579E+6 499.5 * TIME + PRESSURE + TEMPERATURE

```

```

1090000 TOP SNGLJUN
1090101 100010000 108000000 4.9284E-4 0.0 0.0 31000
1090201 0.0 77.0 77.0

```

\* heat structures

```

*
* NH NP GEOM STDY LCO-ORD
11001000 20 4 2 1 1.25E-2
* MFLAG MFFLAG
11001100 0 1
* N-INT
11001101 3 1.34E-2
* COMP N-INT
11001201 1 3
* SOURCE N-INT
11001301 1 3
* TEMP N-MESH
11001401 499.5 4
* LBOUND INC BTYPE SA LEN HSNO
11001501 100010000 000010000 1 1 8.9565E-2 20
* RBOUND INC TYPE SA LEN HSNO
11001601 -939 0 3949 1 8.9565E-2 20
* S-TYPE IS-MULT DHLEFT DHRIGHT HSNO
11001701 999 0.05 0.0 0.0 20
* CHF HY-DIAM H-DIAM LEN HSNO
11001801 0 0.01776 0.0 0.0 20

```

\* MATERIAL 1 S-STEEL

```

20100100 TBL/FCTN 1 1
20100101 273.15 12.98
20100102 1199.82 25.1
20100151 273.15 3.83E6
20100152 366.5 3.83E6
20100153 477.59 4.190E6
20100154 588.59 4.336E6
20100155 699.82 4.504E6
20100156 810.93 4.639E6
20100157 922.04 4.773E6
20100158 1144.26 5.076E6
20100159 1366.5 5.376E6
20100160 1477.59 5.546E6

```

```

20299900 POWER
20299901 0.0 30.E+3
20299902 1.0E+10 30.E+3

```

```

20293900 TEMP
20293901 0.0 499.5

```

```

20294900 HTC-T
20294901 0.0 0.0
* END

```

APPENDIX 2 RELAP5/Mod2 INPUT FOR THE EGEN EXPERIMENT

= CARLOS SUB-COOLED BOILING EXPERIMENT AT 2000 psi

0000100 NEW TRANSNT

0000102 SI BRITISH

0000103 2.0 5.0

\* REF VOL ELEV FLUID NAME

0000120 100010000 0.0 WATER PRIMARY

\* ET:ME MINTS RTS FLAG MN MJR RSTART

0000201 10.0 1.0-7 0.1 0003 2 5 100

0000202 100.0 1.0-7 0.1 0003 20 5 100

0000301 VOIDG 100010000

0000302 VOIDG 100020000

0000303 VOIDG 100030000

0000304 VOIDG 100040000

0000305 VOIDG 100050000

0000306 VOIDG 100060000

0000307 VOIDG 100070000

0000308 VOIDG 100080000

0000309 VOIDG 100090000

0000310 VOIDG 100100000

0000311 VOIDG 100110000

0000312 VOIDG 100120000

0000313 VOIDG 100130000

0000314 VOIDG 100140000

0000315 VOIDG 100150000

0000316 VOIDG 100160000

0000317 VOIDG 100170000

0000318 VOIDG 100180000

0000319 VOIDG 100190000

0000320 VOIDG 100200000

0000321 VOIDG 100210000

0000322 VOIDG 100220000

0000323 VOIDG 100230000

0000324 VOIDG 100240000

0000325 VOIDG 100250000

0000326 VOIDG 100260000

0000327 VOIDG 100270000

0000000 TUBE PIPE

0000001 27 \* NVOLS

0000101 8.650E-5 27 \* VAREA + NV

0000201 8.650E-5 26 \* JAREA + NJ

0000301 2.54E-2 27 \* VLENGTH + NV

1000401 0 27 \* VVOL + NV

1000601 +90 27 \* INC-ANGLE + NV

1000801 4E-5 4.7473E-3 27 \* ROUGHNESS + HYD DIA(4A/P) + NV

1001001 00 27 \* FRICTION,EQUILIB + NV

1001101 00000 26

1001201 103 1.379E+7 602 0.0 0.0 0.0 27 \* PRESSURE + TEMP

1001300 1 \* flag for flows

1001301 7.479E-2 7.479E-2 0.26 \* LIQUID FLO + VAPOUR FLO

1050000 BOTTOM TMDPVOL

1050101 1.0E+6 1.0 1.0E+6

1050102 0.0 0.0 0.0 10

1050200 10?

1050201 0.0 1.379E+7 602 0400

APPENDIX 2 cont.

```

1080000 BOTTOM TMDPJUN
1080101 105000000 100000000 6.6500E-4
1080200 1 * flow flag
1080201 0 7.4798E-2 7.4798E-2 0
*-----
1080000 TOP TMDPVOL
1080101 1.0E+6 1.0 1.0E+6 * VAREA + VLENGTH + VVOL
1080102 0. 0. 0. 0. 0. 10
1080200 103
1080201 0.0 1.379E+7 602.04 * TIME + PRESSURE + TEMPERATURE
*-----
1090000 TOP SNGLJUN
1090101 100010000 108000000 6.6500E-4 0.0 0.0 31000
1090201 1 7.4798E-2 7.4798E-2 0
*-----
* TUBE      heat structures
*          NH NP  GEOM  STDY  LCO-ORD
11001000   27  4   2    1    4.5992E-3
11001100     0   1
11001101     3  5 4992E-3 * assumes .09 cm thick
11001201     1   3
11001301     1   3
*          TEMP  N-MESH
11001401    602.04  4
          LBOUND INC  BTYPE SA  LEN  HSNO
11001501  100010000 000010000 1    1 4.9253E-2 27
*          RBOUND INC  TYPE SA  LEN  HSNO
11001601   -939     0 3949  1 4.9253E-2 27
*          S-TYPE IS-MULT DHLEFT DHRIGHT HSNO
11001701     900   0.03704  0.0  0.0  27
*          CHF  HY-DIAM H-DIAM LEN  HSNO
11001801     0   4.7473E-3  0.0  0.0  27
* MATERIAL 1  S-STEEL
20100100 TBL/FCTN 1  1
20100101 273.15 12.98
20100102 1199.12 25.1
20100151 273.15 3.83E6
20100152 366.5 3.83E6
20100153 477.59 4.190E6
20100154 588.59 4.336E6
20100155 699.82 4.504E6
20100156 810.93 4.639E6
20100157 922.04 4.773E6
20100158 1144.26 5.076E6
20100159 1366.5 5.376E6
20100160 1477.59 5.546E6
*-----
20290000 POWER
20290001 0.0 2.387E+4
20290002 1.0E+10 2.387E+4
*-----
20293900 TEMP
20293901 0.0 602.04
*-----
20294900 HTC-T
20294901 0.0 0.0
* END

```

Distribution (S - Summary only)

S	R N Burbridge	GDCD
S	P M Billam	GDCD
S	B V George	GDCD
	P D Jenkins	GDCD
S	D W Anderson	GDCD
	K H Ardron	GDCD
	I L Hirst	GDCD
	P C Hall	GDCD
	C R Brain	GDCD
S	R Garnsey	PMT
S	J R D Jones	PMT
	N E Buttery	PMT
	A D Rowe	PMT
S	J R Harrison	HSD
	P R Farmer	HSD
	A C Willetts	HSD
S	E W Carpenter	BNL
	J D Young	BNL
	M W E Coney	CERL
	L F Wilson	CISD Park Street
S	D A Ward	NNC
	K T Routledge	NNC
	J P Rippon	NNC
S	D A Howl	BNFL Springfields
	K W Hesketh	BNFL Springfields
S	D Hicks	UKAEA Harwell
S	M R Hayns	UKAEA Winfrith
	I H Gibson	UKAEA Winfrith
	I Brittain	UKAEA Winfrith
	J C Birchley	UKAEA Winfrith
	H Staedtke	JRC Ispra
	Library	GDCD
	Library	BNL
	Library	CERL
	Library	MEL
	Library	Sudbury House



BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER  
(Assigned by NRC, AEE Vol., Supp. Rev.,  
and Addendum Numbers, if any.)

NUREG/IA-0055  
GD/PE-N/729

2. TITLE AND SUB-TITLE

Assessment of the Sub-Cooled Boiling Model used in RELAP5/MOD2  
(Cycle 36.05, Version E03) Against Experimental Data

3. DATE REPORT PUBLISHED

MONTH YEAR

March 1992

4. FUND OR GRANT NUMBER

A4682

5. AUTHOR(S)

C. R. Brain

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (inclusive dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address, if contractor, provide name and mailing address.)

Central Electricity Generating Board  
Generation Development and Construction Division  
Barnett Way  
Barnwood, Gloucester GL4 7R5  
United Kingdom

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, use "Same as above" if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Office of Nuclear Regulatory Research  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

In order to test the ability of RELAP5/MOD2 to describe sub-cooled nucleate boiling under conditions similar to those anticipated during intact circuit fault scenarios in pressurized water reactors the code has been assessed against results of high pressure sub-cooled boiling experiments reported in literature.

It is concluded that RELAP5/MOD2 can be applied with reasonable confidence to the prediction of sub-cooled boiling void fraction for conditions expected during PWR intact circuit faults.

12. KEY WORDS, DESCRIPTORS (Use words or phrases that will assist researchers in locating the report.)

ICAP Program, RELAP5/MOD2, Sub-cooled Nucleate Boiling

13. AVAILABILITY STATEMENT

Unlimited

14. SECURITY CLASSIFICATION

(This Page)

Unclassified

(This Report)

Unclassified

15. NUMBER OF PAGES

16. PRICE

THIS DOCUMENT WAS PRINTED USING RECYCLED PAPER

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

SPECIAL DELIVERY PERMIT  
POSTAGE & FEE PAID  
000000  
PERMIT NO. 000

NUREG-IA-4056

100555134531 1 IANCI  
DIVISION OF REGULATIONS  
PUBLICATIONS SVCS  
WASHINGTON DC 20555

ASSESSMENT OF SUBCOOLED BOILING MODEL USED IN RELAPS/MOD2  
(CYCLE 3685, VERSION E03) AGAINST EXPERIMENTAL DATA

MARCH 1992