

Omaha Public Power District
444 South 16th Street Mall
Omaha, Nebraska 68102-2247
402/636-2000

November 16, 1995
LIC-95-0218

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Application for Amendment of Operating License

Enclosed please find Omaha Public Power District's (OPPD) "Application for Amendment of Operating License" which seeks to amend the Fort Calhoun Station Unit No. 1 Technical Specifications. The changes requested add a Limiting Condition for Operation and surveillance test for safety related inverters and deletes nonsafety related instrument buses. The proposed changes are based on the Combustion Engineering Standard Technical Specifications contained in NUREG-1432 and a similar request by the Calvert Cliffs Nuclear Power Plant.

Attachment A contains a markup reflecting the requested changes of the Technical Specifications. Attachment B provides the "Discussion, Justification and No Significant Hazards Consideration." OPPD requests 60 days from the date of issuance to implement these changes.

If you have additional questions, or require further information, please do not hesitate to contact me or members of my staff.

Sincerely,

W. G. Gates
W. G. Gates
Vice President

WGG/brh

Attachments

c: Winston & Strawn
L. J. Callan, NRC Regional Administrator, Region IV
L. R. Wharton, NRC Project Manager
W. C. Walker, NRC Senior Resident Inspector
B. E. Casari, Director - Environmental Health Division,
State of Nebraska

Adol
11

2

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Omaha Public Power District)
(Fort Calhoun Station)
Unit No. 1))

Docket No. 50-285

AFFIDAVIT

W. G. Gates, being duly sworn, hereby deposes and says that he is the Vice President in charge of all nuclear activities of the Omaha Public Power District; that as such he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached information concerning the Application for Amendment dated November 16, 1995 concerning revisions to add a Limiting Condition for Operation and surveillance test for safety related inverters and delete nonsafety related instrument buses; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information, and belief.

W. G. Gates
W. G. Gates
Vice President

STATE OF NEBRASKA)
) ss
COUNTY OF DOUGLAS)

Subscribed and sworn to before me, a Notary Public in and for the State of Nebraska on this 10th day of November, 1995.

Theresa Petersen
Notary Public

